



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2007 OCT 22 PM 1:01

OCT 22 2007

EPA REGION VIII  
HEARING CLERK

Ref: 8ENF-W

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Henry Gutz, Commissioner  
Daggett County  
POB 219  
Manila, UT 84046

Re: Administrative Order Addendum  
Docket No. SDWA-08-2007-0010  
Dutch John  
PWS ID #UTAH05001

Dear Mr. Gutz:


The Order issued March 20, 2006, to Daggett County, as owner of the Dutch John water system, required submission of a plan for EPA and State approval to bring the water system into compliance with total organic carbon reduction levels. EPA received the County's plan dated August 8, 2007. The specifications of the pump installed July 20, 2007, were not detailed in the plan but the Utah Department of Environmental Quality drinking water staff require that it must be a variable speed raw water pump. This letter constitutes the written approval by EPA of the County's modifications according to the following schedule:

<u>Action</u>	<u>Start Date</u>	<u>Complete Date</u>
Install surface water pump		July 20, 2007
Install air release valve		August 6, 2007
Install vacuum regulator/chlorinator	on order 8/8/07	October 2007
Install clarification tanks settling tubes	obtaining quote 8/8/07	October 2007
Achieve total organic carbon reduction levels sufficient to enable the system to return to compliance with the required running annual average		March 30, 2008

As a reminder, the Order also requires quarterly reports on the progress of the plan be submitted to EPA. The first report shall be due to EPA November 8, 2007.

Please contact Kathelene Brainich, Environmental Specialist, at (303) 312-6481 if you have any questions concerning this Addendum.

Sincerely,



Diane L. Sipe, Director  
Technical Enforcement Program  
Office of Compliance, Enforcement,  
and Environmental Justice



David J. Janik, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: Patti Fauver, UT DEQ  
Wesley Scott Slaugh, Dutch John operator