

**AUTHORIZATION TO DISCHARGE UNDER THE  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Federal Clean Water Act as amended, 33 U.S.C. §§ 1251 et seq. (the “CWA”),

**City of Holyoke  
Department of Public Works**

is authorized to discharge from the facility located at

**Holyoke Water Pollution Control Facility  
1 Berkshire Street  
Holyoke, Massachusetts 01040**

**And**

**Combined Sewer Overflow (CSO) discharges at 10 locations**

to receiving water named

**Connecticut River (Segment MA 34-05)  
Connecticut River Watershed**

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective on the first day of the calendar month immediately following 60 days after signature.<sup>1</sup>

This permit expires at midnight, five years from the last day of the month preceding the effective date.

This permit supersedes the permit issued on October 25, 2016.

---

<sup>1</sup> Pursuant to 40 Code of Federal Regulations (CFR) § 124.15(b)(3), if no comments requesting a change to the Draft Permit are received, the permit will become effective upon the date of signature. Procedures for appealing EPA’s Final Permit decision may be found at 40 CFR § 124.19.

This permit consists of **Part I** including the cover page(s), **Attachment A** (Freshwater Acute Toxicity Test Procedure and Protocol, February 2011), **Attachment B** (Reassessment of Technically Based Industrial Discharge Limits), **Attachment C** (NPDES Permit Requirement for Industrial Pretreatment Annual Report); **Attachment D** (PFAS Analyte List) and **Part II** (NPDES Part II Standard Conditions, April 2018).

Signed this       day of

---

Ken Moraff, Director  
Water Division  
Environmental Protection Agency  
Region 1  
Boston, MA



## PART I

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date and lasting through the expiration date, the Permittee is authorized to discharge treated effluent through Outfall Serial Number 001 to the Connecticut River. The discharge shall be limited and monitored as specified below; the receiving water and the influent shall be monitored as specified below.

Effluent Characteristic	Effluent Limitation			Monitoring Requirements <sup>1,2,3</sup>	
	Average Monthly	Average Weekly	Maximum Daily	Measurement Frequency	Sample Type <sup>4</sup>
Rolling Average Effluent Flow <sup>5</sup>	17.5 MGD <sup>5</sup>	---	---	Continuous	Recorder
Effluent Flow <sup>5</sup>	Report MGD	---	Report MGD	Continuous	Recorder
BOD <sub>5</sub>	30 mg/L	45 mg/L	Report mg/L	5/Week	Composite
BOD <sub>5</sub> Removal	4,379 lb/day	6,568 lb/day	---	1/Month	Calculation
TSS	≥ 85 %	---	---	5/Week	Composite
TSS Removal	30 mg/L	45 mg/L	Report mg/L	1/Month	Calculation
TSS Removal	4,379 lb/day	6,568 lb/day	---	1/Month	Calculation
pH Range <sup>6</sup>	≥ 85 %	---	---	1/Month	Calculation
Total Residual Chlorine <sup>7,8</sup>	0.74 mg/L	---	1.0 mg/L	1/Day	Grab
<i>Escherichia coli</i> <sup>7,8</sup> (April 1 – October 31)	126 cfu/100 mL	---	409 cfu/100 mL	3/Day	Grab
Total Aluminum	87 µg/L	---	Report	2/Week	Grab
Total Copper	21.6 µg/L	---	Report	1/Month	Composite
Total Lead	1.6 µg/L	---	25.1 µg/L	1/Month	Composite
Total Kjeldahl Nitrogen <sup>9</sup>	Report mg/L	---	Report mg/L	1/Week	Composite
Nitrate + Nitrite <sup>9</sup>	Report mg/L	---	Report mg/L	1/Week	Composite
Total Nitrogen <sup>9</sup>	Report mg/L	---	Report mg/L	1/Month	Calculation
Rolling Average Total Nitrogen <sup>10</sup>	Report lb/day	---	---	1/Quarter	Calculation
PFAS Analytes <sup>11</sup>	730 lb/day	---	---	1/Quarter	Calculation
Adorable Organic Fluorine <sup>12</sup>	---	---	Report ng/L	1/Quarter	Grab

Effluent Characteristic	Effluent Limitation			Monitoring Requirements <sup>1,2,3</sup>	
	Average Monthly	Average Weekly	Maximum Daily	Measurement Frequency	Sample Type <sup>4</sup>
<b>Whole Effluent Toxicity (WET) Testing<sup>13,14</sup></b>					
LC <sub>50</sub>	---	---	≥ 100 %	1/Quarter	Composite
Hardness	---	---	Report mg/L	1/Quarter	Composite
Ammonia Nitrogen	---	---	Report mg/L	1/Quarter	Composite
Total Aluminum	---	---	Report mg/L	1/Quarter	Composite
Total Cadmium	---	---	Report mg/L	1/Quarter	Composite
Total Copper	---	---	Report mg/L	1/Quarter	Composite
Total Nickel	---	---	Report mg/L	1/Quarter	Composite
Total Lead	---	---	Report mg/L	1/Quarter	Composite
Total Zinc	---	---	Report mg/L	1/Quarter	Composite
Total Organic Carbon	---	---	Report mg/L	1/Quarter	Composite

Ambient Characteristic <sup>15</sup>	Reporting Requirements			Monitoring Requirements <sup>1,2,3</sup>	
	Average Monthly	Average Weekly	Maximum Daily	Measurement Frequency	Sample Type <sup>4</sup>
Hardness	---	---	Report mg/L	1/Quarter	Grab
Ammonia Nitrogen	---	---	Report mg/L	1/Quarter	Grab
Total Aluminum	---	---	Report mg/L	1/Quarter	Grab
Total Cadmium	---	---	Report mg/L	1/Quarter	Grab
Total Copper	---	---	Report mg/L	1/Quarter	Grab
Total Nickel	---	---	Report mg/L	1/Quarter	Grab
Total Lead	---	---	Report mg/L	1/Quarter	Grab
Total Zinc	---	---	Report mg/L	1/Quarter	Grab
Total Organic Carbon	---	---	Report mg/L	1/Quarter	Grab
Dissolved Organic Carbon <sup>16</sup>	---	---	Report S.U.	1/Quarter	Grab
pH <sup>17</sup>	---	---	Report °C	1/Quarter	Grab
Temperature <sup>17</sup>	---	---			

Influent Characteristic	Reporting Requirements			Monitoring Requirements <sup>1,2,3</sup>	
	Average Monthly	Average Weekly	Maximum Daily	Measurement Frequency	Sample Type <sup>4</sup>
BOD <sub>5</sub>	Report mg/L	---	---	2/Month	Composite
TSS	Report mg/L	---	---	2/Month	Composite
PFAS Analytes <sup>11</sup>	---	---	Report ng/L	1/Quarter	Grab
Adsorbable Organic Fluorine <sup>12</sup>	---	---	Report ng/L	1/Quarter	Grab

Sludge Characteristic	Reporting Requirements			Monitoring Requirements <sup>1,2,3</sup>	
	Average Monthly	Average Weekly	Maximum Daily	Measurement Frequency	Sample Type <sup>4</sup>
PFAS Analytes <sup>11</sup>	---	---	Report ng/g	1/Quarter	Grab <sup>18</sup>

\*For additional monitoring and reporting requirements related to CSOs, see Parts I.H.5 and I.H.6 below.



## Footnotes:

1. All samples shall be collected in a manner to yield representative data. A routine sampling program shall be developed in which samples are taken at the same location, same time and same days of the week each month. Occasional deviations from the routine sampling program are allowed, but the reason for the deviation shall be documented as an electronic attachment to the applicable discharge monitoring report. The Permittee shall report the results to the Environmental Protection Agency Region 1 (EPA) and MassDEP (the "State") of any additional testing above that required herein, if testing is in accordance with 40 CFR Part 136.
2. In accordance with 40 CFR § 122.44(i)(1)(iv), the Permittee shall monitor according to sufficiently sensitive test procedures (i.e., methods) approved under 40 CFR Part 136 or required under 40 CFR chapter I, subchapter N or O, for the analysis of pollutants or pollutant parameters (except WET). A method is "sufficiently sensitive" when: 1) The method minimum level (ML) is at or below the level of the effluent limitation established in the permit for the measured pollutant or pollutant parameter; or 2) The method has the lowest ML of the analytical methods approved under 40 CFR Part 136 or required under 40 CFR chapter I, subchapter N or O for the measured pollutant or pollutant parameter. The term "minimum level" refers either to the sample concentration equivalent to the lowest calibration point in a method or a multiple of the method detection limit (MDL), whichever is higher. Minimum levels may be obtained in the following ways: they may be published in a method; they may be based on the lowest acceptable calibration point used by a laboratory; or they may be calculated by multiplying the MDL in a method, or the MDL determined by a laboratory, by a factor.
3. When a parameter is not detected above the ML, the Permittee must report the data qualifier signifying less than the ML for that parameter (e.g., < 50 µg/L, if the ML for a parameter is 50 µg/L). For reporting an average based on a mix of values detected and not detected, assign a value of "0" to all non-detects for that reporting period and report the average of all the results.
4. A "grab" sample is an individual sample collected in a period of less than 15 minutes.  
  
A "composite" sample is a composite of at least twenty-four (24) grab samples taken during one consecutive 24-hour period, either collected at equal intervals and combined proportional to flow or continuously collected proportional to flow.
5. The limit is a rolling annual average, reported in million gallons per day (MGD), which will be calculated as the arithmetic mean of the monthly average flow for the reporting month and the monthly average flows of the previous eleven months. Also report monthly average and maximum daily flow in MGD.
6. The pH shall be within the specified range at all times. The minimum and maximum pH sample measurement values for the month shall be reported in standard units (S.U.). For NH: See Part I.G.1 below for a provision to modify the pH range.

If the Permittee wishes to continue the lower pH range to 6.0 S.U. for future permit cycles, they must conduct a pH study and submit the results of said study to MassDEP at [massdep.npdes@mass.gov](mailto:massdep.npdes@mass.gov) within three years of the effective date of the authorization to discharge under this permit. For guidance on the study, the Permittee shall contact MassDEP at [massdep.npdes@mass.gov](mailto:massdep.npdes@mass.gov).



7. The Permittee shall minimize the use of chlorine while maintaining adequate bacterial control. Monitoring for total residual chlorine (TRC) is only required for discharges which have been previously chlorinated or which contain residual chlorine. If chlorine is not utilized during a particular monitoring period, TRC monitoring is not necessary and the Permittee may enter "NODI" code 9 (i.e., conditional monitoring) in the relevant discharge monitoring report.

Chlorination and dechlorination systems shall include an alarm system for indicating system interruptions or malfunctions. Any interruption or malfunction of the chlorine dosing system that may have resulted in levels of chlorine that were inadequate for achieving effective disinfection, or interruptions or malfunctions of the dechlorination system that may have resulted in excessive levels of chlorine in the final effluent shall be reported with the monthly DMRs. The report shall include the date and time of the interruption or malfunction, the nature of the problem, and the estimated amount of time that the reduced levels of chlorine or dechlorination chemicals occurred.

8. The monthly average limit for *Escherichia coli* (*E. coli*) is expressed as a geometric mean. *E. coli* monitoring shall be conducted concurrently with TRC monitoring, if TRC monitoring is required.
9. Total Kjeldahl nitrogen and nitrate + nitrite samples shall be collected concurrently. The results of these analyses shall be used to calculate both the concentration and mass loadings of total nitrogen, as follows.

$$\text{Total Nitrogen (mg/L)} = \text{Total Kjeldahl Nitrogen (mg/L)} + \text{Nitrate} + \text{Nitrite (mg/L)}$$

$$\text{Total Nitrogen (lb/day)} = [(\text{average monthly Total Nitrogen (mg/L)} * \text{total monthly effluent flow (Millions of Gallons (MG))} / \# \text{ of days in the month}) * 8.34]$$

10. The rolling annual total nitrogen limit is an annual average mass-based limit (lb/day), which shall be reported as a rolling 12-month average. The value will be calculated as the arithmetic mean of the monthly average total nitrogen for the reporting month and the monthly average total nitrogen for the previous 11 months. Report both the rolling annual average and the monthly average each month.

See Part I.G.1 for special conditions related to nitrogen.

11. Report in nanograms per liter (ng/L) for effluent and influent samples; report nanograms per gram (ng/g) for sludge samples. Until there is an analytical method approved in 40 CFR Part 136 for PFAS, monitoring shall be conducted using Method 1633. Report in NetDMR the results of all PFAS analytes required to be tested in Method 1633, as shown in Attachment D. This reporting requirement for the listed PFAS parameters takes effect the first full calendar quarter following six months after the effective date of the permit.
12. Report in nanograms per liter (ng/L) for effluent and influent samples. Until there is an analytical method approved in 40 CFR Part 136 for Adsorbable Organic Fluorine, monitoring shall be conducted using Method 1621. This reporting requirement takes effect the first full calendar quarter following six months after the effective date of the permit.
13. The Permittee shall conduct acute toxicity tests (LC50) in accordance with test procedures and protocols specified in Attachment A of this permit. LC50 and C-NOEC are defined in Part II.E. of this permit. The Permittee shall test the daphnid, *Ceriodaphnia dubia*. Toxicity test samples shall be collected during the same weeks each time of calendar quarters ending March 31<sup>st</sup>, June 30th, September 30th, and

December 31st. The complete report for each toxicity test shall be submitted as an attachment to the DMR submittal which includes the results for that toxicity test.

14. For Part I.A.1., Whole Effluent Toxicity Testing, the Permittee shall conduct the analyses specified in **Attachment A**, Part VI. CHEMICAL ANALYSIS for the effluent sample. If toxicity test(s) using the receiving water as diluent show the receiving water to be toxic or unreliable, the Permittee shall follow procedures outlined in **Attachment A**, Section IV., DILUTION WATER. Minimum levels and test methods are specified in **Attachment A**, Part VI. CHEMICAL ANALYSIS.
15. For Part I.A.1., Ambient Characteristic, the Permittee shall conduct the analyses specified in **Attachment A**, Part VI. CHEMICAL ANALYSIS for the receiving water sample collected as part of the WET testing requirements. Such samples shall be taken from the receiving water at a point immediately upstream of the permitted discharge's zone of influence at a reasonably accessible location, as specified in **Attachment A**. Minimum levels and test methods are specified in **Attachment A**, Part VI. CHEMICAL ANALYSIS.
16. Monitoring and reporting for dissolved organic carbon (DOC) are not requirements of the Whole Effluent Toxicity (WET) tests but are additional requirements. The Permittee may analyze the WET samples for DOC or may collect separate samples for DOC concurrently with WET sampling.
17. A pH and temperature measurement shall be taken of each receiving water sample at the time of collection and the results reported on the appropriate DMR. These pH and temperature measurements are independent from any pH and temperature measurements required by the WET testing protocols.
18. Sludge sampling shall be as representative as possible based on guidance found at <https://www.epa.gov/sites/production/files/2018-11/documents/potw-sludge-sampling-guidance-document.pdf>.



## Part I.A., continued.

2. The discharge shall not cause a violation of the water quality standards of the receiving water.
3. The discharge shall be free from pollutants in concentrations or combinations that, in the receiving water, settle to form objectionable deposits; float as debris, scum or other matter to form nuisances; produce objectionable odor, color, taste or turbidity; or produce undesirable or nuisance species of aquatic life.
4. The discharge shall be free from pollutants in concentrations or combinations that adversely affect the physical, chemical, or biological nature of the bottom.
5. The discharge shall not result in pollutants in concentrations or combinations in the receiving water that are toxic to humans, aquatic life or wildlife.
6. The discharge shall be free from floating, suspended and settleable solids in concentrations or combinations that would impair any use assigned to the receiving water.
7. The discharge shall be free from oil, grease and petrochemicals that produce a visible film on the surface of the water, impart an oily taste to the water or an oily or other undesirable taste to the edible portions of aquatic life, coat the banks or bottom of the water course, or are deleterious or become toxic to aquatic life.
8. The Permittee must provide adequate notice to EPA-Region 1 and the State of the following:
  - a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to Part 301 or Part 306 of the Clean Water Act if it were directly discharging those pollutants or in a primary industry category (see 40 CFR Part 122 Appendix A as amended) discharging process water; and
  - b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
  - c. For purposes of this paragraph, adequate notice shall include information on:
    - (1) The quantity and quality of effluent introduced into the POTW; and
    - (2) Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
9. Pollutants introduced into the POTW by a non-domestic source (user) shall not pass through the POTW or interfere with the operation or performance of the works.
10. In accordance with 40 CFR § 122.44(j)(1) the Permittee must identify, in terms of character and volume, any Significant Industrial Users (SIUs) discharging into the POTW subject to Pretreatment Standards under section 307(b) of CWA and 40 CFR Part 403. SIUs information shall be updated at a minimum of once per year or at that frequency necessary to ensure that all SIUs are properly permitted and/or controlled. The records shall be maintained and updated as necessary.



**B. UNAUTHORIZED DISCHARGES**

1. This permit authorizes discharges only from the outfall listed in Part I.A.1 and ten combined sewer overflow outfalls (CSOs) listed in Part I.H.1 in accordance with the terms and conditions of this permit. Discharges of wastewater from any other point sources, including sanitary sewer overflows (SSOs), are not authorized by this permit. The Permittee must provide verbal notification to EPA within 24 hours of becoming aware of any unauthorized discharge and a report within 5 days, in accordance with Part II.D.1.e (24-hour reporting). Providing that it contains the information required in Part II.D.1.e, submission of the MassDEP SSO Reporting Form (described in Part I.B.3 below) may satisfy the requirement for a written report. See Part I.I below for reporting requirements.
2. The Permittee must provide notification to the public within 24 hours of becoming aware of any unauthorized discharge, except SSOs that do not impact a surface water or the public, on a publicly available website, and it shall remain on the website for a minimum of 12 months. Such notification shall include the location (including latitude and longitude) and description of the discharge; estimated volume; the period of noncompliance, including exact dates and times, and, if the noncompliance has not been corrected, the anticipated time it is expected to continue.
3. Notification of SSOs to MassDEP shall be made on its SSO Reporting Form (which includes MassDEP Regional Office telephone numbers). The reporting form and instruction for its completion may be found on-line at <https://www.mass.gov/how-to/sanitary-sewer-overflowbypassbackup-notification>. Notification to MassDEP and EPA shall not release the Permittee from the MassDEP public notification requirements of 314 CMR 16.00.

**C. OPERATION AND MAINTENANCE OF THE TREATMENT AND CONTROL FACILITIES**

## 1. Wastewater Treatment Facility

~~Operation and maintenance (O&M) of the wastewater treatment facility<sup>2</sup> (WWTF) owned and/or operated by the Permittee shall be in compliance with 40 CFR § 122.41 (d) and (e) and the terms and conditions of the Part II Standard Conditions, B. Operation and Maintenance of Pollution Controls which is attached to this Permit.~~

- ~~a. *WWTF Major Storm and Flood Events Plan.* Within 12 months of the effective date of this Permit, the Permittee shall develop and submit a *WWTF Major Storm and Flood Events Plan* and begin to implement mitigation measures consistent with the schedule contained in this paragraph. The Plan shall contain three components: (1) an asset vulnerability evaluation, (2) a systemic vulnerability evaluation<sup>3</sup> of the assets, and (3) a mitigation measures alternatives analysis. The Plan shall include~~

<sup>2</sup> Wastewater Treatment Facility means any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage or industrial wastes of a liquid nature. It does not include sewers, pipes and other conveyances to the wastewater treatment facility.

<sup>3</sup> ~~To determine the vulnerabilities to the facilities from major storm and flood events, you must conduct the evaluation using, at a minimum, the worst case data relating to changes in precipitation, sea level rise, extreme weather events, coastal flooding, inland flooding, sewer flow and inflow and infiltration and relevant to the facilities from: 1) the data generated by the 13 federal agencies that conduct or use research on global change that contributed to the latest National Climate Assessment produced by the U.S. Global Change Research Program (USGCRP); 2) climate data generated by the Commonwealth of Massachusetts; and 3) resiliency planning completed by the municipality in which a given facility is located (i.e., City of Boston) and incorporate the results of the evaluation in a manner that demonstrates that the control measures taken are precautionary and sufficiently protective. Evaluation must be completed by a qualified person on a five-year basis considering 1) historical observations from all years the Permittee has operated the facility prior to this permit's term; 2) set midterm (i.e., 20-30 years) and long term (i.e., 80-100 years) ranges.~~



~~resiliency and implementation planning informed by an evaluation of all WWTF vulnerabilities to major storm and flood events<sup>4</sup>. The planning process shall be iterative, and re-evaluations shall be conducted; (1) if on- or off-site structures are added, removed or significantly changed in any way that will impact the vulnerability of the WWTF; and (2) as data sources used for such evaluations are revised, or generated. At a minimum, the Plan must take future conditions into consideration, specifically the midterm (i.e., 20-30 years) and long term (i.e., 80-100 years) and, in the case of sea-level change, the plan must consider extreme sea-level change. The Plan shall be updated at least every five (5) years from the effective date of this Permit and must take future conditions into consideration.<sup>5</sup>~~

- (1) *Component 1: Asset Vulnerability Evaluation.* This first component of the *WWTF Major Storm and Flood Events Plan* must assess the vulnerability of individual WWTF-related assets. The Permittee may find EPA's guide: *Flood Resilience: A Basic Guide for Water and Wastewater Utilities*<sup>6</sup> and EPA's website<sup>7</sup> *Creating Resilient Water Utilities (CRWU)* helpful for completing this component.

The *Asset Vulnerability Evaluation* shall include, at a minimum, the following:

- i. ~~Description of planning priorities related to major storm and flood event vulnerabilities presented by the location of the WWTF (e.g., proximity to waterbodies which may cause flooding).~~
- ii. Identification of all assets related to the WWTF (e.g., buildings, laboratories and offices, WWTF, septage collection facilities, etc.), the elevation of each asset, and if the asset falls into the 100-year flood map or the 500-year flood map;<sup>8</sup>
- iii. ~~Description of structural improvements, either completed or planned, and/or other mitigation measures<sup>9</sup> designed to minimize<sup>10</sup> the impacts of major storm and flood events to each specific asset identified above.~~

~~The Permittee shall consider, at a minimum, the following measures:~~

- ~~(a) Construction of flood barriers to protect infrastructure or reinforce existing structures to withstand flooding and additional exertion of force;~~

<sup>4</sup> "Major storm and flood events" refer to instances resulting from major storms such as hurricanes, extreme/heavy precipitation events, and pluvial, fluvial, and flash flood events such as high-water events, storm surge, and high-tide flooding. "Extreme/heavy precipitation" refers to instances during which the amount of rain or snow experienced in a location substantially exceeds what is normal. What constitutes a period of heavy precipitation varies according to location and season. "Extreme/heavy precipitation" does not necessarily mean the total amount of precipitation at a location has increased-just that precipitation is occurring in more intense or more frequent events.

<sup>5</sup> It will be advantageous to the permittee to consider low, medium, high and extreme levels of sea level change to determine priority assets and plan for increasingly protective mitigation measures.

<sup>6</sup> [https://www.epa.gov/sites/default/files/2015-08/documents/flood\\_resilience\\_guide.pdf](https://www.epa.gov/sites/default/files/2015-08/documents/flood_resilience_guide.pdf)

<sup>7</sup> <https://www.epa.gov/crwu>

<sup>8</sup> See [https://www.epa.gov/sites/default/files/2015-08/documents/flood\\_resilience\\_guide.pdf](https://www.epa.gov/sites/default/files/2015-08/documents/flood_resilience_guide.pdf) for a basic guide to flood resiliency for water and wastewater utilities.

<sup>9</sup> Mitigation measure can be, for example, an emergency planning activity, equipment modification/upgrade or new capital investment/construction project.

<sup>10</sup> For the purposes of this provision, the term "minimize" means to reduce and/or eliminate to the extent achievable the impacts to the facilities.



- ~~(b) Establish remote locations for operations, equipment, records and data backups;~~
- ~~(c) Plan and establish alternative or on-site power supply<sup>11</sup>;~~
- ~~(d) Relocate facilities and/or infrastructure to higher elevations;~~
- ~~(e) Catalog emergency resources used during a major storm or flood event;~~
- ~~(f) Develop emergency response plans;~~
- ~~(g) Establish contracts for backup supplies of critical chemicals;~~
- ~~(h) Establish mutual aid agreements with neighboring utilities;~~
- ~~(i) Integrate long-term risks into capital improvement plans;~~
- ~~(j) Participate in community planning and regional collaborations;~~
- ~~(k) Conduct staff training for implementing your emergency procedures at regular intervals;~~
- ~~(l) When designing new or replacement facilities, strive to locate facilities above the relative base flood elevation<sup>12</sup> for both the 1% (100-year) and 0.2% (500-year) chance storm events.~~
- ~~iv. Identify the source of data used to assess vulnerabilities to major storm and flood events.~~
- ~~v. Identify potential funding sources<sup>13</sup> for resilience planning and implementation. (e.g., EPA, FEMA, MassDEP, capital planning, etc.).~~
- ~~(2) Component 2: Systemic Vulnerability Evaluation. Upon completing assessment of the vulnerabilities of individual assets, the permittee shall evaluate the vulnerability of its WWTF system as a whole. This second component of the evaluation shall include, at a minimum, a systematic vulnerability evaluation for each asset identified in Part I.C.1.a.(1), including the following:~~

<sup>11</sup> The Permittee shall clearly document measures taken specifically to manage energy system disruptions, such as a general power outage, as well as document whether and, if so, to what extent, power supply adequate to ensure safe and reliable operations of the facility is threatened during a major storm or flood. They shall clearly document measures that have been taken to address any risks the facility faces of losing power during a major storm or flood in a manner that could result in environmental or public health impacts.

<sup>12</sup> For activities proposed for MA facilities within Areas Subject to Protection under M.G.L. c. 131, § 40 or the 100-foot buffer zone, the Base Flood Elevation is defined at 310 CMR 10.04, Definitions of Special Flood Hazard Area, Velocity Zone, and Coastal High Hazard Area, Land Subject to Coastal Storm Flowage at 310 CMR 10.36 and Bordering Land Subject to Flooding, and Isolated Land Subject to Flooding at 310 CMR 10.57. Also refer to the Massachusetts State Building Code for any other required standards related to Base Flood Elevation.

<sup>13</sup> See <https://www.epa.gov/fedfunds>



- ~~i. Define the criticality of the asset to overall treatment facility operations<sup>14</sup>.~~
  - ~~ii. Identify the highest<sup>15</sup> priority assets for the facility/system and the measures taken (or planned) to reduce facility vulnerability to risks that could degrade overall system operations in a manner that would result in environmental or public health impacts.~~
- (3) *Component 3: Mitigation Measures Alternatives Evaluation.* Upon completing assessment of the vulnerabilities of the WWTF system as a whole, the Permittee shall provide an assessment of asset-specific mitigation measures, and/or, if appropriate, combinations of mitigation measures to minimize the impact of major storm and flood events. ~~The Permittee shall then select the most effective mitigation measure(s) and include a schedule for implementation. This third component shall include, at a minimum, the following:~~
- ~~i. An evaluation of mitigation measure alternatives including a cost-effectiveness analysis and a review of technical, environmental, and institutional factors.~~
  - ~~ii. For each mitigation measure, quantitatively document (including assumptions and methodologies) the residual risk today, in the midterm (i.e., 20-30 years) and the long-term (i.e., 80-100 years). The evaluation should include estimates of which customers and geographic areas bear the residual risk after implementation of the mitigation measures. Residual risk is a term that refers to the risk remaining for an asset or system, after mitigation measures are taken.~~
  - iii. Selection of mitigation measures to be undertaken, including:
    - a. a schedule<sup>16</sup> of implementation for each selected mitigation measure<sup>17</sup>; and
    - ~~b. a map showing the location of planned mitigation measure.~~
- (4) *Annual Report.* The Permittee shall submit an Annual Operation and Maintenance Report on the *WWTF Major Storm and Flood Events Plan* implementation and results for the prior calendar year including documenting any changes to the WWTF or other assets that may impact the current vulnerability evaluation. The first annual report is due the first March 31 following submittal of the *Wastewater Treatment Facility Major Storm and Flood Events Plan* and shall be included with the annual report required in Part I.C.3 below.

<sup>14</sup> For example, an asset like a pumping station or headworks is often scored "high" for criticality, as the safe and reliable operation of many assets during a major storm or flood depend upon the continued operation of that particular asset. If a pump station is degraded or fails, many other assets operations can degrade or fail, resulting in environmental or public health impacts.

<sup>15</sup> Based on the combined assessment of asset-level vulnerability today and in the midterm (i.e., 20-30 years) and long-term (i.e., 80-100 years), the criticality of that asset's performance to the operations of the system today and in the midterm (i.e., 20-30 years) and long-term (i.e., 80-100 years).

<sup>16</sup> In describing the schedule to implement mitigation measures, the Permittee shall clearly document which mitigation measures identified in the Plan have or have not been integrated into that system's capital planning process. A mitigation measure is integrated when a budget line item in that system's current and adopted capital plan clearly identifies the year of completion and expenditure that has been budgeted and approved to complete that mitigation measure.

<sup>17</sup> For all measures considered, the Permittee must document in the Plan the factual basis (i.e., the maps, data sets and calculations for the analysis), for either implementing or not implementing the measure. The factual basis and analysis must be presented in sufficient detail to allow EPA, the public, or an independent qualified person to evaluate the reasonableness of the decision. For measures already in place, including requirements from state, local or federal agencies, a description of the measures and how they meet the requirement(s) of this permit must be documented in the Plan.



## 2. Sewer System

Operation and maintenance (O&M) of the sewer system shall be in compliance with 40 CFR § 122.41 (d) and (e) and the terms and conditions of the Part II Standard Conditions, B. Operation and Maintenance of Pollution Controls which is attached to this Permit. The Permittee shall complete the following activities for the collection system which it owns:

a. Maintenance Staff

The Permittee shall provide an adequate staff to carry out the operation, maintenance, repair, and testing functions required to ensure compliance with the terms and conditions of this permit. Provisions to meet this requirement shall be described in the Sewer System O&M Plan required pursuant to Part I.C.2.e. below.

b. Preventive Maintenance Program

The Permittee shall maintain an ongoing preventive maintenance program to prevent overflows and bypasses caused by malfunctions or failures of the sewer system infrastructure. The program shall include an inspection program designed to identify all potential and actual unauthorized discharges. Plans and programs to meet this requirement shall be described in the Sewer System O&M Plan required pursuant to Part I.C.2.e. below.

c. Infiltration/Inflow

The Permittee shall control infiltration and inflow (I/I) into the sewer system as necessary to prevent high flow related unauthorized discharges from their collection systems and high flow related violations of the wastewater treatment plant's effluent limitations. Plans and programs to control I/I shall be described in the Sewer System O&M Plan required pursuant to Part I.C.2.e. below.

d. Sewer System Mapping

The Permittee shall maintain a map of the sewer collection system it owns. The map shall be on a street basemap of the community, with sufficient detail and at a scale to allow easy interpretation for the general public. The sewer system information shown on the map shall be based on current conditions and shall be kept up-to-date. The Permittee shall make the map available online in a downloadable Geographic Information System (GIS) format, available to the public, in a manner where the system's performance can be independently assessed and analyzed. It should include as much information as listed below as possible, with full consideration given to concerns of security, where demonstrated. If any items listed below, such as the location of all outfalls, are not fully documented, the Permittee must clearly identify each component of the dataset that is incomplete, as well as the date of the last update of the mapping product. Such map(s) shall include, but not be limited to the following:

- (1) All sanitary sewer lines and related manholes;
- (2) All combined sewer lines, related manholes, and catch basins;
- (3) All combined sewer regulators and any known or suspected connections between the



sanitary sewer and storm drain systems (e.g. combination manholes);

- (4) All outfalls, including the treatment plant outfall(s), CSOs, and any known or suspected SSOs, including stormwater outfalls that are connected to combination manholes;
- (5) All pump stations and force mains;
- (6) The wastewater treatment facility(ies);
- (7) All surface waters (labeled);
- (8) Other major appurtenances such as inverted siphons and air release valves;
- (9) A numbering system which uniquely identifies manholes, catch basins, overflow points, regulators and outfalls;
- (10) The scale and a north arrow; and
- (11) The pipe diameter, date of installation, type of material, distance between manholes, and the direction of flow.

e. Sewer System Operation and Maintenance Plan

The Permittee shall develop and implement a *Sewer System Operation and Maintenance Plan* for the portion of the system it owns.

- (1) Within six (6) months of the effective date of the permit, the Permittee shall submit to EPA and the State:
  - i. A description of the collection system management goals, staffing, information management, and legal authorities;
  - ii. A description of the collection system and the overall condition of the collection system including a list of all pump stations and a description of recent studies and construction activities; and
  - iii. A schedule for the development and implementation of the full *Sewer System Operation and Maintenance Plan* including the elements in Parts I.C.2.e.(3)(i). through (3)(viii). below.
- (2) ~~Within 12 months of the effective date of this Permit, the Permittee shall develop and implement a *Sewer System Major Storm and Flood Events Plan* as an element of the *Sewer System Operations and Maintenance Plan*. The Plan shall contain three components: (1) an asset vulnerability evaluation, (2) a systemic vulnerability evaluation of the system and (3) an alternatives analysis. The Plan shall include resiliency planning and implementation~~

~~informed by an evaluation<sup>18</sup> of all sewer system vulnerabilities to major storm and flood events<sup>19</sup>. The planning process shall be iterative, and re-evaluations shall be conducted; (1) if on- or off-site structures are added, removed or significantly changed in any way that will impact the vulnerability of the sewer system and (2) as data sources used for such evaluations are revised or generated. At a minimum, the Plan must take future conditions into consideration, specifically midterm (i.e., 20-30 years) and long-term (i.e., 80-100 years) and, in the case of sea level change, the plan must consider extreme sea level change. The Plan shall be updated every five (5) years from the effective date of this Permit.~~

- ~~i. *Component I: Asset Vulnerability Evaluation.* The first component of the *Sewer System Operation and Maintenance Plan* must assess the vulnerability of individual sewer system-related assets. The Permittee may find EPA's guide: *Flood Resilience: A Basic Guide for Water and Wastewater Utilities*<sup>20</sup> and EPA's website<sup>21</sup> *Creating Resilient Water Utilities (CRWU)* helpful for completing this component.~~

~~The Asset Vulnerability Evaluation shall include, at a minimum, the following:~~

- ~~(a) Description of planning priorities related to the location of the sewer system;~~
- ~~(b) Identification of all assets (e.g., pump stations, pipes, etc...), the elevation of the asset, and if the asset falls into the 100-year flood map or the 500-year flood map<sup>22</sup>;~~
- ~~(c) Description of structural improvements, and/or other mitigation measures<sup>23</sup> to minimize<sup>24</sup> the impacts of major storm and flood events to each specific asset identified in Part I.C.2.e.(2).i.(b) above.~~

<sup>18</sup> To determine the vulnerabilities to the facilities from major storm and flood events, you must conduct the evaluation using, at a minimum, the worst-case data relating to changes in precipitation, sea level rise, extreme weather events, coastal flooding, inland flooding, sewer flow and inflow and infiltration and relevant to the facilities from: 1) the data generated by the 13 federal agencies that conduct or use research on global change that contributed to the latest National Climate Assessment produced by the U.S. Global Change Research Program (USGCRP); 2) climate data generated by the Commonwealth of Massachusetts; and 3) resiliency planning completed by the municipality in which a given facility is located (i.e., City of Boston) and incorporate the results of the evaluation in a manner that demonstrates that the control measures taken are precautionary and sufficiently protective. Evaluation must be completed by a qualified person on a five-year basis considering 1) historical observations from all years the Permittee has operated the facility prior to this permit's term; 2) set midterm (i.e., 20-30 years) and long term (i.e., 80-100 years) ranges.

<sup>19</sup> "Major storm and flood events" refer to instances resulting from major storms such as hurricanes, extreme/heavy precipitation events, and pluvial, fluvial, and flash flood events such as high-water events, storm surge, and high-tide flooding. "Extreme/heavy precipitation" refers to instances during which the amount of rain or snow experienced in a location substantially exceeds what is normal. What constitutes a period of heavy precipitation varies according to location and season. "Extreme/heavy precipitation" does not necessarily mean the total amount of precipitation at a location has increased-just that precipitation is occurring in more intense or more frequent events.

<sup>20</sup> [https://www.epa.gov/sites/default/files/2015-08/documents/flood\\_resilience\\_guide.pdf](https://www.epa.gov/sites/default/files/2015-08/documents/flood_resilience_guide.pdf)

<sup>21</sup> <https://www.epa.gov/crwu>

<sup>22</sup> See [https://www.epa.gov/sites/default/files/2015-08/documents/flood\\_resilience\\_guide.pdf](https://www.epa.gov/sites/default/files/2015-08/documents/flood_resilience_guide.pdf) for a basic guide to flood resiliency for water and wastewater utilities.

<sup>23</sup> Mitigation measure can be an emergency planning activity, equipment modification/upgrade or new capital investment/construction project.

<sup>24</sup> For the purposes of this provision, the term "minimize" means to reduce and/or eliminate to the extent achievable the impacts to the facilities.



~~The Permittee shall consider, at a minimum, the following measures:~~

- ~~(i) Construction of flood barriers to protect structure or reinforce existing structures to withstand flooding and additional exertion of force;~~
- ~~(ii) Establish remote locations for operations, equipment, records and data backups;~~
- ~~(iii) Plan and establish alternative or on-site power supply<sup>25</sup>;~~
- ~~(iv) Relocate facilities and/or infrastructure to higher elevations;~~
- ~~(v) Catalog emergency resources used during a major storm or flood event;~~
- ~~(vi) Develop emergency response plans;~~
- ~~(vii) Establish mutual aid agreements with neighboring utilities;~~
- ~~(viii) Integrate long-term risks into capital improvement plans;~~
- ~~(ix) Participate in community planning and regional collaborations;~~
- ~~(x) Conduct staff training for implementing your emergency procedures at regular intervals;~~
- ~~(xi) When designing new or replacement facilities, strive to locate facilities above the base flood elevation<sup>26</sup>.~~

~~(d) Identify the source of data used to assess vulnerabilities to major storm and flood events.~~

~~(e) Identify the potential funding sources<sup>27</sup> for resilience planning and implementation (e.g., EPA, FEMA, MassDEP, capital planning, etc.).~~

~~ii. *Component 2: Systemic Vulnerability Evaluation.* Upon completing assessment of the vulnerabilities of individual assets, the Permittee shall evaluate the vulnerability of its sewer system as a whole. This second component of the shall include, at a minimum, a systematic vulnerability evaluation for each asset identified in Part I.C.2.e.(2).i.(b), including the following:~~

~~(a) Define the criticality of each asset to the overall sewer system operations~~

~~(b) Identify the highest priority assets for the sewer system and measures<sup>28</sup> taken to reduce system vulnerability to risks that could degrade the overall system~~

<sup>25</sup> The Permittee shall clearly document measures taken specifically to manage energy system disruptions, such as a general power outage, well as document whether and, if so, to what extent, power supply adequate to ensure safe and reliable operations of the facility is threatened during a major storm or flood. They shall clearly document measures that have been taken to address any risks the facility faces of losing power during a major storm or flood in a manner that could result in environmental or public health impacts.

<sup>21</sup> For MA facilities, For activities proposed within Areas Subject to Protection under M.G.L. c. 131, § 40 or the 100-foot buffer zone, the Base Flood Elevation is defined at 310 CMR 10.04, Definitions of Special Flood Hazard Area, Velocity Zone, and Coastal High Hazard Area, Land Subject to Coastal Storm Flowage at 310 CMR 10.36 and Bordering Land Subject to Flooding, and Isolated Land Subject to Flooding at 310 CMR 10.57. Also refer to the Massachusetts State Building Code for any other required standards related to Base Flood Elevation.

<sup>27</sup> See <https://www.epa.gov/fedfunds>

<sup>28</sup> For example, an asset like a pumping station or headworks is often ranked "high" for criticality, as the safe and reliable operation of many assets during a major storm or flood depend upon the continued operation of that particular asset. If a pump station is degraded or fails, many other assets operations can degrade or fail, resulting in environmental or public health impacts.



~~operations in a manner that would result in environmental or public health impacts~~

- iii. ~~Component 3: Alternatives Evaluation. Upon completing assessment of the vulnerabilities of the sewer system as a whole, the Permittee shall provide an assessment of individual asset-specific, and/or, if appropriate, combinations of mitigation measures must be presented in order to determine the most effective mitigation measures to minimize the impact of major storm and flood events.~~

~~This third component shall include, at a minimum, the following with regard to alternative evaluation, at a minimum~~

- ~~(a) An evaluation of alternatives including a cost-effectiveness analysis and a review of technical, environmental, and institutional factors. The alternatives analysis should conclude with the development of a recommended plan.~~
- ~~(b) For each alternative, quantitatively document (including assumptions and methodologies) the residual risk today and for the midterm (i.e., 20-30 years) and long-term (i.e., 80-100 years). The evaluation should include estimates of which customers and geographic areas bear the residual risk from the approach to resiliency planning in that system. Residual risk is a term that refers to the risk remaining for an asset or system, after mitigation measures are taken.~~
- ~~(c) For each asset, document the total projected alternatives for implementing all planned mitigation measures identified in the Sewer System Major Storm and Flood Events Plan.~~
- ~~(d) Selection of mitigation measures to be undertaken, including:
  - ~~(i) a schedule to implement each selected mitigation measure; and~~
  - ~~(ii) a map showing the location of planned mitigation measures.~~~~

- iv. ~~Annual Report. The Permittee shall submit an Annual Operation and Maintenance Report on the Sewer System Major Storm and Flood Events Plan implementation and results for the prior calendar year including documenting any changes to the sewer system or other assets that may impact the current vulnerability evaluation. The first annual report is due the first March 31 following submittal of the Sewer System Major Storm and Flood Events Plan and shall be included with the annual report required in Part I.C.3 below.~~

(3) The Permittee shall continue to implement the full Sewer System O&M. The Plan shall include:

- i. The required submittal from paragraph Part I.C.2.e.(1). above, updated to reflect current information;
- ii. A preventive maintenance and monitoring program for the collection system;
- iii. Description of sufficient staffing necessary to properly operate and maintain the sanitary sewer collection system and how the operation and maintenance program is staffed;
- iv. Description of funding, the source(s) of funding and provisions for funding sufficient for

implementing the plan;

- v. Identification of known and suspected overflows and back-ups, including manholes. A description of the cause of the identified overflows and back-ups, corrective actions taken, and a plan for addressing the overflows and back-ups consistent with the requirements of this permit;
- vi. A description of the Permittee's programs for preventing I/I related effluent violations and all unauthorized discharges of wastewater, including overflows and by-passes and the ongoing program to identify and remove sources of I/I. The program shall include an inflow identification and control program that focuses on the disconnection and redirection of illegal sump pumps and roof down spouts;
- vii. An educational public outreach program for all aspects of I/I control, particularly private inflow; and
- viii. An Overflow Emergency Response Plan to protect public health from overflows and unanticipated bypasses or upsets that exceed any effluent limitation in the permit.

### 3. Annual Reporting Requirement

The Permittee shall submit a summary report of activities related to the implementation of its O&M Plans during the previous calendar year. The report shall be submitted to EPA and the State annually by March 31. The first annual report is due the first March 31 following submittal of the O&M Plans required by Part I.C. of this permit. The summary report shall, at a minimum, include:

- a. A description of the staffing levels maintained during the year;
- b. A map and a description of inspection and maintenance activities conducted and corrective actions taken during the previous year;
- c. Expenditures for any collection system maintenance activities and corrective actions taken during the previous year;
- d. A map with areas identified for investigation/action in the coming year;
- e. A summary of unauthorized discharges during the past year and their causes and a report of any corrective actions taken as a result of the unauthorized discharges reported pursuant to the Unauthorized Discharges section of this permit;
- f. If the average annual flow in the previous calendar year exceeded 80 percent of the facility's 17.5 MGD design flow (14 MGD), or there have been capacity related overflows, the report shall include:
  - (1) Plans for further potential flow increases describing how the Permittee will maintain compliance with the flow limit and all other effluent limitations and conditions; and
  - (2) A calculation of the maximum daily, weekly, and monthly infiltration and the maximum daily, weekly, and monthly inflow for the reporting year.



- g. The Annual Operation and Maintenance Report on the implementation and results of the *WWTF Major Storm and Flood Events Plan* (beginning the first March 31 following submittal of this Plan) for the prior calendar year; and
- h. The Annual Operation and Maintenance Report on the implementation and results of the *Sewer System Major Storm and Flood Events Plan* (beginning the first March 31 following submittal of this Plan) for the prior calendar year.

#### D. ALTERNATE POWER SOURCE

In order to maintain compliance with the terms and conditions of this permit, the Permittee shall provide an alternative power source(s) sufficient to operate the portion of the publicly owned treatment works it owns and operates, as defined in Part II.E.1 of this permit.

#### E. INDUSTRIAL USERS AND PRETREATMENT PROGRAM

##### 1. Legal Authority

The Permittee has been delegated primary responsibility for enforcing against discharges prohibited by 40 CFR 403.5 and applying and enforcing any national Pretreatment Standards established by the United States Environmental Protection Agency in accordance with Section 307 (b) and (c) of The Clean Water Act (Act), as amended by The Water Quality Act (WQA), of 1987.

The Permittee shall operate an industrial pretreatment program in accordance with the General Pretreatment Regulations found in 40 CFR Part 403 and the approved pretreatment program submitted by the Permittee. The pretreatment program was approved on July 22, 1985 and has subsequently incorporated substantial modifications as approved by EPA. The approved pretreatment program, and any approved modifications thereto, is hereby incorporated by reference and shall be implemented in a manner consistent with the following procedures, as required by 40 CFR Part 403.

The Permittee must have or develop a legally enforceable municipal code or rules and regulations to authorize or enable the POTW to apply and enforce the requirements of Sections 307(b) and (c) and 402(b)(8) and (9) of the Act and comply with the requirements of § 403.8(f)(1). At a minimum, this legal authority shall enable the POTW to:

- a. Deny or condition new or increased contributions of pollutants, or changes in the nature of pollutants, to the POTW by Industrial Users where such contributions do not meet applicable Pretreatment Standards and Requirements or where such contributions would cause the POTW to violate its NPDES permit;
- b. Require compliance with applicable Pretreatment Standards and Requirements by Industrial Users;
- c. Control through Permit, order, or similar means, the contribution to the POTW by each Industrial User to ensure compliance with applicable Pretreatment Standards and Requirements. In the case of Industrial Users this control shall be achieved through permits or equivalent control mechanism identified as significant under § 403.3(v), as required by § 403.8(f)(1)(iii);
- d. Require (a) the development of a compliance schedule by each Industrial User for the installation



of technology required to meet applicable Pretreatment Standards and Requirements and (b) the submission of all notices and self-monitoring reports from Industrial Users as are necessary to assess and assure compliance by Industrial Users with Pretreatment Standards and Requirements, including but not limited to the reports required in § 403.12;

- e. Carry out all inspection, surveillance and monitoring procedures necessary to determine, independent of information supplied by Industrial Users, compliance or noncompliance with applicable Pretreatment Standards and Requirements by Industrial Users. At a minimum, all significant industrial users shall be sampled and inspected at the frequency established in the approved IPP, but in no case less than once per year, and with adequate maintenance of records, Representatives of the POTW shall be authorized to enter any premises of any Industrial User in which a Discharge source or treatment system is located or in which records are required to be kept under § 403.12(o) to assure compliance with Pretreatment Standards. Such authority shall be at least as extensive as the authority provided under section 308 of the Act;
- f. Obtain remedies for noncompliance by any Industrial User with any Pretreatment Standard and Requirement. All POTW's shall be able to seek injunctive relief for noncompliance by Industrial Users with Pretreatment Standards and Requirements. All POTWs shall also have authority to seek or assess civil or criminal penalties in at least the amount of \$1,000 a day for each violation by Industrial Users of Pretreatment Standards and Requirements in accordance with § 403.8(f)(1)(vii)(A); and
- g. Comply with the confidentiality requirements set forth in § 403.14.

## 2. Implementation Requirements

The Permittee shall operate a pretreatment program in accordance with the General Pretreatment Regulations found in 40 CFR Part 403 and with the legal authorities, policies, procedures, and financial provisions of the approved Pretreatment program submitted by the Permittee. The approved Pretreatment program, and any approved modifications thereto, is hereby incorporated by reference and shall be implemented in a manner consistent with the following procedures, as required by 40 CFR Part 403:

- a. In accordance with 40 CFR § 122.44(j)(1), Identify, in terms of character and volume of pollutants contributed from Industrial Users discharging into the POTW subject to Pretreatment Standards under section 307(b) of CWA and 40 CFR Part 403.
- b. The Permittee must notify these identified Industrial Users of applicable Pretreatment Standards and any applicable requirements in accordance with 40 CFR § 403.8(f)(2)(iii). Pursuant to 40 CFR § 403.8(f)(6), prepare and maintain a list of significant industrial users and identify the criteria in 40 CFR § 403.3(v)(1) applicable to each industrial user.
- c. The Permittee must carry out inspection procedures and randomly sample and analyze the effluent from Industrial Users and conduct surveillance activities in accordance with 40 CFR § 403.8(f)(2)(v), which will determine independent of information supplied by the industrial user, whether the industrial user is in compliance with the Pretreatment Standards. At a minimum, all significant industrial users shall be sampled and inspected at the frequency established in the approved IPP but in no case less than once per year and maintain adequate records.



- d. The Permittee shall receive and analyze self-monitoring reports and other notices submitted by Industrial Users in accordance with the self-monitoring requirements in 40 CFR § 403.12; This must include timely and appropriate reviews of industrial user reports and notifications to identify all violations of the user's permit, the local ordinance, and federal pretreatment standards and requirements.
- e. The Permittee shall evaluate whether each SIU needs a plan to control Slug Discharges in accordance with 40 CFR § 403.8(f)(2)(vi). SIUs must be evaluated within 1 year of being designated an SIU. If required, the Permittee shall require the SIU to prepare or update, and implement a slug prevention plan that contains at least the minimum required elements in 40 CFR § 403.8(f)(2)(vi)(A-D) and incorporate the slug control requirements into the SIU's control mechanism;
- f. Pursuant to 40 CFR § 403.8(f)(2)(vii), the Permittee shall investigate instances of non-compliance with Pretreatment Standards and requirements indicated in required reports and notices or indicated by analysis, inspection, and surveillance activities.
- g. The Permittee shall publish, at least annually, in a newspaper or newspapers of general circulation that provides meaningful public notice within the jurisdiction(s) served by the POTW, a list of all non-domestic users which, at any time in the previous 12 months, were in significant noncompliance as defined in 40 CFR § 403.8 (f)(2)(viii).
- h. The Permittee shall provide sufficient resources and qualified personnel to implement its Pretreatment program in accordance with 40 CFR § 403.8(f)(3);
- i. The Permittee shall enforce all applicable Pretreatment Standards and requirements and obtain remedies for noncompliance by any industrial user. The Permittee shall develop, implement, and maintain an enforcement response plan in accordance with 40 CFR § 403.8(f)(5); and
- j. Pursuant to 40 CFR § 403.8(g), the Permittee that chooses to receive electronic documents must satisfy the requirements of 40 CFR Part 3 – (Electronic reporting).

### 3. Local Limit Development

- a. The Permittee shall develop, continually maintain, and enforce, as necessary, local limits to implement the general and specific prohibitions in 40 CFR § 403.5(c)(1) which prohibit the introduction of any pollutant(s) which cause pass through or interference and the introduction of specific pollutants to the waste treatment system from any source of non-domestic discharge.
- b. The Permittee shall develop and enforce specific effluent limits (local limits) for Industrial User(s), and all other users, as appropriate, which together with appropriate changes in the POTW Treatment Plant's Facilities or operation, are necessary to ensure continued compliance with the POTW's NPDES permit or sludge use or disposal practices. Specific local limits shall not be developed and enforced without individual notice to persons or groups who have requested such notice and an opportunity to respond. Within 90 days of the effective date of the permit, the Permittee shall prepare and submit a written technical evaluation to EPA analyzing the need to revise local limits. As part of this evaluation, the Permittee shall assess how the POTW performs with respect to influent and effluent of pollutants, water quality concerns,

sludge quality, sludge processing concerns/inhibition, biomonitoring results, activated sludge inhibition, worker health and safety and collection system concerns. In preparing this evaluation, the Permittee shall complete and submit the attached form (see Attachment B – Reassessment of Technically Based Industrial Discharge Limits) with the technical evaluation to assist in determining whether existing local limits need to be revised. Justifications and conclusions should be based on actual plant data if available and should be included in the report. Should the evaluation reveal the need to revise local limits, the Permittee shall complete the revisions within 120 days of notification by EPA and submit the revisions to EPA for approval. The Permittee shall carry out the local limits revisions in accordance with EPA's Local Limit Development Guidance (July 2004).

#### 4. Notification Requirements

- a. The Permittee must notify EPA of any new introductions or any substantial change in pollutants from any Industrial User within sixty (60) days following the introduction or change, as required in 40 CFR 122.42(b)(1-3). Such notice must identify:
  - (1) Any new introduction of pollutants from an Industrial User which would be subject to Sections 301, 306, and 307 of the Act if it were directly discharging those pollutants; or
  - (2) Any substantial change in the volume or character of pollutants being discharged by any Industrial User;
  - (3) For the purposes of this section, adequate notice shall include information on:
    - i. The identity of the Industrial User;
    - ii. The nature and concentration of pollutants in the discharge and the average and maximum flow of the discharge; and
    - iii. Any anticipated impact of the change on the quantity or quality of effluent to be discharged from or biosolids produced at such POTW.
- b. The Permittee must notify EPA as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required when:
  - (1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source pursuant to 40 CFR § 122.29 (b);
  - (2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged; or
  - (3) The alteration or addition results in a significant change in the Permittee's sludge use or disposal practices.
- c. The Permittee must notify EPA if the POTW modifies or intends to modify its Pretreatment Program.
- d. The Permittee must notify EPA of any instance of pass through or interference, known or suspected to be related to a discharge from an Industrial User. The notification shall be attached to the DMR submitted EPA and shall describe the incident, including the date, time, length, cause, and the steps taken by the Permittee and Industrial User to address the incident.



- e. The Permittee shall notify all Industrial Users of the users' obligations to comply with applicable requirements under Subtitles C and D of the Resource Conservation and Recovery Act (RCRA) and that Industrial Users shall certify that it has a program in place to reduce the volume and toxicity of hazardous wastes generated to the degree it has determined to be economically practical as well as their obligation to notify the EPA Regional Waste Management Division Director, in writing of any discharge into the POTW of a substance, which, if otherwise disposed of, would be a hazardous waste under 40 CFR Part 261. Such notification must include:

- (1) the name of the hazardous waste as set forth in 40 CFR Part 261;
- (2) the EPA hazardous waste number; and
- (3) the type of discharge (continuous, batch, or other).

#### 5. Annual Report Requirements

The Permittee shall provide EPA with a hard copy annual report that briefly describes the POTW's program activities, including activities of all participating agencies, if more than one jurisdiction is involved in the local program. The report required by this section shall be submitted no later than one year after approval of the POTW's Pretreatment Program, and at least annually thereafter. The report must include, at a minimum, the applicable required data in Appendix A to 40 CFR Part 127, a summary of changes to the POTW's pretreatment program that have not been previously reported to EPA, and any other relevant information requested by EPA. Beginning on December 21, 2025 all annual reports submitted in compliance with this section must be submitted electronically by the POTW Pretreatment Program to EPA or initial recipient, as defined in 40 CFR § 127.2(b). Electronic submittals shall be in compliance with this section and 40 CFR Part 3 (including, in all cases, subpart D to Part 3), 40 CFR § 122.22(e), and 40 CFR Part 127 (Part 127 is not intended to undo existing requirements for electronic reporting). Prior to this date, and independent of 40 CFR Part 127, EPA may also require POTW Pretreatment Programs to electronically submit annual reports under this section if specified by a particular permit or if required to do so by state law.

The Permittee shall provide EPA with an annual report describing the Permittee's pretreatment program activities for the twelve (12) month period ending 60 days prior to the due date in accordance with 40 CFR § 403.12(i). The annual report shall be consistent with the format described in Attachment C (NPDES Permit Requirement for Industrial Pretreatment Annual Report) of this permit and shall be submitted by **March 31** of each year.

6. Beginning the first full calendar year after the effective date of the permit, the Permittee shall commence annual sampling of the following types of industrial discharges into the POTW:

- Commercial Car Washes
- Platers/Metal Finishers
- Paper and Packaging Manufacturers
- Tanneries and Leather/Fabric/Carpet Treaters
- Manufacturers of Parts with Polytetrafluoroethylene (PTFE) or teflon type coatings (e.g., bearings)
- Landfill Leachate
- Centralized Waste Treaters
- Known or Suspected PFAS Contaminated Sites

- Fire Fighting Training Facilities
- Airports
- Any Other Known or Expected Sources of PFAS

Sampling shall be conducted using Method 1633 for the PFAS analytes listed in Attachment D. The industrial discharges sampled, and the sampling results shall be summarized and included in the annual report (see Part I.E.5).

#### F. SLUDGE CONDITIONS

1. The Permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices, including EPA regulations promulgated at 40 CFR § 503, which prescribe “Standards for the Use or Disposal of Sewage Sludge” pursuant to § 405(d) of the CWA, 33 U.S.C. § 1345(d).
2. If both state and federal requirements apply to the Permittee’s sludge use and/or disposal practices, the Permittee shall comply with the more stringent of the applicable requirements.
3. The requirements and technical standards of 40 CFR Part 503 apply to the following sludge use or disposal practices:
  - a. Land application - the use of sewage sludge to condition or fertilize the soil
  - b. Surface disposal - the placement of sewage sludge in a sludge only landfill
  - c. Sewage sludge incineration in a sludge only incinerator
4. The requirements of 40 CFR Part 503 do not apply to facilities which dispose of sludge in a municipal solid waste landfill. 40 CFR § 503.4. These requirements also do not apply to facilities which do not use or dispose of sewage sludge during the life of the permit but rather treat the sludge (e.g., lagoons, reed beds), or are otherwise excluded under 40 CFR § 503.6.
5. The 40 CFR Part 503 requirements include the following elements:
  - a. General requirements
  - b. Pollutant limitations
  - c. Operational Standards (pathogen reduction requirements and vector attraction reduction requirements)
  - d. Management practices
  - e. Record keeping
  - f. Monitoring
  - g. Reporting

Which of the 40 CFR Part 503 requirements apply to the Permittee will depend upon the use or disposal practice followed and upon the quality of material produced by a facility. The EPA Region 1 guidance



document, “EPA Region 1 - NPDES Permit Sludge Compliance Guidance” (November 4, 1999), may be used by the Permittee to assist it in determining the applicable requirements.

6. The sludge shall be monitored for pollutant concentrations (all Part 503 methods) and pathogen reduction and vector attraction reduction (land application and surface disposal) at the following frequency. This frequency is based upon the volume of sewage sludge generated at the facility in dry metric tons per year, as follows:

less than 290	1/ year
290 to less than 1,500	1 /quarter
1,500 to less than 15,000	6 /year
15,000 +	1 /month

Sampling of the sewage sludge shall use the procedures detailed in 40 CFR § 503.8.

7. Under 40 CFR § 503.9(r), the Permittee is a “person who prepares sewage sludge” because it “is ... the person who generates sewage sludge during the treatment of domestic sewage in a treatment works ....” If the Permittee contracts with another “person who prepares sewage sludge” under 40 CFR § 503.9(r) – i.e., with “a person who derives a material from sewage sludge” – for use or disposal of the sludge, then compliance with Part 503 requirements is the responsibility of the contractor engaged for that purpose. If the Permittee does not engage a “person who prepares sewage sludge,” as defined in 40 CFR § 503.9(r), for use or disposal, then the Permittee remains responsible to ensure that the applicable requirements in Part 503 are met. 40 CFR § 503.7. If the ultimate use or disposal method is land application, the Permittee is responsible for providing the person receiving the sludge with notice and necessary information to comply with the requirements of 40 CFR § 503 Subpart B.
8. The Permittee shall submit an annual report containing the information specified in the 40 CFR Part 503 requirements (§ 503.18 (land application), § 503.28 (surface disposal), or § 503.48 (incineration)) by February 19 (see also “EPA Region 1 - NPDES Permit Sludge Compliance Guidance”). Reports shall be submitted electronically using EPA’s Electronic Reporting tool (“NeT”) (see “Reporting Requirements” section below).

## G. SPECIAL CONDITIONS

### 1. Nitrogen Optimization Requirement

The Permittee shall continue to optimize the treatment facility operations relative to total nitrogen (TN) removal through measures and/or operational changes designed to enhance the removal of nitrogen in order to minimize the annual average mass discharge of total nitrogen.

The Permittee shall submit an annual report to EPA and the State, by **February 1st** of each year, that summarizes activities related to optimizing nitrogen removal efficiencies, documents the annual nitrogen discharge load from the facility, and tracks trends relative to the previous calendar year and the previous five (5) calendar years. If, in any year, the treatment facility discharges of TN on an average annual basis have increased, the annual report shall include a detailed explanation of the reasons why TN discharges have increased, including any changes in influent flows/loads and any operational changes. The report shall include all supporting data.



**H. COMBINED SEWER OVERFLOWS (CSOs)**

1. During wet weather (including snowmelt), the Permittee is authorized to discharge storm water/wastewater from the CSO Outfalls listed below to the Connecticut River.

Outfall	Latitude	Longitude	Description
002	42° 10' 18.1305" N	72° 37' 47.8194" W	Providence Hospital
007	42° 11' 11.4228" N	72° 37' 22.3278" W	Northampton St./Glen St
008	42° 11' 17.4372" N	72° 37' 6.3366" W	Springdale Park
009	42° 11' 24.8244" N	72° 36' 42.6636" W	Berkshire
016	42° 12' 14.0868" N	72° 36' 27.7122" W	Front St./Appleton St.
018	42° 12' 42.3" N	72° 36' 21.8442" W	Walnut St.
019	42° 13' 9.2496" N	72° 36' 46.872" W	Yale St.
020	42° 13' 31.9578" N	72° 37' 2.0136" W	Cleveland St.
021	42° 13' 41.7966" N	72° 37' 21.4782" W	River Terrace
023	42° 13' 20.6226" N	72° 37' 28.4304" W	Jefferson

2. The effluent discharged from the CSO is subject to the following limitations:
- The discharges shall receive treatment at a level providing Best Practicable Control Technology Currently Available ("BPT"), Best Conventional Pollutant Control Technology ("BCT") to control and abate conventional pollutants and Best Available Technology Economically Achievable ("BAT") to control and abate non-conventional and toxic pollutants. The EPA has made a Best Professional Judgment (BPJ) determination that BPT, BCT, and BAT for combined sewer overflow (CSO) control includes the implementation of Nine Minimum Controls (NMC) specified below. These Nine Minimum Controls and the Nine Minimum Controls Minimum Implementation Levels which are detailed further in Part I.H.3. are requirements of this permit.
    - Proper operation and regular maintenance programs for the sewer system and the combined sewer overflows;
    - Maximum use of the collection system for storage;
    - Review and modification of the pretreatment program to assure CSO impacts are minimized;
    - Maximization of flow to the POTW for treatment;
    - Prohibition of dry weather overflows from CSOs;
    - Control of solid and floatable materials in CSOs;
    - Pollution prevention programs that focus on contaminant reduction activities;
    - Public notification to ensure that the public receives adequate notification of CSO occurrences and impacts;
    - Monitoring to effectively characterize CSO impacts and the efficacy of CSO controls.
  - The discharges shall not cause or contribute to violations of federal or state Water Quality Standards.

## 3. Nine Minimum Controls Minimum Implementation Levels

- a. The Permittee must implement the nine minimum controls in accordance with the documentation provided to EPA and MassDEP or as subsequently modified to enhance the effectiveness of the controls. This implementation must include the controls identified in Part I.H.3.b-g of this permit plus other controls the Permittee can reasonably undertake as set forth in the documentation.
- b. Each CSO structure/regulator, pumping station and/or tidegate shall be routinely inspected, at a minimum of once per month, to ensure that they are in good working condition and adjusted to minimize combined sewer discharges (NMC # 1, 2 and 4). The following inspection results shall be recorded: the date and time of inspection, the general condition of the facility, and whether the facility is operating satisfactorily. If maintenance is necessary, the Permittee shall record: the description of the necessary maintenance, the date the necessary maintenance was performed, and whether the observed problem was corrected. The Permittee shall maintain all records of inspections for at least three years.
- c. **Annually, by April 30<sup>th</sup>**, the Permittee shall submit a certification to MassDEP and EPA which states that the previous calendar year's monthly inspections were conducted, results recorded, and records maintained. MassDEP and EPA have the right to inspect any CSO related structure or outfall at any time without prior notification to the Permittee. Discharges to the combined system of septage, holding tank wastes, or other material which may cause a visible oil sheen or containing floatable material are prohibited during wet weather when CSO discharges may be active (NMC # 3, 6, and 7).
- d. Dry weather overflows ("DWOs") are prohibited (NMC # 5). All dry weather sanitary and/or industrial discharges from CSOs must be reported to EPA and MassDEP orally within 24 hours of the time the Permittee becomes aware of the circumstances and a report shall also be provided within 5 days of the time the Permittee becomes aware of the circumstances using "NeT" as described in Part I.I.4 below. See also Paragraph D.1.e. of Part II of this permit.
- e. The Permittee shall quantify and record all discharges from combined sewer outfalls (NMC # 9). Quantification shall be through direct measurement. The following information must be recorded for each combined sewer outfall for each discharge event, as set forth in Part I.H.4.:
  - Duration (hours) of discharge;
  - Volume (gallons) of discharge;
  - National Weather Service precipitation data from the nearest gage where precipitation is available at daily (24-hour) intervals and the nearest gage where precipitation is available at one-hour intervals. Cumulative precipitation per discharge event shall be calculated.

The Permittee shall maintain all records of discharges for at least six years after the effective date of this permit.

- f. The Permittee shall install and maintain identification signs for all combined sewer outfall structures (NMC # 8). The signs must be located at or near the combined sewer outfall structures and easily readable by the public from the land and water. These signs shall be a minimum of 12 x 18 inches in size, with white lettering against a green background, and shall contain the following information:



WET WEATHER  
SEWAGE DISCHARGE  
OUTFALL (discharge serial number)

The Permittee, to the extent feasible, shall add a universal wet weather sewage discharge symbol to existing signs.

Where there are easements over property not owned by the Permittee that must be obtained to meet this requirement, the Permittee shall identify the appropriate landowners and obtain the necessary easements, to the extent practicable.

g. Public Notification Plan

- (1) Within 180 days of the effective date of the permit, the Permittee shall submit to EPA and MassDEP a Public Notification Plan describing the measures that will be taken to meet NMC#8 in Part I.H.2 of this permit (NMC #8). The Public Notification Plan shall include the means for disseminating information to the public, including communicating the initial, supplemental, and annual notifications required in Part I.H.3.g.(2), (3) and (4) of this permit, as well as procedures for communicating with public health departments, including downstream communities, whose waters may be affected by discharges from the Permittee's CSOs.
- (2) Initial notification of a probable CSO activation shall be provided to the public as soon as practicable, but no later than, two (2) hours after becoming aware by monitoring, modeling or other means that a CSO discharge may have occurred. In addition to posting this notification to a website, this information may also be communicated using other electronic means. The initial notification shall include the following information:
  - Date and time of probable CSO discharge
  - CSO number and location
- (3) Supplemental notification shall be provided to the public as soon as practicable, but no later than, twenty-four (24) hours after becoming aware of the termination of any CSO discharge(s). In addition to posting this notification to a website, this information may also be communicated using other electronic means. The supplemental notification shall include the following information:
  - CSO number and location
  - Confirmation of CSO discharge
  - Date, start time and stop time of the CSO discharge
- (4) Annual notification - **Annually, by April 30<sup>th</sup>**, the Permittee shall post the annual report for the previous calendar year described in Part I.H.4 below on a publicly available website, and it shall remain on the website for a minimum of 24 months.
- (5) The Public Notification Plan shall be implemented no later than 12 months following the effective date of the Permit.

4. Nine Minimum Controls Reporting Requirement

**Annually, by April 30<sup>th</sup>**, the Permittee shall submit a report summarizing activities during the previous calendar year relating to compliance with the nine minimum controls. The annual report shall include information on the locations of CSOs, a summary of CSO outfall monitoring data required by Part I.H.5 of this permit, status and progress of CSO abatement work, and the impacts of CSOs on water quality of the receiving water.

#### 5. Combined Sewer Overflow Outfall Monitoring

For CSO Outfalls 002, 007, 008, 016, 018, 019, 020, 021, and 023, the Permittee must monitor and report the following:

Parameters	Reporting Requirements	Monitoring Requirements	
	Total Monthly	Measurement Frequency	Sample Type
Total Flow	Report Gallons	Daily, when discharging	Continuous
Total Flow Duration (Duration of flow through CSO)	Report Hours	Daily, when discharging	Continuous
Number of CSO Discharge Events	Report Monthly Count	Daily, when discharging	Count

- For Total Flow, measure the total flow discharged from each CSO outfall during the month. For Total Flow Duration, report the total duration (hours) of discharges for each CSO outfall during the month.
- For those months when a CSO discharge does not occur, the Permittee must indicate “no discharge” for the outfall for which data was not collected.
- This information shall be reported for each monthly DMR and submitted with the annual report required by Part I.H.4. of this permit.

#### 6. Berkshire Street CSO Treatment Facility

Discharges from the Berkshire Street CSO Treatment Facility to CSO Outfall 009 are subject to water quality-based limits and technology-based numeric effluent limits as enhanced minimum controls for CSO Outfall 009, as set forth below. Additional monitoring and reporting requirements also apply.



## Outfall 009 and Berkshire Street CSO Treatment Facility, Effluent Limitations and Monitoring Requirements

EFFLUENT		EFFLUENT LIMITS		MONITORING REQUIREMENTS	
PARAMETER	AVERAGE MONTHLY	MAXIMUM DAILY	MEASUREMENT FREQUENCY	SAMPLE TYPE	
E. Coli Bacteria <sup>1</sup>	126 cfu/100 ml	409 cfu/100 ml	1 Event/Month, Hourly	Grab	
Total Residual Chlorine <sup>2</sup>	0.14 mg/L	0.24 mg/L	Hourly	Grab	
pH Range	Report Maximum and Minimum, S.U.		1 Event/Month	Grab	
BOD <sub>5</sub> <sup>3</sup>	Report mg/L and lb/day	Report mg/L and lb/day	2/Year	Event Composite <sup>4</sup>	
TSS <sup>3</sup>	Report mg/L and lb/day	Report mg/L and lb/day	2/Year	Event Composite <sup>4</sup>	
Total Kjeldahl Nitrogen, Nitrate, Nitrite, Ammonia as Nitrogen, and Total Nitrogen <sup>3,5</sup>	Report mg/L and lb/day	*****	2/Year	Event Composite <sup>4</sup>	
LC <sub>50</sub> <sup>6</sup>	Report		2/Year	Event Composite <sup>4</sup>	
Parameter	Total Monthly	Measurement Frequency	Sample Type		
Total Flow (Treated Flow from Facility) <sup>7</sup>	Report Gallons	Daily, when discharging	Continuous		
Total Flow (Untreated Flow to River) <sup>7</sup>	Report Gallons	Daily, when discharging	Continuous		
Total Flow (Drained back to WPCF) <sup>7</sup>	Report Gallons	Daily, when discharging	Continuous		
Total Flow (Duration of flow through facility)	Report Hours	Daily, when discharging	Continuous		
Number of CSO Events	Report Monthly Count	Daily, when discharging	Count		

\*Footnotes for Outfall 009 and Berkshire Street CSO Treatment Facility:

1. Hourly sampling for *E. coli* will be performed for a four-hour duration. If the event lasts longer than four (4) hours, no further sampling is required. If hourly sampling is started and the event does not last at least four hours, another event during that month will be used for the hourly testing. The limits for *E. coli* are expressed as a geometric mean.
2. Monitoring shall be conducted for all events in which duration of flow from the facility exceeds 15 minutes. Hourly sampling for total residual chlorine will be performed for each hour up to a four-hour duration. If the event lasts longer than four (4) hours, sampling will be required every four hours after the fourth hour.
3. The Permittee shall collect BOD<sub>5</sub>, TSS, total Kjeldahl nitrogen, nitrite, nitrate and ammonia samples two times per year in May and November.
4. Event composite must represent an event duration of at least four hours. An event composite is considered to represent an event duration of at least four hours where (i) the composite represents at least four consecutive hours of flow through the facility; or (ii) the composite represents at least four hours of flow during a 24 hour period starting at approximately 8:00 AM each day ( $\pm 2$  hours) coinciding with the Permittee's composite sampling schedule, if flow through the facility is discontinuous.
5. The total Kjeldahl nitrogen, nitrite, nitrate and ammonia samples shall be collected concurrently. The results of the total Kjeldahl nitrogen, nitrite, and nitrate analyses may be used to determine the concentration and mass loading of total nitrogen. The Permittee shall report the monitoring results for each species of nitrogen as well as total nitrogen.
6. The Permittee shall conduct acute toxicity tests two times per year (*i.e.*, in May and November). The test results shall be submitted by the last day of the month following the completion of the test. The results are due June 30 and December 31, respectively. If weather does not permit collection of a four-hour composite in these months, the tests may be delayed to the first available event of four hour or more duration. The Permittee shall test the daphnid, Ceriodaphnia dubia, only. The tests must be performed in accordance with test procedures and protocols specified in **Attachment A** of this permit, except that the Permittee may use an alternate dilution water.
7. The Permittee shall also submit a monthly operating report, as an attachment to their monthly DMR, for the Berkshire Street CSO Treatment Facility. The monthly operating reports shall contain:
  - (i) Total precipitation for each day (whether or not there was flow through facility);
  - (ii) Date on which flow through facility occurred;
  - (iii) Time in which the flow initiated;
  - (iv) Total Duration of flow through facility for each day (hours);
  - (v) Treated flow from facility (gallons);
  - (vi) Untreated flow to river (gallons);
  - (vii) Flow drained back to WPCD (gallons);
  - (viii) Concurrent flow rate at the WPCD (gallons);
  - (ix) Monitoring results for each event.



**I. REPORTING REQUIREMENTS**

Unless otherwise specified in this permit, the Permittee shall submit reports, requests, and information and provide notices in the manner described in this section.

**1. Submittal of DMRs Using NetDMR**

The Permittee shall continue to submit its monthly monitoring data in discharge monitoring reports (DMRs) to EPA and the State electronically using NetDMR no later than the 15th day of the month. When the Permittee submits DMRs using NetDMR, it is not required to submit hard copies of DMRs to EPA or the State. NetDMR is accessible through EPA's Central Data Exchange at <https://cdx.epa.gov/>.

**2. Submittal of Reports as NetDMR Attachments**

Unless otherwise specified in this permit, the Permittee shall electronically submit all reports to EPA as NetDMR attachments rather than as hard copies. See Part I.I.7. for more information on State reporting. Because the due dates for reports described in this permit may not coincide with the due date for submitting DMRs (which is no later than the 15th day of the month), a report submitted electronically as a NetDMR attachment shall be considered timely if it is electronically submitted to EPA using NetDMR with the next DMR due following the report due date specified in this permit.

**3. Submittal of Industrial User and Pretreatment Related Reports**

- a. Prior to 21 December 2025, all reports and information required of the Permittee in the Industrial Users and Pretreatment Program section of this permit shall be submitted to the Pretreatment Coordinator in EPA Region 1 Water Division (WD). Starting on 21 December 2025, these submittals must be done electronically as NetDMR attachments and/or using EPA's NPDES Electronic Reporting Tool ("NeT"), or another approved EPA system, which will be accessible through EPA's Central Data Exchange at <https://cdx.epa.gov/>. These requests, reports and notices include:

- (1) Annual Pretreatment Reports,
- (2) Pretreatment Reports Reassessment of Technically Based Industrial Discharge Limits Form,
- (3) Revisions to Industrial Discharge Limits,
- (4) Report describing Pretreatment Program activities, and
- (5) Proposed changes to a Pretreatment Program

- b. This information shall be submitted to EPA WD as a hard copy at the following address:

**U.S. Environmental Protection Agency  
Water Division  
Regional Pretreatment Coordinator  
5 Post Office Square - Suite 100 (06-03)  
Boston, MA 02109-3912**

4. Submittal of Biosolids/Sewage Sludge Reports

By February 19 of each year, the Permittee must electronically report their annual Biosolids/Sewage Sludge Report for the previous calendar year using EPA's NPDES Electronic Reporting Tool ("NeT"), or another approved EPA system, which is accessible through EPA's Central Data Exchange at <https://cdx.epa.gov/>.

5. Submittal of Requests and Reports to EPA Water Division (WD)

- a. The following requests, reports, and information described in this permit shall be submitted to the NPDES Applications Coordinator in EPA Water Division (WD):
- (1) Transfer of permit notice;
  - (2) Request for changes in sampling location;
  - (3) Request for reduction in testing frequency;
  - (4) Report on unacceptable dilution water / request for alternative dilution water for WET testing;
- b. These reports, information, and requests shall be submitted to EPA WD electronically at [R1NPDESReporting@epa.gov](mailto:R1NPDESReporting@epa.gov).

6. Submittal of Sewer Overflow and Bypass Reports and Notifications

The Permittee shall submit required reports and notifications under Part II.B.4.c, for bypasses, and Part II.D.1.e, for sanitary sewer overflows (SSOs) electronically using EPA's NPDES Electronic Reporting Tool ("NeT"), which will be accessible through EPA's Central Data Exchange at <https://cdx.epa.gov/>.

7. State Reporting

Duplicate signed copies of all WET test reports shall be submitted to the Massachusetts Department of Environmental Protection, Division of Watershed Management, at the following address:

**Massachusetts Department of Environmental Protection  
Bureau of Water Resources  
Division of Watershed Management**



**8 New Bond Street  
Worcester, Massachusetts 01606**

8. Verbal Reports and Verbal Notifications
  - a. Any verbal reports or verbal notifications, if required in Parts I and/or II of this permit, shall be made to both EPA and to the State. This includes verbal reports and notifications which require reporting within 24 hours (e.g., Part II.B.4.c.(2), Part II.B.5.c.(3), and Part II.D.1.e).
  - b. Verbal reports and verbal notifications shall be made to:

**EPA ECAD at 617-918-1510  
and  
MassDEP Emergency Response at 888-304-1133**

**J. STATE 401 CERTIFICATION CONDITIONS**

1. This Permit is in the process of receiving state water quality certification issued by the State under § 401(a) of the CWA and 40 CFR § 124.53. EPA will incorporate appropriate State water quality certification requirements (if any) into the Final Permit.

## ATTACHMENT A

### USEPA REGION 1 FRESHWATER ACUTE TOXICITY TEST PROCEDURE AND PROTOCOL

#### I. GENERAL REQUIREMENTS

The permittee shall conduct acceptable acute toxicity tests in accordance with the appropriate test protocols described below:

- Daphnid (*Ceriodaphnia dubia*) definitive 48 hour test.
- Fathead Minnow (*Pimephales promelas*) definitive 48 hour test.

Acute toxicity test data shall be reported as outlined in Section VIII.

#### II. METHODS

The permittee shall use 40 CFR Part 136 methods. Methods and guidance may be found at:

[http://water.epa.gov/scitech/methods/cwa/wet/disk2\\_index.cfm](http://water.epa.gov/scitech/methods/cwa/wet/disk2_index.cfm)

The permittee shall also meet the sampling, analysis and reporting requirements included in this protocol. This protocol defines more specific requirements while still being consistent with the Part 136 methods. If, due to modifications of Part 136, there are conflicting requirements between the Part 136 method and this protocol, the permittee shall comply with the requirements of the Part 136 method.

#### III. SAMPLE COLLECTION

A discharge sample shall be collected. Aliquots shall be split from the sample, containerized and preserved (as per 40 CFR Part 136) for chemical and physical analyses required. The remaining sample shall be measured for total residual chlorine and dechlorinated (if detected) in the laboratory using sodium thiosulfate for subsequent toxicity testing. (Note that EPA approved test methods require that samples collected for metals analyses be preserved immediately after collection.) Grab samples must be used for pH, temperature, and total residual chlorine (as per 40 CFR Part 122.21).

Standard Methods for the Examination of Water and Wastewater describes dechlorination of samples (APHA, 1992). Dechlorination can be achieved using a ratio of 6.7 mg/L anhydrous sodium thiosulfate to reduce 1.0 mg/L chlorine. If dechlorination is necessary, a thiosulfate control (maximum amount of thiosulfate in lab control or receiving water) must also be run in the WET test.

All samples held overnight shall be refrigerated at 1- 6°C.



#### IV. DILUTION WATER

A grab sample of dilution water used for acute toxicity testing shall be collected from the receiving water at a point immediately upstream of the permitted discharge's zone of influence at a reasonably accessible location. Avoid collection near areas of obvious road or agricultural runoff, storm sewers or other point source discharges and areas where stagnant conditions exist. In the case where an alternate dilution water has been agreed upon an additional receiving water control (0% effluent) must also be tested.

If the receiving water diluent is found to be, or suspected to be toxic or unreliable, an alternate standard dilution water of known quality with a hardness, pH, conductivity, alkalinity, organic carbon, and total suspended solids similar to that of the receiving water may be substituted **AFTER RECEIVING WRITTEN APPROVAL FROM THE PERMIT ISSUING AGENCY(S)**. Written requests for use of an alternate dilution water should be mailed with supporting documentation to the following address:

Director  
Office of Ecosystem Protection (CAA)  
U.S. Environmental Protection Agency-New England  
5 Post Office Sq., Suite 100 (OEP06-5)  
Boston, MA 02109-3912

and

Manager  
Water Technical Unit (SEW)  
U.S. Environmental Protection Agency  
5 Post Office Sq., Suite 100 (OES04-4)  
Boston, MA 02109-3912

Note: USEPA Region 1 retains the right to modify any part of the alternate dilution water policy stated in this protocol at any time. Any changes to this policy will be documented in the annual DMR posting.

*See the most current annual DMR instructions which can be found on the EPA Region 1 website at <http://www.epa.gov/region1/enforcement/water/dmr.html> for further important details on alternate dilution water substitution requests.*

It may prove beneficial to have the proposed dilution water source screened for suitability prior to toxicity testing. EPA strongly urges that screening be done prior to set up of a full definitive toxicity test any time there is question about the dilution water's ability to support acceptable performance as outlined in the 'test acceptability' section of the protocol.

#### V. TEST CONDITIONS

The following tables summarize the accepted daphnid and fathead minnow toxicity test conditions and test acceptability criteria:

**EPA NEW ENGLAND EFFLUENT TOXICITY TEST CONDITIONS FOR THE  
DAPHNID, CERIODAPHNIA DUBIA 48 HOUR ACUTE TESTS<sup>1</sup>**

1. Test type	Static, non-renewal
2. Temperature (°C)	20 ± 1°C or 25 ± 1°C
3. Light quality	Ambient laboratory illumination
4. Photoperiod	16 hour light, 8 hour dark
5. Test chamber size	Minimum 30 ml
6. Test solution volume	Minimum 15 ml
7. Age of test organisms	1-24 hours (neonates)
8. No. of daphnids per test chamber	5
9. No. of replicate test chambers per treatment	4
10. Total no. daphnids per test concentration	20
11. Feeding regime	As per manual, lightly feed YCT and <u>Selenastrum</u> to newly released organisms while holding prior to initiating test
12. Aeration	None
13. Dilution water <sup>2</sup>	Receiving water, other surface water, synthetic water adjusted to the hardness and alkalinity of the receiving water (prepared using either Millipore Milli-Q <sup>R</sup> or equivalent deionized water and reagent grade chemicals according to EPA acute toxicity test manual) or deionized water combined with mineral water to appropriate hardness.
14. Dilution series	≥ 0.5, must bracket the permitted RWC
15. Number of dilutions	5 plus receiving water and laboratory water control and thiosulfate control, as necessary. An additional dilution at the permitted effluent concentration (% effluent) is required if it is not included in the dilution



series.

- |                            |   |
|----------------------------|---|
| 16. Effect measured        | Mortality-no movement of body or appendages on gentle prodding  |
| 17. Test acceptability     | 90% or greater survival of test organisms in dilution water control solution  |
| 18. Sampling requirements  | For on-site tests, samples must be used within 24 hours of the time that they are removed from the sampling device. For off-site tests, samples must first be used within 36 hours of collection. |
| 19. Sample volume required | Minimum 1 liter   |

---

Footnotes:

1. Adapted from EPA-821-R-02-012.
2. Standard prepared dilution water must have hardness requirements to generally reflect the characteristics of the receiving water.

**EPA NEW ENGLAND TEST CONDITIONS FOR THE FATHEAD MINNOW  
(PIMEPHALES PROMELAS) 48 HOUR ACUTE TEST<sup>1</sup>**

---

1. Test Type	Static, non-renewal
2. Temperature (°C)	$20 \pm 1$ °C or $25 \pm 1$ °C
3. Light quality	Ambient laboratory illumination
4. Photoperiod	16 hr light, 8 hr dark
5. Size of test vessels	250 mL minimum
6. Volume of test solution	Minimum 200 mL/replicate
7. Age of fish	1-14 days old and age within 24 hrs of each other
8. No. of fish per chamber	10
9. No. of replicate test vessels per treatment	4
10. Total no. organisms per concentration	40
11. Feeding regime	As per manual, lightly feed test age larvae using concentrated brine shrimp nauplii while holding prior to initiating test
12. Aeration	None, unless dissolved oxygen (D.O.) concentration falls below 4.0 mg/L, at which time gentle single bubble aeration should be started at a rate of less than 100 bubbles/min. (Routine D.O. check is recommended.)
13. dilution water <sup>2</sup>	Receiving water, other surface water, synthetic water adjusted to the hardness and alkalinity of the receiving water (prepared using either Millipore Milli-Q <sup>R</sup> or equivalent deionized and reagent grade chemicals according to EPA acute toxicity test manual) or deionized water combined with mineral water to appropriate hardness.
14. Dilution series	$\geq 0.5$ , must bracket the permitted RWC



- |                            |  |
|----------------------------|--|
| 15. Number of dilutions    | 5 plus receiving water and laboratory water control and thiosulfate control, as necessary. An additional dilution at the permitted effluent concentration (% effluent) is required if it is not included in the dilution series. |
| 16. Effect measured        |  |
| 17. Test acceptability     | Mortality-no movement on gentle prodding<br>90% or greater survival of test organisms in dilution water control solution   |
| 18. Sampling requirements  | For on-site tests, samples must be used within 24 hours of the time that they are removed from the sampling device. For off-site tests, samples are used within 36 hours of collection.  |
| 19. Sample volume required | Minimum 2 liters   |

---

Footnotes:

1. Adapted from EPA-821-R-02-012
2. Standard dilution water must have hardness requirements to generally reflect characteristics of the receiving water.

## VI. CHEMICAL ANALYSIS

At the beginning of a static acute toxicity test, pH, conductivity, total residual chlorine, oxygen, hardness, alkalinity and temperature must be measured in the highest effluent concentration and the dilution water. Dissolved oxygen, pH and temperature are also measured at 24 and 48 hour intervals in all dilutions. The following chemical analyses shall be performed on the 100 percent effluent sample and the upstream water sample for each sampling event.

Parameter	Effluent	Receiving Water	ML (mg/l)
Hardness <sup>1</sup>	x	x	0.5
Total Residual Chlorine (TRC) <sup>2, 3</sup>	x		0.02
Alkalinity	x	x	2.0
pH	x	x	--
Specific Conductance	x	x	--
Total Solids	x		--
Total Dissolved Solids	x		--
Ammonia	x	x	0.1
Total Organic Carbon	x	x	0.5
Total Metals			
Cd	x	x	0.0005
Pb	x	x	0.0005
Cu	x	x	0.003
Zn	x	x	0.005
Ni	x	x	0.005
Al	x	x	0.02
Other as permit requires			

### Notes:

- Hardness may be determined by:
  - APHA Standard Methods for the Examination of Water and Wastewater, 21st Edition
    - Method 2340B (hardness by calculation)
    - Method 2340C (titration)
- Total Residual Chlorine may be performed using any of the following methods provided the required minimum limit (ML) is met.
  - APHA Standard Methods for the Examination of Water and Wastewater, 21st Edition
    - Method 4500-CL E Low Level Amperometric Titration
    - Method 4500-CL G DPD Colorimetric Method
- Required to be performed on the sample used for WET testing prior to its use for toxicity testing.



## **VII. TOXICITY TEST DATA ANALYSIS**

### LC50 Median Lethal Concentration (Determined at 48 Hours)

Methods of Estimation:

- Probit Method
- Spearman-Kärber
- Trimmed Spearman-Kärber
- Graphical

See the flow chart in Figure 6 on p. 73 of EPA-821-R-02-012 for appropriate method to use on a given data set.

### No Observed Acute Effect Level (NOAEL)

See the flow chart in Figure 13 on p. 87 of EPA-821-R-02-012.

## **VIII. TOXICITY TEST REPORTING**

A report of the results will include the following:

- Description of sample collection procedures, site description
- Names of individuals collecting and transporting samples, times and dates of sample collection and analysis on chain-of-custody
- General description of tests: age of test organisms, origin, dates and results of standard toxicant tests; light and temperature regime; other information on test conditions if different than procedures recommended. Reference toxicant test data should be included.
- All chemical/physical data generated. (Include minimum detection levels and minimum quantification levels.)
- Raw data and bench sheets.
- Provide a description of dechlorination procedures (as applicable).
- Any other observations or test conditions affecting test outcome.

## ATTACHMENT B

### EPA - New England

#### Reassessment of Technically Based Industrial Discharge Limits

Under 40 CFR §122.21(j)(4), all Publicly Owned Treatment Works (POTWs) with approved Industrial Pretreatment Programs (IPPs) shall provide the following information to the Director: a written evaluation of the need to revise local industrial discharge limits under 40 CFR §403.5(c)(1).

Below is a form designed by the U.S. Environmental Protection Agency (EPA - New England) to assist POTWs with approved IPPs in evaluating whether their existing Technically Based Local Limits (TBLLs) need to be recalculated. The form allows the permittee and EPA to evaluate and compare pertinent information used in previous TBLLs calculations against present conditions at the POTW.

**Please read direction below before filling out form.**

#### ITEM I.

- \* In Column (1), list what your POTW's influent flow rate was when your existing TBLLs were calculated. In Column (2), list your POTW's present influent flow rate. Your current flow rate should be calculated using the POTW's average daily flow rate from the previous 12 months.
- \* In Column (1) list what your POTW's SIU flow rate was when your existing TBLLs were calculated. In Column (2), list your POTW's present SIU flow rate.
- \* In Column (1), list what dilution ratio and/or 7Q10 value was used in your old/expired NPDES permit. In Column (2), list what dilution ration and/or 7Q10 value is presently being used in your new/reissued NPDES permit.

The 7Q10 value is the lowest seven day average flow rate, in the river, over a ten year period. The 7Q10 value and/or dilution ratio used by EPA in your new NPDES permit can be found in your NPDES permit "Fact Sheet."

- \* In Column (1), list the safety factor, if any, that was used when your existing TBLLs were calculated.
- \* In Column (1), note how your bio-solids were managed when your existing TBLLs were calculated. In Column (2), note how your POTW is presently disposing of its biosolids and how your POTW will be disposing of its biosolids in the future.



## ITEM II.

- \* List what your existing TBLLs are - as they appear in your current Sewer Use Ordinance (SUO).

## ITEM III.

- \* Identify how your existing TBLLs are allocated out to your industrial community. Some pollutants may be allocated differently than others, if so please explain.

## ITEM IV.

- \* Since your existing TBLLs were calculated, identify the following in detail:
  - (1) if your POTW has experienced any upsets, inhibition, interference or pass-through as a result of an industrial discharge.
  - (2) if your POTW is presently violating any of its current NPDES permit limitations - include toxicity.

## ITEM V.

- \* Using current sampling data, list in Column (1) the average and maximum amount of pollutants (in pounds per day) received in the POTW's influent. Current sampling data is defined as data obtained over the last 24 month period.

All influent data collected and analyzed must be in accordance with 40 CFR §136. Sampling data collected should be analyzed using the lowest possible detection method(s), e.g. graphite furnace.

- \* Based on your existing TBLLs, as presented in Item II., list in Column (2), for each pollutant the Maximum Allowable Headwork Loading (MAHL) values derived from an applicable environmental criteria or standard, e.g. water quality, sludge, NPDES, inhibition, etc. For more information, please see EPA's Local Limit Guidance Document (July 2004).

## Item VI.

- \* Using current sampling data, list in Column (1) the average and maximum amount of pollutants (in micrograms per liter) present your POTW's effluent. Current sampling data is defined as data obtained during the last 24 month period.

**(Item VI. continued)**

All effluent data collected and analyzed must be in accordance with 40 CFR §136. Sampling data collected should be analyzed using the lowest possible detection method(s), e.g. graphite furnace.

- \* List in Column (2A) what the Water Quality Standards (WQS) were (in micrograms per liter) when your TBLLs were calculated, please note what hardness value was used at that time. Hardness should be expressed in milligram per liter of Calcium Carbonate.

List in Column (2B) the current WQSs or "Chronic Gold Book" values for each pollutant multiplied by the dilution ratio used in your new/reissued NPDES permit. For example, with a dilution ratio of 25:1 at a hardness of 25 mg/l - Calcium Carbonate (copper's chronic WQS equals 6.54 ug/l) the chronic NPDES permit limit for copper would equal 156.25 ug/l.

**ITEM VII.**

- \* In Column (1), list all pollutants (in micrograms per liter) limited in your new/reissued NPDES permit. In Column (2), list all pollutants limited in your old/expired NPDES permit.

**ITEM VIII.**

- \* Using current sampling data, list in Column (1) the average and maximum amount of pollutants in your POTW's biosolids. Current data is defined as data obtained during the last 24 month period. Results are to be expressed as total dry weight.

All biosolids data collected and analyzed must be in accordance with 40 CFR §136.

In Column (2A), list current State and/or Federal sludge standards that your facility's biosolids must comply with. Also note how your POTW currently manages the disposal of its biosolids. If your POTW is planning on managing its biosolids differently, list in Column (2B) what your new biosolids criteria will be and method of disposal.

In general, please be sure the units reported are correct and all pertinent information is included in your evaluation. If you have any questions, please contact your pretreatment representative at EPA - New England.



## REASSESSMENT OF TECHNICALLY BASED LOCAL LIMITS (TBLLs)

POTW Name & Address : \_\_\_\_\_

NPDES	PERMIT	#
-------	--------	---

Date EPA approved current TBLLs : \_\_\_\_\_

Date	EPA approved	current	Sewer	Use	Ordinance
------	--------------	---------	-------	-----	-----------

ITEM I.

In Column (1) list the conditions that existed when your current TBLLs were calculated. In Column (2), list current conditions or expected conditions at your POTW.

	Column (1) EXISTING TBLLs	Column (2) PRESENT CONDITIONS
POTW Flow (MGD)		
Dilution Ratio or 7Q10 (from NPDES Permit)		
SIU Flow (MGD)		
Safety Factor		N/A
Biosolids Disposal Method(s)		

**ITEM II.**

EXISTING TBLLs			
POLLUTANT	NUMERICAL LIMIT (mg/l) or (lb/day)	POLLUTANT	NUMERICAL LIMIT (mg/l) or (lb/day)

**ITEM III.**

Note how your existing TBLLs, listed in Item II., are allocated to your Significant Industrial Users (SIUs), i.e. uniform concentration, contributory flow, mass proportioning, other. Please specify by circling.

**ITEM IV.**

Has your POTW experienced any upsets, inhibition, interference or pass-through from industrial sources since your existing TBLLs were calculated?

If yes, explain.

---

---

Has your POTW violated any of its NPDES permit limits and/or toxicity test requirements?

If yes, explain.

---

---



# ITEM V.

Using current POTW influent sampling data fill in Column (1). In Column (2), list your Maximum Allowable Headwork Loading (MAHL) values used to derive your TBLLs listed in Item II. In addition, please note the Environmental Criteria for which each MAHL value was established, i.e. water quality, sludge, NPDES etc.

Pollutant	Column (1) Influent Data Analyses		Column (2)	Criteria
	Maximum (lb/day)	Average (lb/day)	MAHL Values (lb/day)	
Arsenic				
Cadmium				
Chromium				
Copper				
Cyanide				
Lead				
Mercury				
Nickel				
Silver				
Zinc				
Other (List)				

# ITEM VI.

Using current POTW effluent sampling data, fill in Column (1). In Column (2A) list what the Water Quality Standards (Gold Book Criteria) were at the time your existing TBLLs were developed. List in Column (2B) current Gold Book values multiplied by the dilution ratio used in your new/reissued NPDES permit.

Pollutant	Column (1)		Columns (2A) (2B)	
	Effluent Data Analyses Maximum (ug/l)	Average (ug/l)	Water Quality Criteria (Gold Book) From TBLLs Today (ug/l) (ug/l)	
Arsenic				
*Cadmium				
*Chromium				
*Copper				
Cyanide				
*Lead				
Mercury				
*Nickel				
Silver				
*Zinc				
Other (List)				

\*Hardness Dependent (mg/l - CaCO<sub>3</sub>)



ITEM VII.

In Column (1), identify all pollutants limited in your new/reissued NPDES permit. In Column (2), identify all pollutants that were limited in your old/expired NPDES permit.

[illegible]

### ITEM VIII.

<p>Using current POTW biosolids data, fill in Column (1). In Column (2A), list the biosolids criteria that was used at the time your existing TBLLs were calculated. If your POTW is planing on managing its biosolids differently, list in Column (2B) what your new biosolids criteria would be and method of disposal.</p>			
Pollutant	Column (1) Data Analyses  Average (mg/kg)	Biosolids	Columns (2A) (2B) Biosolids Criteria From TBLLs New (mg/kg) (mg/kg)
Arsenic			
Cadmium			
Chromium			
Copper			
Cyanide			
Lead			
Mercury			
Nickel			
Silver			
Zinc			
Molybdenum			
Selenium			
Other (List)			



## ATTACHMENT C

### NPDES PERMIT REQUIREMENT FOR INDUSTRIAL PRETREATMENT ANNUAL REPORT

The information described below shall be included in the pretreatment program annual reports:

1. An updated list of all industrial users by category, as set forth in 40 C.F.R. 403.8(f)(2)(i), indicating compliance or noncompliance with the following:
  - baseline monitoring reporting requirements for newly promulgated industries
  - compliance status reporting requirements for newly promulgated industries
  - periodic (semi-annual) monitoring reporting requirements,
  - categorical standards, and
  - local limits;
2. A summary of compliance and enforcement activities during the preceding year, including the number of:
  - significant industrial users inspected by POTW (include inspection dates for each industrial user),
  - significant industrial users sampled by POTW (include sampling dates for each industrial user),
  - compliance schedules issued (include list of subject users),
  - written notices of violations issued (include list of subject users),
  - administrative orders issued (include list of subject users),
  - criminal or civil suits filed (include list of subject users) and,
  - penalties obtained (include list of subject users and penalty amounts);
3. A list of significantly violating industries required to be published in a local newspaper in accordance with 40 C.F.R. 403.8(f)(2)(vii);
4. A narrative description of program effectiveness including present and proposed changes to the program, such as funding, staffing, ordinances, regulations, rules and/or statutory authority;
5. A summary of all pollutant analytical results for influent, effluent, sludge and any toxicity or bioassay data from the wastewater treatment facility. The summary shall include a comparison of influent sampling results versus threshold inhibitory concentrations for the Wastewater Treatment System and effluent sampling results versus water quality standards. Such a comparison shall be based on the sampling program described in the paragraph below or any similar sampling program described in this Permit.

At a minimum, annual sampling and analysis of the influent and effluent of the Wastewater Treatment Plant shall be conducted for the following pollutants:

- |                    |                   |
|--------------------|-------------------|
| a.) Total Cadmium  | f.) Total Nickel  |
| b.) Total Chromium | g.) Total Silver  |
| c.) Total Copper   | h.) Total Zinc    |
| d.) Total Lead     | i.) Total Cyanide |
| e.) Total Mercury  | j.) Total Arsenic |

The sampling program shall consist of one 24-hour flow-proportioned composite and at least one grab sample that is representative of the flows received by the POTW. The composite shall consist of hourly flow-proportioned grab samples taken over a 24-hour period if the sample is collected manually or shall consist of a minimum of 48 samples collected at 30 minute intervals if an automated sampler is used. Cyanide shall be taken as a grab sample during the same period as the composite sample. Sampling and preservation shall be consistent with 40 CFR Part 136.

6. A detailed description of all interference and pass-through that occurred during the past year;
7. A thorough description of all investigations into interference and pass-through during the past year;
8. A description of monitoring, sewer inspections and evaluations which were done during the past year to detect interference and pass-through, specifying parameters and frequencies;
9. A description of actions being taken to reduce the incidence of significant violations by significant industrial users; and,
10. The date of the latest adoption of local limits and an indication as to whether or not the permittee is under a State or Federal compliance schedule that includes steps to be taken to revise local limits.



# Attachment D: PFAS Analyte List

Target Analyte Name	Abbreviation	CAS Number
<b>Perfluoroalkyl carboxylic acids</b>		
Perfluorobutanoic acid	PFBA	375-22-4
Perfluoropentanoic acid	PFPeA	2706-90-3
Perfluorohexanoic acid	PFHxA	307-24-4
Perfluoroheptanoic acid	PFHpA	375-85-9
Perfluorooctanoic acid	PFOA	335-67-1
Perfluorononanoic acid	PFNA	375-95-1
Perfluorodecanoic acid	PFDA	335-76-2
Perfluoroundecanoic acid	PFUnA	2058-94-8
Perfluorododecanoic acid	PFDaA	307-55-1
Perfluorotridecanoic acid	PFTTrDA	72629-94-8
Perfluorotetradecanoic acid	PFTeDA	376-06-7
<b>Perfluoroalkyl sulfonic acids</b>		
<b>Acid Form</b>		
Perfluorobutanesulfonic acid	PFBS	375-73-5
Perfluoropentanesulfonic acid	PFPeS	2706-91-4
Perfluorohexanesulfonic acid	PFHxS	355-46-4
Perfluoroheptanesulfonic acid	PFHpS	375-92-8
Perfluorooctanesulfonic acid	PFOS	1763-23-1
Perfluorononanesulfonic acid	PFNS	68259-12-1
Perfluorodecanesulfonic acid	PFDS	335-77-3
Perfluorododecanesulfonic acid	PFDoS	79780-39-5
<b>Fluorotelomer sulfonic acids</b>		
1H,1H, 2H, 2H-Perfluorohexane sulfonic acid	4:2FTS	757124-72-4
1H,1H, 2H, 2H-Perfluorooctane sulfonic acid	6:2FTS	27619-97-2
1H,1H, 2H, 2H-Perfluorodecane sulfonic acid	8:2FTS	39108-34-4
<b>Perfluorooctane sulfonamides</b>		
Perfluorooctanesulfonamide	PFOSA	754-91-6
N-methyl perfluorooctanesulfonamide	NMeFOSA	31506-32-8
N-ethyl perfluorooctanesulfonamide	NEtFOSA	4151-50-2
<b>Perfluorooctane sulfonamidoacetic acids</b>		
N-methyl perfluorooctanesulfonamidoacetic acid	NMeFOSAA	2355-31-9
N-ethyl perfluorooctanesulfonamidoacetic acid	NEtFOSAA	2991-50-6
<b>Perfluorooctane sulfonamide ethanols</b>		
N-methyl perfluorooctanesulfonamidoethanol	NMeFOSE	24448-09-7
N-ethyl perfluorooctanesulfonamidoethanol	NEtFOSE	1691-99-2
<b>Per- and Polyfluoroether carboxylic acids</b>		
Hexafluoropropylene oxide dimer acid	HFPO-DA	13252-13-6
4,8-Dioxa-3H-perfluorononanoic acid	ADONA	919005-14-4
Perfluoro-3-methoxypropanoic acid	PFMPA	377-73-1
Perfluoro-4-methoxybutanoic acid	PFMBA	863090-89-5
Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	151772-58-6

Target Analyte Name	Abbreviation	CAS Number
<b>Ether sulfonic acids</b>		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF3ONS	756426-58-1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	763051-92-9
Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	113507-82-7
<b>Fluorotelomer carboxylic acids</b>		
3-Perfluoropropyl propanoic acid	3:3FTCA	356-02-5
2H,2H,3H,3H-Perfluorooctanoic acid	5:3FTCA	914637-49-3
3-Perfluoroheptyl propanoic acid	7:3FTCA	812-70-4



NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)<sup>1</sup>

TABLE OF CONTENTS

A. GENERAL CONDITIONS	Page
1. <u>Duty to Comply</u>	2
2. <u>Permit Actions</u>	3
3. <u>Duty to Provide Information</u>	4
4. <u>Oil and Hazardous Substance Liability</u>	4
5. <u>Property Rights</u>	4
6. <u>Confidentiality of Information</u>	4
7. <u>Duty to Reapply</u>	4
8. <u>State Authorities</u>	4
9. <u>Other laws</u>	5
B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS	
1. <u>Proper Operation and Maintenance</u>	5
2. <u>Need to Halt or Reduce Not a Defense</u>	5
3. <u>Duty to Mitigate</u>	5
4. <u>Bypass</u>	5
5. <u>Upset</u>	6
C. MONITORING AND RECORDS	
1. <u>Monitoring and Records</u>	7
2. <u>Inspection and Entry</u>	8
D. REPORTING REQUIREMENTS	
1. <u>Reporting Requirements</u>	8
a. Planned changes	8
b. Anticipated noncompliance	8
c. Transfers	9
d. Monitoring reports	9
e. Twenty-four hour reporting	9
f. Compliance schedules	10
g. Other noncompliance	10
h. Other information	10
i. Identification of the initial recipient for NPDES electronic reporting data	11
2. <u>Signatory Requirement</u>	11
3. <u>Availability of Reports</u>	11
E. DEFINITIONS AND ABBREVIATIONS	
1. <u>General Definitions</u>	11
2. <u>Commonly Used Abbreviations</u>	20

<sup>1</sup> Updated July 17, 2018 to fix typographical errors.

NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

A. GENERAL REQUIREMENTS

1. Duty to Comply

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act (CWA or Act) and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

- a. The Permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
- b. Penalties for Violations of Permit Conditions: The Director will adjust the civil and administrative penalties listed below in accordance with the Civil Monetary Penalty Inflation Adjustment Rule (83 Fed. Reg. 1190-1194 (January 10, 2018) and the 2015 amendments to the Federal Civil Penalties Inflation Adjustment Act of 1990, 28 U.S.C. § 2461 note. See Pub. L. 114-74, Section 701 (Nov. 2, 2015)). These requirements help ensure that EPA penalties keep pace with inflation. Under the above-cited 2015 amendments to inflationary adjustment law, EPA must review its statutory civil penalties each year and adjust them as necessary.

(1) Criminal Penalties

- (a) *Negligent Violations.* The CWA provides that any person who negligently violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to criminal penalties of not less than \$2,500 nor more than \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation or by imprisonment of not more than 2 years, or both.
- (b) *Knowing Violations.* The CWA provides that any person who knowingly violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to a fine of not less than \$5,000 nor more than \$50,000 per day of violation, or by imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.
- (c) *Knowing Endangerment.* The CWA provides that any person who knowingly violates permit conditions implementing Sections 301, 302, 303, 306, 307, 308, 318, or 405 of the Act and who knows at that time that he or she is placing another person in imminent danger of death or serious bodily injury shall upon conviction be subject to a fine of not more than \$250,000 or by imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing



NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in Section 309(c)(3)(B)(iii) of the Act, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.

- (d) *False Statement.* The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both. The Act further provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.
- (2) *Civil Penalties.* The CWA provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to a civil penalty not to exceed the maximum amounts authorized by Section 309(d) of the Act, the 2015 amendments to the Federal Civil Penalties Inflation Adjustment Act of 1990, 28 U.S.C. § 2461 note, and 40 C.F.R. Part 19. *See* Pub. L. 114-74, Section 701 (Nov. 2, 2015); 83 Fed. Reg. 1190 (January 10, 2018).
- (3) *Administrative Penalties.* The CWA provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to an administrative penalty as follows:
  - (a) *Class I Penalty.* Not to exceed the maximum amounts authorized by Section 309(g)(2)(A) of the Act, the 2015 amendments to the Federal Civil Penalties Inflation Adjustment Act of 1990, 28 U.S.C. § 2461 note, and 40 C.F.R. Part 19. *See* Pub. L. 114-74, Section 701 (Nov. 2, 2015); 83 Fed. Reg. 1190 (January 10, 2018).
  - (b) *Class II Penalty.* Not to exceed the maximum amounts authorized by Section 309(g)(2)(B) of the Act the 2015 amendments to the Federal Civil Penalties Inflation Adjustment Act of 1990, 28 U.S.C. § 2461 note, and 40 C.F.R. Part 19. *See* Pub. L. 114-74, Section 701 (Nov. 2, 2015); 83 Fed. Reg. 1190 (January 10, 2018).

2. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit

NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

condition.

3. Duty to Provide Information

The Permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The Permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

4. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from responsibilities, liabilities or penalties to which the Permittee is or may be subject under Section 311 of the CWA, or Section 106 of the Comprehensive Environmental Response, Compensation and Liability Act of 1980 (CERCLA).

5. Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

6. Confidentiality of Information

- a. In accordance with 40 C.F.R. Part 2, any information submitted to EPA pursuant to these regulations may be claimed as confidential by the submitter. Any such claim must be asserted at the time of submission in the manner prescribed on the application form or instructions or, in the case of other submissions, by stamping the words "confidential business information" on each page containing such information. If no claim is made at the time of submission, EPA may make the information available to the public without further notice. If a claim is asserted, the information will be treated in accordance with the procedures in 40 C.F.R. Part 2 (Public Information).
- b. Claims of confidentiality for the following information will be denied:
  - (1) The name and address of any permit applicant or Permittee;
  - (2) Permit applications, permits, and effluent data.
- c. Information required by NPDES application forms provided by the Director under 40 C.F.R. § 122.21 may not be claimed confidential. This includes information submitted on the forms themselves and any attachments used to supply information required by the forms.

7. Duty to Reapply

If the Permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the Permittee must apply for and obtain a new permit. The Permittee shall submit a new application at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Director. (The Director shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)

8. State Authorities

Nothing in Parts 122, 123, or 124 precludes more stringent State regulation of any activity



NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

covered by the regulations in 40 C.F.R. Parts 122, 123, and 124, whether or not under an approved State program.

9. Other Laws

The issuance of a permit does not authorize any injury to persons or property or invasion of other private rights, or any infringement of State or local law or regulations.

B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

1. Proper Operation and Maintenance

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

2. Need to Halt or Reduce Not a Defense

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

3. Duty to Mitigate

The Permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

4. Bypass

a. Definitions

- (1) *Bypass* means the intentional diversion of waste streams from any portion of a treatment facility.
- (2) *Severe property damage* means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

- b. *Bypass not exceeding limitations.* The Permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs (c) and (d) of this Section.

c. Notice

NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

- (1) *Anticipated bypass.* If the Permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass. As of December 21, 2020 all notices submitted in compliance with this Section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases, Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to report electronically if specified by a particular permit or if required to do so by state law.
- (2) *Unanticipated bypass.* The Permittee shall submit notice of an unanticipated bypass as required in paragraph D.1.e. of this part (24-hour notice). As of December 21, 2020 all notices submitted in compliance with this Section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases, Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to report electronically if specified by a particular permit or required to do so by law.

d. *Prohibition of bypass.*

- (1) Bypass is prohibited, and the Director may take enforcement action against a Permittee for bypass, unless:
  - (a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
  - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance; and
  - (c) The Permittee submitted notices as required under paragraph 4.c of this Section.
- (2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 4.d of this Section.

5. Upset

- a. *Definition.* *Upset* means an exceptional incident in which there is an unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or



## NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

improper operation.

- b. *Effect of an upset.* An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph B.5.c. of this Section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- c. *Conditions necessary for a demonstration of upset.* A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (1) An upset occurred and that the Permittee can identify the cause(s) of the upset;
  - (2) The permitted facility was at the time being properly operated; and
  - (3) The Permittee submitted notice of the upset as required in paragraph D.1.e.2.b. (24-hour notice).
  - (4) The Permittee complied with any remedial measures required under B.3. above.
- d. *Burden of proof.* In any enforcement proceeding the Permittee seeking to establish the occurrence of an upset has the burden of proof.

### C. MONITORING REQUIREMENTS

#### 1. Monitoring and Records

- a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. Except for records of monitoring information required by this permit related to the Permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least 5 years (or longer as required by 40 C.F.R. § 503), the Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application. This period may be extended by request of the Director at any time.
- c. Records of monitoring information shall include:
  - (1) The date, exact place, and time of sampling or measurements;
  - (2) The individual(s) who performed the sampling or measurements;
  - (3) The date(s) analyses were performed;
  - (4) The individual(s) who performed the analyses;
  - (5) The analytical techniques or methods used; and
  - (6) The results of such analyses.
- d. Monitoring must be conducted according to test procedures approved under 40 C.F.R. § 136 unless another method is required under 40 C.F.R. Subchapters N or O.
- e. The Clean Water Act provides that any person who falsifies, tampers with, or

NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.

2. Inspection and Entry

The Permittee shall allow the Director, or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the Permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

D. REPORTING REQUIREMENTS

1. Reporting Requirements

- a. *Planned Changes.* The Permittee shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
  - (1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 C.F.R. § 122.29(b); or
  - (2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements at 40 C.F.R. § 122.42(a)(1).
  - (3) The alteration or addition results in a significant change in the Permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. *Anticipated noncompliance.* The Permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.



NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

- c. *Transfers.* This permit is not transferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the Permittee and incorporate such other requirements as may be necessary under the Clean Water Act. *See* 40 C.F.R. § 122.61; in some cases, modification or revocation and reissuance is mandatory.
- d. *Monitoring reports.* Monitoring results shall be reported at the intervals specified elsewhere in this permit.
  - (1) Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Director for reporting results of monitoring of sludge use or disposal practices. As of December 21, 2016 all reports and forms submitted in compliance with this Section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases, Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to report electronically if specified by a particular permit or if required to do so by State law.
  - (2) If the Permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 C.F.R. § 136, or another method required for an industry-specific waste stream under 40 C.F.R. Subchapters N or O, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Director.
  - (3) Calculations for all limitations which require averaging or measurements shall utilize an arithmetic mean unless otherwise specified by the Director in the permit.
- e. *Twenty-four hour reporting.*
  - (1) The Permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Permittee becomes aware of the circumstances. A written report shall also be provided within 5 days of the time the Permittee becomes aware of the circumstances. The written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. For noncompliance events related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports must include the data described above (with the exception of time of discovery) as well as the type of event (combined sewer overflows, sanitary sewer overflows, or bypass events), type of sewer overflow structure (e.g., manhole, combined sewer overflow outfall), discharge volumes untreated by the treatment works treating domestic sewage, types of human health and environmental impacts of the sewer overflow event, and whether the noncompliance was related to wet weather. As of December 21, 2020 all

NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

reports related to combined sewer overflows, sanitary sewer overflows, or bypass events submitted in compliance with this section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to electronically submit reports related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section by a particular permit or if required to do so by state law. The Director may also require Permittees to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section.

- (2) The following shall be included as information which must be reported within 24 hours under this paragraph.
  - (a) Any unanticipated bypass which exceeds any effluent limitation in the permit. *See* 40 C.F.R. § 122.41(g).
  - (b) Any upset which exceeds any effluent limitation in the permit.
  - (c) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in the permit to be reported within 24 hours. *See* 40 C.F.R. § 122.44(g).
- (3) The Director may waive the written report on a case-by-case basis for reports under paragraph D.1.e. of this Section if the oral report has been received within 24 hours.
- f. *Compliance Schedules.* Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
- g. *Other noncompliance.* The Permittee shall report all instances of noncompliance not reported under paragraphs D.1.d., D.1.e., and D.1.f. of this Section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph D.1.e. of this Section. For noncompliance events related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports shall contain the information described in paragraph D.1.e. and the applicable required data in Appendix A to 40 C.F.R. Part 127. As of December 21, 2020 all reports related to combined sewer overflows, sanitary sewer overflows, or bypass events submitted in compliance with this section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 C.F.R. § 127.2(b), in compliance with this Section and 40 C.F.R. Part 3 (including, in all cases, Subpart D to Part 3), § 122.22, and 40 C.F.R. Part 127. Part 127 is not intended to undo existing requirements for electronic reporting. Prior to this date, and independent of Part 127, Permittees may be required to electronically submit reports related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section by a particular permit or if required to do so by state law. The Director may also require Permittees to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this Section.
- h. *Other information.* Where the Permittee becomes aware that it failed to submit any



NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

- i. *Identification of the initial recipient for NPDES electronic reporting data.* The owner, operator, or the duly authorized representative of an NPDES-regulated entity is required to electronically submit the required NPDES information (as specified in Appendix A to 40 C.F.R. Part 127) to the appropriate initial recipient, as determined by EPA, and as defined in 40 C.F.R. § 127.2(b). EPA will identify and publish the list of initial recipients on its Web site and in the FEDERAL REGISTER, by state and by NPDES data group (see 40 C.F.R. § 127.2(c) of this Chapter). EPA will update and maintain this listing.

2. Signatory Requirement

- a. All applications, reports, or information submitted to the Director shall be signed and certified. *See* 40 C.F.R. § 122.22.
- b. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

3. Availability of Reports.

Except for data determined to be confidential under paragraph A.6. above, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the State water pollution control agency and the Director. As required by the CWA, effluent data shall not be considered confidential. Knowingly making any false statements on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the CWA.

E. DEFINITIONS AND ABBREVIATIONS

1. General Definitions

For more definitions related to sludge use and disposal requirements, see EPA Region 1's NPDES Permit Sludge Compliance Guidance document (4 November 1999, modified to add regulatory definitions, April 2018).

*Administrator* means the Administrator of the United States Environmental Protection Agency, or an authorized representative.

*Applicable standards and limitations* means all, State, interstate, and federal standards and limitations to which a "discharge," a "sewage sludge use or disposal practice," or a related activity is subject under the CWA, including "effluent limitations," water quality standards, standards of performance, toxic effluent standards or prohibitions, "best management practices," pretreatment standards, and "standards for sewage sludge use or disposal" under Sections 301, 302, 303, 304, 306, 307, 308, 403 and 405 of the CWA.

*Application* means the EPA standard national forms for applying for a permit, including any additions, revisions, or modifications to the forms; or forms approved by EPA for use in

NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

“approved States,” including any approved modifications or revisions.

*Approved program* or *approved State* means a State or interstate program which has been approved or authorized by EPA under Part 123.

*Average monthly discharge limitation* means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month.

*Average weekly discharge limitation* means the highest allowable average of “daily discharges” over a calendar week, calculated as the sum of all “daily discharges” measured during a calendar week divided by the number of “daily discharges” measured during that week.

*Best Management Practices (“BMPs”)* means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of “waters of the United States.” BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

*Bypass* see B.4.a.1 above.

*C-NOEC* or “*Chronic (Long-term Exposure Test) – No Observed Effect Concentration*” means the highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specified time of observation.

*Class I sludge management facility* is any publicly owned treatment works (POTW), as defined in 40 C.F.R. § 501.2, required to have an approved pretreatment program under 40 C.F.R. § 403.8 (a) (including any POTW located in a State that has elected to assume local program responsibilities pursuant to 40 C.F.R. § 403.10 (c)) and any treatment works treating domestic sewage, as defined in 40 C.F.R. § 122.2, classified as a Class I sludge management facility by the EPA Regional Administrator, or, in the case of approved State programs, the Regional Administrator in conjunction with the State Director, because of the potential for its sewage sludge use or disposal practice to affect public health and the environment adversely.

*Contiguous zone* means the entire zone established by the United States under Article 24 of the Convention on the Territorial Sea and the Contiguous Zone.

*Continuous discharge* means a “discharge” which occurs without interruption throughout the operating hours of the facility, except for infrequent shutdowns for maintenance, process changes, or similar activities.

*CWA* means the Clean Water Act (formerly referred to as the Federal Water Pollution Control Act or Federal Water Pollution Control Act Amendments of 1972) Public Law 92-500, as amended by Public Law 95-217, Public Law 95-576, Public Law 96-483 and Public Law 97-117, 33 U.S.C. 1251 *et seq.*

*CWA and regulations* means the Clean Water Act (CWA) and applicable regulations promulgated thereunder. In the case of an approved State program, it includes State program requirements.

*Daily Discharge* means the “discharge of a pollutant” measured during a calendar day or any



NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

other 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the “daily discharge” is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurements, the “daily discharge” is calculated as the average measurement of the pollutant over the day.

*Direct Discharge* means the “discharge of a pollutant.”

*Director* means the Regional Administrator or an authorized representative. In the case of a permit also issued under Massachusetts’ authority, it also refers to the Director of the Division of Watershed Management, Department of Environmental Protection, Commonwealth of Massachusetts.

*Discharge*

- (a) When used without qualification, *discharge* means the “discharge of a pollutant.”
- (b) As used in the definitions for “interference” and “pass through,” *discharge* means the introduction of pollutants into a POTW from any non-domestic source regulated under Section 307(b), (c) or (d) of the Act.

*Discharge Monitoring Report (“DMR”)* means the EPA uniform national form, including any subsequent additions, revisions, or modifications for the reporting of self-monitoring results by Permittees. DMRs must be used by “approved States” as well as by EPA. EPA will supply DMRs to any approved State upon request. The EPA national forms may be modified to substitute the State Agency name, address, logo, and other similar information, as appropriate, in place of EPA’s.

*Discharge of a pollutant* means:

- (a) Any addition of any “pollutant” or combination of pollutants to “waters of the United States” from any “point source,” or
- (b) Any addition of any pollutant or combination of pollutants to the waters of the “contiguous zone” or the ocean from any point source other than a vessel or other floating craft which is being used as a means of transportation.

This definition includes additions of pollutants into waters of the United States from: surface runoff which is collected or channeled by man; discharges through pipes, sewers, or other conveyances owned by a State, municipality, or other person which do not lead to a treatment works; and discharges through pipes, sewers, or other conveyances, leading into privately owned treatment works. This term does not include an addition of pollutants by any “indirect discharger.”

*Effluent limitation* means any restriction imposed by the Director on quantities, discharge rates, and concentrations of “pollutants” which are “discharged” from “point sources” into “waters of the United States,” the waters of the “contiguous zone,” or the ocean.

*Effluent limitation guidelines* means a regulation published by the Administrator under section 304(b) of CWA to adopt or revise “effluent limitations.”

*Environmental Protection Agency (“EPA”)* means the United States Environmental Protection

NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

Agency.

*Grab Sample* means an individual sample collected in a period of less than 15 minutes.

*Hazardous substance* means any substance designated under 40 C.F.R. Part 116 pursuant to Section 311 of CWA.

*Incineration* is the combustion of organic matter and inorganic matter in sewage sludge by high temperatures in an enclosed device.

*Indirect discharger* means a nondomestic discharger introducing “pollutants” to a “publicly owned treatment works.”

*Interference* means a discharge (see definition above) which, alone or in conjunction with a discharge or discharges from other sources, both:

- (a) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
- (b) Therefore is a cause of a violation of any requirement of the POTW’s NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resources Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to Subtitle D of the SDWA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

*Landfill* means an area of land or an excavation in which wastes are placed for permanent disposal, and that is not a land application unit, surface impoundment, injection well, or waste pile.

*Land application* is the spraying or spreading of sewage sludge onto the land surface; the injection of sewage sludge below the land surface; or the incorporation of sewage sludge into the soil so that the sewage sludge can either condition the soil or fertilize crops or vegetation grown in the soil.

*Land application unit* means an area where wastes are applied onto or incorporated into the soil surface (excluding manure spreading operations) for agricultural purposes or for treatment and disposal.

*LC<sub>50</sub>* means the concentration of a sample that causes mortality of 50% of the test population at a specific time of observation. The LC<sub>50</sub> = 100% is defined as a sample of undiluted effluent.

*Maximum daily discharge limitation* means the highest allowable “daily discharge.”

*Municipal solid waste landfill (MSWLF) unit* means a discrete area of land or an excavation that receives household waste, and that is not a land application unit, surface impoundment, injection well, or waste pile, as those terms are defined under 40 C.F.R. § 257.2. A MSWLF unit also may receive other types of RCRA Subtitle D wastes, such as commercial solid waste, nonhazardous sludge, very small quantity generator waste and industrial solid waste. Such a landfill may be



## NPDES PART II STANDARD CONDITIONS

(April 26, 2018)

publicly or privately owned. A MSWLF unit may be a new MSWLF unit, an existing MSWLF unit or a lateral expansion. A construction and demolition landfill that receives residential lead-based paint waste and does not receive any other household waste is not a MSWLF unit.

### *Municipality*

- (a) When used without qualification *municipality* means a city, town, borough, county, parish, district, association, or other public body created by or under State law and having jurisdiction over disposal of sewage, industrial wastes, or other wastes, or an Indian tribe or an authorized Indian tribal organization, or a designated and approved management agency under Section 208 of CWA.
- (b) As related to sludge use and disposal, *municipality* means a city, town, borough, county, parish, district, association, or other public body (including an intermunicipal Agency of two or more of the foregoing entities) created by or under State law; an Indian tribe or an authorized Indian tribal organization having jurisdiction over sewage sludge management; or a designated and approved management Agency under Section 208 of the CWA, as amended. The definition includes a special district created under State law, such as a water district, sewer district, sanitary district, utility district, drainage district, or similar entity, or an integrated waste management facility as defined in Section 201 (e) of the CWA, as amended, that has as one of its principal responsibilities the treatment, transport, use or disposal of sewage sludge.

*National Pollutant Discharge Elimination System* means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under Sections 307, 402, 318, and 405 of the CWA. The term includes an "approved program."

*New Discharger* means any building, structure, facility, or installation:

- (a) From which there is or may be a "discharge of pollutants;"
- (b) That did not commence the "discharge of pollutants" at a particular "site" prior to August 13, 1979;
- (c) Which is not a "new source;" and
- (d) Which has never received a finally effective NPDES permit for discharges at that "site."

This definition includes an "indirect discharger" which commences discharging into "waters of the United States" after August 13, 1979. It also includes any existing mobile point source (other than an offshore or coastal oil and gas exploratory drilling rig or a coastal oil and gas exploratory drilling rig or a coastal oil and gas exploratory drilling rig or a coastal oil and gas developmental drilling rig) such as a seafood processing rig, seafood processing vessel, or aggregate plant, that begins discharging at a "site" for which it does not have a permit; and any offshore or coastal mobile oil and gas exploratory drilling rig or coastal mobile oil and gas developmental drilling rig that commences the discharge of pollutants after August 13, 1979, at a "site" under EPA's permitting jurisdiction for which it is not covered by an individual or general permit and which is located in an area determined by the Director in the issuance of a final permit to be in an area of biological concern. In determining whether an area is an area of biological concern, the Director shall consider the factors specified in 40 C.F.R. §§ 125.122 (a) (1) through (10).

## NPDES PART II STANDARD CONDITIONS (April 26, 2018)

An offshore or coastal mobile exploratory drilling rig or coastal mobile developmental drilling rig will be considered a “new discharger” only for the duration of its discharge in an area of biological concern.

*New source* means any building, structure, facility, or installation from which there is or may be a “discharge of pollutants,” the construction of which commenced:

- (a) After promulgation of standards of performance under Section 306 of CWA which are applicable to such source, or
- (b) After proposal of standards of performance in accordance with Section 306 of CWA which are applicable to such source, but only if the standards are promulgated in accordance with Section 306 within 120 days of their proposal.

*NPDES* means “National Pollutant Discharge Elimination System.”

*Owner or operator* means the owner or operator of any “facility or activity” subject to regulation under the NPDES programs.

*Pass through* means a Discharge (see definition above) which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW’s NPDES permit (including an increase in the magnitude or duration of a violation).

*Pathogenic organisms* are disease-causing organisms. These include, but are not limited to, certain bacteria, protozoa, viruses, and viable helminth ova.

*Permit* means an authorization, license, or equivalent control document issued by EPA or an “approved State” to implement the requirements of Parts 122, 123, and 124. “Permit” includes an NPDES “general permit” (40 C.F.R. § 122.28). “Permit” does not include any permit which has not yet been the subject of final agency action, such as a “draft permit” or “proposed permit.”

*Person* means an individual, association, partnership, corporation, municipality, State or Federal agency, or an agent or employee thereof.

*Person who prepares sewage sludge* is either the person who generates sewage sludge during the treatment of domestic sewage in a treatment works or the person who derives a material from sewage sludge.

*pH* means the logarithm of the reciprocal of the hydrogen ion concentration measured at 25° Centigrade or measured at another temperature and then converted to an equivalent value at 25° Centigrade.

*Point Source* means any discernible, confined, and discrete conveyance, including but not limited to, any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, landfill leachate collection system, vessel or other floating craft from which pollutants are or may be discharged. This term does not include return flows from irrigated agriculture or agricultural storm water runoff (see 40 C.F.R. § 122.3).

*Pollutant* means dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, chemical wastes, biological materials, radioactive materials



NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

(except those regulated under the Atomic Energy Act of 1954, as amended (42 U.S.C. 2011 *et seq.*)), heat, wrecked or discarded equipment, rock, sand, cellar dirt and industrial, municipal, and agricultural waste discharged into water. It does not mean:

- (a) Sewage from vessels; or
- (b) Water, gas, or other material which is injected into a well to facilitate production of oil or gas, or water derived in association with oil and gas production and disposed of in a well, if the well is used either to facilitate production or for disposal purposes is approved by the authority of the State in which the well is located, and if the State determines that the injection or disposal will not result in the degradation of ground or surface water resources.

*Primary industry category* means any industry category listed in the NRDC settlement agreement (*Natural Resources Defense Council et al. v. Train*, 8 E.R.C. 2120 (D.D.C. 1976), *modified* 12 E.R.C. 1833 (D.D.C. 1979)); also listed in Appendix A of 40 C.F.R. Part 122.

*Privately owned treatment works* means any device or system which is (a) used to treat wastes from any facility whose operator is not the operator of the treatment works and (b) not a "POTW."

*Process wastewater* means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.

*Publicly owned treatment works (POTW)* means a treatment works as defined by Section 212 of the Act, which is owned by a State or municipality (as defined by Section 504(4) of the Act). This definition includes any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage or industrial wastes of a liquid nature. It also includes sewers, pipes and other conveyances only if they convey wastewater to a POTW Treatment Plant. The term also means the municipality as defined in Section 502(4) of the Act, which has jurisdiction over the indirect discharges to and the discharges from such a treatment works.

*Regional Administrator* means the Regional Administrator, EPA, Region I, Boston, Massachusetts.

*Secondary industry category* means any industry which is not a "primary industry category."

*Septage* means the liquid and solid material pumped from a septic tank, cesspool, or similar domestic sewage treatment system, or a holding tank when the system is cleaned or maintained.

*Sewage Sludge* means any solid, semi-solid, or liquid residue removed during the treatment of municipal waste water or domestic sewage. Sewage sludge includes, but is not limited to, solids removed during primary, secondary, or advanced waste water treatment, scum, septage, portable toilet pumpings, type III marine sanitation device pumpings (33 C.F.R. Part 159), and sewage sludge products. Sewage sludge does not include grit or screenings, or ash generated during the incineration of sewage sludge.

*Sewage sludge incinerator* is an enclosed device in which only sewage sludge and auxiliary fuel are fired.

*Sewage sludge unit* is land on which only sewage sludge is placed for final disposal. This does

NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

not include land on which sewage sludge is either stored or treated. Land does not include waters of the United States, as defined in 40 C.F.R. § 122.2.

*Sewage sludge use or disposal practice* means the collection, storage, treatment, transportation, processing, monitoring, use, or disposal of sewage sludge.

*Significant materials* includes, but is not limited to: raw materials; fuels; materials such as solvents, detergents, and plastic pellets; finished materials such as metallic products; raw materials used in food processing or production; hazardous substance designated under Section 101(14) of CERCLA; any chemical the facility is required to report pursuant to Section 313 of title III of SARA; fertilizers; pesticides; and waste products such as ashes, slag and sludge that have the potential to be released with storm water discharges.

*Significant spills* includes, but is not limited to, releases of oil or hazardous substances in excess of reportable quantities under Section 311 of the CWA (see 40 C.F.R. §§ 110.10 and 117.21) or Section 102 of CERCLA (see 40 C.F.R. § 302.4).

*Sludge-only facility* means any “treatment works treating domestic sewage” whose methods of sewage sludge use or disposal are subject to regulations promulgated pursuant to section 405(d) of the CWA, and is required to obtain a permit under 40 C.F.R. § 122.1(b)(2).

*State* means any of the 50 States, the District of Columbia, Guam, the Commonwealth of Puerto Rico, the Virgin Islands, American Samoa, the Commonwealth of the Northern Mariana Islands, the Trust Territory of the Pacific Islands, or an Indian Tribe as defined in the regulations which meets the requirements of 40 C.F.R. § 123.31.

*Store or storage of sewage sludge* is the placement of sewage sludge on land on which the sewage sludge remains for two years or less. This does not include the placement of sewage sludge on land for treatment.

*Storm water* means storm water runoff, snow melt runoff, and surface runoff and drainage.

*Storm water discharge associated with industrial activity* means the discharge from any conveyance that is used for collecting and conveying storm water and that is directly related to manufacturing, processing, or raw materials storage areas at an industrial plant.

*Surface disposal site* is an area of land that contains one or more active sewage sludge units.

*Toxic pollutant* means any pollutant listed as toxic under Section 307(a)(1) or, in the case of “sludge use or disposal practices,” any pollutant identified in regulations implementing Section 405(d) of the CWA.

*Treatment works treating domestic sewage* means a POTW or any other sewage sludge or waste water treatment devices or systems, regardless of ownership (including federal facilities), used in the storage, treatment, recycling, and reclamation of municipal or domestic sewage, including land dedicated for the disposal of sewage sludge. This definition does not include septic tanks or similar devices.

For purposes of this definition, “domestic sewage” includes waste and waste water from humans or household operations that are discharged to or otherwise enter a treatment works. In States where there is no approved State sludge management program under Section 405(f) of the CWA, the Director may designate any person subject to the standards for sewage sludge use and



NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

disposal in 40 C.F.R. Part 503 as a “treatment works treating domestic sewage,” where he or she finds that there is a potential for adverse effects on public health and the environment from poor sludge quality or poor sludge handling, use or disposal practices, or where he or she finds that such designation is necessary to ensure that such person is in compliance with 40 C.F.R. Part 503.

*Upset* see B.5.a. above.

*Vector attraction* is the characteristic of sewage sludge that attracts rodents, flies, mosquitoes, or other organisms capable of transporting infectious agents.

*Waste pile* or *pile* means any non-containerized accumulation of solid, non-flowing waste that is used for treatment or storage.

*Waters of the United States* or *waters of the U.S.* means:

- (a) All waters which are currently used, were used in the past, or may be susceptible to use in interstate or foreign commerce, including all waters which are subject to the ebb and flow of the tide;
- (b) All interstate waters, including interstate “wetlands;”
- (c) All other waters such as intrastate lakes, rivers, streams (including intermittent streams), mudflats, sandflats, “wetlands”, sloughs, prairie potholes, wet meadows, playa lakes, or natural ponds the use, degradation, or destruction of which would affect or could affect interstate or foreign commerce including any such waters:
  - (1) Which are or could be used by interstate or foreign travelers for recreational or other purpose;
  - (2) From which fish or shellfish are or could be taken and sold in interstate or foreign commerce; or
  - (3) Which are used or could be used for industrial purposes by industries in interstate commerce;
- (d) All impoundments of waters otherwise defined as waters of the United States under this definition;
- (e) Tributaries of waters identified in paragraphs (a) through (d) of this definition;
- (f) The territorial sea; and
- (g) “Wetlands” adjacent to waters (other than waters that are themselves wetlands) identified in paragraphs (a) through (f) of this definition.

Waste treatment systems, including treatment ponds or lagoons designed to meet the requirements of CWA (other than cooling ponds as defined in 40 C.F.R. § 423.11(m) which also meet the criteria of this definition) are not waters of the United States. This exclusion applies only to manmade bodies of water which neither were originally created in waters of the United States (such as disposal area in wetlands) nor resulted from the impoundment of waters of the United States. Waters of the United States do not include prior converted cropland.

NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

Notwithstanding the determination of an area's status as prior converted cropland by any other federal agency, for the purposes of the Clean Water Act, the final authority regarding Clean Water Act jurisdiction remains with EPA.

*Wetlands* means those areas that are inundated or saturated by surface or groundwater at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

*Whole Effluent Toxicity (WET)* means the aggregate toxic effect of an effluent measured directly by a toxicity test.

*Zone of Initial Dilution (ZID)* means the region of initial mixing surrounding or adjacent to the end of the outfall pipe or diffuser ports, provided that the ZID may not be larger than allowed by mixing zone restrictions in applicable water quality standards.

2. Commonly Used Abbreviations

BOD	Five-day biochemical oxygen demand unless otherwise specified
CBOD	Carbonaceous BOD
CFS	Cubic feet per second
COD	Chemical oxygen demand
Chlorine	
Cl <sub>2</sub>	Total residual chlorine
TRC	Total residual chlorine which is a combination of free available chlorine (FAC, see below) and combined chlorine (chloramines, etc.)
TRO	Total residual chlorine in marine waters where halogen compounds are present
FAC	Free available chlorine (aqueous molecular chlorine, hypochlorous acid, and hypochlorite ion)
Coliform	
Coliform, Fecal	Total fecal coliform bacteria
Coliform, Total	Total coliform bacteria
Cont.	Continuous recording of the parameter being monitored, i.e. flow, temperature, pH, etc.
Cu. M/day or M <sup>3</sup> /day	Cubic meters per day
DO	Dissolved oxygen



NPDES PART II STANDARD CONDITIONS  
(April 26, 2018)

kg/day	Kilograms per day
lbs/day	Pounds per day
mg/L	Milligram(s) per liter
mL/L	Milliliters per liter
MGD	Million gallons per day
Nitrogen	
Total N	Total nitrogen
NH <sub>3</sub> -N	Ammonia nitrogen as nitrogen
NO <sub>3</sub> -N	Nitrate as nitrogen
NO <sub>2</sub> -N	Nitrite as nitrogen
NO <sub>3</sub> -NO <sub>2</sub>	Combined nitrate and nitrite nitrogen as nitrogen
TKN	Total Kjeldahl nitrogen as nitrogen
Oil & Grease	Freon extractable material
PCB	Polychlorinated biphenyl
Surfactant	Surface-active agent
Temp. °C	Temperature in degrees Centigrade
Temp. °F	Temperature in degrees Fahrenheit
TOC	Total organic carbon
Total P	Total phosphorus
TSS or NFR	Total suspended solids or total nonfilterable residue
Turb. or Turbidity	Turbidity measured by the Nephelometric Method (NTU)
µg/L	Microgram(s) per liter
WET	“Whole effluent toxicity”
ZID	Zone of Initial Dilution

**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
NEW ENGLAND - REGION 1  
5 POST OFFICE SQUARE, SUITE 100  
BOSTON, MASSACHUSETTS 02109-3912**

**FACT SHEET**

**DRAFT NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
PERMIT TO DISCHARGE TO WATERS OF THE UNITED STATES PURSUANT TO  
THE CLEAN WATER ACT (CWA)**

**NPDES PERMIT NUMBER:** MA0101630

**PUBLIC NOTICE START AND END DATES:** April 6, 2023 - May 5, 2023

**NAME AND MAILING ADDRESS OF APPLICANT:**

City of Holyoke  
Department of Public Works  
63 Canal Street  
Holyoke, MA 01040

**NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:**

Holyoke Water Pollution Control Facility  
1 Berkshire Street  
Holyoke, Massachusetts 01040

And

Combined Sewer Overflow (CSO) discharges at 10 locations

**RECEIVING WATER AND CLASSIFICATION:**

Connecticut River (Segment MA 34-05)  
Class B – Warm Water Fishery and CSO



### Table of Contents

1.0	Proposed Action.....	5
2.0	Statutory and Regulatory Authority.....	5
2.1	Technology-Based Requirements .....	5
2.2	Water Quality-Based Requirements .....	6
2.2.1	Water Quality Standards .....	6
2.2.2	Antidegradation.....	7
2.2.3	Assessment and Listing of Waters and Total Maximum Daily Loads.....	7
2.2.4	Reasonable Potential .....	8
2.2.5	State Certification .....	8
2.3	Effluent Flow Requirements .....	9
2.4	Monitoring and Reporting Requirements .....	10
2.4.1	Monitoring Requirements .....	10
2.4.2	Reporting Requirements .....	11
2.5	Standard Conditions.....	12
2.6	Anti-backsliding.....	12
3.0	Description of Facility and Discharge .....	12
3.1	Location and Type of Facility.....	12
3.1.1	Treatment Process Description .....	13
3.1.2	Collection System Description .....	14
4.0	Description of Receiving Water and Dilution .....	14
4.1	Receiving Water.....	14
4.2	Ambient Data .....	15
4.3	Available Dilution.....	15
5.0	Proposed Effluent Limitations and Conditions.....	16
5.1	Effluent Limitations and Monitoring Requirements.....	16
5.1.1	Effluent Flow .....	16
5.1.2	Biochemical Oxygen Demand (BOD <sub>5</sub> ).....	16
5.1.3	Total Suspended Solids (TSS) .....	17
5.1.4	Eighty-Five Percent (85%) BOD <sub>5</sub> and TSS Removal Requirement.....	18
5.1.5	pH.....	19
5.1.6	Bacteria .....	19
5.1.7	Total Residual Chlorine .....	19
5.1.8	Ammonia.....	20
5.1.9	Nutrients.....	21
5.1.10	Metals.....	36
5.1.11	Whole Effluent Toxicity .....	39
5.1.12	Per- and polyfluoroalkyl substances (PFAS).....	41
5.2	Industrial Pretreatment Program .....	43
5.3	Sludge Conditions.....	44
5.4	Infiltration/Inflow (I/I) .....	44
5.5	Operation and Maintenance .....	44
5.5.1	Operation and Maintenance of the Wastewater Treatment Facility .....	45
5.5.2	Operation and Maintenance of the Sewer System .....	45
5.6	Combined Sewer Overflows.....	46
5.7	Standard Conditions.....	49

6.0	Federal Permitting Requirements .....	49
6.1	Endangered Species Act .....	49
6.2	Essential Fish Habitat .....	51
7.0	Public Comments, Hearing Requests and Permit Appeals .....	53
8.0	Administrative Record .....	53
Figure 1: Location of the Holyoke WPCF .....		54
.....		55
Figure 2: Location of the Holyoke CSOs .....		55
Figure 3: Flow Diagram.....		56



**Tables**

Table 1 – Summary of Designated Uses and Listing Status.....	15
Table 2 - Summary of Massachusetts Out-of-Basin Non-Stormwater Point Source Loads.....	26
Table 3 - Annual Average Total Nitrogen Limits for Massachusetts WWTP Dischargers to the Long Island Sound Watershed.....	31
Table 4: Instream total phosphorus concentrations (mg/L).....	36

**Figures**

Figure 1: Location of the Holyoke WPCF .....	54
Figure 2: Location of the Holyoke CSOs .....	55
Figure 3: Flow Diagram.....	56

**Appendices**

Appendix A – Monitoring Data Summary
Appendix B – Reasonable Potential and Limits Calculations
Appendix C – NH, VT, MA Discharges to Connecticut River Watershed

## 1.0 Proposed Action

The above-named applicant (the Permittee) has applied to the U.S. Environmental Protection Agency (EPA) for reissuance of a National Pollutant Discharge Elimination System (NPDES) permit to discharge from the Holyoke Water Pollution Control Facility (the Facility) into the Connecticut River.

The permit currently in effect was issued on October 25, 2016 with an effective date of January 1, 2017 and expired on December 31, 2021 (the 2016 Permit). The Permittee filed an application for permit reissuance with EPA dated June 30, 2021, as required by 40 Code of Federal Regulations (CFR) § 122.6. Since the permit application was deemed timely and complete by EPA on July 27, 2021, the Facility's 2016 Permit has been administratively continued pursuant to 40 CFR § 122.6 and § 122.21(d).

## 2.0 Statutory and Regulatory Authority

Congress enacted the Federal Water Pollution Control Act, codified at 33 U.S.C. § 1251-1387 and commonly known as the Clean Water Act (CWA), “to restore and maintain the chemical, physical, and biological integrity of the Nation’s waters.” CWA § 101(a). To achieve this objective, the CWA makes it unlawful for any person to discharge any pollutant into the waters of the United States from any point source, except as authorized by specific permitting sections of the CWA, one of which is § 402. *See* CWA §§ 301(a), 402(a). Section 402(a) established one of the CWA’s principal permitting programs, the NPDES Permit Program. Under this section, EPA may “issue a permit for the discharge of any pollutant or combination of pollutants” in accordance with certain conditions. CWA § 402(a). NPDES permits generally contain discharge limitations and establish related monitoring and reporting requirements. *See* CWA § 402(a)(1) and (2). The regulations governing EPA’s NPDES permit program are generally found in 40 CFR §§ 122, 124, 125, and 136.

“Congress has vested in the Administrator [of EPA] broad discretion to establish conditions for NPDES permits” in order to achieve the statutory mandates of Section 301 and 402. *Arkansas v. Oklahoma*, 503 U.S. 91, 105 (1992). *See also* 40 CFR §§ 122.4(d), 122.44(d)(1), and 122.44(d)(5). CWA §§ 301 and 306 provide for two types of effluent limitations to be included in NPDES permits: “technology-based” effluent limitations (TBELs) and “water quality-based” effluent limitations (WQBELs). *See* CWA §§ 301, and 304(d); 40 CFR Parts 122, 125, 131.

### 2.1 Technology-Based Requirements

Technology-based limitations, generally developed on an industry-by-industry basis, reflect a specified level of pollutant reducing technology available and economically achievable for the type of facility being permitted. *See* CWA § 301(b). As a class, publicly owned treatment works (POTWs) must meet performance-based requirements based on available wastewater treatment technology. *See* CWA § 301(b)(1)(B). The performance level for POTWs is referred to as “secondary treatment.” Secondary treatment is comprised of technology-based requirements expressed in terms of biochemical oxygen demand (BOD<sub>5</sub>), total suspended solids (TSS) and pH. *See* 40 CFR Part 133.



Under CWA § 301(b)(1), POTWs must have achieved effluent limits based upon secondary treatment technology by July 1, 1977. Since all statutory deadlines for meeting various treatment technology-based effluent limitations established pursuant to the CWA have expired, when technology-based effluent limits are included in a permit, compliance with those limitations is from the date the issued permit becomes effective. *See* 40 CFR § 125.3(a)(1).

## **2.2 Water Quality-Based Requirements**

The CWA and federal regulations also require that permit effluent limits based on water quality considerations be established for point source discharges when such limitations are necessary to meet state or federal water quality standards that are applicable to the designated receiving water. This is necessary when less stringent TBELs would interfere with the attainment or maintenance of water quality criteria in the receiving water. *See* CWA § 301(b)(1)(C) and 40 CFR §§ 122.44(d)(1), 122.44(d)(5).

### **2.2.1 Water Quality Standards**

The CWA requires that each state develop water quality standards (WQSs) for all water bodies within the State. *See* CWA § 303 and 40 CFR § 131.10-12. Generally, WQSs consist of three parts: 1) the designated use or uses assigned for a water body or a segment of a water body; 2) numeric or narrative water quality criteria sufficient to protect the assigned designated use(s); and 3) antidegradation requirements to ensure that once a use is attained it will not be degraded and to protect high quality and National resource waters. *See* CWA § 303(c)(2)(A) and 40 CFR § 131.12. The applicable State WQSs can be found in 314 of the Code of Massachusetts Regulations, Chapter 4 (314 CMR 4.00).

As a matter of state law, state WQSs specify different water body classifications, each of which is associated with certain designated uses and numeric and narrative water quality criteria. When using chemical-specific numeric criteria to develop permit limitations, acute and chronic aquatic life criteria and human health criteria are used and expressed in terms of maximum allowable in-stream pollutant concentrations. In general, aquatic-life acute criteria are considered applicable to daily time periods (maximum daily limit) and aquatic-life chronic criteria are considered applicable to monthly time periods (average monthly limit). Chemical-specific human health criteria are typically based on lifetime chronic exposure and, therefore, are typically applicable to average monthly limits.

When permit effluent limitation(s) are necessary to ensure that the receiving water meets narrative water quality criteria, the permitting authority must establish effluent limits in one of the following three ways: 1) based on a “calculated numeric criterion for the pollutant which the permitting authority demonstrates will attain and maintain applicable narrative water quality criteria and fully protect the designated use,” 2) based on a “case-by-case basis” using CWA § 304(a) recommended water quality criteria, supplemented as necessary by other relevant information; or, 3) in certain circumstances, based on use of an indicator parameter. *See* 40 CFR § 122.44(d)(1)(vi)(A-C).



### **2.2.2 Antidegradation**

Federal regulations found at 40 CFR § 131.12 require states to develop and adopt a statewide antidegradation policy that maintains and protects existing in-stream water uses and the level of water quality necessary to protect these existing uses. In addition, the antidegradation policy ensures maintenance of high quality waters which exceed levels necessary to support propagation of fish, shellfish, and wildlife and to support recreation in and on the water, unless the State finds that allowing degradation is necessary to accommodate important economic or social development in the area in which the waters are located.

Massachusetts' statewide antidegradation policy, entitled "Antidegradation Provisions" is found in the State's WQSs at 314 CMR 4.04. Massachusetts guidance for the implementation of this policy is in an associated document entitled "Implementation Procedure for the Anti-Degradation Provisions of the State Water Quality Standards," dated October 21, 2009. According to the policy, no lowering of water quality is allowed, except in accordance with the antidegradation policy, and all existing in-stream uses, and the level of water quality necessary to protect the existing uses of a receiving water body must be maintained and protected.

This permit is being reissued with effluent limitations sufficiently stringent to satisfy the State's antidegradation requirements, including the protection of the existing uses of the receiving water.

### **2.2.3 Assessment and Listing of Waters and Total Maximum Daily Loads.**

The objective of the CWA is to restore and maintain the chemical, physical and biological integrity of the Nation's waters. To meet this goal, the CWA requires states to develop information on the quality of their water resources and report this information to EPA, the U.S. Congress, and the public. To this end, EPA released guidance on November 19, 2001, for the preparation of an integrated "List of Waters" that could combine reporting elements of both § 305(b) and § 303(d) of the CWA. The integrated list format allows states to provide the status of all their assessed waters in one list. States choosing this option must list each water body or segment in one of the following five categories: 1) unimpaired and not threatened for all designated uses; 2) unimpaired waters for some uses and not assessed for others; 3) insufficient information to make assessments for any uses; 4) impaired or threatened for one or more uses but not requiring the calculation of a Total Maximum Daily Load (TMDL); and 5) impaired or threatened for one or more uses and requiring a TMDL.

A TMDL is a planning tool and potential starting point for restoration activities with the ultimate goal of attaining water quality standards. A TMDL essentially provides a pollution budget designed to restore the health of an impaired water body. A TMDL typically identifies the source(s) of the pollutant from point sources and non-point sources, determines the maximum load of the pollutant that the water body can tolerate while still attaining WQSs for the designated uses, and allocates that load among to the various sources, including point source discharges, subject to NPDES permits. *See* 40 CFR § 130.7.

For impaired waters where a TMDL has been developed for a particular pollutant and the TMDL includes a waste load allocation (WLA) for a NPDES permitted discharge, the effluent limitation



in the permit must be “consistent with the assumptions and requirements of any available WLA”. 40 CFR § 122.44(d)(1)(vii)(B).

#### **2.2.4 Reasonable Potential**

Pursuant to CWA § 301(b)(1)(C) and 40 CFR § 122.44(d)(1), NPDES permits must contain any requirements in addition to TBELs that are necessary to achieve water quality standards established under § 303 of the CWA. *See also* 33 U.S.C. § 1311(b)(1)(C). In addition, limitations “must control any pollutant or pollutant parameter (conventional, non-conventional, or toxic) which the permitting authority determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any water quality standard, including State narrative criteria for water quality.” 40 CFR § 122.44(d)(1)(i). To determine if the discharge causes, or has the reasonable potential to cause, or contribute to an excursion above any WQS, EPA considers: 1) existing controls on point and non-point sources of pollution; 2) the variability of the pollutant or pollutant parameter in the effluent; 3) the sensitivity of the species to toxicity testing (when evaluating whole effluent toxicity); and 4) where appropriate, the dilution of the effluent by the receiving water. *See* 40 CFR § 122.44(d)(1)(ii).

If the permitting authority determines that the discharge of a pollutant will cause, has the reasonable potential to cause, or contribute to an excursion above WQSs, the permit must contain QBELs for that pollutant. *See* 40 CFR § 122.44(d)(1)(i).

#### **2.2.5 State Certification**

EPA may not issue a permit unless the State Water Pollution Control Agency with jurisdiction over the receiving water(s) either certifies that the effluent limitations contained in the permit are stringent enough to assure that the discharge will not cause the receiving water to violate the State WQSs, the State waives, or is deemed to have waived, its right to certify. *See* 33 U.S.C. § 1341(a)(1). Regulations governing state certification are set forth in 40 CFR § 124.53 and § 124.55. EPA has requested permit certification by the State pursuant to 40 CFR § 124.53 and expects that the Draft Permit will be certified.

If the State believes that conditions more stringent than those contained in the Draft Permit are necessary to meet the requirements of either CWA §§ 208(e), 301, 302, 303, 306 and 307, or applicable requirements of State law, the State should include such conditions in its certification and, in each case, cite the CWA or State law provisions upon which that condition is based. Failure to provide such a citation waives the right to certify as to that condition. EPA includes properly supported State certification conditions in the NPDES permit. The only exception to this is that the permit conditions/requirements regulating sewage sludge management and implementing CWA § 405(d) are not subject to the State certification requirements. Reviews and appeals of limitations and conditions attributable to State certification shall be made through the applicable procedures of the State and may not be made through EPA’s permit appeal procedures of 40 CFR Part 124.



In addition, the State should provide a statement of the extent to which any condition of the Draft Permit can be made less stringent without violating the requirements of State law. Since the State's certification is provided prior to final permit issuance, any failure by the State to provide this statement waives the State's right to certify or object to any less stringent condition.

It should be noted that under CWA § 401, EPA's duty to defer to considerations of State law is intended to prevent EPA from relaxing any requirements, limitations or conditions imposed by State law. Therefore, "[a] State may not condition or deny a certification on the grounds that State law allows a less stringent permit condition." 40 CFR § 124.55(c). In such an instance, the regulation provides that, "The Regional Administrator shall disregard any such certification conditions or denials as waivers of certification." *Id.* EPA regulations pertaining to permit limitations based upon WQSs and State requirements are contained in 40 CFR §§ 122.4(d) and 122.44(d).

### 2.3 Effluent Flow Requirements

Sewage treatment plant discharge is encompassed within the definition of "pollutant" and is subject to regulation under the CWA. The CWA defines "pollutant" to mean, *inter alia*, "municipal...waste" and "sewage...discharged into water." 33 U.S.C. § 1362(6).

Generally, EPA uses effluent flow both to determine whether an NPDES permit needs certain effluent limitations and to calculate the limitations themselves. EPA practice is to use effluent flow as a reasonable and important worst-case condition in EPA's reasonable potential and WQBEL calculations to ensure compliance with WQSs under § 301(b)(1)(C). Should the effluent flow exceed the flow assumed in these calculations, the in-stream dilution would be reduced, and the calculated effluent limitations may not be sufficiently protective (i.e. might not meet WQSs). Further, pollutants that do not have the reasonable potential to exceed WQSs at the lower discharge flow may have reasonable potential at a higher flow due to the decreased dilution. In order to ensure that the assumptions underlying EPA's reasonable potential analyses and permit effluent limitation derivations remain sound for the duration of the permit, EPA may ensure the validity of its "worst-case" wastewater effluent flow assumptions through imposition of permit conditions for effluent flow.<sup>1</sup> In this regard, the effluent flow limitation is a component of WQBELs because the WQBELs are premised on a maximum level flow. The effluent flow limit is also necessary to ensure that other pollutants remain at levels that do not have a reasonable potential to exceed WQSs.

The limitation on wastewater effluent flow is within EPA's authority to condition a permit to carry out the objectives of the Act. *See* CWA §§ 402(a)(2) and 301(b)(1)(C); 40 CFR §§ 122.4(a) and (d), 122.43 and 122.44(d). A condition on the discharge designed to ensure the WQBEL and reasonable potential calculations account for "worst case" conditions is encompassed by the references to "condition" and "limitations" in CWA §§ 402 and 301 and

---

<sup>1</sup> EPA's regulations regarding "reasonable potential" require EPA to consider "where appropriate, the dilution of the effluent in the receiving water," *id.* 40 CFR § 122.44(d)(1)(ii). Both the effluent flow and receiving water flow may be considered when assessing reasonable potential. *In re Upper Blackstone Water Pollution Abatement Dist.*, 14 E.A.D. 577, 599 (EAB 2010). EPA guidance directs that this "reasonable potential" analysis be based on "worst-case" conditions. *See In re Washington Aquaduct Water Supply Sys.* 11 E.A.D. 565, 584 (EAB 2004)



implementing regulations, as they are designed to assure compliance with applicable water quality regulations, including antidegradation. Regulating the quantity of pollutants in the discharge through a restriction on the quantity of wastewater effluent is consistent with the overall structure and purposes of the CWA.

In addition, as provided in Part II.B.1 of this permit and 40 CFR § 122.41(e), the Permittee is required to properly operate and maintain all facilities and systems of treatment and control. Operating the facilities wastewater treatment systems as designed includes operating within the facility's design wastewater effluent flow.

EPA has also included the effluent flow limit in the permit to minimize or prevent infiltration and inflow (I/I) that may result in unauthorized discharges and compromise proper operation and maintenance of the facility. Improper operation and maintenance may result in non-compliance with permit effluent limitations. Infiltration is groundwater that enters the collection system through physical defects such as cracked pipes or deteriorated joints. Inflow is extraneous flow added to the collection system that enters the collection system through point sources such as roof leaders, yard and area drains, sump pumps, manhole covers, tide gates, and cross connections from storm water systems. Significant I/I in a collection system may displace sanitary flow, reducing the capacity available for treatment and the operating efficiency of the treatment works and to properly operate and maintain the treatment works.

Furthermore, the extraneous flow due to significant I/I greatly increases the potential for sanitary sewer overflows (SSOs) in separate systems. Consequently, the effluent flow limit is a permit condition that relates to the permittee's duty to mitigate (*i.e.*, minimize or prevent any discharge in violation of the permit that has a reasonable likelihood of adversely affecting human health or the environment) and to properly operate and maintain the treatment works. *See* 40 CFR §§ 122.41(d), (e).

## **2.4 Monitoring and Reporting Requirements**

### **2.4.1 Monitoring Requirements**

Sections 308(a) and 402(a)(2) of the CWA and the implementing regulations at 40 CFR Parts 122, 124, 125, and 136 authorize EPA to include monitoring and reporting requirements in NPDES permits.

The monitoring requirements included in this permit have been established to yield data representative of the Facility's discharges in accordance with CWA §§ 308(a) and 402(a)(2), and consistent with 40 CFR §§ 122.41(j), 122.43(a), 122.44(i) and 122.48. The Draft Permit specifies routine sampling and analysis requirements to provide ongoing, representative information on the levels of regulated constituents in the discharges. The monitoring program is needed to enable EPA and the State to assess the characteristics of the Facility's effluent, whether Facility discharges are complying with permit limits, and whether different permit conditions may be necessary in the future to ensure compliance with technology-based and water quality-based standards under the CWA. EPA and/or the State may use the results of the chemical analyses conducted pursuant to this permit, as well as national water quality criteria developed pursuant to

CWA § 304(a)(1), State water quality criteria, and any other appropriate information or data, to develop numerical effluent limitations for any pollutants, including, but not limited to, those pollutants listed in Appendix D of 40 CFR Part 122.

NPDES permits require that the approved analytical procedures found in 40 CFR Part 136 be used for sampling and analysis unless other procedures are explicitly specified. Permits also include requirements necessary to comply with the *National Pollutant Discharge Elimination System (NPDES): Use of Sufficiently Sensitive Test Methods for Permit Applications and Reporting Rule*.<sup>2</sup> This Rule requires that where EPA-approved methods exist, NPDES applicants must use sufficiently sensitive EPA-approved analytical methods when quantifying the presence of pollutants in a discharge. Further, the permitting authority must prescribe that only sufficiently sensitive EPA-approved methods be used for analyses of pollutants or pollutant parameters under the permit. The NPDES regulations at 40 CFR § 122.21(e)(3) (completeness), 40 CFR § 122.44(i)(1)(iv) (monitoring requirements) and/or as cross referenced at 40 CFR § 136.1(c) (applicability) indicate that an EPA-approved method is sufficiently sensitive where:

- The method minimum level<sup>3</sup> (ML) is at or below the level of the effluent limitation established in the permit for the measured pollutant or pollutant parameter; or
- In the case of permit applications, the ML is above the applicable water quality criterion, but the amount of the pollutant or pollutant parameter in a facility's discharge is high enough that the method detects and quantifies the level of the pollutant or parameter in the discharge; or
- The method has the lowest ML of the analytical methods approved under 40 CFR Part 136 or required under 40 CFR chapter I, subchapter N or O for the measured pollutant or pollutant parameter.

#### 2.4.2 Reporting Requirements

The Draft Permit requires the Permittee to report monitoring results obtained during each calendar month to EPA and the State electronically using NetDMR. The Permittee must submit a Discharge Monitoring Report (DMR) for each calendar month no later than the 15<sup>th</sup> day of the month following the completed reporting period.

NetDMR is a national web-based tool enabling regulated CWA permittees to submit DMRs electronically via a secure internet application to EPA through the Environmental Information Exchange Network. NetDMR has eliminated the need for participants to mail in paper forms to EPA under 40 CFR §§ 122.41 and 403.12. NetDMR is accessible through EPA's Central Data

---

<sup>2</sup> Fed. Reg. 49,001 (Aug 19, 2014).

<sup>3</sup> The term "minimum level" refers to either the sample concentration equivalent to the lowest calibration point in a method or a multiple of the method detection limit (MDL). Minimum levels may be obtained in several ways: They may be published in a method; they may be sample concentrations equivalent to the lowest acceptable calibration point used by a laboratory; or they may be calculated by multiplying the MDL in a method, or the MDL determined by a lab, by a factor. EPA is considering the following terms related to analytical method sensitivity to be synonymous: "quantitation limit," "reporting limit," "level of quantitation," and "minimum level." See Fed. Reg. 49,001 (Aug. 19, 2014).



Exchange at <https://cdx.epa.gov/>. Further information about NetDMR can be found on EPA's NetDMR support portal webpage.<sup>4</sup>

With the use of NetDMR, the Permittee is no longer required to submit hard copies of DMRs and reports to EPA and the State unless otherwise specified in the Draft Permit. In most cases, reports required under the permit shall be submitted to EPA as an electronic attachment through NetDMR. Certain exceptions are provided in the permit, such as for providing written notifications required under the Part II Standard Conditions.

## 2.5 Standard Conditions

The standard conditions, included as Part II of the Draft Permit, are based on applicable regulations found in the Code of Federal Regulations. *See generally* 40 CFR Part 122.

## 2.6 Anti-backsliding

The CWA's anti-backsliding requirements prohibit a permit from being renewed, reissued or modified to include with less stringent limitations or conditions than those contained in a previous permit except in compliance with one of the specified exceptions to those requirements. *See* CWA §§ 402(o) and 303(d)(4) and 40 CFR § 122.44(l). Anti-backsliding provisions apply to effluent limits based on technology, water quality and/or state certification requirements.

All proposed limitations in the Draft Permit are at least as stringent as limitations included in the 2016 Permit unless specific conditions exist to justify relaxation in accordance with CWA § 402(o) or § 303(d)(4). Discussion of any less stringent limitations and corresponding exceptions to anti-backsliding provisions is provided in the sections that follow.

## 3.0 Description of Facility and Discharge

### 3.1 Location and Type of Facility

The location of the treatment plant, outfall 001, and the CSOs to the Connecticut River are shown in Figures 1 and 2. The longitude and latitude of the outfalls are as follows:

Outfall 001: 42° 11' 25.3" N, 72° 36' 38.5" W  
CSO Outfall 002: 42° 10' 18.1305" N, 72° 37' 47.8194" W  
CSO Outfall 007: 42° 11' 11.4228" N, 72° 37' 22.3278" W  
CSO Outfall 008: 42° 11' 17.4372" N, 72° 37' 6.3366" W  
CSO Outfall 009: 42° 11' 24.8244" N, 72° 36' 42.6636" W  
CSO Outfall 016: 42° 12' 14.0868" N, 72° 36' 27.7122" W  
CSO Outfall 018: 42° 12' 42.3" N, 72° 36' 21.8442" W  
CSO Outfall 019: 42° 13' 9.2496" N, 72° 36' 46.872" W  
CSO Outfall 020: 42° 13' 31.9578" N, 72° 37' 2.0136" W  
CSO Outfall 021: 42° 13' 41.7966" N, 72° 37' 21.4782" W

<sup>4</sup> <https://netdmr.zendesk.com/hc/en-us/articles/209616266-EPA-Region-1-NetDMR-Information>

CSO Outfall 023: 42° 13' 20.6226" N, 72° 37' 28.4304" W

The Holyoke Water Pollution Control Facility (WPCF) is a secondary biological treatment facility that is engaged in the collection and treatment of municipal wastewater. Currently, the Facility serves approximately 40,000 residents in the City of Holyoke.

The Facility has a design flow of 17.5 MGD, the median monthly average flow during the most recent 5-year review period was 7.2 MGD. The system is about 39% separate and 61% combined sewers. Wastewater is comprised of mostly domestic sewage, industrial wastewater, and some commercial sewage.

There are seven significant industrial users that discharge to the POTW:

- (1) Bay State Plating, consisting of 7,000 gallons per day of process wastewater,
- (2) D & S Plating, consisting of 3,000 gallons per day of process wastewater
- (3) New England Etching Company, consisting of 500 gallons per day of process wastewater
- (4) SONOCO Products Company, consisting of 300,000 gallons per day of process wastewater
- (5) R.R. LeDuc Corp., consisting of 1,000 gallons per day of process wastewater
- (6) Hazen Paper Company, consisting of 150 gallons per day of process wastewater, and
- (7) Marox Corporation, consisting of 750 gallons per day process wastewater.

Pollutants introduced into POTWs by a non-domestic source shall not pass through the POTW or interfere with the operation or performance of the treatment works.

A quantitative description of the discharge in terms of effluent parameters, based on monitoring data submitted by the permittee from October 2017 through September 2022 is provided in Appendix A of this Fact Sheet.

### **3.1.1 Treatment Process Description**

The Holyoke Water Pollution Control Facility (WPCF) is a secondary biological treatment plant. The treatment process train includes mechanical screens, grit removal, influent submersible pumps, primary clarification, activated sludge biological treatment, secondary clarification, chlorine disinfection, sludge thickening and sludge dewatering. The treatment plant discharges to the Connecticut River via a submerged outfall about 200 feet from the western bank of the river. Effluent pumps are also included in the event of high water in the receiving stream. A flow diagram of the Treatment Facility is shown in Figure 3.

The Berkshire Street CSO 9 Facility, which is located adjacent to the WPCF, has the capability to screen and disinfect a flow rate of up to 103 mgd of CSO wastewater. The facility design included provisions for maximizing the flow to the WPCF from the Highland Park/Front Street (HP/FS) interceptor, transporting the overflow from regulator 009 to an area adjacent to the WPCF by means of the Berkshire Street outfall, diverting the flow into a CSO pump station, installing fine mechanical screens, installing a CSO chlorine disinfection system, dechlorinating



the effluent, then diverting the flow back to the Holyoke WPCF for full secondary treatment or to the Berkshire Street outfall below the pump station location.

The WPCF produces an average of 1,786 dry metric tons of sludge annually. Sludge is trucked to Synagro in Waterbury, CT for incineration.

### **3.1.2 Collection System Description**

The Holyoke WPCF collection system is about 39% a separate sewer system and 61% a combined sewer system.

A separate sanitary sewer conveys domestic, industrial and commercial sewage, but not stormwater. It is part of a “two pipe system” consisting of separate sanitary sewers and storm sewers. The two systems have no interconnections; the sanitary sewer leads to the wastewater treatment plant and the storm sewers discharge to a local water body.

A combined sewer system (CSS) is a wastewater collection system which conveys domestic, industrial and commercial sewage and stormwater through a single-pipe system to a wastewater treatment plant. A combined sewer overflow (CSO) is the discharge from a CSS at a point prior to the wastewater treatment plant. CSO discharges occur when the volume of wastewater exceeds the capacity of the CSS or treatment plant (e.g., during heavy rainfall events or snowmelt). Section 5.6 includes further discussion of Holyoke’s CSO infrastructure.

## **4.0 Description of Receiving Water and Dilution**

### **4.1 Receiving Water**

The Holyoke WPCF discharges through Outfall 001 and 10 CSOs into the Connecticut River, within Segment MA 34-05. One of the CSO outfalls (Front St/Appleton St. #16) discharges via the Holyoke Canal System to the Connecticut River; this CSO is considered a discharge to the Connecticut River. Connecticut River Segment MA34-05 runs from the Holyoke Dam, Holyoke/South Hadley to the Massachusetts/Connecticut border, a length of 15.9 miles.

The Connecticut River is classified as a Class B warm water fishery with the CSO qualifier in the Massachusetts WQSs, 314 Code of Massachusetts Regulations (“CMR”) 4.06(6)(b). The MA WQS at 314 CMR 4.05(3)(b) state that Class B “*waters are designated as a habitat for fish, other aquatic life, and wildlife, including for their reproduction, migration, growth and other critical functions, and for primary and secondary contact recreation. Where designated in 314 CMR 4.06(1)(d)6. and (6)(b) as a "Treated Water Supply", they shall be suitable as a source of public water supply with appropriate treatment. Class B waters shall be suitable for irrigation and other agricultural uses and for compatible industrial cooling and process uses. These waters shall have consistently good aesthetic value.*”

The Connecticut River is listed in the final *Massachusetts Integrated List of Waters for the Clean Water Act 2018-2020 Reporting Cycle* (“303(d) List”) as a Category 5 “Waters Requiring a

TMDL.<sup>5</sup> The pollutants requiring a TMDL are *E. Coli* and PCBs in fish tissue. To date no TMDL has been developed for this segment for any of the listed impairments. The status of each designated use is presented in Table 1.

**Table 1 – Summary of Designated Uses and Listing Status**

Designated Use	Status
Aquatic Life	Good
Aesthetics	Good
Primary Contact Recreation	Impaired ( <i>E. Coli</i> )
Secondary Contact Recreation	Impaired ( <i>E. Coli</i> )
Fish Consumption	Impaired (PCBs in Fish Tissue)

## 4.2 Ambient Data

A summary of the ambient data collected in the receiving water in the vicinity of the outfall that is referenced in this Fact Sheet can be found in Appendix A of this Fact Sheet.

## 4.3 Available Dilution

To ensure that discharges do not cause or contribute to violations of WQS under all expected conditions, WQBELs are derived assuming critical conditions for the receiving water<sup>6</sup>. The critical flow in rivers and streams is some measure of the low flow of that river or stream. Massachusetts WQSs require that:

(a) for rivers and streams, the lowest condition is the lowest mean flow for seven consecutive days, recorded once in 10 years, or 7-day 10-year low flow (7Q10). *See* 314 CMR 4.03(3)(a); and

(b) in waters where flows are regulated by dams or similar structures, the lowest flow condition is the flow equaled or exceeded 99% of the time on a yearly basis, or another equivalent flow agreed upon by the State.

The lowest flow in this case is the 7Q10. *See* 314 CMR 4.03(3)(b). MassDEP calculated the 7Q10 for the Connecticut River based on data from the United States Geological Survey (USGS) low-flow frequency statistics for the nearest USGS gaging to the Facility along the Connecticut River (Station Number 01172010) based on the last 19 years of streamflow data (4/1/2003 to 3/31/2022). EPA notes that this is less than the typical 30 years of ambient flow data because the gauging station began collecting flow data in November 2002 and EPA determined that this gauge best characterizes the receiving water in the vicinity of the discharge.

The dilution factor (DF) was calculated using the design flow ( $Q_e$ ) and the critical flow in the receiving water upstream of the discharge ( $Q_s$ ) as follows:

<sup>5</sup> *Massachusetts 2018-2020 Integrated List of Waters for the Clean Water Act 2018/2020 Reporting Cycle*, MassDEP Division of Watershed Management Watershed Planning Program, Worcester, Massachusetts, December 2019.

<sup>6</sup> EPA Permit Writer's Manual, Section 6.2.4



$$DF = (Q_s + Q_e)/Q_e$$

Where:

$Q_s = 7Q_{10}$  in million gallons per day (MGD) = 1,275 MGD [1,973 cfs]

$Q_e$  = Design flow in MGD = 17.5 MGD

Therefore:

$$DF = (1,275 \text{ MGD} + 17.5 \text{ MGD}) / 17.5 \text{ MGD} = 74$$

EPA used this dilution factor (DF) in its quantitative derivation of WQBELs for pollutants in the Draft Permit.

## 5.0 Proposed Effluent Limitations and Conditions

The proposed effluent limitations and conditions derived under the CWA and State WQSs are described below. These proposed effluent limitations and conditions, the basis of which are discussed throughout this Fact Sheet, may be found in Part I of the Draft Permit.

### 5.1 Effluent Limitations and Monitoring Requirements

In addition to the State and Federal regulations described in Section 2, data submitted by the permittee in its permit application, in monthly discharge monitoring reports (DMRs) and in WET test reports from October 2017 to September 2022 (the “review period”) were used to identify the pollutants of concern and to evaluate the discharge during the effluent limitations development process (*See Appendix A*). The reasonable potential analysis is included in Appendix B and results are discussed in the sections below.

#### 5.1.1 Effluent Flow

The effluent flow limit in the 2016 Permit is 17.5 MGD, as a rolling annual average flow, based on the Facility’s design flow. The DMR data during the review period shows a maximum rolling annual average flow of 8.7 MGD. There have been no exceedances of the flow limit during the review period.

The Draft Permit continues the 17.5 MGD flow limit from the 2016 Permit. The Draft Permit requires that flow be measured continuously and that the rolling annual average flow, as well as the average monthly and maximum daily flow for each month be reported. The rolling annual average flow is calculated as the average of the flow for the reporting month and 11 previous months.

#### 5.1.2 Biochemical Oxygen Demand (BOD<sub>5</sub>)

##### 5.1.2.1 BOD<sub>5</sub> Concentration Limits

The BOD<sub>5</sub> limits in the 2016 Permit were based on the secondary treatment standards in 40 CFR § 133.102; the average monthly limit is 30 mg/L and the average weekly limit is 45 mg/L.

The DMR data during the review period shows that there have been no violations of BOD<sub>5</sub> concentration limits.

The Draft Permit proposes the same BOD<sub>5</sub> concentration limits as in the 2016 Permit as no new WLAs have been established and there have been no changes to the secondary treatment standards. The monitoring frequency remains five times per week.

#### **5.1.2.2 BOD<sub>5</sub> Mass Limits**

The mass-based BOD<sub>5</sub> limits in the 2016 Permit of 4,379 lb/day (average monthly) and 6,568 lb/day (average weekly) were based on EPA's secondary treatment standards and the design flow of the Facility.

The DMR data from the review period shows that there have been no exceedances of BOD<sub>5</sub> mass limits.

Calculations of maximum allowable loads for average monthly and average weekly BOD<sub>5</sub> are based on the following equation:

$$L = C_d * Q_d * 8.34$$

Where:

L = Maximum allowable load in lb/day

C<sub>d</sub> = Maximum allowable effluent concentration for reporting period in mg/L  
(reporting periods are average monthly and average weekly)

Q<sub>d</sub> = Design flow of the Facility

8.34 = Factor to convert effluent concentration in mg/L and design flow in MGD to lb/day

Limits:

Average Monthly: 30 mg/L \* 17.5 MGD \* 8.34 = 4,379 lb/day

Average Weekly: 45 mg/L \* 17.5 MGD \* 8.34 = 6,568 lb/day

The Draft Permit proposes the same BOD<sub>5</sub> mass limits as in the 2016 Permit as no new WLAs have been established and there have been no changes to the secondary treatment standards. The monitoring frequency remains five times per week.

### **5.1.3 Total Suspended Solids (TSS)**

#### **5.1.3.1 TSS Concentration Limits**

The TSS limits in the 2016 Permit were based on the secondary treatment standards in 40 CFR § 133.102; the average monthly limit is 30 mg/L and the average weekly limit is 45 mg/L. The DMR data during the review period shows that there have been no exceedances of the average monthly TSS concentration limit and two exceedances of the average weekly TSS concentration limit.



The Draft Permit proposes the same TSS concentration limits as in the 2016 Permit as no new WLAs have been established and there have been no changes to the secondary treatment standards. The monitoring frequency remains five times per week.

#### 5.1.3.2 TSS Mass Limits

The mass-based TSS limits in the 2016 Permit of 4,379 lb/day (average monthly) and 6,568 lb/day (average weekly) were based on EPA's secondary treatment standards and the design flow of the Facility.

The DMR data from the review period shows that there have been no exceedances of TSS mass limits.

Calculations of maximum allowable loads for average monthly and average weekly BOD<sub>5</sub> are based on the following equation:

$$L = C_d * Q_d * 8.34$$

Where:

L = Maximum allowable load in lb/day

C<sub>d</sub> = Maximum allowable effluent concentration for reporting period in mg/L  
(reporting periods are average monthly and average weekly)

Q<sub>d</sub> = Design flow of the Facility

8.34 = Factor to convert effluent concentration in mg/L and design flow in MGD to lb/day

Limits:

Average Monthly: 30 mg/L \* 17.5 MGD \* 8.34 = 4,379 lb/day

Average Weekly: 45 mg/L \* 17.5 MGD \* 8.34 = 6,568 lb/day

The Draft Permit proposes the same TSS mass limits as in the 2016 Permit as no new WLAs have been established and there have been no changes to the secondary treatment standards. The monitoring frequency remains five times per week.

#### 5.1.4 Eighty-Five Percent (85%) BOD<sub>5</sub> and TSS Removal Requirement

In accordance with the provisions of 40 CFR § 133.102(a)(3) and (b)(3), the 2016 Permit requires that the 30-day average percent removal for BOD<sub>5</sub> and TSS be not less than 85%. The DMR data during the review period shows that the median BOD<sub>5</sub> and TSS removal percentages are 96% and 95%, respectively. There were no exceedances of the 85% removal requirement for BOD<sub>5</sub> or TSS during that period.

The requirement to achieve 85% BOD<sub>5</sub> and TSS removal has been carried forward into the Draft Permit.

### 5.1.5 pH

The Massachusetts water quality standards specify that the pH of Class B waters shall be within the range of 6.5-8.3 Standard Units (S.U.), and within 0.5 S.U. of the natural background range (see 314 CMR 4.05(3)(b)(3)). The 2016 Permit includes a pH upper limit value of 8.3 S.U. consistent with this regulation. The 2016 Permit has an approved lower limit pH value of 6.0 S.U.

The DMR data during the review period show that there have been no exceedances of the pH limits.

The expanded pH range in the 2016 Permit will be carried forward. An optional pH study (described in footnote 6 of Part I.A of the Permit) must be conducted within three years for this expanded limit to be carried forward in the next permitting cycle. If the Permittee chooses not to conduct the study, the pH limits in the next permit reissuance will be aligned with the MA WQS (*i.e.*, 6.5-8.3 S.U.).

### 5.1.6 Bacteria

The 2016 Permit includes effluent limitations for bacteria using *E. Coli* bacteria as the indicator bacteria with limits of 126 colonies/100 ml as a geometric mean, and 409 colonies/100 ml as a maximum daily. These limits were based on the applicable WQS at the time the permit was issued. The bacteria limits apply April 1 through October 31, and the monitoring frequency is twice (2x) per week.

Updated Massachusetts WQS with respect to bacteria, 314 CMR 4.05(5)(f)1, were approved by EPA on March 31, 2022. Permit limits based on the new 2022 WQS for *E. Coli* would be 126 colonies/100 ml as a geometric mean (same as the current limit) and 410 colonies/100 ml as a maximum daily value (slightly less stringent than the current limit). Given that the more stringent limit of 409 colonies/100 ml (compared to 410 colonies/100 ml as described above) is already effective under the 2016 Permit, it will be carried forward based on anti-backsliding regulations discussed in Section 2.6 above. Therefore, the same *E. Coli* limits and monitoring frequency from the 2016 Permit are carried forward in the Draft Permit.

### 5.1.7 Total Residual Chlorine

The Permittee uses chlorine disinfection. The 2016 Permit includes effluent limitations for total residual chlorine (TRC) of 0.74 mg/L (average monthly) and 1.0 mg/L (maximum daily). The DMR data during the review period show that there have been no exceedances of the TRC limitations.

The TRC permit limits are based on the instream chlorine criteria defined in *National Recommended Water Quality Criteria: 2002*, EPA 822R-02-047 (November 2002), as adopted by the MassDEP into the state water quality standards at 314 CMR 4.05(5)(e). These freshwater instream criteria for chlorine are 11 µg/L (chronic) and 19 µg/L (acute). Because the upstream



chlorine is assumed to be zero in this case, the water quality-based chlorine limits are calculated as the criteria times the dilution factor, as follows:

Chronic criteria \* dilution factor \* 0.001 (conversion factor  $\mu\text{g/l}$  to  $\text{mg/l}$ ) = Chronic limit  
 $11 \mu\text{g/L} * 74 * 0.001 = 0.81 \text{ mg/L}$  (average monthly)

Acute criteria \* dilution factor \* 0.001 (conversion factor  $\mu\text{g/l}$  to  $\text{mg/l}$ ) = Acute limit  
 $19 \mu\text{g/L} * 74 * 0.001 = 1.4 \text{ mg/L}$  (maximum daily)

These calculated limits are less stringent than the limits in the 2016 Permit. Therefore, the 0.74  $\text{mg/L}$  average monthly and 1.0  $\text{mg/L}$  maximum daily limits will be carried forward due to anti-backsliding regulations discussed in Section 2.6 above.

### 5.1.8 Ammonia

The 2016 Permit does not include ammonia limits, but the Permittee was required to monitor effluent ammonia concentrations on a weekly basis from April 1<sup>st</sup> through October 31<sup>st</sup> and monthly from November 1<sup>st</sup> through March 31<sup>st</sup>. Additionally, the Permittee was required to monitor and report effluent and ambient ammonia concentrations on a quarterly basis as part of the Whole Effluent Toxicity (WET) testing. These effluent data and ambient data (taken upstream of the Holyoke outfall in the Connecticut River) are presented in Appendix A.

The ammonia criteria in EPA's *National Recommended Water Quality Criteria*, 2002 (EPA 822-R-02-047) document are included by reference in the Massachusetts WQS (*See* 314 CMR 4.05(5)(e)). The freshwater acute criterion is dependent on pH, temperature and whether early life stages of fish are present in the receiving water and the freshwater chronic criterion is dependent on pH and temperature. The marine water quality criteria are dependent on pH and temperature.

In determining whether the discharge has the reasonable potential to cause or contribute to excursions above the instream water quality criteria for ammonia, EPA used the mass balance equation presented in Appendix B for both warm and cold weather conditions to project the ammonia concentration downstream of the discharge. If there is reasonable potential, this mass balance equation is also used to determine the limit that is required in the permit.

To determine the applicable ammonia criteria, EPA assumes a warm weather (April through October) temperature of 25° C and a cold weather (November through March) temperature of 5° C. EPA used the ambient pH monitoring shown in Appendix A, which indicates that the median pH is 7.3 S.U. Additionally, the Connecticut River in the vicinity of the Holyoke WPCF discharge is within Essential Fish Habitat (EFH) for Atlantic salmon (*Salmo salar*), so EPA has assumed that salmonids could be present in the receiving waters.

Based on the information and assumptions described above, Appendix B presents the applicable ammonia criteria, the details of the mass balance equation, the reasonable potential determination, and, if necessary, the limits required in the Draft Permit. As shown, there is no

reasonable potential to cause or contribute to an excursion of WQS, so the Draft Permit does not propose ammonia limits.

Effluent and ambient monitoring for ammonia will continue to be required in the quarterly WET tests.

### 5.1.9 Nutrients

Nutrients are compounds containing nitrogen and phosphorus. Although nitrogen and phosphorus are essential for plant growth, high concentrations of these nutrients can cause eutrophication, a condition in which aquatic plant and algal growth is excessive. Plant and algae respiration and decomposition reduces dissolved oxygen in the water, creating poor habitat for fish and other aquatic animals. Recent studies provide evidence that both phosphorus and nitrogen can play a role in the eutrophication of certain ecosystems. However, typically phosphorus is the limiting nutrient triggering eutrophication in freshwater ecosystems and nitrogen in marine or estuarine ecosystems. Thus, for this receiving water both are nutrients of concern evaluated below.

#### 5.1.9.1 Total Nitrogen

The Holyoke WPCF discharges to the Connecticut River, which drains to Long Island Sound (LIS). The 2016 Permit required weekly monitoring (April 1 – October 31) and monthly monitoring (November 1 – March 31) for total Kjeldahl nitrogen, nitrate and nitrite, the sum of which provides the total nitrogen (TN) concentration. As shown in Attachment A, the Facility also reported TN concentration data and the calculated monthly average total nitrogen loading from the Facility, total nitrogen discharges ranged from 208.17 lb/day to 922 lb/day with a median of 516.7 lb/day during the review period. Using these data to calculate 12-month rolling annual average loads for the review period results in a range from 403 lb/day to 668 lb/day.

As explained below, since 2019 EPA has adopted a systemic, state-by-state approach to control nitrogen pollution discharging from “out-of-basin” point sources in Massachusetts, New Hampshire and Vermont into tributaries of LIS, a severely impaired water body shared by New York and Connecticut. EPA’s methodology for establishing TN limitations for out-of-basin POTWs in Massachusetts and New Hampshire has been challenged in the United States Environmental Appeals Board (EAB) and the case has been resolved in EPA’s favor. EPA’s Response to the Petition was filed on December 11, 2020, and EPA incorporates that filing herein, inclusive of attachments (*e.g.*, Exhibit S, Response to the Comments, as it relates to TN.<sup>7</sup>) EAB’s order denying review is dated May 17, 2021<sup>8</sup>

---

<sup>7</sup>[https://yosemite.epa.gov/OA/EAB\\_WEB\\_Docket.nsf/Filings%20By%20Appeal%20Number/11443A888232A1C88525863B006D4491/\\$File/Springfield%20Response%20to%20Petition\\_Final\\_12\\_11\\_2020.pdf](https://yosemite.epa.gov/OA/EAB_WEB_Docket.nsf/Filings%20By%20Appeal%20Number/11443A888232A1C88525863B006D4491/$File/Springfield%20Response%20to%20Petition_Final_12_11_2020.pdf)

<sup>8</sup>

[https://yosemite.epa.gov/oa/EAB\\_Web\\_Docket.nsf/NPDES%20Permit%20Appeals%20\(CWA\)/61585EEC1C328394852586E20073D0FD/\\$File/Springfield%20Water%20&%20Sewer%20Commission.pdf](https://yosemite.epa.gov/oa/EAB_Web_Docket.nsf/NPDES%20Permit%20Appeals%20(CWA)/61585EEC1C328394852586E20073D0FD/$File/Springfield%20Water%20&%20Sewer%20Commission.pdf)



In 2000, New York and Connecticut finalized a Total Maximum Daily Load<sup>9</sup> (TMDL) that addressed dissolved oxygen impairments in Long Island Sound due to excessive nitrogen loading. It was approved by EPA in 2001. While the TMDL included waste load allocations (WLAs) for point sources in Connecticut and New York, out-of-basin facilities were not assigned WLAs. However, the Connecticut and New York WLAs included in the TMDL were based on an assumption that out-of-basin point source loads of total nitrogen would be reduced in aggregate by 25% from the baseline through enforceable permit requirements imposed by permitting authorities in the out-of-basin states to protect downstream waters.

EPA implemented optimization requirements in many out-of-basin permits issued in the LIS watershed from 2007 through early 2019 in accordance with an agreement forged in 2012 among the five LIS watershed states, known as the “Enhanced Implementation Plan” (EIP).<sup>10</sup> However, concerns raised in recent public comments by the downstream state (Connecticut) and citizens highlighted the need for clearly enforceable, numeric, loading-based effluent limits to ensure that the annual aggregate nitrogen loading from out-of-basin point sources are consistent with the assumptions of the TMDL WLA of 19,657 lb/day and to ensure that current aggregate loadings do not increase. This is in accordance with the State of Connecticut’s antidegradation policy, which requires existing uses to be fully maintained and protected. These uses are already being compromised given the continued, severe nitrogen-driven impairments in LIS. After further review of federal and state requirements, EPA agreed with the concerns raised by the downstream affected state and the public and noted that optimization requirements, by themselves, do not prevent further increases in nitrogen due to population growth (and consequent flow increases) or new industrial dischargers.

#### Scientific, Statutory and Regulatory Implementation Considerations

As discussed in Section 2 of this Fact Sheet, statutory and regulatory requirements regarding the development of water quality-based effluent limits include: (1) consideration of applicable water quality requirements of downstream states, including provisions to prevent further degradation of receiving waters that are already impaired, pursuant to a state’s antidegradation policy, and provisions to implement other applicable water quality standards, including translation of narrative water quality criteria, and (2) provisions to ensure consistency with the assumptions of any available WLAs.

LIS covers about 1,300 square miles and borders Connecticut and New York. It drains a densely populated watershed area of over 16,000 square miles, including portions of Maine, Vermont, New Hampshire and Massachusetts. About 613 square miles of LIS fall within Connecticut. Connecticut classifies LIS as Class SA and Class SB and designates these waters as, *inter alia*, suitable for recreation and aquatic life habitat. R.C.S.A. § 22a-426-4(f), (j).

---

<sup>9</sup> Connecticut Department of Environmental Protection and New York State Department of Environmental Conservation, *A Total Maximum Daily Load Analysis to Achieve Water Quality Standards for Dissolved Oxygen in Long Island Sound* (LIS TMDL), December 2000.

<sup>10</sup> Long Island Sound Study Steering Committee, NY, CT, MA, NH, VT, *Enhanced Implementation Plan for the Long Island Sound Total Maximum Daily Load*, 2012. Available at: <https://neiwpcc.org/our-programs/pollution-control/lis-tmdl/>.



Connecticut regulations establish DO, biological condition, and nutrient criteria for each water class. For Class SA and SB waters, DO must not be less than 3 mg/L and may be less than 4.8 mg/L for only limited periods of time. R.C.S.A. § 22a-426-9(a)(1). Regarding biologic condition, “Surface waters... shall be free from...constituents...which...can reasonably be expected to...impair the biological integrity of aquatic or marine ecosystems...” *Id.* at § 22a-426-4(a)(5). “The loading of...nitrogen...to any surface water body shall not exceed that which supports maintenance or attainment of designated uses.” *Id.* at § 22a-426-9; *see also* § 22a-426-4(a)(11) (authorizing “imposition of discharge limitations or other reasonable controls... for point...sources of ...nitrogen...which have the potential to contribute to the impairment of any surface water, to ensure maintenance and attainment of existing and designated uses, restore impaired waters, and prevent excessive anthropogenic inputs of nutrients or impairment of downstream waters.”)

Connecticut regulations mandate protection of “existing” and “designated” uses. R.C.S.A. § 22a-426-8(a)(1). “Tier 1” antidegradation review provides:

The Commissioner shall determine whether the discharge or activity is consistent with the maintenance, restoration, and protection of existing and designated uses assigned to the receiving water body by considering all relevant available data and the best professional judgment of department staff. *All narrative and numeric water quality standards, criteria and associated policies contained in the Connecticut Water Quality Standards shall form the basis for such evaluation considering the discharge or activity both independently and in the context of other discharges and activities in the affected water body and considering any impairment listed pursuant to 33 USC 1313(d) or any Total Maximum Daily Load (TMDL) established for the water body.*

R.C.S.A. § 22a-426-8(f) (emphasis added). The standards further provide, “The procedures for review outlined in this policy apply to any discharge or activity that is affecting or *may affect* [emphasis added] water quality in Connecticut, including but not limited to any existing, new or increased activity or discharge requiring a permit, water quality certificate or authorization pursuant to chapters 439, 440, 445 or 446i to 446k, inclusive of the Connecticut General Statutes.”

Although nitrogen driven impairments in LIS have been reduced in recent years, they have not been eliminated, and they remain significant. In EPA’s technical and scientific judgment, the current quantity of nitrogen in LIS exceeds the narrative and numeric nutrient-related criteria applicable to LIS, and designated aquatic life uses are not being protected, based on analyses of water quality data and information in the administrative record.<sup>11</sup> While there have been significant reductions in the size of the hypoxic zone in LIS due largely to in-basin point source TN reductions, LIS continues to be impaired.<sup>12</sup> It is undisputed that significant amounts of nitrogen from out-of-basin facilities are discharged to the LIS watershed (as much as 6 million pounds per year, based on the sum of the maximum annual discharge from each out-of-basin

---

<sup>11</sup> See e.g. Long Island Sound Report Card 2018, at <https://www.ctenvironment.org/wp-content/uploads/2018/09/ReportCard2018-BestView.pdf>

<sup>12</sup> Long Island Sound Study, *A Healthier Long Island Sound: Nitrogen Pollution*, 2019, page 2.



discharger from 2013 to 2017). The out-of-basin loads in the aggregate necessarily contribute, or have the reasonable potential to contribute, to these exceedances.

Since the LIS TMDL was approved by EPA in 2001, the study of water quality conditions in LIS and the nitrogen loadings that contribute to hypoxia and other impairments there has continued. Annual monitoring of hypoxia and dissolved oxygen conditions in Long Island continues, as most recently documented in the *2019 Long Island Sound Hypoxia Season Review*<sup>13</sup> which notes that while the area of hypoxia has been reduced, water quality standards have not yet been met.<sup>14</sup> In 2015, the Long Island Sound Study (LISS)<sup>15</sup> updated its Long Island Sound Comprehensive Conservation and Management Plan (CCMP)<sup>16</sup> which sets watershed targets, implementation actions to meet those targets, and monitoring strategies. One of the objectives of the CCMP is to improve water quality by further reducing nitrogen pollution from sources that are more distant from the Sound,<sup>17</sup> such as wastewater treatment plants in Massachusetts.

A study published in 2008 used both measurements and mass-balance modeling to evaluate the potential for nitrogen attenuation in the main stem of the Connecticut River in April and August 2005. One of the reaches studied was a 55 km stretch of the Connecticut River in Massachusetts and the other was a 66 km stretch of the Connecticut River along the New Hampshire/Vermont border. The study found no nitrogen loss in that reach either in April or August, most likely due to the depth and higher velocities in the main stem of the river compared to the shallower, slower tributaries where previous models and studies had demonstrated varying degrees of nitrogen attenuation.<sup>18</sup> For the New Hampshire reach, measured nitrogen loss occurred only in August 2005. This finding may be due to the presence of hydroelectric power dams on the Connecticut River, which significantly alter the natural character of the channel. Dams are present at the head and foot of both study reaches, but a greater length of deep, impounded water extends across the southern reach than the northern study reach which, by contrast, has substantially more shallow, gravelly pool-and-riffle sequences. It is possible that, by allowing greater interaction of the water column with a biologically active substrate, these shallow channel sections in the north provide an opportunity for attenuation of in-stream nitrogen that does not exist in the southern reach. As noted by Alexander et al. (2000)<sup>19</sup>, nitrogen removal by denitrification and settling is generally less in deeper channels where streamwater has less contact with benthic sediment.

In addition, subsequent studies refined the understanding of out-of-basin baseline nitrogen loading which suggest lower out-of-basin baseline point source loading to the Connecticut River

---

<sup>13</sup> CTDEEP, Interstate Environmental Commission, EPA, *2019 Long Island Sound Hypoxia Season Review*, available at: [http://www.iec-nynjct.org/sites/default/files/2020-07/FINAL\\_LISound-Hypoxia-2019-Combined-Report\\_april2020.pdf](http://www.iec-nynjct.org/sites/default/files/2020-07/FINAL_LISound-Hypoxia-2019-Combined-Report_april2020.pdf)

<sup>14</sup> *2019 Long Island Sound Hypoxia Season Review* (page 13)

<sup>15</sup> The Long Island Sound Study (LISS) is a bi-state partnership, formed by EPA, New York and Connecticut in 1985, consisting of federal and state agencies, user groups, concerned organizations, and individuals dedicated to restoring and protecting the Long Island Sound. For more information see <https://longislandsoundstudy.net/>

<sup>16</sup> LISS, Long Island Sound Comprehensive Conservation and Management Plan 2015 Returning the Urban Sea to Abundance (CCMP), 2015.

<sup>17</sup> CCMP, page 19.

<sup>18</sup> Smith, Thor E., et al, *Nitrogen Attenuation in the Connecticut River, Northeastern USA: A Comparison of Mass Balance and N<sub>2</sub> Production Modeling Approaches*, *Biogeochemistry*, Mar., 2008, Vol. 87, No. 3 (Mar., 2008), pp. 311-323

<sup>19</sup> <https://link.springer.com/article/10.1007/s10533-008-9186-7#ref-CR1>



than the 21,672 lb/day assumed in the 2000 TMDL. In 2013, the United States Geological Survey (USGS) published an estimation of the total nitrogen load to Long Island Sound from Connecticut and contributing areas to the north for October 1998 to September 2009.<sup>20</sup> Available total nitrogen and continuous flow data from 37 water-quality monitoring stations in the LIS watershed, for some or all of these years, were used to compute total annual nitrogen yields and loads. In order to extract the non-point source loadings from the total nitrogen measured, the authors relied on point source estimates from the SPARROW model of nutrient delivery to waters in the Northeastern and Mid-Atlantic states in 2002, including the Connecticut River, that was published by Moore and others in 2011.<sup>21</sup> The SPARROW model estimated that 1,776.7 metric tons per year (MT/yr) (or annual average 10,820 lb/day) of total nitrogen was discharged to the Connecticut River from Massachusetts, New Hampshire and Vermont in 2002<sup>22</sup>. These estimates were based on an approach by Maupin and Ivahnenko, published the same year, which used discharge monitoring data available from EPA's Permit Compliance System (PCS) database for 2002.<sup>23,24</sup> Where no data was available, an estimated typical pollutant concentration (TPC) and flow was used to approximate nitrogen loading from point sources according to their industrial category.<sup>25</sup>

Finally, Long Island Sound continues to be listed as impaired on Connecticut's latest EPA-approved list of impaired waters and is experiencing ongoing effects of eutrophication, including low DO, although the system has experienced improvements since the TMDL was approved.

In light of the foregoing, EPA is establishing water quality-based effluent limitations for total nitrogen on three grounds: (1) to ensure compliance with the State of Connecticut's antidegradation provisions, a downstream affected state under 401(a)(2) of the Act and 40 CFR § 122.4(d); (2) to translate and fully implement the state's narrative water quality criterion for nutrients, pursuant to 40 CFR § 122.44(d)(1)(vi)(A); and (3) to ensure consistency with the assumptions and requirements of the available WLA, pursuant to 40 CFR § 122.44(d)(1)(vii)(B).

#### Compliance with Antidegradation Requirements of Downstream Affected State

One of the principal objectives of the CWA, articulated in CWA § 101(a) is to "maintain the chemical, physical and biological integrity of the Nation's waters." The antidegradation requirements in federal regulations at 40 CFR § 131.12 provide a framework for maintaining and protecting water quality that has already been achieved and require states to adopt provisions in

---

<sup>20</sup> Mullaney, J.R., and Schwarz, G.E., 2013, Estimated Nitrogen Loads from Selected Tributaries in Connecticut Draining to Long Island Sound, 1999–2009: U.S. Geological Survey Scientific Investigations Report 2013–5171, 65

<sup>21</sup> Moore, Richard B., Craig M. Johnston, Richard A. Smith, and Bryan Milstead, 2011. Source and Delivery of Nutrients to Receiving Waters in the Northeastern and Mid-Atlantic Regions of the United States. *Journal of the American Water Resources Association (JAWRA)* 47(5):965-990. DOI: 10.1111/j.1752-1688.2011.00582.x

<sup>22</sup> Extrapolated from Moore, et.al 2011, Table 3 on page 977 which estimated that for 2002 an 33.2 % of the total 4,553 MT/yr Massachusetts nitrogen load was from point sources, 2.5% of the total 3,795 MT/yr Vermont nitrogen load was from point sources and 6.1 percent of the total 2,790 MT/yr New Hampshire nitrogen load was from point sources.

<sup>23</sup> Moore (2011), page 968.

<sup>24</sup>Maupin, Molly A. and Tamara Ivahnenko, 2011. Nutrient Loadings to Streams of the Continental United States From Municipal and Industrial Effluent. *Journal of the American Water Resources Association (JAWRA)* 47(5):950-964.

<sup>25</sup> Maupin (2011), page 954.



their water quality standards that prevent further degradation of both degraded waters and waters which are meeting or exceeding the water quality necessary to protect designated and existing uses. As noted above, antidegradation provisions of Connecticut's water quality standards require that existing uses be fully maintained and protected. They expressly required consideration of any applicable TMDL, as well as narrative and numeric water quality criteria. EPA therefore undertakes Tier 1 review in light of the LIS TMDL, which has still not resulted in attainment of water quality standards in LIS, as well as Connecticut's numeric water quality criteria for dissolved oxygen, which are routinely violated, and its narrative water quality criteria nutrients, which is likewise not being met. Authorizing a significantly increased nitrogen loading into an impaired water body that is suffering the ongoing effects of cultural eutrophication would further compromise receiving water conditions and uses and be inconsistent with applicable antidegradation requirements. In arriving at this conclusion, EPA also notes that Connecticut's antidegradation procedures are precautionary in nature and apply to discharges that "may affect" water quality.

To ensure that the out-of-basin point-source load does not violate Connecticut's antidegradation standards, the new total nitrogen loading limits (for dischargers with design flows greater than 1 MGD) along with the requirement to minimize nitrogen discharge by facility optimization (for all dischargers with design flow greater than 0.1 MGD) are intended to ensure that nitrogen loads are held at current loadings. As can be seen from the summary in Table 2, 92 % of this load is from POTWs with design flow > 1 MGD. The impact of the new TN effluent limits will be to cap that load at approximately the same average loading. Table 2 summarizes the five-year average out-of-basin loads generated by Massachusetts non-stormwater point sources, based on data provided in Appendix C. While the sum of effluent limited loads for POTWs with design flow greater than 1 MGD is somewhat higher than the average loads observed in recent years, actual effluent limited loads can be expected be lower than the limits in order to avoid permit exceedances. EPA will continue to track out-of-basin loads as new data becomes available and will re-evaluate permit requirements for nitrogen for all out-of-basin dischargers in future permit actions.

**Table 2 - Summary of Massachusetts Out-of-Basin Non-Stormwater Point Source Loads**

	Sum of Average Load 2017-2021 (lb/day)	Sum of Effluent Limited Loads (lb/day)
POTWs with design Flow > 1 MGD	9,877 (93.2%)	10,907
POTWs with design Flow 0.1 to 1 MGD	704 (6.6%)	
POTWs with design Flow < 0.1 MGD and Industrial Sources.	20 (0.2%)	

#### Translation of Narrative Nutrient Criteria

Using the TMDL as the "calculated numeric water quality criterion for the pollutant which the permitting authority demonstrates will attain and maintain applicable narrative water quality



criteria and will fully protect the designated use” under the regulatory provision used to translate narrative water quality criteria into numeric effluent limitations, 40 CFR § 122.44(d)(1)(vi)(A), EPA has determined that an effluent limitation is necessary to ensure compliance with the State’s narrative water quality criterion for nutrients. In order to assure compliance with water quality standards, and fully implement and translate the states’ narrative nutrient and related criteria, out-of-basin loads in EPA’s judgment should not be increased, because water quality data indicates that the assimilative capacity for nitrogen has been reached in portions of LIS and cultural eutrophication, the impacts of which include hypoxia, is ongoing. It is reasonable, in EPA’s view, to issue permits to out-of-basin dischargers that hold loads constant and in so doing curtail the potential for these out-of-basin loadings to contribute to further impairment and degradation of a water that is already beyond its assimilative capacity for nitrogen. The TN effluent limits and optimization requirements are necessary to assure that the out-of-basin load does not cause or contribute to further violation of water quality criteria in the downstream LIS. Holding these loads level, in conjunction with significant nitrogen pollution reduction efforts being pursued by in-basin dischargers will, under EPA’s analysis, be sufficient to make a finding that the out-of-basin permits taken as a whole contain nutrient controls sufficient to ensure that the discharges comply with water quality standards under Section 301 of the Act, based on information in the record currently before EPA. EPA acknowledges the complexity of the system and the receiving water response, and EPA recognizes that work that is currently ongoing with regards to additional water quality modeling, point source load reductions and WWTP upgrades in other states, particularly New York and Connecticut. In order to ensure that water quality standards are met, EPA has determined that, at most, TN should be no greater than that resulting from nitrogen currently being discharged from all sources. Holding the load from out-of-basin sources, along with reductions resulting from the nitrogen optimization special condition, combined with other ongoing work to further reduce in-basin loadings, are in EPA’s judgment together sufficient to assure that the discharge is in compliance with standards.

#### Consistency with Assumptions of Available WLA

Finally, EPA is imposing an enforceable total nitrogen limitation to ensure consistency with the assumptions and requirements of the applicable WLA, which calls for out-of-basin loads to be capped at 25% of the baseline in fact at the time of TMDL approval. A WQBEL for a discharge must ensure compliance with WQS and be “consistent with the assumptions and requirements” of an available WLA. 40 CFR § 122.44(d)(1)(vii)(B). Capping the aggregate out-of-basin load at current levels will ensure that this requirement is met.

In sum, the permit conditions at issue here have been fashioned to ensure full implementation of CWA §§ 301(b)(1)(C), 401(a)(2) and 402, as well as consistency with the assumptions of the LIS WLA. A permitting authority has wide discretion to determine appropriate effluent limits for a permit. “Congress has vested in the Administrator [of EPA] broad discretion to establish conditions for NPDES permits” in order to achieve these statutory mandates of establishing effluent limitations, including narrative permit conditions, to attain and maintain water quality standards. *Arkansas v. Oklahoma*, 503 U.S. 91, 105 (1992). Section 402 provides that a permit may be issued upon condition “that such discharge will meet either all applicable requirements under sections 301, 302, 306, 307, 308 and 403 of this Act, or prior to taking of necessary implementing actions relating to all such requirements, such conditions as the Administrator



determines are necessary to carry out the provisions of this Act.” 33 U.S.C. §1342(a). “This provision gives EPA considerable flexibility in framing the permit to achieve a desired reduction in pollutant discharges.” *Id.* An increased discharge of nitrogen beyond current loads into nitrogen-degraded waters experiencing the effects of cultural eutrophication (*e.g.*, DO impairments) under the circumstances here would not be consistent with the Act. Holding the load from these facilities will maintain and protect existing uses. This allows EPA to ensure that the nitrogen limits are applied fairly and in a technologically feasible manner while ensuring that antidegradation provisions of Connecticut’s water quality standards are being met.

EPA’s decision to cap the out-of-basin TN loads in the aggregate was consistent with a gross approach to pollutant control, which is appropriate here given the need to ensure reasonable further progress toward restoration of uses in LIS based on reductions that have already occurred and whose impact is still being realized. It is also appropriate in light of the fact that more sophisticated models to precisely define the exact level of pollutant controls needed are not available. EPA has explained that when permitting for nutrients, time is of the essence, because of the tendency of nutrients to recycle in the ecosystem and exacerbate existing impairments, as outlined in EPA’s Nutrient Technical Guidance Manual. Rather than wait for the development of that information, a daunting task because of the size and complexity of LIS and vast areal extent of loading, EPA determined that it would be reasonable to move forward. This decision is also reasonable because the permits for Holyoke and many other contributing sources are long expired. The D.C. Circuit has described the CWA’s balance when confronted with a difficult situation and the obligation to eliminate water quality impairments: “EPA may issue permits with conditions designed to reduce the level of effluent discharges to acceptable levels. This may well mean opting for a gross reduction in pollutant discharge rather than the fine-tuning suggested by numerical limitations. *But this ambitious statute is not hospitable to the concept that the appropriate response to a difficult pollution problem is not to try at all.*” *Natural Resources Defense Council, Inc. v. Costle*, 568 F.2d 1369, 1380 (D.C. Cir. 1977) (emphasis added) (finding unlawful a rule that would have exempted certain discharges from permitting requirements based on the difficulty in setting limits).

### Derivation of Effluent Limits

As mentioned above, the TMDL did not assign each out-of-basin POTW a specific WLA but instead specifies an aggregate reduction target. Therefore, the task of allocating nitrogen loads among these facilities in a manner that ensures compliance with water quality standards, as required under Section 301 of the Act, falls to EPA. That EPA would implement any necessary reductions through the issuance and oversight of NPDES permits was expressly assumed by the TMDL. EPA notes that as much as 6 million pounds of nitrogen per year from out-of-basin facilities are discharged to the LIS watershed and that ongoing nitrogen-driven water quality impairments exist in LIS.

In developing allocations for Massachusetts and New Hampshire dischargers, EPA began with two facts: first, that significant amounts of nitrogen from out-of-basin facilities are discharged to the LIS watershed (as much as 6 million pounds per year, based on the sum of the sum of the maximum annual discharge from each out-of-basin discharger from 2013 to 2017) and, second, that ongoing nitrogen water quality impairments exist in LIS.



When confronting the difficult environmental regulatory problem of controlling or accounting for dozens of discharges into a complex water body like Long Island Sound, EPA was presented with a variety of potential permitting approaches. Long Island Sound is a nitrogen-impaired water body spanning 1,268 square miles that implicates the sometimes-divergent interests of five states, dozens of municipalities and numerous non-governmental organizations (NGOs), along with interested members of the public. In developing its overarching permitting approach, as well as each individual permit, EPA carefully considered, but ultimately rejected, several possible alternatives, on two principal grounds: (1) that they were not sufficiently protective to assure that all the applicable requirements of the Act would be met (*i.e.*, they lacked enforceable TN effluent limitations to *ensure* as a matter of law that nitrogen loads would be maintained at protective levels), or (2) that they would entail unwarranted uncertainty and delay (*i.e.*, they called for the development of new or revised TMDLs or for development of extensive new data collection or modelling in an attempt refine or pinpoint necessary targets and loads, even though the permits at issue have long-since expired and water quality impairments are ongoing). Rather than approach this complex permitting task on an *ad hoc* basis, EPA instead fashioned a systemic permitting approach designed to comprehensively regulate nitrogen loading from out-of-basin nitrogen sources on a gross, basin-level scale. EPA addressed the existing TN loading to ensure achievement of the following overarching objectives:

- the overall out-of-basin TN load does not increase in accordance with antidegradation requirements, given that the LIS is already nitrogen impaired, through the imposition of enforceable effluent limits that are annual average mass-based, consistent with the assumptions of the TMDL;
- no individual facility is left with an effluent limit that is not achievable using readily available treatment technology at the facility's design flow; and
- smaller facilities can achieve their limits through optimization.

EPA's derivation of effluent limitations to implement these objectives, based on its best professional judgment and information reasonably available to the permit writer at the time of permit issuance, consists of three essential parts:

- First, EPA *identified* the existing aggregate load from all contributing facilities in a given state.
- Second, because Long Island Sound is already nitrogen impaired and failing to achieve applicable water quality standards,<sup>26</sup> EPA *capped* that load to avoid contributing to further impairments and fully protect existing uses.
- Third, EPA *allocated* the load according to a water quality-related consideration rationally related to achieving water quality standards in Long Island Sound and carrying out the objectives of the Act.

---

<sup>26</sup> CTDEEP, Interstate Environmental Commission, EPA, *2019 Long Island Sound Hypoxia Season Review*, available at: [http://www.iec-nynjct.org/sites/default/files/2020-07/FINAL\\_LISound-Hypoxia-2019-Combined-Report\\_april2020.pdf](http://www.iec-nynjct.org/sites/default/files/2020-07/FINAL_LISound-Hypoxia-2019-Combined-Report_april2020.pdf)



In the case of Massachusetts and New Hampshire, that consideration was facility *size*, with loads distributed based on the design flow of the POTW treatment plants. In deriving design-flow-based effluent limitations, EPA utilized the following methodology:

- EPA estimated the current maximum out-of-basin annual point source load using data for the five years prior to the year of the Draft Permit, consistent with Region 1's ordinary practice of using the most recent five years of data in the derivation of effluent limits for permits, which is in accordance with the recommendation in EPA guidance to use three to five years and, by use of the longer timeframe, is intended to more fully capture a representative data set<sup>27</sup> (see estimate of recent effluent loadings in Appendix C);
- It developed mass-based rolling annual average TN effluent limits based on design flow (consistent with 40 CFR § 122.45(b)(1)) and effluent concentrations that can be achieved by means of currently available nitrogen removal technology for all facilities and the design flow for each facility, where  $\text{effluent limit (lb/day)} = \text{Concentration (mg/L)} \times \text{Design Flow (MGD)} \times 8.34$ ;
- EPA based limits on concentrations that can typically be achieved through optimization for POTW facilities with design flow less than 10 MGD, with more aggressive optimization expected for facilities with design flow greater than 5 MGD; and,
- For the four POTW facilities with design flow greater than 10 MGD (which together comprise more than half of the total Massachusetts load to LIS), EPA based limits on concentrations achievable through optimization or upgrades.

Although EPA considered caps for individual dischargers at their current loadings, that approach was rejected because these effluent limits are subject to statutory anti-backsliding requirements of CWA § 402(o) which would prevent a limit from being increased if flows increase due to new residential or industrial development. Therefore, a facility currently discharging well below its design flow, could be put in a position of having a load limit that is below the limit of technology at its design flow. For example, if a new industrial discharger was to tie in, even if that discharger was willing to invest in readily available treatment technology, the load would preclude the facility from operating at its design flow.

Instead, EPA examined out-of-basin loads across the watershed and developed effluent limits that are achievable through optimization or readily available treatment technologies for all facilities, even if they are operating at their design flow. EPA has determined that this approach will be protective of water quality and will carefully monitor receiving water response over the permit term and adjust as necessary. EPA recognizes that Connecticut and New York have very substantially reduced their nitrogen loadings into LIS and water quality conditions have improved, although LIS is not yet fully achieving water quality standards. Additional work is being undertaken in New York and Connecticut to further reduce nitrogen loadings into LIS. It will take time to allow the impact of these reductions to be fully realized and for designated uses to be fully restored. EPA believes that this approach reasonably balances the need to hold overall TN loadings constant to avoid exacerbating ongoing nitrogen-driven environmental degradation against the inherent scientific and technical uncertainty associated with receiving water response

---

<sup>27</sup> NPDES Permit Writer's Manual, EPA-833-K-10-001, September 2010, page 5-30, available at: [https://www.epa.gov/sites/production/files/2015-09/documents/pwm\\_2010.pdf](https://www.epa.gov/sites/production/files/2015-09/documents/pwm_2010.pdf).



in a water body as complex as LIS. More stringent limitations on the out-of-basin dischargers are therefore not necessitated at this time.

Based on the approach described above, Table 3 summarizes the TN requirements implemented for this and other permits in the LIS watershed in Massachusetts since 2019. EPA is also working with the States of New Hampshire and Vermont to ensure that comparable requirements are included in NPDES permits issued in those states.

**Table 3 - Annual Average Total Nitrogen Limits for Massachusetts WWTP Dischargers to the Long Island Sound Watershed**

Facility Design Flow, $Q_D$ (MGD)	Number of Facilities	Annual Average TN Limit (lb/day)
$Q_D > 10$	4	$Q_D$ (MGD) * 5 mg/L * 8.34 + optimize
$5 < Q_D \leq 10$	5	$Q_D$ (MGD) * 8 mg/L * 8.34 + optimize
$1 \leq Q_D \leq 5$	20	$Q_D$ (MGD) * 10 mg/L * 8.34 + optimize
$0.1 \leq Q_D < 1$	17	Optimize
$Q_D < 0.1$	8	TN monitoring only

The basis for establishing mass-based effluent limits using facility design flow and 5, 8 and 10 mg/L as total nitrogen concentrations that facilities can meet by means of optimization or, for the four largest facilities, readily available treatment technology, meets the legal requirements of the CWA but was derived in order to balance the burden of treatment with the four largest facilities (currently generating more than half of the Massachusetts out-of-basin load) required to meet 5 mg/L concentration at design flow, and the remaining facilities with effluent limits that can be achieved through system optimization. In tiering the facilities, EPA considered the relative magnitude of flows from these facilities and observed that there was a significant divide between the four largest facilities and the remaining facilities (67 MGD for Springfield, 17.5 MGD for Holyoke, 17 MGD for Pittsfield and 15 MGD for Chicopee compared to the next largest at 8.6 MGD for Northhampton). The four largest facilities contribute 53% of the design flow for the out-of-basin watershed. EPA also observed that three of these facilities are on the main stem of the Connecticut River and Pittsfield is on the mainstem of the Housatonic, so there is little or no attenuation of nitrogen. All these factors, in EPA's technical judgment, warranted the further additional assurance of meeting water quality standards provided by a more stringent numeric cap in loading that may necessitate a facility upgrade, as opposed to limits achievable through optimization only. EPA also notes that the four larger facilities will be able to spread the cost of any upgrade over a much larger user base.

Thus, in arriving at its tiering determination, EPA considered a series of technical and environmental factors within its expertise, and also took into account equitable considerations. EPA acknowledges that the chosen tiers are not the only way to divide the out-of-basin TN allocations, but was not presented with any alternatives that capped the existing load based on design flow through the imposition of enforceable permit limits.



For example, EPA considered, and rejected, the option to apply a limit based on 8 mg/L effluent limit for all facilities with design flow greater than 1 MGD (at their respective design flows) because that would result in an increase in the current loading and place a greater burden on facilities that service relatively small communities. The combined design flow for the 29 MA POTW facilities with design flow greater than 1 MGD is 196 MGD. Of this combined design flow, 60%, or 117 MGD consists of the design flow for the four largest POTWs. Under the selected permitting approach, the proportion of the permitted load from the four largest facilities will be 60% of the combined permitted load for all 29 MA facilities, consistent with the proportion of design flow. If all POTWs with design flow over 1 MGD had a concentration-based limit of 8 mg/L (or a load based limit based on 8 mg/L and design flow), the proportion of the permitted load coming from the four largest facilities would increase from 60% of the total permitted load to 90%, shifting the burden of treatment significantly from larger to smaller facilities. In addition, the total permitted TN loading from those 29 facilities would increase from 8,100 lb/day under the chosen approach to 8,600 lb/day.

In addition to the effluent limits described above, EPA is also requiring all POTWs with a design flow of 0.1 MGD or greater to optimize for nitrogen removal to ensure that the aggregate 25% reduction is maintained or increased. The optimization condition in the Draft Permit requires the Permittee to evaluate alternative methods of operating their treatment plant to optimize the removal of nitrogen, and to describe previous and ongoing optimization efforts. Specifically, the Draft Permit requires an evaluation of alternative methods of operating the existing wastewater treatment facility to control total nitrogen levels, including, but not limited to, operational changes designed to enhance nitrification (seasonal and year-round), incorporation of anoxic zones, septage receiving policies and procedures, and side stream management. This evaluation is required to be completed and submitted to EPA and MassDEP within one year of the effective date of the permit, along with a description of past and ongoing optimization efforts. The permit also requires implementation of optimization methods to ensure that the facility is operated in such a way that discharges of total nitrogen are minimized. The permit requires annual reports to be submitted that summarize progress and activities related to optimizing nitrogen removal efficiencies and track trends relative to previous years.

In addition to the rolling annual average total nitrogen effluent limit and optimization requirements, the Draft Permit includes weekly monitoring and average monthly reporting requirements for total nitrogen (TN), total Kjeldahl nitrogen (TKN), and total nitrite/nitrate nitrogen ( $\text{NO}_2/\text{NO}_3$ ).

Since the design flow for the Holyoke facility is greater than 10 MGD (17.5 MGD), the annual loading TN limit calculated for the Draft Permit is:

$$17.5 \text{ MGD} * 5 \text{ mg/L} * 8.34 = 730 \text{ lb/day.}$$

The effluent limit is a rolling annual average based on the average of the current average monthly and the average monthly of the previous 11 months. The monitoring frequency in the Draft Permit is once per week throughout the year.



As noted at the beginning of this section, the maximum value for the rolling annual average nitrogen load during the review period was 668 lb/day. Given that the Holyoke WPCF is already in compliance with the proposed total nitrogen limit of 730 lb/day in the Draft Permit, EPA has determined that a compliance schedule is not appropriate, and one has not been included in the Draft Permit.

The limit is a 12-month rolling average limit calculated as the arithmetic mean of the monthly average total nitrogen load for each reporting month and the previous eleven months. Therefore, compliance will be measured beginning 12 months after the Permit issuance and will be based on the arithmetic mean of the first 12 monthly average total nitrogen loads. Compliance will continue to be measured each month following.

### **Future Nitrogen Limits**

The new nitrogen annual loading limit in this Draft Permit is intended to meet the requirements of the 2001 LIS TMDL, which was developed to address hypoxic conditions in the bottom waters of LIS. In December 2015, EPA signed a letter detailing a post-TMDL EPA nitrogen reduction strategy for waters in the LIS watershed. The strategy recognizes that more work may need to be done to reduce nitrogen levels, further improve DO conditions, and attain other related water quality standards in LIS, particularly in coastal embayments and the estuarine portions of rivers that flow into the Sound. EPA is working to establish nitrogen thresholds for Western LIS and several coastal embayments, including the mouth of the Connecticut River. Documents regarding the EPA Nitrogen Reduction Strategy are available for public review on EPA's Long Island Sound website (<http://longislandsoundstudy.net/issues-actions/water-quality/nitrogen-strategy/>). Upon completion of establishing thresholds and assessing the water quality conditions of the estuarine waters of the Connecticut River, allocations of total nitrogen loadings may be lowered if further reductions are necessary. If further reductions are needed for the Holyoke discharge, a lower water quality-based effluent limit will be added in a future permit action. If so, EPA anticipates exploring possible trading approaches for nitrogen loading in the Massachusetts portion of the Connecticut River watershed.

#### **5.1.9.2 Total Phosphorus**

While phosphorus is an essential nutrient for the growth of aquatic plants, it can stimulate rapid plant growth in freshwater ecosystems when it is present in high quantities.

The excessive growth of aquatic plants and algae within freshwater systems negatively impacts water quality and can interfere with the attainment of designated uses by: 1) increasing oxygen demand within the water body to support an increase in both plant respiration and the biological breakdown of dead organic (plant) matter;<sup>28</sup> 2) causing an unpleasant appearance and odor; 3)

---

<sup>28</sup> "Algae" includes phytoplankton (microscopic algae measured by levels of chlorophyll a), macroalgae (commonly referred to as seaweed), and other plants stimulated by nutrient over-enrichment. Excessive algal growth contributes to low levels of dissolved oxygen through increased plant respiration and decomposition of dead plant matter. Notably, during the day, algae provide oxygen to the water as a by-product of photosynthesis. At night, however, when photosynthesis ceases but plant respiration continues, dissolved oxygen levels decline. Additionally, as these algae die, they are decomposed by bacteria that consume yet more oxygen. When dissolved oxygen levels are low, aquatic organisms become stressed and die, and overall aquatic health is degraded.



interfering with navigation and recreation, for instance, by fouling engines and propellers, making waters unappealing to swimmers, and interfering with fishing lures and equipment; 4) reducing water clarity; 5) reducing the quality and availability of suitable habitat for aquatic life; and 6) producing toxic cyanobacteria during certain algal blooms. Cultural (or accelerated) eutrophication is the term used to describe dense and excessive plant growth in a water body that results from nutrients entering the system as a result of human activities. Discharges from municipal and industrial wastewater treatment plants, agriculture runoff, and stormwater are examples of human-derived (*i.e.*, anthropogenic) sources of nutrients in surface waters. See generally, *Nutrient Criteria Technical Guidance Manual – Rivers and Streams*, EPA July 2000 [EPA-822-B-00-002], Chapters 1 and 3.

The MA WQS under 314 CMR 4.05(5)(c) requires that, unless naturally occurring, surface waters must be free from nutrients that cause or contribute to impairment of the existing or designated uses, and the concentration of phosphorus may not exceed site specific criteria developed in a TMDL. Nutrients are also prohibited in concentrations that would cause or contribute to cultural eutrophication. Cultural eutrophication also results in exceedances of other nutrient-related water quality standards such as low dissolved oxygen, decreased water clarity, objectionable odors, and surface scum. The MA WQS at 314 CMR 4.05(3)(b)(1) requires that dissolved oxygen not be less than 6.0 mg/L in cold water fisheries or 5.0 mg/L in warm water fisheries. Further, the MA WQS at 4.05(3)(b)(5), (6) and (8) state that waters must be free from “floating, suspended, and settleable solids,” free from “color and turbidity in concentrations or combinations that are aesthetically objectionable...”, and have no taste and odor “in such concentrations or combinations that are aesthetically objectionable, that would impair any use assigned to this Class, or that would cause tainting or undesirable flavors in the edible portions of aquatic life.” To prevent cultural eutrophication, the MA WQS at 4.05(5)(c) states that “Any existing point source discharge containing nutrients in concentrations that would cause or contribute to cultural eutrophication, including the excessive growth of aquatic plants or algae, in any surface water shall be provided with the most appropriate treatment as determined by the Department, including, where necessary, highest and best practical treatment (HBPT) for POTWs and best available technology economically achievable (BAT) for non-POTWs, to remove such nutrients to ensure protection of existing and designated uses.” Also see Part 2.2.2 of this Fact Sheet above regarding antidegradation and existing uses which may be impacted by nutrient over-enrichment.

When permitting nutrient discharges, EPA analyzes available information from a reasonably conservative standpoint, as it regards one key function of a nutrient limit as preventative. This protective approach is appropriate because, once begun, the cycle of eutrophication can be difficult to reverse due to the tendency of nutrients to be retained in the sediments. For this reason, time is of the essence when permitting for nutrients, so EPA acts on the best information reasonably available when developing the draft permit, and does not generally delay permit issuance pending collection of new data or development of new models. This approach is also consistent with the requirement for NPDES permits to be revisited and reissued at regular intervals, with permit terms not to exceed five years.

When translating narrative phosphorus criteria into numeric values (and establishing WQBELs, if necessary), EPA looks to a wide range of materials, including nationally recommended criteria



and other relevant materials, such as EPA nutrient technical guidance and information published under Section 304(a) of the CWA, peer-reviewed scientific literature and site-specific surveys and data to determine instream targets that are protective of water quality. See 40 CFR § 122.44(d)(1)(vi)(A), (B).

EPA has produced several guidance documents, described below, that recommend a range of total ambient phosphorus concentrations that are sufficiently stringent to control cultural eutrophication and other adverse nutrient-related impacts, with 0.1 mg/L representing the upper end of this range. These guidance documents recommend protective in-stream phosphorus concentrations based on two different analytical approaches. An effects-based approach provides a threshold value above which adverse effects (*i.e.*, water quality impairments) are likely to occur. This approach applies empirical observations of a causal variable (*i.e.*, phosphorus) and a response variable (*i.e.*, chlorophyll-a as a measure of algal biomass) associated with designated use impairments. Alternatively, reference-based values are statistically derived from a comparison within a population of rivers in the same ecoregion class. They are a quantitative set of river characteristics (physical, chemical and biological) that represent conditions in waters in that ecoregion that are minimally impacted by human activities (*i.e.*, reference conditions), and thus by definition representative of water without cultural eutrophication. Dischargers in Massachusetts and New Hampshire are located within either Ecoregion VIII, Nutrient-Poor, Largely Glaciated Upper Midwest and Northeast or Ecoregion XIV, Eastern Coastal Plains. The recommended total phosphorus criteria for these ecoregions are 10 µg/L and 31.25 µg/L, respectively. While reference conditions reflect in-stream phosphorus concentrations that are sufficiently low to meet the requirements necessary to support designated uses, they may also represent levels of water quality beyond what is necessary to support such uses.

EPA follows an effects-based approach. EPA's 1986 *Quality Criteria for Water* (the "Gold Book") recommends maximum threshold concentrations that are designed to prevent or control adverse nutrient-related impacts from occurring. Specifically, the Gold Book recommends in-stream phosphorus concentrations of no greater than 0.1 mg/L for any stream not discharging directly to lakes or impoundments 0.05 mg/L in any stream entering a lake or reservoir, and 0.025 mg/L within a lake or reservoir. In this case, EPA is applying a target concentration of 0.1 mg/L because the receiving water is a stream/river not discharging directly to a lake or impoundment.

As the Gold Book notes, there are natural conditions of a water body that can result in either increased or reduced eutrophic response to phosphorus inputs; in some waters more stringent phosphorus reductions may be needed, while in some others a higher total phosphorus threshold could be assimilated without inducing a eutrophic response. In this case, EPA is not aware of any site-specific factors relevant to the receiving water that would result in it being unusually more or less susceptible to phosphorus loading.

The Facility's 2016 Permit did not include a phosphorus limit. However, sampling data was collected and submitted with the 2021 permit application that listed a phosphorus maximum daily discharge of 0.72 mg/L.



Sampling data from 2008<sup>29</sup>, summarized in Table 4, reported five summer in-stream phosphorus concentrations collected at Station W1784 located approximately 14 miles upstream of the Holyoke WPCF.

**Table 4: Instream total phosphorus concentrations (mg/L)**

	W-1784
5/06/2008	0.015
6/03/2008	0.014
7/01/2008	0.021
7/29/2008	0.035
9/09/2008	0.024

In determining whether the discharge has the reasonable potential to cause or contribute to excursions above the instream water quality criteria for phosphorus, EPA used the mass balance equation presented in Appendix B to project the phosphorus concentration downstream of the discharge. If there is reasonable potential, this mass balance equation is also used to determine the limit that is required in the permit.

Based on the phosphorus criterion described above, the ambient data presented above, the upstream 7Q10 flow, and the design flow of the Facility, Appendix B presents the details of the mass balance equation, the determination of whether there is reasonable potential to cause or contribute to an excursion of WQS and, if necessary, the limits proposed in the Draft Permit WQS. As shown, it was determined that the downstream concentration is 30 µg/L which does not exceed the instream target of 100 µg/L. Therefore, there is no reasonable potential to cause or contribute to an excursion of WQS, so the Draft Permit does not propose a phosphorus limit.

Given that the downstream concentration is well below the target and there is significant available dilution, EPA is not requiring a phosphorus monitoring requirement and notes that effluent monitoring will be required in the next permit application for EPA to use in the next permit reissuance.

### 5.1.10 Metals

#### 5.1.10.1 Applicable Metals Criteria

State water quality criteria for cadmium, copper, lead, nickel and zinc are established in terms of dissolved metals. However, many inorganic components of domestic wastewater, including metals, are in particulate form, and differences in the chemical composition between the effluent and the receiving water affects the partitioning of metals between the particulate and dissolved fractions as the effluent mixes with the receiving water, often resulting in a transition from the particulate to dissolved form (*The Metals Translator: Guidance for Calculating a Total Recoverable Permit Limit from a Dissolved Criterion* (USEPA 1996 [EPA-823-B96-007])). Consequently, quantifying only the dissolved fraction of metals in the effluent prior to discharge may not accurately reflect the biologically-available portion of metals in the receiving water.

<sup>29</sup> <https://www.mass.gov/guides/water-quality-monitoring-program-data>

Regulations at 40 CFR § 122.45(c) require, with limited exceptions, that effluent limits for metals in NPDES permits be expressed as total recoverable metals.

The criteria for cadmium, copper, lead, nickel and zinc are hardness-dependent using the equations found at 314 CMR 4.06 Appendix C. The estimated hardness of the Connecticut River downstream of the treatment plant is calculated using the critical low flow (7Q10), the design flow of the treatment plant, and the median hardness for both the receiving water upstream of the discharge and the treatment plant effluent. Effluent and receiving water data are presented in Appendix A. Using the mass balance equation discussed in Appendix B, the resulting downstream hardness is 34.8 mg/L and the corresponding criteria are also presented in Appendix B.

Based on the 2022 MA WQS update, the aluminum criteria are dependent on hardness, pH and dissolved organic carbon (DOC) as described at 314 CMR 4.06 Table 29. Given that there is limited site-specific data available, the watershed default values are used in the analysis below.

#### **5.1.10.2 Reasonable Potential Analysis and Limit Derivation**

To determine whether the effluent has the reasonable potential to cause or contribute to an exceedance above the in-stream water quality criteria for each metal, EPA uses the mass balance equation presented in Appendix B to project the concentration downstream of the discharge and, if applicable, to determine the limit required in the permit.

For any metal with an existing limit in the 2016 Permit, the same mass balance equation is used to determine if a more stringent limit would be required to continue to meet WQS under current conditions. The limit is determined to be the more stringent of either (1) the existing limit or (2) the calculated effluent concentration ( $C_e$ ) allowable to meet WQS based on current conditions. The 2016 Permit includes a monthly average aluminum limit of 87 ug/L, a monthly average copper limit of 3.5 ug/L, a daily maximum copper limit of 4.7 ug/L, and a monthly average lead limit of 0.73 ug/L. These limits were subject to a compliance schedule and became effective on January 1, 2022.

Related to these limits established in the 2016 Permit, the City of Holyoke completed an Ambient Connecticut River Study dated November 2020 and submitted it to EPA and MassDEP on December 30, 2020. This study included clean sampling of ambient conditions for aluminum, copper and lead in the Connecticut River upstream of Holyoke's discharge. The ambient data were collected in June, July and August of 2020. The study compares these 2020 results to the 2010 through 2014 ambient data that were collected from Holyoke's WET tests and were used in the development of the 2016 Permit. For each metal, the results were significantly lower than the prior years, and the report indicates that the previous sampling may have been contaminated due to proximity of the previous sampling location to moored boats, boat traffic and boat docks. The new sampling location is approximately one mile farther downstream of the old sampling location at a point in the river described as being less impacted by these types of contamination.

In the development of the 2023 Draft Permit, EPA is using all available data during the review period (*i.e.*, October 2017 to September 2022) to characterize the ambient condition. This includes ambient WET data upstream of the discharge during these recent years as well as the



result of this ambient study. EPA notes that it is unclear whether the more recent WET sampling was taken at the old or new sampling location described above. Therefore, EPA has maintained the more recent WET data in current analysis. The ambient data collected through the WET tests is presented in Appendix A of this Fact Sheet and results in a median background concentration of 79 ug/L for aluminum, non-detect for copper, and non-detect for lead. The inclusion of the 2020 samples from this report slightly reduced the median aluminum concentration of 68 ug/L and has no impact on the copper and lead median background concentrations of non-detect.

Based on the information described above, the results of this analysis for each metal are presented in Appendix B.

As shown, there is no reasonable potential to cause or contribute to an excursion of WQS for cadmium, nickel, and zinc, so the Draft Permit does not propose any limits for these metals. Additionally, there is no need for more stringent aluminum, copper, or lead limits to continue to protect WQS. However, as part of the submission described above, the City also requested the EPA reevaluate these three metals limits for the potential to backslide based on this more recent data. In response to this request, EPA has reevaluated these limits below.

In conducting this analysis, EPA considered the CWA's anti-backsliding provisions found at CWA § 402(o) and 303(d)(4). One provision, found at CWA § 303(d)(4)(B), specifies the following:

“For waters identified [on a state impaired waters list under section 303(d)(1)(A)] where the quality of such waters equals or exceeds levels necessary to protect the designated use for such waters or otherwise required by applicable water quality standards, any effluent limitation based on a total maximum daily load or other waste load allocation established under this section, or any other permitting standard may be revised only if such revision is subject to and consistent with the antidegradation policy established under this section.”

For aluminum, copper and lead, the receiving water exceeds the levels necessary to achieve applicable water quality standards. In other words, the receiving water is not impaired for these metals and the ambient levels (shown in Appendix B) are below the applicable water quality criteria. Therefore, this provision applies to these parameters and may allow the limits to become less stringent but only to the extent that is consistent with antidegradation and continues to protect water quality standards.

Given that an antidegradation study has not been conducted for these metals from this facility, the reference to antidegradation in the provision above prevents EPA from allowing any new or increased discharge of these pollutants at this time. However, EPA notes that adjusting these limits to the current actual load (if higher than the permitted load) would not be a new or increased discharge of pollutants and would, therefore, be consistent with antidegradation at this time. EPA has conferred with MassDEP and they agree that this would be in accordance with Massachusetts' antidegradation policy given that such revised limits would not allow any increase in the actual load from current levels and would continue to fully protect water quality standards.

Therefore, EPA compared current levels to the existing permit limits to determine if any of these limits could become less stringent. EPA calculated the 95<sup>th</sup> percentile of the effluent data during the 5-year review period that was presented in Appendix A of the Fact Sheet. The results of this analysis are summarized in the table below.

Metal	Current Limit (µg/L)	Effluent 95 <sup>th</sup> (µg/L)	Achieving limit?
Aluminum (monthly average)	87	63	Yes
Copper (daily maximum)	4.7	25.1	No
Copper (monthly average)	3.5	21.6	No
Lead (monthly average)	0.73	1.6	No

As shown, the facility is not achieving the applicable copper and lead limits and may qualify for less stringent copper and lead limits. However, they are achieving the applicable aluminum limit so EPA may not increase their aluminum limit without triggering the need for an antidegradation review, because increasing the aluminum limit would constitute an increase in the actual load and thus would be considered an increased discharge.

Therefore, EPA conducted a further evaluation for copper and lead to determine if a less stringent limit (up to their current level) would comply with WQS for these metals under updated critical conditions. EPA conducted a mass-balance evaluation using the equation presented in Appendix B of the Fact Sheet. The results of these calculations are presented below (see Appendix B of the Fact Sheet for the full equation and definition of terms).

Metal	Q <sub>s</sub> (MGD)	C <sub>s</sub> (µg/L, median)	Q <sub>c</sub> (MGD)	C <sub>c</sub> (µg/L, 95 <sup>th</sup> )	Q <sub>d</sub> (MGD)	C <sub>d</sub> (µg/L)	Criteria (µg/L)
Copper (daily maximum)	1274.56	0	17.5	<b>25.1</b>	1292.06	0.34	5.2
Copper (monthly average)	1274.56	0	17.5	<b>21.6</b>	1292.06	0.29	3.8
Lead (monthly average)	1274.56	0	17.5	<b>1.6</b>	1292.06	0.021	0.8

As shown, the 95<sup>th</sup> percentile of the effluent data (C<sub>c</sub>) for each metal results in a downstream concentration (C<sub>d</sub>) significantly below the relevant criterion. Therefore, EPA has determined that the 95<sup>th</sup> percentile values (shown in bold above in the column labeled C<sub>c</sub>) are protective of WQS under updated critical conditions. Given that these values protect WQS and are consistent with antidegradation, they are proposed as the revised limits in the Draft Permit.

Effluent and ambient monitoring for each of these metals will continue to be required in the WET tests.

#### 5.1.11 Whole Effluent Toxicity

CWA §§ 402(a)(2) and 308(a) provide EPA and States with the authority to require toxicity testing. Section 308 specifically describes biological monitoring methods as techniques that may be used to carry out objectives of the CWA. Whole effluent toxicity (WET) testing is conducted



to ensure that the additivity, antagonism, synergism and persistence of the pollutants in the discharge do not cause toxicity, even when the pollutants are present at low concentrations in the effluent. The inclusion of WET requirements in the Draft Permit will assure that the Facility does not discharge combinations of pollutants into the receiving water in amounts that would be toxic to aquatic life or human health.

In addition, under CWA § 301(b)(1)(C), discharges are subject to effluent limitations based on WQSs. Under CWA §§ 301, 303 and 402, EPA and the States may establish toxicity-based limitations to implement the narrative water quality criteria calling for “no toxics in toxic amounts”. *See also* 40 CFR § 122.44(d)(1). The Massachusetts WQSs at 314 CMR 4.05(5)(e) state, “All surface waters shall be free from pollutants in concentrations or combinations that are toxic to humans, aquatic life or wildlife.”

National studies conducted by EPA have demonstrated that domestic sources, as well as industrial sources, contribute toxic constituents to POTWs. These constituents include metals, chlorinated solvents, aromatic hydrocarbons and others. Some of these constituents may cause synergistic effects, even if they are present in low concentrations. Because of the source variability and contribution of toxic constituents in domestic and industrial sources, reasonable potential may exist for this discharge to cause or contribute to an exceedance of the “no toxics in toxic amounts” narrative water quality standard.

In accordance with current EPA guidance and State policy<sup>30</sup>, whole effluent chronic effects are regulated by limiting the highest measured continuous concentration of an effluent that causes no observed chronic effect on a representative standard test organism, known as the chronic No Observed Effect Concentration (C-NOEC). Whole effluent acute effects are regulated by limiting the concentration that is lethal to 50% of the test organisms, known as the LC<sub>50</sub>. This policy recommends that permits for discharges having a dilution factor greater than 20 and less than 100 require acute toxicity testing four times per year for two species. Additionally, for discharges with dilution factors greater than 20 and less than 100, the LC<sub>50</sub> limit should be greater than or equal to 100%.

The acute WET limit in the 2016 Permit is LC<sub>50</sub> greater than or equal to 100%, using the daphnid (*Ceriodaphnia dubia*) as the test species. EPA notes the Facility had previously received a reduction from the 2 monitoring species testing requirement to only the daphnid. The DMR data during the review period shows that there has been one exceedance of the WET limit (Appendix A).

Based on the potential for toxicity from domestic and industrial contributions, the state narrative water quality criterion, the dilution factor of 74, and in accordance with EPA national and regional policy and 40 CFR § 122.44(d), the Draft Permit continues the effluent limits from the 2016 Permit including the test organism and the quarterly testing frequency. Toxicity testing must be performed in accordance with the updated EPA Region 1 WET test procedures and

---

<sup>30</sup> *Massachusetts Water Quality Standards Implementation Policy for the Control of Toxic Pollutants in Surface Waters*. February 23, 1990.

protocols specified in Attachments A, *Freshwater Acute Toxicity Test Procedure and Protocol* (February 2011) of the Draft Permit.

In addition, EPA's 2018 *National Recommended Water Quality Criteria* for aluminum are calculated based on water chemistry parameters that include dissolved organic carbon (DOC), hardness and pH. Since aluminum monitoring is required as part of each WET test, an accompanying new testing and reporting requirement for DOC, in conjunction with each WET test, is warranted in order to assess potential impacts of aluminum in the receiving water.

#### 5.1.12 Per- and polyfluoroalkyl substances (PFAS)

As explained at <https://www.epa.gov/pfas>, PFAS are a group of synthetic chemicals that have been in use since the 1940s. PFAS are found in a wide array of consumer and industrial products. PFAS manufacturing and processing facilities, facilities using PFAS in production of other products, airports, and military installations can be contributors of PFAS releases into the air, soil, and water. Due to their widespread use and persistence in the environment, most people in the United States have been exposed to PFAS. Exposure to some PFAS above certain levels may increase risk of adverse health effects.<sup>31</sup> EPA is collecting information to evaluate the potential impacts that discharges of PFAS from wastewater treatment plants may have on downstream drinking water, recreational and aquatic life uses.

##### Background Information

On October 20, 2020, MassDEP published final regulations establishing a drinking water standard, or a Maximum Contaminant Level (MCL) of 20 parts per trillion (ppt) for the sum of the following six PFAS. See 310 CMR 22.00.

- Perfluorohexanesulfonic acid (PFHxS)
- Perfluoroheptanoic acid (PFHpA)
- Perfluorononanoic acid (PFNA)
- Perfluorooctanesulfonic acid (PFOS)
- Perfluorooctanoic acid (PFOA)
- Perfluorodecanoic acid (PFDA)

Although the Massachusetts water quality standards do not include numeric criteria for PFAS, the Massachusetts narrative criterion for toxic substances at 314 CMR 4.05(5)(e) states:

All surface waters shall be free from pollutants in concentrations or combinations that are toxic to humans, aquatic life or wildlife.

The narrative criterion is further elaborated at 314 CMR 4.05(5)(e)2 which states:

---

<sup>31</sup> EPA, *EPA's Per- and Polyfluoroalkyl Substances (PFAS) Action Plan*, EPA 823R18004, February 2019. Available at: [https://www.epa.gov/sites/production/files/2019-02/documents/pfas\\_action\\_plan\\_021319\\_508compliant\\_1.pdf](https://www.epa.gov/sites/production/files/2019-02/documents/pfas_action_plan_021319_508compliant_1.pdf)



Human Health Risk Levels. Where EPA has not set human health risk levels for a toxic pollutant, the human health-based regulation of the toxic pollutant shall be in accordance with guidance issued by the Department of Environmental Protection's Office of Research and Standards. The Department's goal is to prevent all adverse health effects which may result from the ingestion, inhalation or dermal absorption of toxins attributable to waters during their reasonable use as designated in 314 CMR 4.00.

Since PFAS chemicals are persistent in the environment and may lead to adverse human health and environmental effects, and consistent with recent EPA guidance,<sup>32</sup> the Draft Permit requires that the Facility conduct quarterly influent, effluent and sludge sampling for PFAS chemicals and annual sampling of certain industrial users. The quarterly monitoring shall begin the first full calendar quarter following six months after the effective date of the permit. The annual monitoring for certain industrial users shall begin the first full calendar year following the effective date of the permit.

The purpose of this monitoring and reporting requirement is to better understand potential discharges of PFAS from this facility and to inform future permitting decisions, including the potential development of water quality-based effluent limits on a facility specific basis. EPA is authorized to require this monitoring and reporting by CWA § 308(a), which states:

“SEC. 308. (a) Whenever required to carry out the objective of this Act, including but not limited to (1) developing or assisting in the development of any effluent limitation, or other limitation, prohibition, or effluent standard, pretreatment standard, or standard of performance under this Act; (2) determining whether any person is in violation of any such effluent limitation, or other limitation, prohibition or effluent standard, pretreatment standard, or standard of performance; (3) any requirement established under this section; or (4) carrying out sections 305, 311, 402, 404 (relating to State permit programs), 405, and 504 of this Act—

(A) the Administrator shall require the owner or operator of any point source to (i) establish and maintain such records, (ii) make such reports, (iii) install, use, and maintain such monitoring equipment or methods (including where appropriate, biological monitoring methods), (iv) sample such effluents (in accordance with such methods, at such locations, at such intervals, and in such manner as the Administrator shall prescribe), and (v) provide such other information as he may reasonably require;”.

(See 40 CFR § 122.21(e)(3)(ii) and 40 CFR § 122.44(i)(1)(iv)(B)).

In the absence of a final 40 CFR § 136 method for measuring PFAS in wastewater and sludge, the Draft Permit requires the use of the single lab validated Draft Method 1633 or, when it becomes available, the multi-lab validated Method 1633. Monitoring should include each of the

---

<sup>32</sup> Radhika Fox, Assistant Administrator, EPA to Water Division Directors, EPA Regions 1-10, December 6, 2022, Subject: “Addressing PFAS Discharges in NPDES Permits and Through the Pretreatment Program and Monitoring Programs.” Available at: [https://www.epa.gov/system/files/documents/2022-12/NPDES\\_PFAS\\_State%20Memo\\_December\\_2022.pdf](https://www.epa.gov/system/files/documents/2022-12/NPDES_PFAS_State%20Memo_December_2022.pdf)

40 PFAS parameters detectable by Method 1633 (see Draft Permit Attachment B for list of PFAS parameters) and the monitoring frequency is quarterly. All PFAS results must be reported on DMRs (see 40 CFR § 122.41)(l)(4)(i)).

This approach is consistent with 40 CFR § 122.44(i)(1)(iv)(B) which states that in the case of pollutants or pollutant parameters for which there are no approved methods under 40 CFR Part 136 or methods are not otherwise required under 40 CFR chapter I, subchapter N or O, monitoring shall be conducted according to a test procedure specified in the permit for such pollutants or pollutant parameters.

Additionally, EPA has recently published Method 1621 to screen for organofluorines in wastewater. Organofluorines (molecules with a carbon-fluorine bond) are rarely naturally occurring and the most common source of organofluorines are PFAS and non-PFAS fluorinated compounds such as pesticides and pharmaceuticals. The Permittee shall monitor Adsorbable Organic Fluorine using Method 1621 once per quarter concurrently with PFAS monitoring to screen for a broader range of these types of emerging contaminants. This requirement also takes effect the first full calendar quarter following six months after the effective date of the permit.

All monitoring results may be used by EPA in the next permit reissuance to ensure the discharge continues to protect designated uses.

## **5.2 Industrial Pretreatment Program**

The Permittee is required to administer a pretreatment program under 40 CFR Part 403. *See also* CWA § 307; 40 CFR § 122.44(j). The Permittee's pretreatment program received EPA approval on July 22, 1985 and, as a result, appropriate pretreatment program requirements were incorporated into the previous permit, which were consistent with that approval and federal pretreatment regulations in effect when the permit was issued.

The Federal Pretreatment Regulations in 40 CFR part 403 were amended in October 1988, in July 1990, and again in October 2005. Those amendments established new requirements for implementation of pretreatment programs. Upon reissuance of this NPDES permit, the permittee is obligated to modify its pretreatment program to be consistent with current Federal Regulations. The activities that the permittee must address include, but are not limited to, the following: 1) develop and enforce EPA-approved specific effluent limits (technically-based local limits); 2) revise the local sewer-use ordinance or regulation, as appropriate, to be consistent with Federal Regulations; 3) develop an enforcement response plan; 4) implement a slug control evaluation program; 5) track significant noncompliance for industrial users; and 6) establish a definition of and track significant industrial users.

These requirements are necessary to ensure continued compliance with the POTW's NPDES permit and its sludge use or disposal practices.

In addition to the requirements described above, the Draft Permit requires the Permittee to submit to EPA in writing, within 180 days of the permit's effective date, a description of proposed changes to permittee's pretreatment program deemed necessary to assure conformity



with current federal pretreatment regulations. These requirements are included in the Draft Permit to ensure that the pretreatment program is consistent and up-to-date with all pretreatment requirements in effect. Lastly, the Permittee must continue to submit, annually by **March 1st**, a pretreatment report detailing the activities of the program for the twelve-month period ending 60 days prior to the due date.

### **5.3 Sludge Conditions**

Section 405(d) of the Clean Water Act requires that EPA develop technical standards regarding the use and disposal of sewage sludge. On February 19, 1993, EPA promulgated technical standards. These standards are required to be implemented through permits. The conditions in the permit satisfy this requirement.

### **5.4 Infiltration/Inflow (I/I)**

Infiltration is groundwater that enters the collection system through physical defects such as cracked pipes, or deteriorated joints. Inflow is extraneous flow entering the collection system through point sources such as roof leaders, yard and area drains, sump pumps, manhole covers, tide gates, and cross connections from storm water systems. Significant I/I in a collection system may displace sanitary flow, reducing the capacity and the efficiency of the treatment works and may cause bypasses to secondary treatment. It greatly increases the potential for sanitary sewer overflows (SSOs) in separate systems, and combined sewer overflows (CSOs) in combined systems.

The Draft Permit includes a requirement for the permittee to control infiltration and inflow (I/I) within the sewer collections system it owns and operates. The permittee shall develop an I/I removal program commensurate with the severity of I/I in the collection system. This program may be scaled down in sections of the collection system that have minimal I/I.

### **5.5 Operation and Maintenance**

The standard permit conditions for 'Proper Operation and Maintenance', found at 40 CFR § 122.41(e), require the proper operation and maintenance of permitted wastewater systems and related facilities to achieve compliance with permit conditions. The requirements at 40 CFR § 122.41(d) impose a 'duty to mitigate,' which requires the permittee to "take all reasonable steps to minimize or prevent any discharge in violation of the permit that has a reasonable likelihood of adversely affecting human health or the environment.

General requirements for proper operation and maintenance, and mitigation have been included in Part II of the permit (See Part II.B.). Specific permit conditions have also been included in Part I.C.1. & 2. of the Draft Permit. These requirements are included to minimize the occurrence of permit exceedances and unauthorized discharges that have a reasonable likelihood of adversely affecting human health or the environment.

### **5.5.1 Operation and Maintenance of the Wastewater Treatment Facility**

The Draft Permit, in Part I.C.1. requires the Permittee to address major storm and flood events as part of their wastewater treatment facility operation and maintenance planning. The major storm and flood plan addresses risks to the facility and its infrastructure from extreme weather events<sup>33</sup>. The Plan should address resiliency of the facility, evaluate<sup>34</sup>, and implement control measures to minimize<sup>35</sup> the impacts of major storm and flood events at the wastewater treatment facility. The plan's requirements include: an asset vulnerability evaluation, systemic vulnerability evaluation, and alternative evaluation. These requirements are included to ensure the proper operation and maintenance of the wastewater treatment facility and to minimize the impacts of major storm and flood events.

These requirements are new. EPA has determined that these additional requirements are necessary to ensure the proper operation and maintenance of the wastewater treatment facility and has included schedules in the Draft Permit for completing these requirements.

### **5.5.2 Operation and Maintenance of the Sewer System**

The Draft Permit, in Part I.C.2. requires the Permittee to address major storm and flood events as part of their sewer system operation and maintenance planning. The major storm and flood plan should address risks to the sewer system and its infrastructure from extreme weather events.<sup>36</sup> The Plan should address resiliency of the system, evaluate, and implement control measures to minimize the impacts of major storm and flood events throughout the sewer system. The requirements include; an asset vulnerability evaluation, systemic vulnerability evaluation, and

---

<sup>33</sup> "Major storm and flood events" refer to instances resulting from major storms such as hurricanes, extreme/heavy precipitation events, and pluvial, fluvial, and flash flood events such as high-water events, storm surge, and high-tide flooding. "Extreme/heavy precipitation" refers to instances during which the amount of rain or snow experienced in a location substantially exceeds what is normal. What constitutes a period of heavy precipitation varies according to location and season. "Extreme/heavy precipitation" does not necessarily mean the total amount of precipitation at a location has increased-just that precipitation is occurring in more intense or more frequent events.

<sup>34</sup> To determine the vulnerabilities to the facilities from major storm and flood events, you must conduct the evaluation using, at a minimum, the worst-case data relating to changes in precipitation, sea level rise, extreme weather events, coastal flooding, inland flooding, sewer flow and inflow and infiltration and relevant to the facilities from: 1) the data generated by the 13 federal agencies that conduct or use research on global change that contributed to the latest National Climate Assessment produced by the U.S. Global Change Research Program (USGCRP); 2) climate data generated by the Commonwealth of Massachusetts; and 3) resiliency planning completed by the municipality in which a given facility is located (i.e., City of Boston) and incorporate the results of the evaluation in a manner that demonstrates that the control measures taken are precautionary and sufficiently protective. Evaluation must be completed by a qualified person on a five-year basis considering 1) historical observations from all years the Permittee has operated the facility prior to this permit's term; 2) the 25 to 100 years forward-looking from the review year to assess impacts that are likely to occur.

<sup>35</sup> For the purposes of this provision, the term "minimize" means to reduce and/or eliminate to the extent achievable the impacts to the facilities.

<sup>36</sup> "Major storm and flood events" refer to instances resulting from major storms such as hurricanes, extreme/heavy precipitation events, and pluvial, fluvial, and flash flood events such as high-water events, storm surge, and high-tide flooding. "Extreme/heavy precipitation" refers to instances during which the amount of rain or snow experienced in a location substantially exceeds what is normal. What constitutes a period of heavy precipitation varies according to location and season. "Extreme/heavy precipitation" does not necessarily mean the total amount of precipitation at a location has increased-just that precipitation is occurring in more intense or more frequent events.



alternative evaluation. These requirements are included to ensure the proper operation and maintenance of the sewer system and to minimize the impacts of major storm and flood events. Several of these requirements are new. EPA has determined that these additional requirements are necessary to ensure the proper operation and maintenance of the wastewater treatment facility and has included schedules in the Draft Permit for completing these requirements.

## 5.6 Combined Sewer Overflows

### Description and History

The wastewater collection system that conveys flow to the Holyoke Water Pollution Control Facility consists of approximately two-thirds combined sewers that convey both sanitary sewage and stormwater runoff during rain events. During wet weather, the combined flow exceeds the capacity of the interceptor sewers and the wastewater treatment plant, and a portion of the combined flow is discharged to the Connecticut River through combined sewer overflows (CSOs). One of the CSO outfalls (Front St/Appleton St. #16) discharges via the Holyoke Canal System to the Connecticut River; this CSO is considered a discharge to the Connecticut River. CSOs have been identified as a significant source of pollution to the Connecticut River. *See 2003 Connecticut River Water Quality Assessment Report.*

The City currently has ten active CSO outfalls that discharge to the Connecticut River. *See Figure 2.* Appendix A includes CSO discharge data for October 2017 – September 2022. One of the CSO outfalls, the Berkshire Street CSO Outfall 009, is the largest discharge and is the location of the Berkshire Street Treatment Facility. The facility provides screening and disinfection of up to 103 MGD of CSO flows as well as a small amount of storage for flows that can be pumped back to the WPCF for treatment.

Eleven CSO outfalls were included in the Holyoke WPCF's 2016 Permit (since that time CSO Outfall 011 has been closed). On July 25, 2016, the U.S. Environmental Protection Agency (EPA) issued an administrative order (CWA-01-16-012) addressing the submittal of an updated Long-Term Control Plan (LTCP) and removal of the Jackson Street CSO (which was removed in 2022). An updated LTCP was submitted in December 2019.

### Regulatory Framework

CSOs are point sources subject to NPDES permit requirements for both water-quality based and technology-based requirements but are not subject to the secondary treatment regulations applicable to publicly owned treatment works in accordance with 40 CFR §133.103(a). Section 301(b)(1)(C) of the Clean Water Act of 1977 mandated compliance with water quality standards by July 1, 1977. Technology-based permit limits must be established for best conventional pollutant control technology (BCT) and best available technology economically achievable (BAT) based on best professional judgment (BPJ) in accordance with Section 301(b) and Section 402(a) of the Water Quality Act Amendments of 1987 (WQA). The framework for compliance with Clean Water Act requirements for CSOs is set forth in EPA's National CSO Control Policy, 59 Fed. Reg. 18688 (1994). It sets the following objectives:

- 1) To ensure that if the CSO discharges occur, they are only as a result of wet weather;
  - 2) To bring all wet weather CSO discharge points into compliance with the technology-based requirements of the CWA and applicable federal and state water quality standards;
- and
- 3) To minimize water quality, aquatic biota, and human health impacts from wet weather flows.

Among the elements established to achieve these objectives, the CSO Policy set forth the minimum BCT/BAT controls (i.e., technology-based limits) that represent the BPJ of the Agency on a consistent, national basis. These are the Nine Minimum Controls (“NMCs”) defined in the CSO Policy and set forth in Part I.H. of the Draft Permit: 1) proper operation and regular maintenance programs for the sewer system and the combined sewer overflows; 2) maximum use of the collection system for storage; 3) review and modification of the pretreatment programs to assure CSO impacts are minimized; 4) maximization of flow to the POTW for treatment; 5) prohibition of dry weather overflows; 6) control of solid and floatable materials in CSOs; 7) pollution prevention programs which focus on contaminant reduction activities; 8) public notification to ensure that the public receives adequate notification of CSO occurrences and CSO impacts; and 9) monitoring to effectively characterize CSO impacts and the efficacy of CSO controls.

To reflect advances in technologies, the Draft Permit includes more specific public notification implementation level requirements to ensure that the public receives adequate notification of CSO occurrences and CSO impacts. The Draft Permit requires the permittee to develop a public notification plan to fulfill NMC #8. As part of this plan, notification shall be provided electronically to any interested party, and a posting made on the permittee’s website, of a probable CSO activation within two (2) hours of the initiation of any CSO discharge(s). Subsequently, within 24 hours of the termination of any CSO discharges(s), the permittee shall provide follow-up information on their website and in a follow-up electronic communication to any interested party. EPA invites comment on this new requirement during the public comment period with a goal of a workable public notification plan.

In January 2021, Massachusetts enacted a law, *An Act Promoting Awareness of Sewage in Public Waters*. The law requires that the public be aware when untreated sewage flows into Massachusetts waters. This includes CSO outfall discharges and certain Sanitary Sewer Overflows (SSOs). Per 314 CMR 16.06(1), a Permittee with a combined sewer system shall submit to MassDEP for review and approval a preliminary CSO Notification Plan. Instruction for developing a preliminary plan can be found at: <https://www.mass.gov/doc/instructions-combined-sewer-overflow-public-notification-plan/download>. A final CSO notification plan shall be submitted to MassDEP for review and approval by January 12, 2023.

The Permittee submitted documentation addressing its continuing efforts implementing the Nine Minimum Controls in the recent CSO Annual Report dated 4/22/2022.



The CSO Policy also recommended that each community that has a combined sewer system develop and implement a long-term CSO control plan (“LTCP”) that will ultimately result in compliance with the requirements of the CWA. The Permittee submitted a Draft LTCP on May 12, 2000 and an updated LTCP in December 2019.

#### Additional Requirements

The Permittee’s operation of the Berkshire Street CSO Treatment Facility is subject to additional effluent limitations and monitoring requirements. The CSO Treatment Facility represents an enhancement of the Nine Minimum Controls, allowing greater use of the system for storage (control #2) and return of the flow to the POTW for treatment (control #3), removal of floatables and some solid materials (control #6), and reduction of bacteria through disinfection (and the related control of chlorine discharges) (control # 7). The facility was designed to provide screening and chlorine disinfection with dechlorination in order to meet water quality standards for bacteria and to avoid toxic discharges of chlorine compounds. Monitoring results from the CSO Facility from the period October 2017 to September 2022 are shown in Appendix A.

In determining effluent limits for CSO treatment facilities, EPA applies BCT/BAT effluent limitations using its best professional judgment (BPJ), considering the factors identified in 40 CFR § 125.3(d), including the cost and benefits of the facility (analyzed in connection with the development of the city’s CSO control plan); the age of the facility, the design parameters that the facility was engineered to meet; and the performance of the facility. In this case the facility was designed to meet interim limits for bacteria (fecal coliform 200 cfu/100 ml average monthly) and total residual chlorine (0.74 mg/L average monthly). The 2016 Permit superseded the interim limits with water quality-based limits for bacteria (*E. coli* 126 colonies/100 ml and 409 colonies/100 ml) and TRC (0.24 mg/L daily maximum).

For bacteria, the indicator bacteria was changed in the 2016 Permit from fecal coliform to *E. Coli*. Updated Massachusetts WQS with respect to bacteria were approved by EPA on March 31, 2022. Permit limits based on the new 2022 WQS for *E. Coli* would be 126 colonies/100 ml as a geometric mean (same as the current limit) and 410 colonies/100 ml as a maximum daily value (slightly less stringent than the current limit of 409 colonies/100 ml). Given that the more stringent limit of 409 colonies/100 ml (compared to 410 colonies/100 ml as described above) is already effective under the 2016 Permit, it will be carried forward based on anti-backsliding regulations discussed in Section 2.6 above.

The TRC permit limits are based on the instream chlorine criteria defined in *National Recommended Water Quality Criteria: 2002*, EPA 822R-02-047 (November 2002), as adopted by the MassDEP into the state water quality standards at 314 CMR 4.05(5)(e). These freshwater instream criteria for chlorine are 11 µg/L (chronic) and 19 µg/L (acute). Because the upstream chlorine is assumed to be zero in this case, the water quality-based chlorine limits are calculated as the criteria times the dilution factor. While this is a wet weather facility (and might therefore be expected to only discharge under higher receiving water flows), facility records indicate frequent discharges in connection with high intensity summer storms when river flows are relatively low, therefore 7Q10 conditions are appropriate for determining CSO permit limits under critical conditions. The dilution factor and limits are calculated as follows:

$$DF = (Q_s + Q_d)/Q_d$$

Where:

$Q_s = 7Q_{10}$  in million gallons per day (MGD) = 1,275 MGD [1,973 cfs]

$Q_d = \text{CSO Facility Design flow in MGD} = 103 \text{ MGD}$

Therefore:

$$DF = (1,275 \text{ MGD} + 103 \text{ MGD}) / 103 \text{ MGD} = 13$$

Chronic criteria \* dilution factor \* 0.001 (conversion factor  $\mu\text{g/l}$  to  $\text{mg/l}$ ) = Chronic limit  
 $11 \mu\text{g/L} * 13 * 0.001 = 0.14 \text{ mg/L}$  (average monthly)

Acute criteria \* dilution factor \* 0.001 (conversion factor  $\mu\text{g/l}$  to  $\text{mg/l}$ ) = Acute limit  
 $19 \mu\text{g/L} * 13 * 0.001 = 0.25 \text{ mg/L}$  (maximum daily)

The calculated maximum daily limit is less stringent than the limit in the 2016 Permit. Therefore, the 0.24 mg/L maximum daily limit will be carried forward due to anti-backsliding regulations discussed in Section 2.6 above. Additionally, this Draft Permit establishes an average monthly TRC limit of 0.14 mg/L.

The Draft Permit also continues to require reporting of flow (including treated flow, untreated flow diverted from the facility, and flow to the treatment plant), BOD<sub>5</sub>, TSS, pH, Whole Effluent Toxicity, TKN, Nitrate, Nitrite and Ammonia. Further, the Draft Permit requires that the annual report include a comparison of annual precipitation to that in a “typical” year as assumed in the modeling of the CSO system and an assessment of whether the volume and frequency of untreated CSO discharges from CSO Outfall 009 is consistent with the assumptions underlying the modeling of the system.

Further, for the 10 other CSO outfalls the permit continues to require reporting of total flow, flow duration, and the number of CSO events.

## 5.7 Standard Conditions

The standard conditions of the permit are based on 40 CFR §122, Subparts A, C, and D and 40 CFR § 124, Subparts A, D, E, and F and are consistent with management requirements common to other permits.

## 6.0 Federal Permitting Requirements

### 6.1 Endangered Species Act

Section 7(a) of the Endangered Species Act of 1973, as amended (ESA), grants authority and imposes requirements on Federal agencies regarding endangered or threatened species of fish, wildlife, or plants (listed species) and any habitat of such species that has been designated as critical under the ESA (a “critical habitat”).



Section 7(a)(2) of the ESA requires every federal agency, in consultation with and with the assistance of the Secretary of Interior, to ensure that any action it authorizes, funds or carries out, in the United States or upon the high seas, is not likely to jeopardize the continued existence of any listed species or result in the destruction or adverse modification of critical habitat. The United States Fish and Wildlife Service (USFWS) administers Section 7 consultations for freshwater species. The National Oceanic and Atmospheric Administration Fisheries (NOAA Fisheries) administers Section 7 consultations for marine and anadromous species.

The Federal action being considered in this case is EPA's proposed NPDES permit for the Facility's discharges of pollutants. The Draft Permit is intended to replace the 2016 Permit in governing the Facility. As the federal agency charged with authorizing the discharge from this Facility, EPA determines potential impacts to federally listed species and initiates consultation with the Services when required under § 7(a)(2) of the ESA.

EPA has reviewed the federal endangered or threatened species of fish, wildlife, and plants in the expected action area of the outfall to determine if EPA's proposed NPDES permit could potentially impact any such listed species in this section of the Connecticut River.

For protected species under the jurisdiction of the USFWS, one federally listed threatened species has been identified in the action area of the Holyoke discharge.<sup>37</sup> A terrestrial listed threatened species, the northern long-eared bat (*Myotis septentrionalis*) was identified as potentially occurring in the action area of the Holyoke WPCF's discharge. According to the USFWS, the threatened northern long-eared bat is found in the following habitats based on seasons, "winter – mines and caves; summer – wide variety of forested habitats." This species is not considered aquatic. However, because the Facility's projected action area in the Connecticut River in Williamstown overlaps with the general statewide range of the northern long-eared bat, EPA prepared an Effects Determination Letter for the Holyoke WPCF NPDES Permit Reissuance and submitted it to USFWS. Based on the information submitted by EPA, the USFWS notified EPA by letter, dated February 5, 2023, that the permit reissuance is consistent with activities analyzed in the USFWS January 5, 2016, Programmatic Biological Opinion (PBO).<sup>38</sup> The PBO outlines activities that are excepted from "take" prohibitions applicable to the northern long-eared bat under the Endangered Species Act of 1973 (ESA) (87 Stat.884, as amended; 16 U.S.C. 1531 et seq.). The USFWS consistency letter concluded EPA's consultation responsibilities for the Holyoke WPCF NPDES permitting action under ESA section 7(a)(2) with respect to the northern long-eared bat.

For protected species under the jurisdiction of NOAA Fisheries, the following life stages of shortnose sturgeon (*Acipenser brevirostrum*) are likely present in the action area: adult (migrating, foraging, and overwintering); juvenile (migrating, foraging and overwintering); young-of-year (migrating and foraging); and post yolk-sac larvae (migrating and foraging). Additionally, the following life stages of Atlantic sturgeon (*Acipenser oxyrinchus oxyrinchus*) are likely present in the action area: adult (spawning, migrating, and foraging); juvenile (migrating and foraging); young-of-year (migrating and foraging); subadult (migrating and

<sup>37</sup> <https://ipac.ecosphere.fws.gov/location/index>

<sup>38</sup> USFWS Project Code: 2023-0041850, February 5, 2023..



foraging); egg and yolk-sac larvae; and post yolk-sac larvae (migrating and foraging). Further, the action area is likely in or near Critical Habitat for Atlantic sturgeon.

Because these species may be affected by the discharges authorized by the proposed permit, EPA has thoroughly evaluated the potential impacts of the permit action on these anadromous species through the preparation of a Biological Assessment (BA). EPA is in the process of finalizing the BA. On the basis of the evaluation, EPA's preliminary determination is that this action may affect, but is not likely to adversely affect, the life stages of shortnose sturgeon or Atlantic sturgeon that are expected to inhabit the Connecticut River in the vicinity of the action area of the discharge. Therefore, EPA has judged that a formal consultation pursuant to Section 7 of the ESA is not required. EPA is seeking concurrence from NOAA Fisheries regarding this determination through the information in the Draft Permit, this Fact Sheet, as well as the detailed BA that will be sent to NOAA Fisheries Protected Resources Division during the Draft Permit's public comment period.

At the beginning of the public comment period, EPA notified NOAA Fisheries and USFWS that the Draft Permit and Fact Sheet were available for review and provided a link to the EPA NPDES Permit website to allow direct access to the documents.

Reinitiation of consultation will not need to take place unless: (a) new information reveals effects of the action that may affect listed species or critical habitat in a manner or to an extent not previously considered in the consultation; (b) the identified action is subsequently modified in a manner that causes an effect to the listed species or critical habitat that was not considered in the consultation; or (c) a new species is listed or critical habitat is designated that may be affected by the identified action.

## 6.2 Essential Fish Habitat

Under the 1996 Amendments (PL 104-267) to the Magnuson-Stevens Fishery Conservation and Management Act (*see* 16 U.S.C. § 1801 *et seq.*, 1998), EPA is required to consult with the NOAA Fisheries if EPA's action or proposed actions that it funds, permits, or undertakes, "may adversely impact any essential fish habitat." 16 U.S.C. § 1855(b).

The Amendments broadly define "essential fish habitat" (EFH) as: "waters and substrate necessary to fish for spawning, breeding, feeding, or growth to maturity." 16 U.S.C. § 1802(10). "Adverse impact" means any impact that reduces the quality and/or quantity of EFH 50 CFR § 600.910(a). Adverse effects may include direct (e.g., contamination or physical disruption), indirect (e.g., loss of prey, reduction in species' fecundity), or site specific or habitat-wide impacts, including individual, cumulative, or synergistic consequences of actions. EFH is only designated for fish species for which federal Fisheries Management Plans exist. *See* 16 U.S.C. § 1855(b)(1)(A). EFH designations for New England were approved by the U.S. Department of Commerce on March 3, 1999.

Based on available EFH information, including the NOAA Fisheries EFH Mapper,<sup>39</sup> EPA has determined that the Connecticut River in the vicinity of the discharge from the Holyoke WPCF is

---

<sup>39</sup> <https://www.habitat.noaa.gov/apps/efhmapper/>



designated as EFH for Atlantic salmon (*Salmo salar*). Therefore, consultation with NOAA Fisheries under the Magnuson-Stevens Fishery Conservation and Management Act is required. EPA has determined that the operation of this Facility, as governed by this permit action, may adversely affect the EFH of the Atlantic salmon in the Connecticut River. The Draft Permit has been conditioned in the following way to minimize any impacts that reduce the quality and/or quantity of EFH:

- This Draft Permit action does not constitute a new source of pollutants. It is the reissuance of an existing NPDES permit;
- TSS, BOD, total residual chlorine, *E. Coli*, pH, total aluminum, total copper and total lead are regulated by the Draft Permit to meet State water quality standards;
- EPA's evaluation indicates that there is no reasonable potential for the discharge to cause or contribute to an excursion above water quality criteria for cadmium, nickel, or zinc, as the concentrations of these metals in the effluent were well below the maximum allowable concentrations that may be present in the discharge;
- The permit establishes a new nitrogen limit;
- The Draft Permit requires quarterly toxicity testing to ensure that the discharge does not present toxicity problems;
- The Facility withdraws no water from the Connecticut River, so there will be no impact that reduces the quality and/or quantity of EFH from impingement and entrainment of organisms;
- The Draft Permit prohibits the discharge to cause a violation of State water quality standards;
- The Draft Permit prohibits the discharge of pollutants or combinations of pollutants in toxic amounts;
- The effluent limitations and conditions in the Draft Permit were developed to be protective of all aquatic life; and
- The proposed Draft Permit requirements minimize any reduction in quality and/or quantity of EFH, either directly or indirectly.

EPA believes that the conditions and limitations contained within the Holyoke WPCF Draft Permit adequately protect all aquatic life, as well as the essential fish habitat of Atlantic salmon. Further mitigation is not warranted. Should adverse impacts to EFH be detected as a result of this permit action, or if new information is received that changes the basis for EPA's conclusions, NOAA Fisheries Habitat and Ecosystem Services Division will be contacted and an EFH consultation will be reinitiated.

At the beginning of the public comment period, EPA notified NOAA Fisheries Habitat and Ecosystem Services Division that the Draft Permit and Fact Sheet were available for review and provided a link to the EPA NPDES Permit website to allow direct access to the documents. In addition to this Fact Sheet and the Draft Permit, information to support EPA's finding was included in a letter under separate cover and sent to the NOAA Fisheries Habitat and Ecosystem Services Division during the public comment period.

## **7.0 Public Comments, Hearing Requests and Permit Appeals**

All persons, including applicants, who believe any condition of the Draft Permit is inappropriate must raise all issues and submit all available arguments and all supporting material for their arguments in full by the close of the public comment period, to the permit writer, Elise Scholl at the following email address: [Duspiva.Michele@epa.gov](mailto:Duspiva.Michele@epa.gov).

Prior to the close of the public comment period, any person may submit a written request to EPA for a public hearing to consider the Draft Permit. Such requests shall state the nature of the issues proposed to be raised in the hearing. A public hearing may be held if the criteria stated in 40 CFR § 124.12 are satisfied. In reaching a final decision on the Draft Permit, EPA will respond to all significant comments in a Response to Comments document attached to the Final Permit and make these responses available to the public on EPA's website.

Following the close of the comment period, and after any public hearings, if such hearings are held, EPA will issue a Final Permit decision, forward a copy of the final decision to the applicant, and provide a copy or notice of availability of the final decision to each person who submitted written comments or requested notice. Within 30 days after EPA serves notice of the issuance of the Final Permit decision, an appeal of the federal NPDES permit may be commenced by filing a petition for review of the permit with the Clerk of EPA's Environmental Appeals Board in accordance with the procedures at 40 CFR § 124.19.

If for any reason, comments on the Draft Permit and/or a request for a public hearing cannot be emailed to the permit writer specified above, please contact them at telephone number: (617) 918-1675.

## **8.0 Administrative Record**

The administrative record on which this Draft Permit is based may be accessed by contacting Michele Duspiva at 617-918-1682 or via email to [Duspiva.Michele@epa.gov](mailto:Duspiva.Michele@epa.gov).

April 2023  
Date

---

Ken Moraff, Director  
Water Division  
U.S. Environmental Protection Agency



**Figure 1: Location of the Holyoke WPCF**






Figure 2: Location of the Holyoke CSOs







Figure 3: Flow Diagram



## Outfall 001

Parameter	Flow	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5
	Annual Rolling Ave	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Monthly Ave Min	Weekly Ave	Weekly Ave
Units	MGD	MGD	MGD	lb/d	mg/L	%	lb/d	mg/L
Effluent Limit	17.5	Report	Report	4379	30	85	6568	45
Minimum	6.5	4.7	6.8	306	5.2	85.8	47	5.2
Maximum	8.7	11.9	21	1333	19.7	99.9	3018	34.2
Median	7.2	7.05	14.45	556	9.3	96.0	648.5	9.8
No. of Violations	0	N/A	N/A	0	0	0	0	0
10/31/2017	7.2	6.4	15.9	806	11.6	96	1131	19.8
11/30/2017	7.2	5.6	6.8	385	8.2	97	1372	13
12/31/2017	7.1	5.7	10.5	542	11.1	95.9	821	16.2
1/31/2018	7.1	7.3	18.2	651	11.3	94.7	965	19.8
2/28/2018	7.3	9.5	19.1	959	10.6	93.4	1448	14
3/31/2018	7.3	8.4	20.4	823.7	12	93.7	1277	16
4/30/2018	7.1	8.7	17.2	1069	14.2	90.8	1584	26.6
5/31/2018	6.9	6.9	10.6	610	10.3	94.8	949	13.2
6/30/2018	6.8	6.1	15.3	1001	15.8	93.2	1950	22.2
7/31/2018	6.9	6.4	14	1125	19.7	89.8	2041	34.2
8/31/2018	6.9	6.9	11.2	831	14.8	91.7	924	16
9/30/2018	7.2	8.4	18.5	724	9.3	94	988	20.6
10/31/2018	7.4	8.67	16.5	751	10.3	94.2	1361	21
11/30/2018	7.9	11.9	20.3	1138	10.4	90.6	2729	23
12/31/2018	8.2	9.7	18.1	852	10.4	91.9	2729	23
1/31/2019	8.4	8.8	18	1333	17.3	85.8	2802	31.5
2/28/2019	8.3	8.2	15.4	671	8.6	94.1	804	9.8
3/31/2019	8.2	8.1	15.1	597	9	94.3	1121	13.2
4/30/2019	8.5	11.4	21	702	7.5	93.6	784	9.2
5/31/2019	8.7	9.3	16.1	832	11.2	91.7	1049	11.4
6/30/2019	8.7	6.4	10.4	595	10.5	99.8	682	11.6
7/31/2019	8.6	5.8	11.7	823	13.6	99.8	899	14.6
8/31/2019	8.5	5.4	9.8	729	15.7	99.8	663	14.3
9/30/2019	8.3	6.5	8.9	446	8	99.9	497	8.2
10/31/2019	8.2	7.4	14.7	691	10	99.8	634	10.1
11/30/2019	7.9	7.2	17.3	1265	13.2	99.8	3018	24.9
12/31/2019	7.8	8.6	19	752	9.3	99.8	761	9.4
1/31/2020	7.6	7.4	10.7	389	6.2	99.9	668	8.4
2/29/2020	7.6	7.5	13.8	464	7.3	99.9	441	7
3/31/2020	7.5	7.8	13.7	463	6.5	99.9	405	6
4/30/2020	7.3	8.8	14.7	565	7.4	99.8	594	16
5/31/2020	7.2	7.3	15.2	427	7.4	99.8	47	7.4



Outfall 001

Parameter	Flow	Flow	Flow	BOD5	BOD5	BOD5	BOD5	BOD5
	Annual Rolling Ave	Monthly Ave	Daily Max	Monthly Ave	Monthly Ave	Monthly Ave Min	Weekly Ave	Weekly Ave
Units	MGD	MGD	MGD	lb/d	mg/L	%	lb/d	mg/L
Effluent Limit	17.5	Report	Report	4379	30	85	6568	45
6/30/2020	7.1	5.7	8.7	330	6.6	99.9	279	6.2
7/31/2020	7.1	6	8.5	394	8	99.8	435	8.3
8/31/2020	7.2	5.9	8.2	491	9.9	99.8	483	9.8
9/30/2020	7.1	5.7	10.6	474	8.9	99.8	456	8.8
10/31/2020	7	6.7	14.6	839	11.4	99.8	734	10.5
11/30/2020	7	6.3	12.8	466	8.4	99.8	481	8.7
12/31/2020	7	8.5	18	352	5.2	99.9	333	5.2
1/31/2021	7.2	6.9	14.3	339	5.7	99.9	356	5.6
2/28/2021	6.8	6.3	13.4	478	8.5	99.8	469	8.4
3/31/2021	6.7	6.5	11.1	495	8.6	99.8	442	8.2
4/30/2021	6.6	7.5	19.5	547	8.4	99.8	565	8.8
5/31/2021	6.7	8	14.8	723	10.2	99.8	654	9.8
6/30/2021	6.7	5.7	8.6	473	9.1	94.2	604	10.2
7/31/2021	7	9.7	17.5	800	9.6	90.7	718	9.2
8/31/2021	7.1	6.9	12.7	346	5.5	96.4	371	5.9
9/30/2021	7.2	7.4	18	397	6.3	94.6	404	6.2
10/31/2021	7.3	7	18.8	473	7.3	95.5	424	6.9
11/30/2021	7.3	6.5	11.7	306	5.9	95.5	323	6
12/31/2021	7.2	7.1	11.7	504	8.2	95.3	487	8
1/31/2022	7.1	6.4	11.8	529	9.5	94.9	530	9.1
2/28/2022	7.2	7.6	17.1	643	10.2	95.2	643	10.3
3/31/2022	7.3	7.6	12.6	487	7.6	95.3	431	6.8
4/30/2022	7.4	8.8	15.8	791	10.7	92.8	777	10.7
5/31/2022	7.2	5.9	10.3	366	7.5	96.7	370	7.6
6/30/2022	7.2	5	9.3	307	7.4	96.7	333	7.8
7/31/2022	6.8	5.1	9.1	483	9.8	95.8	443	9.2
8/31/2022	6.6	4.7	6.9	434	11.1	95.9	458	11.6
9/30/2022	6.5	5.8	19.7	482	8.9	96.4	475	8.7

Outfall 001

Parameter	BOD5	BOD5	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Monthly Ave	Weekly Ave	Weekly Ave	Daily Max
Units	lb/d	mg/L	lb/d	mg/L	%	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	4379	30	85	6568	45	Report
Minimum	500.4	9	330	5.4	85	316	6.2	708.9
Maximum	18756	130	2533	27	99.9	6013	50	37513
Median	1761.4	22	676.5	10.95	95	769	12.4	2402.5
No. of Violations	N/A	N/A	0	0	0	0	2	N/A
10/31/2017	3580	52	822	11.8	95.3	651	12	6376
11/30/2017	1141	24	503	10.9	94.6	1914	18.2	1061
12/31/2017	1234	22	532	10.7	93.7	758	14.2	1524
1/31/2018	1446	34	878	15	93.6	1021	19.2	3138
2/28/2018	3505	22	1467	15.1	91.8	2530	23.2	7328
3/31/2018	1798.1	22	927	14	92.8	1106	14	2125
4/30/2018	3586	63	1208	13.7	93.2	2158	19	7459
5/31/2018	3479	43	586	9.2	95.5	1384	18.8	5420
6/30/2018	6380	50	1672	27	93.5	4977	13.8	13611
7/31/2018	4373	49	1342	22.4	88.1	2463	38.8	8121
8/31/2018	3233	68	538	9.3	95.5	729	12.6	1261
9/30/2018	2070	17	986	11	92.7	1608	13.6	5660
10/31/2018	3457	60	865	10.3	93.2	2233	20.2	8815
11/30/2018	7320	54	2025	18	85	4760	40.3	14911
12/31/2018	6986	76	1740	20.5	85	4760	40.3	19302
1/31/2019	5419	44	1377	17.8	87.5	4622	50	6773
2/28/2019	3586	28	770	10.2	93.3	954	11	4099
3/31/2019	1293	20	613	9.2	94.4	1166	13	1437
4/30/2019	1598	12	1126	11.2	90.2	1612	14.1	2801
5/31/2019	1614	23	861	11.1	92.7	1145	12.8	2958
6/30/2019	1404.8	20	589	10	99.9	653	10.6	1823
7/31/2019	9128.1	100	752	12.7	99.8	827	13.3	8397.9
8/31/2019	2125	26	377	7.6	99.9	360	7.4	1471.2
9/30/2019	1039.2	14	549	9.7	99.9	673	11	1187.6
10/31/2019	2014.1	23	913	13.1	92.8	775	12.1	2808.2
11/30/2019	18756	130	2533	26.3	99.6	6013	49.1	37513
12/31/2019	5245.9	37	1490	18.3	99.7	1572	17.8	10066.4
1/31/2020	803.1	10	612	9.7	99.8	1245	15.4	1541.2
2/29/2020	920.7	13	659	10.4	99.8	657	10.3	1332.7
3/31/2020	2206.8	21	825	11	99.9	783	10.8	4413.5
4/30/2020	1961.6	16	1388	14.2	99.8	1476	15.2	17163.7
5/31/2020	1140.9	19	330	5.4	99.9	441	6.2	708.9



## Outfall 001

Parameter	BOD5	BOD5	TSS	TSS	TSS	TSS	TSS	TSS
	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Monthly Ave Min	Weekly Ave	Weekly Ave	Daily Max
Units	lb/d	mg/L	lb/d	mg/L	%	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	4379	30	85	6568	45	Report
6/30/2020	1088.4	15	430	8.4	99.9	316	7	1741.4
7/31/2020	935.7	22	614	12.2	99.8	715	13.3	1844.8
8/31/2020	1120.9	21	586	11.6	99.8	597	11.8	1227.6
9/30/2020	3913.1	69	830	15.7	99.8	833	15.9	8506.8
10/31/2020	8645.2	71	835	13.8	99.8	757	12.8	3689.6
11/30/2020	1236	16	785	14.4	99.8	807	15	2091.7
12/31/2020	863.2	14	568	8.2	99.8	563	8.5	1918.2
1/31/2021	720.6	12	472	7.9	99.8	496	7.8	1100.9
2/28/2021	1546.6	14	622	10.8	99.8	620	10.8	2682.1
3/31/2021	1296	16	600	10.2	99.8	501	9.2	2221.8
4/30/2021	1868.2	16	657	9.9	99.8	693	10.5	2452
5/31/2021	2361.9	27	1051	13.8	99.7	763	11.2	6987.3
6/30/2021	1553.7	23	599	11.7	91.8	979	15.1	1936.5
7/31/2021	2732.2	39	1091	12.6	90.7	979	12	5963.1
8/31/2021	1155.9	11	495	7.5	95.2	524	7.8	1771.4
9/30/2021	1050.8	10	574	9	94.2	572	8.5	1801.4
10/31/2021	1724.7	16	584	9	94.6	546	9	1881.5
11/30/2021	500.4	9	391	7.5	95	409	7.5	864.9
12/31/2021	1285.5	19	791	12.8	91.7	738	12.2	2229.3
1/31/2022	1968.2	20	694	12.7	92.2	726	12.7	2165.1
2/28/2022	2732	28	916	14.2	92.4	922	14.5	4684
3/31/2022	1577.9	22	542	8.4	94.9	451	7.1	2080
4/30/2022	2349	23	770	10.4	92.9	793	11	2669
5/31/2022	731	13	425	8	95.6	435	7.9	2062
6/30/2022	726	13	341	7.8	96	387	8.7	1163
7/31/2022	2884	38	445	9	94.6	403	8.3	2353
8/31/2022	1415	32	364	9.3	95.7	389	9.8	1183
9/30/2022	1600	22	484	8	93.7	456	7.3	2957

## Outfall 001

Parameter	TSS	pH	pH	E. coli	E. coli	TRC	TRC	Ammonia
	Daily Max	Minimum	Maximum	Monthly Geometric Mean	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	mg/L	SU	SU	CFU/100mL	CFU/100mL	mg/L	mg/L	lb/d
Effluent Limit	Report	6	8.3	126	409	0.74	1	Report
Minimum	10	6	6.5	1	2	0.39	0.4	50.29
Maximum	260	6.5	7.6	50	241	0.52	1	671
Median	28	6.4	6.8	7	50	0.42	0.68	327.0785
No. of Violations	N/A	0	0	0	0	0	0	N/A
10/31/2017	55	6.4	6.7	7	72	0.43	0.75	439.3
11/30/2017	24	6.4	6.7			NODI: C	NODI: C	92.8
12/31/2017	24	6	6.9			NODI: C	NODI: C	671
1/31/2018	53	6.3	7			NODI: C	NODI: C	557
2/28/2018	46	6.3	6.9			NODI: C	NODI: C	335
3/31/2018	26	6.5	7			NODI: C	NODI: C	379
4/30/2018	52	6.5	6.8	8	128	0.43	0.67	396
5/31/2018	67	6.4	7.4	7	120	0.44	0.88	466
6/30/2018	240	6.4	6.6	22	50	0.42	0.83	408
7/31/2018	91	6.3	6.7	34	92	0.43	0.96	395.5
8/31/2018	18	6.4	6.7	18	65	0.46	0.8	354
9/30/2018	39	6.4	6.8	12	50	0.44	0.99	390
10/31/2018	75	6.2	7	2	7	0.48	0.89	327
11/30/2018	110	6.5	6.8			NODI: C	NODI: C	74.5
12/31/2018	210	6.4	6.8			NODI: C	NODI: C	238.7
1/31/2019	53	6.5	6.9			NODI: C	NODI: C	338
2/28/2019	32	6.5	6.8			NODI: C	NODI: C	433
3/31/2019	20	6.5	7.6			NODI: C	NODI: C	275
4/30/2019	25	6.4	6.8	2	14	0.52	0.85	277
5/31/2019	22	6.5	6.9	2	10	0.45	0.95	320
6/30/2019	21	6.2	6.7	1	4	0.45	0.95	430.64
7/31/2019	92	6.3	6.6	4	28	0.39	0.78	383.47
8/31/2019	18	6.5	7	5	20	0.47	0.86	334.93
9/30/2019	16	6.5	6.9	4	30	0.44	0.86	408.6
10/31/2019	32	6.3	6.8	2	40	0.42	0.86	463.42
11/30/2019	260	6.1	6.9			NODI: C	NODI: C	390.81
12/31/2019	71	6.5	6.9			NODI: C	NODI: C	423.17
1/31/2020	21	6.5	7			NODI: C	NODI: C	246.86
2/29/2020	17	6.4	6.7			NODI: C	NODI: C	346.77
3/31/2020	42	6.3	6.9			NODI: C	NODI: C	237.69
4/30/2020	140	6.4	7.1	1	10	0.48	0.85	233.9
5/31/2020	10	6.5	7	2	10	0.48	0.77	326.51



## Outfall 001

Parameter	TSS	pH	pH	E. coli	E. coli	TRC	TRC	Ammonia
	Daily Max	Minimum	Maximum	Monthly Geometric Mean	Daily Max	Monthly Ave	Daily Max	Monthly Ave
Units	mg/L	SU	SU	CFU/100mL	CFU/100mL	mg/L	mg/L	lb/d
Effluent Limit	Report	6	8.3	126	409	0.74	1	Report
6/30/2020	24	6.4	6.6	6	52	0.46	0.83	235.75
7/31/2020	29	6.4	6.8	5	71	0.39	0.75	293.63
8/31/2020	23	6.3	6.8	9	24	0.43	0.74	393.64
9/30/2020	150	6.4	6.6	7	20	0.41	0.83	298.28
10/31/2020	79	6.3	6.7	10	92	0.47	0.91	287.95
11/30/2020	24	6.4	6.8			NODI: C	NODI: C	201.49
12/31/2020	20	6.3	7			NODI: C	NODI: C	163.047
1/31/2021	19	6.4	6.9			NODI: C	NODI: C	97.57
2/28/2021	35	6.5	7			NODI: C	NODI: C	269.632
3/31/2021	24	6.4	6.8			NODI: C	NODI: C	412.747
4/30/2021	21	6.3	6.7	1	4	0.45	0.79	222.55
5/31/2021	71	6.5	6.7	1	2	0.45	0.71	261.88
6/30/2021	27	6.5	6.6	5	241	0.44	0.72	327.157
7/31/2021	55	6.5	6.7	15	130	0.49	1	221.074
8/31/2021	18	6.4	6.8	25	53	0.44	0.65	289.16
9/30/2021	13	6.3	6.7	24	49	0.44	0.59	238.92
10/31/2021	24	6.4	6.7	5	55	0.47	0.69	363.02
11/30/2021	17	6.5	6.7			NODI: C	NODI: C	166.88
12/31/2021	33	6.4	6.8			NODI: 9	NODI: 9	550.69
1/31/2022	22	6.4	6.7			NODI: 9	NODI: 9	50.29
2/28/2022	48	6.5	6.9			NODI: 9	NODI: 9	227
3/31/2022	29	6.4	6.8			0.4	0.4	332
4/30/2022	25	6.4	6.8	19	124	0.47	0.63	164
5/31/2022	24	6.3	6.6	11	50	0.43	0.6	278.3
6/30/2022	15	6.4	6.5	50	145	0.45	0.69	353.8
7/31/2022	31	6.3	6.5	38	97	0.46	0.7	217.653
8/31/2022	33	6.3	6.6	42	146	0.42	0.73	388
9/30/2022	25	6.2	6.5	13	87	0.48	0.73	363

## Outfall 001

Parameter	Ammonia	Ammonia	Ammonia	TKN	TKN	TKN	TKN	TN
	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Daily Max	Monthly Ave
Units	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report	Report
Minimum	0.9	50.29	0.9	175.64	2.4	175.64	2.4	208.17
Maximum	12	771	14	1062	19	1375	22	922
Median	5.3375	405.947	7.05	503.865	8.2	585.84	9.7	516.7
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/31/2017	9.78	623.8	14	716.4	14.87	1134.2	20	723
11/30/2017	2.1	98.2	2.1	619	14	655	14	641
12/31/2017	12	671	12	1062	19	1062	19	922
1/31/2018	4.7	557	4.7	853	7.2	853	7.2	471
2/28/2018	4.7	345	4.7	514	7	514	7	550
3/31/2018	5	379	5	622	8.2	622	8.2	660
4/30/2018	5.8	565	7.8	630	9.1	942	13	665
5/31/2018	7.66	752	9.3	690	11	1375	17	725
6/30/2018	8.4	508	10	571	11.7	711	14	736.5
7/31/2018	8.55	607.2	14	678	13.45	954.1	22	708.5
8/31/2018	6.78	408	7.8	539	10.33	578	11	565
9/30/2018	6.78	771	11	618	9.93	938	14	651
10/31/2018	3.94	520	5.2	606	6.94	1023	8.7	649
11/30/2018	0.9	74.5	0.9	199	2.4	199	2.4	240
12/31/2018	2.8	238.7	2.8	409.2	4.8	409.2	4.8	451.8
1/31/2019	4.55	495	6.2	493	6.8	639	8	529
2/28/2019	4.7	433	4.7	755	8.2	755	8.2	801
3/31/2019	4.5	275	4.5	434	7.1	434	7.1	464
4/30/2019	2.96	414	4.5	543	5.62	839	7.7	592
5/31/2019	4.7	365	6.4	451	6.48	521	7.4	486
6/30/2019	7.7	554.89	9.2	624.12	11.06	913.11	13	645.74
7/31/2019	7.6	525.57	9.7	548.26	10.44	924.61	12	577.74
8/31/2019	8	433.18	9.8	449.4	10.65	618.83	14	499.24
9/30/2019	8.1	600.4	12	591.8	11.78	800.6	16	622.2
10/31/2019	8.16	625.5	11	670.15	11.9	813.98	16	700.39
11/30/2019	6.6	390.81	6.6	521.08	8.8	521.08	8.8	562.53
12/31/2019	8.6	423.17	8.6	590.47	12	590.47	12	615.08
1/31/2020	3.7	246.86	3.7	493.73	7.4	493.73	7.4	531.76
2/29/2020	6.6	346.77	6.6	478.13	9.1	478.13	9.1	504.4
3/31/2020	3.8	237.69	3.8	206.42	3.3	206.42	3.3	237.69
4/30/2020	3.24	343.6	4	399.72	5.56	541.18	6.3	436.52
5/31/2020	5.5	617.16	10	543.27	9.48	822.32	17	584.43



## Outfall 001

Parameter	Ammonia	Ammonia	Ammonia	TKN	TKN	TKN	TKN	TN
	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Daily Max	Monthly Ave
Units	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report	Report
6/30/2020	5	319.75	7.1	364.98	7.46	493.73	9.4	393.61
7/31/2020	5.77	512.41	9.6	567.33	11.5	640.51	13	592.57
8/31/2020	7.77	512.91	8.2	594.43	11.75	750.6	12	629.06
9/30/2020	6.5	500.4	10	422.27	9.24	650.52	13	444.87
10/31/2020	5.95	406.57	7.5	424.38	8.75	596.31	11	449.85
11/30/2020	3.2	245.53	3.2	333.73	5.3	406.66	5.3	365.21
12/31/2020	1.7	163.047	1.7	316.5	3.3	316.5	3.3	364.46
1/31/2021	1.5	97.57	1.5	175.64	2.7	175.64	2.7	208.17
2/28/2021	5.3	269.632	5.3	381.56	7.5	381.56	7.5	406.99
3/31/2021	4.9	412.747	4.9	581.21	6.9	581.21	6.9	623.33
4/30/2021	4.22	332.76	7	357.62	6.58	406.32	8.4	378.52
5/31/2021	4.38	341.61	7.8	401.75	6.54	467.87	11	420.82
6/30/2021	6.65	405.324	7.8	369.01	7.44	520.17	12	381.51
7/31/2021	2.95	283.89	4.6	404.07	4.93	477.38	7	416.75
8/31/2021	5.52	381.64	8.8	409.56	7.64	520.42	12	423.96
9/30/2021	4.63	345.61	7.4	391.08	7.48	513.74	11	399.4
10/31/2021	5.63	449.86	9.3	587.78	8.33	721.24	13	601.31
11/30/2021	2.9	166.88	2.9	224.43	3.9	224.43	3.9	274.49
12/31/2021	9.3	550.69	9.3	532.93	9	532.93	9	549.44
1/31/2022	0.9	50.29	0.9	312.92	5.6	312.92	5.6	256.71
2/28/2022	4.7	248	4.7	351	7.15	367	8.3	405
3/31/2022	5.1	332	5.1	403	6.2	403	6.2	452
4/30/2022	2.575	205	2.8	319	5.05	364	5.9	326
5/31/2022	5.375	407.9	6.7	459.78	8.68	608.82	10	469.4
6/30/2022	8.5	391.8	8.9	473	11.34	498.7	13	480.57
7/31/2022	5.375	399.314	9.4	582.32	11.83	637.2	15	588
8/31/2022	9.06	433	11	553	13	747	14	563
9/30/2022	6.725	520	8.9	565	10.33	817	14	394.41

## Outfall 001

Parameter	TN	TN	TN	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate
	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Daily Max
Units	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	Report
Minimum	2.9	208.17	2.9	0	0	0.5	0
Maximum	19.5	1416	22.5	59.2	26.27	66.59	26.27
Median	8.6	609.54	10.305	27.48	0.5	31.905	0.5
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/31/2017	15	1142	20.1	6.95	0.14	10.67	0.2
11/30/2017	14.5	678	14.5	22.1	0.5	23.39	0.5
12/31/2017	19.5	922	19.5	27.94	0.5	27.94	0.5
1/31/2018	7.7	471	7.7	59.2	0.5	59.2	0.5
2/28/2018	7.5	593	7.5	36.7	< .5	36.7	< .5
3/31/2018	8.7	660	8.7	0.5	0.5	0.5	0.5
4/30/2018	9.55	978	13.5	35.45	0.5	46.29	0.5
5/31/2018	11.58	1416	17.5	34.9	0.58	47.1	0.91
6/30/2018	12.2	810	14.5	24.3	0.5	27.9	0.5
7/31/2018	13.95	975.8	22.5	< 30.44	0.5	58.38	0.5
8/31/2018	10.83	604	11.5	26.17	< .25	28.36	< .25
9/30/2018	10.43	1017	14.5	33.4	0.5	60.88	0.5
10/31/2018	7.44	1081	9.2	43.15	0.5	58.77	0.5
11/30/2018	2.9	240	2.9	41.4	0.5	41.4	0.5
12/31/2018	5.3	451.8	5.3	42.6	0.5	42.6	0.5
1/31/2019	7.3	680	8.5	39.98	0.5	39.98	0.5
2/28/2019	8.7	801	8.7	46	0.5	46	0.5
3/31/2019	7.6	464	7.6	30.5	0.5	30.5	0.5
4/30/2019	6.12	893	8.2	49.37	0.5	66.59	0.5
5/31/2019	6.98	561	7.9	34.9	0.5	40.68	0.5
6/30/2019	11.46	948.23	13.5	27.02	0.5	35.12	0.5
7/31/2019	11.01	973.28	12.5	29.47	0.57	48.66	0.83
8/31/2019	11.84	665.68	15.06	49.84	1.19	64.57	1.58
9/30/2019	12.4	825.6	16.5	30.41	0.62	48.64	1.08
10/31/2019	12.43	844.43	16.5	30.24	0.53	41.51	0.63
11/30/2019	9.5	562.53	9.5	41.45	0.7	41.45	0.7
12/31/2019	12.5	615.08	12.5	24.6	0.5	24.6	0.5
1/31/2020	7.97	531.76	7.97	38.03	0.57	38.03	0.57
2/29/2020	9.6	504.4	9.6	0.5	26.27	0.5	26.27
3/31/2020	3.8	237.69	3.8	31.28	0.5	31.28	0.5
4/30/2020	6.07	587.57	6.84	0.51	0.25	0.54	0.29
5/31/2020	10.18	874.57	18.08	41.16	0.71	52.24	1.08



## Outfall 001

Parameter	TN	TN	TN	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate	Nitrite+Nitrate
	Monthly Ave	Daily Max	Daily Max	Monthly Ave	Monthly Ave	Daily Max	Daily Max
Units	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	Report
6/30/2020	8.25	524.59	10.44	28.63	0.61	46.84	1.04
7/31/2020	12.01	669.34	13.5	25.24	0.51	28.82	0.54
8/31/2020	12.44	795.01	12.71	34.62	0.69	44.41	0.71
9/30/2020	9.74	675.54	13.5	22.6	0.5	25.02	0.5
10/31/2020	9.28	623.42	11.5	25.47	0.53	28.49	0.61
11/30/2020	5.8	445.02	5.8	31.48	0.5	38.36	0.5
12/31/2020	3.8	364.46	3.8	47.96	0.5	47.96	0.5
1/31/2021	3.2	208.17	3.2	32.53	0.5	32.53	0.5
2/28/2021	8	406.99	8	25.44	0.5	25.44	0.5
3/31/2021	7.4	623.33	7.4	42.12	0.5	42.12	0.5
4/30/2021	7.11	430.51	8.93	29.34	0.53	35.45	0.63
5/31/2021	6.82	500.4	11.29	19.07	0.28	33.36	0.5
6/30/2021	7.68	541.11	12.17	12.5	0.24	20.94	0.31
7/31/2021	5.08	496.48	7.19	12.68	0.15	19.1	0.19
8/31/2021	7.88	530.56	12.23	14.4	0.24	22.35	0.29
9/30/2021	7.63	524.86	11.24	8.31	0.16	11.12	0.24
10/31/2021	8.5	736.92	13.15	13.53	0.17	25.27	0.3
11/30/2021	4.77	274.49	4.77	50.07	0.87	50.07	0.87
12/31/2021	9.15	549.44	9.15	8.88	0.15	8.88	0.15
1/31/2022	5.7	256.71	5.7	5.59	0.05	5.59	0.05
2/28/2022	7.25	405	7.25	5	0.1	5.59	0.1
3/31/2022	6.3	452	6.3	6.51	< .05	6.51	< .05
4/30/2022	5.16	372	6	7.01	0.11	7.63	0.12
5/31/2022	8.86	619.17	10.17	9.62	0.18	10.35	0.2
6/30/2022	11.52	506.4	13.2	7.57	0.18	8.93	0.21
7/31/2022	11.96	641	15.1	6.03	0.14	8.07	0.19
8/31/2022	13.23	630	14.26	9.61	0.23	11.49	0.26
9/30/2022	10.51	828.41	14.19	10	0.113	12.76	0.21

## Outfall 001

Parameter	Aluminum	Aluminum	Copper	Copper	Lead	Lead
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	62.4	80.3	2.7	Report
Minimum	13	13	6	6	0	0
Maximum	96	96	27	32	2.1	2.8
Median	37.5	38	11	11	0.9675	1
No. of Violations	N/A	N/A	0	0	0	N/A
10/31/2017	47.5	50	11	11	0.985	< 1
11/30/2017	44	44	14	14	1.1	1.1
12/31/2017	40	40	14	14	< 1	< 1
1/31/2018	46	46	27	27	< 1	< 1
2/28/2018	63	63	11	11	1.9	2.8
3/31/2018	36	36	26	26	1.1	1.1
4/30/2018	73	73	26	26	1.2	1.2
5/31/2018	41	41	6	6	1.2	1.2
6/30/2018	26	26	7.9	7.9	0.66	0.66
7/31/2018	52	52	16	16	1.4	1.4
8/31/2018	28	28	7.9	7.9	< 1	< 1
9/30/2018	13	13	6.2	6.2	< 1	< 1
10/31/2018	32	32	21	21	1	1
11/30/2018	19	19	6.2	6.2	< 1	< 1
12/31/2018	34	34	7.8	7.8	< 1	< 1
1/31/2019	32	35	9.4	11	1.3	1.6
2/28/2019	70	70	19	19	1	1
3/31/2019	42.4	42.4	10.5	10.5	< 1	< 1
4/30/2019	39	39	17	17	< 1	< 1
5/31/2019	37	37	11	11	< 1	< 1
6/30/2019	38	38	7.7	7.7	2.1	2.1
7/31/2019	36	36	10	10	1	1
8/31/2019	37	37	8.2	8.2	1	1
9/30/2019	39	39	12	12	< 1	< 1
10/31/2019	66	66	19	19	1.2	1.2
11/30/2019	45	45	18	18	1	1
12/31/2019	44.9	44.9	15.3	15.3	1.14	1.14
1/31/2020	30	30	8.3	8.3	<= 1	<= 1
2/29/2020	28	28	10	10	1.5	1.5
3/31/2020	34	34	8.7	8.7	0.9	0.9
4/30/2020	29	29	7.7	7.7	0.76	0.76
5/31/2020	28.5	39	19.95	32	< .83	< 1



## Outfall 001

Parameter	Aluminum	Aluminum	Copper	Copper	Lead	Lead
	Monthly Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave	Daily Max
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Effluent Limit	Report	Report	62.4	80.3	2.7	Report
6/30/2020	29	34	7.25	7.8	< 1.45	1.9
7/31/2020	48	57	16	20	1.4	1.8
8/31/2020	29.5	31	16	20	1.4	1.8
9/30/2020	48	48	8.6	8.6	1.1	1.1
10/31/2020	30	30	8	8	< 1	< 1
11/30/2020	40	40	12	12	1.1	1.1
12/31/2020	31	32	6.35	6.5	0.765	0.83
1/31/2021	24	24	6.4	6.4	<= .5	<= .5
2/28/2021	24	24	9.6	9.6	0.5	0.5
3/31/2021	36	44	10.5	11	0.575	0.58
4/30/2021	37	37	9	9	0.8	0.8
5/31/2021	33	33	6.8	6.8	0.83	0.83
6/30/2021	40.6	61	11.58	16	1.298	2.4
7/31/2021	64	64	12	12	1.1	1.1
8/31/2021	40	40	11	11	0.84	0.84
9/30/2021	36.5	37	9.85	10	1	1
10/31/2021	34	34	7.6	7.6	0.79	0.79
11/30/2021	38	38	12	12	0.79	0.79
12/31/2021	43	43	16	16	0.84	0.84
1/31/2022	35	35	14	14	0.95	0.95
2/28/2022	43.5	45	18.5	23	0.99	1
3/31/2022	38	38	15	15	1	1
4/30/2022	96	96	18	18	1.1	1.1
5/31/2022	26	26	12	12	0.61	0.61
6/30/2022	38	38	14	14	1	1
7/31/2022	38	38	9.4	9.4	1.5	1.5
8/31/2022	40	40	11	11	1.1	1.1
9/30/2022	26	29	6.67	8	0.867	1

## WET Effluent

Parameter	LC50 Acute Ceriodaphnia	Ammonia	Aluminum	Cadmium	Copper	Lead	Nickel
	Daily Min	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	%	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Effluent Limit	100	Report	Report	Report	Report	Report	Report
Minimum	70.7	0.0039	0.023	0	0.0065	0.00058	0.0072
Maximum	100	12	21	0.0005	0.042	0.083	0.077
Median	100	5.25	0.0335	Non-Detect	0.01	0.00086	0.024
No. of Violations	1	N/A	N/A	N/A	N/A	N/A	N/A
12/31/2017	100	12	0.05	< .0005	0.018	0.00087	0.024
3/31/2018	100	10	0.035	< .0005	0.016	0.00075	0.07
6/30/2018	70.7	8.2	0.026	0.0005	0.0079	0.00066	0.018
9/30/2018	100	3	0.036	< .0005	0.011	0.00095	0.017
12/31/2018	100	5.1	0.025	< .0005	0.0087	0.00063	0.015
3/31/2019	100	5.6	0.05	< .0005	0.022	0.00082	0.048
6/30/2019	100	8.5	NODI: B	NODI: B	0.008	NODI: B	0.014
9/30/2019	100	9.1	0.043	NODI: B	0.015	0.00089	0.043
12/31/2019	100	8.3	0.061	NODI: B	0.022	0.0012	0.048
3/31/2020	100	5.4	21	NODI: B	0.01	0.00079	0.017
6/30/2020	100	6.4	0.032	NODI: B	0.0093	0.00071	0.064
9/30/2020	100	3.5	0.041	NODI: B	0.0093	0.00098	0.017
12/31/2020	100	1.6	0.032	NODI: B	0.0065	0.083	0.019
3/31/2021	100	0.0039	0.028	NODI: B	0.011	0.00058	0.077
6/30/2021	100	4.1	0.031	0.0005	0.0076	0.00093	0.012
9/30/2021	100	1.9	0.029	< .0005	0.0093	0.00097	0.0072
12/31/2021	100	0.0054	0.043	0.0005	0.013	0.00081	0.024
3/31/2022	100	4.7	0.042	< .0005	0.042	0.00099	0.027
6/30/2022	100	11	0.03	< .0005	0.01	0.00085	0.025
9/30/2022	100	1	0.023	< .005	0.0078	0.0069	0.028



## WET Effluent

Parameter	Zinc	Hardness
	Daily Max	Daily Max
Units	mg/L	mg/L
Effluent Limit	Report	Report
Minimum	0.02	30
Maximum	0.056	120
Median	0.0325	90.5
No. of Violations	N/A	N/A
12/31/2017	0.056	87
3/31/2018	0.035	120
6/30/2018	0.031	72
9/30/2018	0.032	47
12/31/2018	0.034	110
3/31/2019	0.041	110
6/30/2019	0.03	95
9/30/2019	0.038	71
12/31/2019	0.036	100
3/31/2020	0.033	88
6/30/2020	0.026	93
9/30/2020	NODI: B	51
12/31/2020	0.032	30
3/31/2021	0.04	100
6/30/2021	0.044	90
9/30/2021	0.02	95
12/31/2021	0.028	91
3/31/2022	0.04	98
6/30/2022	0.032	81
9/30/2022	0.028	64

## WET Ambient

Parameter	pH	Ammonia	Aluminum	Cadmium	Copper	Lead	Nickel	Zinc
	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max	Daily Max
Units	S.U.	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
Minimum	6.8	0	0.01	0	0	0	0	0
Maximum	8	0	0.84	0	0.0027	0.0047	0	0.0062
Median	7.3	Non-Detect	0.079	Non-Detect	Non-Detect	Non-Detect	Non-Detect	Non-Detect
12/31/2017	6.9	<0.02	0.42	<0.0005	<0.005	0.0011	<0.005	<0.02
3/31/2018	7	<0.02	0.089	<0.0005	<0.005	<0.0003	<0.005	<0.02
6/30/2018			0.05	<0.0005	<0.005	<0.0003	<0.005	<0.02
9/30/2018			0.083	<0.0005	<0.005	<0.0003	<0.005	<0.02
12/31/2018			0.079	<0.0005	<0.005	<0.0003	<0.005	<0.02
3/31/2019	6.8	<0.02	0.06	<0.0005	<0.0003	<0.0003	<0.005	<0.02
6/30/2019			0.01	<0.0005	<0.0003	<0.0025	<0.005	<0.02
9/30/2019			0.035	<0.0005	<0.0003	<0.0003	<0.005	<0.02
12/31/2019			0.12	<0.0005	<0.0003	0.00031	<0.005	<0.02
3/31/2020	6.9	<0.02	0.13	<0.0005	<0.0025	0.00035	<0.0005	<0.02
6/30/2020	7.5	<0.02	0.13	<0.0005	<0.0025	0.00048	<0.005	<0.02
9/30/2020	7	<0.02	0.022	<0.0005	<0.0025	<0.0003	<0.005	<0.02
12/31/2020			0.84	<0.0005	0.0027	0.0012	<0.005	0.0062
3/31/2021	7.1	<0.2	0.067	<0.0005	<0.0025	<0.0003	<0.005	<0.005
6/30/2021	8	<0.02	0.037	<0.0005	<0.0025	<0.0003	<0.005	<0.005
9/30/2021	7.6	<0.02	0.11	<0.0005	<0.003	<0.0005	<0.002	<0.005
12/31/2021	7.8	<0.02	0.068	<0.0005	<0.005	<0.0003	<0.005	<0.02
3/31/2022	7.5	<0.2	0.17	<0.0005	<0.0025	0.0047	<0.005	<0.005
6/30/2022	7.5	<0.2	0.043	<0.0005	<0.0025	<0.0003	<0.005	<0.005
9/30/2022								



## WET Ambient

Parameter	Hardness
	Daily Max
Units	mg/L
Minimum	26
Maximum	48
Median	34
12/31/2017	38
3/31/2018	32
6/30/2018	37
9/30/2018	37
12/31/2018	30
3/31/2019	38
6/30/2019	34
9/30/2019	48
12/31/2019	32
3/31/2020	30
6/30/2020	36
9/30/2020	39
12/31/2020	30
3/31/2021	39
6/30/2021	34
9/30/2021	31
12/31/2021	32
3/31/2022	26
6/30/2022	40
9/30/2022	

## CSO Outfall 002

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	0	0	0
Maximum	274403	40.92	9
Median	10730.5	1.08	2
No. of Violations	N/A	N/A	N/A
10/31/2017	44708	9.5	5
11/30/2017	NODI: C	NODI: C	0
12/31/2017	NODI: C	NODI: C	NODI: C
1/31/2018	65737	6.3	3
2/28/2018	585	1	3
3/31/2018	0	0	0
4/30/2018	13630	8.75	2
5/31/2018	3632	0.166	1
6/30/2018	51360	4.75	6
7/31/2018	76224	3.16	6
8/31/2018	98002	2.83	6
9/30/2018	144057	6	4
10/31/2018	212250	4.41	4
11/30/2018	30962	0.83	2
12/31/2018	113677	8.08	1
1/31/2019	274403	5	1
2/28/2019	0	0	0
3/31/2019	0	0	0
4/30/2019	112672	4.5	5
5/31/2019	16508	0.16	2
6/30/2019	0	0	0
7/31/2019	20886	0.5	2
8/31/2019	9915	2.41	2
9/30/2019	5148	0.25	3
10/31/2019	52062	2.25	3
11/30/2019	NODI: C	NODI: C	NODI: C
12/31/2019	53566	1.16	1
1/31/2020	11316	2.58	1
2/29/2020	0	0	0
3/31/2020	NODI: C	NODI: C	NODI: C
4/30/2020	12616	0.5	2
5/31/2020	19.231	0.58	2
6/30/2020	31002	0.5	4



## CSO Outfall 002

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	44620	4	4
8/31/2020	24658	0.41	3
9/30/2020	10640	0.16	2
10/31/2020	NODI: C	NODI: C	NODI: C
11/30/2020	22761	4.91	3
12/31/2020	4041	12.67	3
1/31/2021	1161	1.58	1
2/28/2021	NODI: C	NODI: C	NODI: C
3/31/2021	NODI: C	NODI: C	NODI: C
4/30/2021	2817	10.92	2
5/31/2021	3475	4.58	3
6/30/2021	10821	1.5	2
7/31/2021	56550	40.92	9
8/31/2021	27308	1.91	4
9/30/2021	66209	6.33	2
10/31/2021	1313	0.1	1
11/30/2021	13972	2.3	2
12/31/2021	1029	0.25	1
1/31/2022	NODI: C	NODI: C	NODI: C
2/28/2022	NODI: C	NODI: C	NODI: C
3/31/2022	973	0.1	1
4/30/2022	31630	4.75	2
5/31/2022	32496	2.25	4
6/30/2022	NODI: C	NODI: C	NODI: C
7/31/2022	0.034484	3.58	3
8/31/2022	8435	0.75	1
9/30/2022	14965	7.83	4

## CSO Outfall 007

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	0	0	0
Maximum	182017	30.75	8
Median	10214.5	1.495	2
No. of Violations	N/A	N/A	N/A
10/31/2017	55290	13.1	5
11/30/2017	NODI: C	NODI: C	0
12/31/2017	NODI: C	NODI: C	NODI: C
1/31/2018	64911	6.25	3
2/28/2018	932	2	2
3/31/2018	0	0	0
4/30/2018	6070	1.75	2
5/31/2018	4896	1	1
6/30/2018	71346	5.16	6
7/31/2018	182017	4.25	7
8/31/2018	24659	4.41	8
9/30/2018	82099	15.58	4
10/31/2018	63061	10.5	5
11/30/2018	4938	0.58	2
12/31/2018	28325	9.16	2
1/31/2019	171630	11.33	1
2/28/2019	309	0.83	1
3/31/2019	0	0	0
4/30/2019	58790	19.16	8
5/31/2019	6622	0.33	2
6/30/2019	4130	0.41	2
7/31/2019	36686	1.08	5
8/31/2019	9525	2.83	3
9/30/2019	12604	1.66	3
10/31/2019	30879	2.67	4
11/30/2019	NODI: C	NODI: C	NODI: C
12/31/2019	1730	0.58	1
1/31/2020	2603	0.42	1
2/29/2020	0	0	0
3/31/2020	NODI: C	NODI: C	NODI: C
4/30/2020	3063	1.33	1
5/31/2020	12604	0.25	1
6/30/2020	28977	0.62	3



## CSO Outfall 007

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	27657	4.3	4
8/31/2020	42539	1.08	4
9/30/2020	78621	2.16	3
10/31/2020	NODI: C	NODI: C	NODI: C
11/30/2020	27010	5.66	1
12/31/2020	1185	9.67	1
1/31/2021	1724	3.66	1
2/28/2021	NODI: C	NODI: C	NODI: C
3/31/2021	NODI: C	NODI: C	NODI: C
4/30/2021	137	0.08	1
5/31/2021	10904	5.33	5
6/30/2021	19697	2.5	2
7/31/2021	103884	30.75	8
8/31/2021	66326	2.75	5
9/30/2021	65957	5.75	3
10/31/2021	868	0.25	1
11/30/2021	41177	1.2	1
12/31/2021	129	0.17	1
1/31/2022	NODI: C	NODI: C	NODI: C
2/28/2022	37462	13.92	2
3/31/2022	2869	0.25	2
4/30/2022	21250	5.5	2
5/31/2022	23653	1.66	3
6/30/2022	NODI: C	NODI: C	NODI: C
7/31/2022	0.136287	2.41	5
8/31/2022	50594	1.25	2
9/30/2022	37700	2.33	5

## CSO Outfall 008

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	77362	1.91	1
Maximum	9141344	210.67	11
Median	1931037	16.03	4
No. of Violations	N/A	N/A	N/A
10/31/2017	6447097	20.58	6
11/30/2017	622077	22.1	1
12/31/2017	108471	1.91	2
1/31/2018	6028402	25.1	2
2/28/2018	3657334	25.5	6
3/31/2018	184222	5.16	2
4/30/2018	1307406	26	4
5/31/2018	492710	2.66	2
6/30/2018	4579622	16.41	5
7/31/2018	5454217	16.66	9
8/31/2018	2670582	16.8	11
9/30/2018	7694458	35.33	9
10/31/2018	4684751	21.41	6
11/30/2018	4630696	44.1	7
12/31/2018	4437422	21.25	5
1/31/2019	5864966	22.75	5
2/28/2019	318391	8.41	3
3/31/2019	77362	4.91	3
4/30/2019	4980583	75.58	9
5/31/2019	1092530	31.5	8
6/30/2019	907807	6.91	6
7/31/2019	2954641	17.08	6
8/31/2019	1516756	20.91	3
9/30/2019	1510787	3.66	4
10/31/2019	4303434	17.67	5
11/30/2019	902757	11.91	2
12/31/2019	3388517	20.16	2
1/31/2020	857063	3.17	1
2/29/2020	312676	5.58	2
3/31/2020	1911000	19.5	9
4/30/2020	1633492	41.08	4
5/31/2020	936680	7.83	4
6/30/2020	1165625	2.33	5



## CSO Outfall 008

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	2184767	7.36	5
8/31/2020	1951074	3.5	5
9/30/2020	2682753	6.5	3
10/31/2020	1473943	21.85	5
11/30/2020	4018687	16.91	4
12/31/2020	3440863	22.67	3
1/31/2021	2060302	5.75	1
2/28/2021	295199	3.17	1
3/31/2021	309168	10.83	4
4/30/2021	916585	19.3	4
5/31/2021	2377102	24.2	8
6/30/2021	1235101	3.58	2
7/31/2021	9141344	210.67	8
8/31/2021	3589392	16.16	5
9/30/2021	5948498	13.93	5
10/31/2021	2157638	15.9	7
11/30/2021	1590253	5.7	2
12/31/2021	387367	4.83	5
1/31/2022	470129	2.5	1
2/28/2022	4334932	20.17	2
3/31/2022	349575	6.42	3
4/30/2022	2995815	10.67	3
5/31/2022	793813	5.5	4
6/30/2022	432089	3.42	2
7/31/2022	2514889	13.75	5
8/31/2022	872082	1.92	3
9/30/2022	2879337	19.25	4

## CSO Outfall 009

Parameter	Flow	Flow - B - A	Flow 009 - O - A	BOD5	BOD5	BOD5	BOD5	TSS
	MO TOTAL	MO TOTAL	MO TOTAL	Monthly Ave	Monthly Ave	Daily Max	Daily Max	Monthly Ave
Units	gal/mo	gal/mo	gal/mo	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report	Report
Minimum	0	0	1.164	1012	20	1012	20	25
Maximum	32414000	24814000	9183000	2399	21	2399	21	6970
Median	9.5045	0	4.7725	Non-Detect	Non-Detect	Non-Detect	Non-Detect	Non-Detect
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/31/2017	22520000	8300000	3199000					
11/30/2017	NODI: C	NODI: C	553000	2399	21	2399	21	6970
12/31/2017	NODI: C	NODI: C	1216000					
1/31/2018	29880000	3700000	2612000					
2/28/2018	20.42	NODI: C	2.975					
3/31/2018	0	403000	403000					
4/30/2018	11.81	0	2.534					
5/31/2018	2550000	0	2301000	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F
6/30/2018	14060000	9239000	3998000					
7/31/2018	9290000	24814000	4559000					
8/31/2018	29876000	3700000	2612000					
9/30/2018	32414000	8447000	4311000					
10/31/2018	7099000	13261000	3973000					
11/30/2018	19961000	0	5198000	1012	20	1012	20	243
12/31/2018	22242000	3254000	3336000					
1/31/2019	28875000	6818000	2001000					
2/28/2019	0	0	1130000					
3/31/2019	0	0	477000					
4/30/2019	22316000	2053000	9183000					
5/31/2019	3763000	1850000	3332000	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
6/30/2019	0.19	0	5.82					
7/31/2019	6.901	3.473	4.639					
8/31/2019	6.379	0	4.155					
9/30/2019	1.867	0	4.879					
10/31/2019	13.033	10.058	3.616					
11/30/2019	3.507	0	3.51	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F
12/31/2019	10.421	0	2.542					
1/31/2020	5.671	0	1.567					
2/29/2020	4.3	0	1.287					
3/31/2020	2.734	0	3.007					
4/30/2020	11.709	0	3.997					
5/31/2020	8.775	2.06	2.884	NODI: Z	NODI: Z	NODI: Z	NODI: Z	25
6/30/2020	2.96	0	2.05					



## CSO Outfall 009

Parameter	Flow	Flow 009 - B - A	Flow 009 - O - A	BOD5	BOD5	BOD5	BOD5	TSS
	MO TOTAL	MO TOTAL	MO TOTAL	Monthly Ave	Monthly Ave	Daily Max	Daily Max	Monthly Ave
Units	gal/mo	gal/mo	gal/mo	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report	Report
7/31/2020	3.766	6.443	5.757					
8/31/2020	1.012	4.326	4.55					
9/30/2020	7.001	17.639	1.977					
10/31/2020	12.303	0	4.913					
11/30/2020	6.3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3
12/31/2020	25.927	0	4.666					
1/31/2021	10.851	0	1.498					
2/28/2021	2.794	0	1.443					
3/31/2021	1.413	0	2.158					
4/30/2021	8.077	0	4.614					
5/31/2021	7.72	0	6.548	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3
6/30/2021	1.478	0	3.134					
7/31/2021	30.567	19.091	9.182					
8/31/2021	16.87	0	4.582					
9/30/2021	27.242	19.201	2.673					
10/31/2021	9.737	0	3.422					
11/30/2021	7.45	5.674	2.18	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
12/31/2021	NODI: C	NODI: C	1500000					
1/31/2022	1.275	0	1.164					
2/28/2022	24950000	NODI: C	2813000					
3/31/2022	NODI: C	NODI: C	2582000					
4/30/2022	18981000	2200000	4374000					
5/31/2022	4178000	NODI: C	2462000	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
6/30/2022	1301000	NODI: C	1149000					
7/31/2022	9.272	8.61	4.369					
8/31/2022	1.514	8.186	2.809					
9/30/2022	16.283	7.276	4.151					

## CSO Outfall 009

Parameter	TSS	TSS	TSS	pH	pH	TRC	TRC	Ammonia
	Monthly Ave	Daily Max	Daily Max	Minimum	Maximum	Monthly Ave	Daily Max	Monthly Ave
Units	mg/L	lb/d	mg/L	SU	SU	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	0.24	Report
Minimum	4.8	25	4.8	5.1	6.2	0	0	0.84
Maximum	61	6970	61	7.7	8.9	8	0.23	1.2
Median	Non-Detect	Non-Detect	Non-Detect	6.69	7.275	0.05	0.085	Non-Detect
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	0	N/A
10/31/2017				6.3	6.9	0.05	0.12	
11/30/2017	61	6970	61	NODI: C	NODI: C	NODI: C	NODI: C	0.84
12/31/2017				NODI: C	NODI: C	NODI: C	NODI: C	
1/31/2018				6.9	7.8	0.13	0.18	
2/28/2018				7.5	7.9	0.14	0.22	
3/31/2018				NODI: C	NODI: C	NODI: C	NODI: C	
4/30/2018				7.2	7.3	0.13	0.2	
5/31/2018	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F	0.12	0.17	NODI: F
6/30/2018				5.1	6.8	0.09	0.2	
7/31/2018				5.9	7.1	0.1	0.2	
8/31/2018				7.2	7.5	0.1	0.15	
9/30/2018				6.7	7.7	0.08	0.2	
10/31/2018				7.5	7.8	0.07	0.13	
11/30/2018	4.8	243	4.8	7.4	8.3	0.03	0.1	1.2
12/31/2018				6.2	7.3	0.06	0.2	
1/31/2019				6.5	7.4	0.05	0.11	
2/28/2019				6.2	6.2	0.07	0.07	
3/31/2019				NODI: C	NODI: C	NODI: C	NODI: C	
4/30/2019				6.3	7.25	8	0.21	
5/31/2019	NODI: C	NODI: C	NODI: C	6.9	7.9	0.04	0.08	NODI: C
6/30/2019				NODI: F	NODI: F	NODI: F	NODI: F	
7/31/2019				6.21	6.69	4	0.04	
8/31/2019				6.87	7.09	0.03	0.1	
9/30/2019				6.3	6.7	0.14	0.19	
10/31/2019				6.7	7.2	0.04	0.07	
11/30/2019	NODI: F	NODI: F	NODI: F	6.4	6.8	0.08	0.11	NODI: F
12/31/2019				6.2	7.6	0.08	0.08	
1/31/2020				6.02	6.37	0.13	0.2	
2/29/2020				6.5	6.6	0.03	0.05	
3/31/2020				6.68	7.11	0.05	0.07	
4/30/2020				7.1	7.6	4.17	0.05	
5/31/2020	25	25	25	6.3	7.8	0.03	0.07	NODI: B
6/30/2020				7.2	8.9	0	0	



## CSO Outfall 009

Parameter	TSS	TSS	TSS	pH	pH	TRC	TRC	Ammonia
	Monthly Ave	Daily Max	Daily Max	Minimum	Maximum	Monthly Ave	Daily Max	Monthly Ave
Units	mg/L	lb/d	mg/L	SU	SU	mg/L	mg/L	mg/L
Effluent Limit	Report	Report	Report	Report	Report	Report	0.24	Report
7/31/2020				7.7	7.8	0.02	0.06	
8/31/2020				7.4	8.6	0.11	0.22	
9/30/2020				6.3	7.3	0.02	0.07	
10/31/2020				6.44	7.6	0.06	0.21	
11/30/2020	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3
12/31/2020				6.7	8.11	0.08	0.16	
1/31/2021				7.51	7.79	0.02	0.05	
2/28/2021				7.24	7.41	0.06	0.09	
3/31/2021				6.87	7	0.035	0.07	
4/30/2021				7.4	7.8	0.04	0.1	
5/31/2021	NODI: 3	NODI: 3	NODI: 3	7.1	8.2	0.05	0.1	NODI: 3
6/30/2021				7	7.2	0.12	0.19	
7/31/2021				6.9	8.8	0.08	0.23	
8/31/2021				7.2	8.3	0.04	0.08	
9/30/2021				5.82	8.1	0.05	0.07	
10/31/2021				6.8	7.13	0.01	0.09	
11/30/2021	NODI: C	NODI: C	NODI: C	6.7	7.1	0.02	0.1	NODI: C
12/31/2021				NODI: C	NODI: C	NODI: C	NODI: C	
1/31/2022				7.3	7.3	0	0	
2/28/2022				6.4	6.76	0.04	0.04	
3/31/2022				NODI: C	NODI: C	NODI: C	NODI: C	
4/30/2022				6.72	8.22	0.06	0.12	
5/31/2022	NODI: C	NODI: C	NODI: C	6.72	7.5	0.06	0.18	NODI: C
6/30/2022				6.82	6.82	0.03	0.03	
7/31/2022				6.4	7	0.01	0.03	
8/31/2022				6.7	6.8	0.02	0.04	
9/30/2022				6	7.3	0.03	0.07	

## CSO Outfall 009

Parameter	Ammonia	TKN	TKN	TN	TN	Nitrate	Nitrate	Nitrite
	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave
Units	Mlb/d	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report	Report
Minimum	61	23.1	1.8	134.9	2	11.46	0.17	2.5
Maximum	96	308	3.5	331	3.8	25.1	0.26	5.7
Median	Non-Detect	Non-Detect	Non-Detect	Non-Detect	Non-Detect	Non-Detect	Non-Detect	Non-Detect
No. of Violations	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/31/2017								
11/30/2017	96	308	2.7	331	2.9	25.1	0.22	5.7
12/31/2017								
1/31/2018								
2/28/2018								
3/31/2018								
4/30/2018								
5/31/2018	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F
6/30/2018								
7/31/2018								
8/31/2018								
9/30/2018								
10/31/2018								
11/30/2018	61	177	3.5	192	3.8	13.2	0.26	2.5
12/31/2018								
1/31/2019								
2/28/2019								
3/31/2019								
4/30/2019								
5/31/2019	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
6/30/2019								
7/31/2019								
8/31/2019								
9/30/2019								
10/31/2019								
11/30/2019	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F	NODI: F
12/31/2019								
1/31/2020								
2/29/2020								
3/31/2020								
4/30/2020								
5/31/2020	NODI: B	23.1	1.8	134.9	2	11.46	0.17	NODI: B
6/30/2020								



## CSO Outfall 009

Parameter	Ammonia	TKN	TKN	TN	TN	Nitrate	Nitrate	Nitrite
	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave	Monthly Ave
Units	Mlb/d	lb/d	mg/L	lb/d	mg/L	lb/d	mg/L	lb/d
Effluent Limit	Report	Report	Report	Report	Report	Report	Report	Report
7/31/2020								
8/31/2020								
9/30/2020								
10/31/2020								
11/30/2020	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3
12/31/2020								
1/31/2021								
2/28/2021								
3/31/2021								
4/30/2021								
5/31/2021	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 3	NODI: 2
6/30/2021								
7/31/2021								
8/31/2021								
9/30/2021								
10/31/2021								
11/30/2021	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
12/31/2021								
1/31/2022								
2/28/2022								
3/31/2022								
4/30/2022								
5/31/2022	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C	NODI: C
6/30/2022								
7/31/2022								
8/31/2022								
9/30/2022								

## CSO Outfall 009

Parameter	Nitrite	E. coli	Duration of discharge	E. coli	Number of Events
	Monthly Ave	Daily Max	MO TOTAL	MO GEOMN	MO TOTAL
Units	mg/L	CFU/100mL	hr/mo	CFU/100mL	#
Effluent Limit	Report	409	Report	126	Report
Minimum	No Data	5	0	5	0
Maximum	No Data	1150	17.9	599	9
Median	No Data	14	4.305	7.5	2
No. of Violations	N/A	2	N/A	2	N/A
10/31/2017		248	13.1	28.9	3
11/30/2017	< .05	NODI: C	NODI: C	NODI: C	0
12/31/2017		NODI: C	NODI: C	NODI: C	NODI: C
1/31/2018		658	11.5	208	1
2/28/2018		404	11.8	16	3
3/31/2018		NODI: C	0	NODI: C	0
4/30/2018		1150	4	599	1
5/31/2018	NODI: F	NODI: F	2	NODI: F	1
6/30/2018		180	7.6	93	1
7/31/2018		NODI: C	8.2	NODI: C	4
8/31/2018		NODI: C	11.5	NODI: C	3
9/30/2018		400	15.3	33	5
10/31/2018		17	5.5	9	4
11/30/2018	< .05	160	12.5	105	4
12/31/2018		264	11.7	78	3
1/31/2019		160	10.1	112	2
2/28/2019		NODI: C	1.2	NODI: C	2
3/31/2019		NODI: C	0	NODI: C	0
4/30/2019		NODI: C	12.3	NODI: C	5
5/31/2019	NODI: C	NODI: C	1.3	NODI: C	3
6/30/2019		NODI: F	0.2	NODI: F	2
7/31/2019		NODI: F	4.1	NODI: F	3
8/31/2019		NODI: F	4.51	NODI: F	2
9/30/2019		NODI: F	1	NODI: F	2
10/31/2019		47	7.2	10	3
11/30/2019	NODI: F	NODI: F	2.1	NODI: F	1
12/31/2019		75	5.7	38	1
1/31/2020		NODI: F	2	NODI: F	1
2/29/2020		NODI: F	3.1	NODI: F	1
3/31/2020		NODI: F	2.1	NODI: F	2
4/30/2020		48	6.1	14	2
5/31/2020	NODI: B	52	4.9	16	2
6/30/2020		NODI: F	1	NODI: F	3



## CSO Outfall 009

Parameter	Nitrite	E. coli	Duration of discharge	E. coli	Number of Events
	Monthly Ave	Daily Max	MO TOTAL	MO GEOMN	MO TOTAL
Units	mg/L	CFU/100mL	hr/mo	CFU/100mL	#
Effluent Limit	Report	409	Report	126	Report
7/31/2020		NODI: F	2.9	NODI: F	3
8/31/2020		NODI: F	0.7	NODI: F	2
9/30/2020		NODI: F	4.1	NODI: F	2
10/31/2020		NODI: 3	8.4	NODI: 3	4
11/30/2020	NODI: 3	NODI: 3	9.4	NODI: 3	NODI: 3
12/31/2020		63	16.2	43	2
1/31/2021		43	4.9	23	1
2/28/2021		NODI: F	1.5	NODI: F	1
3/31/2021		5	1.3	5	1
4/30/2021		45	5	20	3
5/31/2021	NODI: 2	47	9.5	8	7
6/30/2021		78	0.9	78	2
7/31/2021		75	17.9	8.49	9
8/31/2021		24	8.6	9	3
9/30/2021		69	9.7	41	3
10/31/2021		49	6.1	19.7	2
11/30/2021	NODI: C	58	3.4	19	2
12/31/2021		NODI: C	NODI: C	NODI: C	NODI: C
1/31/2022		31	1	31	1
2/28/2022		55	17.7	56	1
3/31/2022		NODI: C	NODI: C	NODI: C	NODI: C
4/30/2022		20	8.5	10	3
5/31/2022	NODI: C	NODI: C	2.6	NODI: C	2
6/30/2022		50	1.1	50	1
7/31/2022		203	3.7	28	4
8/31/2022		11	1.2	11	1
9/30/2022		17	9.3	7	4

## WET CSO Outfall 009

Parameter	LC50 Acute Ceriodaphnia
	Monthly Ave Min
Units	%
Effluent Limit	Report
Minimum	70.7
Maximum	100
Median	100
No. of Violations	N/A
11/30/2017	70.7
5/31/2018	NODI: F
11/30/2018	100
5/31/2019	NODI: C
11/30/2019	100
5/31/2020	100
11/30/2020	100
5/31/2021	100
11/30/2021	100
5/31/2022	NODI: C



## CSO Outfall 011

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	398	0.17	0
Maximum	5267551	775	19
Median	400195	8.44	4
No. of Violations	N/A	N/A	N/A
10/31/2017	1179073	27.75	4
11/30/2017	NODI: C	NODI: C	0
12/31/2017	28027	2.16	2
1/31/2018	2026312	46.7	2
2/28/2018	684706	18.92	5
3/31/2018	48750	2.5	2
4/30/2018	1168919	11.8	3
5/31/2018	133041	2.83	3
6/30/2018	1345848	17.25	6
7/31/2018	2117202	16.66	8
8/31/2018	589724	18.16	11
9/30/2018	1671985	35.16	7
10/31/2018	845883	15.66	5
11/30/2018	1524636	26.75	7
12/31/2018	1267917	18.75	9
1/31/2019	901728	11.08	3
2/28/2019	30492	44.08	10
3/31/2019	26969	38.6	10
4/30/2019	2629532	42.75	19
5/31/2019	1041453	123.75	12
6/30/2019	121585	19.5	6
7/31/2019	604156	17.5	6
8/31/2019	300721	21	3
9/30/2019	268497	4.16	5
10/31/2019	753710	13.67	5
11/30/2019	118838	7.16	1
12/31/2019	309257	8.58	2
1/31/2020	149270	3.17	1
2/29/2020	72453	5.6	2
3/31/2020	526525	7.3	4
4/30/2020	619241	28.75	5
5/31/2020	478253	4.16	4
6/30/2020	401462	3.67	4

## CSO Outfall 011

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	796170	8.3	5
8/31/2020	545111	4.25	6
9/30/2020	766052	7.08	5
10/31/2020	373895	22.83	4
11/30/2020	726265	15.33	4
12/31/2020	858338	18.33	7
1/31/2021	541966	5.41	1
2/28/2021	100516	3.33	1
3/31/2021	350409	5.25	3
4/30/2021	404492	13.92	5
5/31/2021	2580871	30.75	7
6/30/2021	194279	1.92	3
7/31/2021	5267551	775	9
8/31/2021	352544	10.41	5
9/30/2021	1113457	10.67	4
10/31/2021	47566	2.3	2
11/30/2021	165260	5.4	2
12/31/2021	398	0.33	1
1/31/2022	1147	0.75	1
2/28/2022	6972	2.25	2
3/31/2022	1057	0.17	1
4/30/2022	398928	8.25	2
5/31/2022	NODI: C	NODI: C	NODI: C
6/30/2022	NODI: C	NODI: C	NODI: C
7/31/2022	NODI: C	NODI: C	NODI: C
8/31/2022	NODI: C	NODI: C	NODI: C
9/30/2022	NODI: C	NODI: C	NODI: C



## CSO Outfall 016

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	10901	0.58	2
Maximum	1009550	459.41	19
Median	151347.5	37.44	7
No. of Violations	N/A	N/A	N/A
10/31/2017	557765	48.3	10
11/30/2017	10901	18.58	6
12/31/2017	25458	16.66	7
1/31/2018	286469	40.7	2
2/28/2018	136237	52.58	8
3/31/2018	16825	24.25	3
4/30/2018	217572	100.3	9
5/31/2018	140156	26.58	8
6/30/2018	474283	46.08	5
7/31/2018	538720	34.08	8
8/31/2018	488334	52.33	15
9/30/2018	464849	25.33	6
10/31/2018	255722	37.8	8
11/30/2018	290091	103.9	13
12/31/2018	282934	55.33	7
1/31/2019	234729	37.08	5
2/28/2019	33920	49.6	8
3/31/2019	37451	31.5	7
4/30/2019	336608	97.33	12
5/31/2019	133968	38.58	13
6/30/2019	80323	29.1	8
7/31/2019	172403	38.25	9
8/31/2019	120864	25.58	7
9/30/2019	54592	10.16	7
10/31/2019	270344	45.17	10
11/30/2019	88248	25.25	5
12/31/2019	147271	87	4
1/31/2020	56592	15.3	4
2/29/2020	66488	67.5	6
3/31/2020	19597	20.41	6
4/30/2020	155424	87.41	11
5/31/2020	89783	26.8	5
6/30/2020	128280	6.75	8

## CSO Outfall 016

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	174570	10	5
8/31/2020	62548	0.58	3
9/30/2020	196734	1.25	2
10/31/2020	211644	76.41	10
11/30/2020	305730	39.83	11
12/31/2020	294683	41.83	5
1/31/2021	144203	22	2
2/28/2021	69265	21.58	3
3/31/2021	120679	31.16	6
4/30/2021	164721	51.26	8
5/31/2021	293230	57.33	7
6/30/2021	67671	229.6	14
7/31/2021	1009550	459.41	15
8/31/2021	349737	78.83	19
9/30/2021	401165	31.25	9
10/31/2021	276704	95.7	6
11/30/2021	79108	23.9	6
12/31/2021	77887	54.83	12
1/31/2022	32455	16.33	3
2/28/2022	186187	56.33	4
3/31/2022	84813	38.5	12
4/30/2022	245169	44.08	13
5/31/2022	80259	22.66	9
6/30/2022	NODI: C	NODI: C	NODI: C
7/31/2022	157187	2.91	4
8/31/2022	105217	1.17	2
9/30/2022	183213	0.92	3



## CSO Outfall 018

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	8.91628	1	1
Maximum	8502493	105.75	18
Median	1834815.5	26.025	9.5
No. of Violations	N/A	N/A	N/A
10/31/2017	7826642	50.5	15
11/30/2017	26463	1	2
12/31/2017	669073	13.5	7
1/31/2018	6463543	87.58	7
2/28/2018	3759535	43.75	13
3/31/2018	189160	9.75	1
4/30/2018	1123693	29.16	6
5/31/2018	73475	4.5	5
6/30/2018	4031550	38.58	13
7/31/2018	7445697	26.91	14
8/31/2018	2774396	21.41	15
9/30/2018	8502493	65.67	17
10/31/2018	4424045	45.41	10
11/30/2018	3486244	58.16	11
12/31/2018	5330824	60	9
1/31/2019	5736393	36.5	8
2/28/2019	939173	24.91	5
3/31/2019	178629	17.5	4
4/30/2019	4214205	105.75	17
5/31/2019	991915	17.5	10
6/30/2019	611331	15.8	6
7/31/2019	1322378	33.91	11
8/31/2019	734018	16.41	7
9/30/2019	205226	3.66	6
10/31/2019	4330478	38.75	12
11/30/2019	1834236	30.83	8
12/31/2019	2902964	56.83	6
1/31/2020	835916	10.67	4
2/29/2020	698372	16.17	6
3/31/2020	1262524	24.2	7
4/30/2020	2478376	57.08	11
5/31/2020	1243933	14.16	9
6/30/2020	1614428	20.58	15

## CSO Outfall 018

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	5630170	40	18
8/31/2020	1201186	5.8	10
9/30/2020	3420871	26	15
10/31/2020	665884	40.91	10
11/30/2020	2340175	43.91	9
12/31/2020	2353776	52.33	4
1/31/2021	652138	12.66	3
2/28/2021	519692	10.58	3
3/31/2021	1413890	23.41	10
4/30/2021	2871065	61.25	11
5/31/2021	1206112	31.33	13
6/30/2021	213092	10.41	6
7/31/2021	6014204	26.05	15
8/31/2021	4564187	17.58	12
9/30/2021	2541929	23.67	7
10/31/2021	3989524	67.2	10
11/30/2021	2826163	14.3	4
12/31/2021	1679859	38.42	15
1/31/2022	877423	8.08	2
2/28/2022	7554448	71.75	8
3/31/2022	1772833	19.1	11
4/30/2022	5642394	35.91	13
5/31/2022	1835395	8.42	8
6/30/2022	1284366	8.67	5
7/31/2022	8.91628	26.25	12
8/31/2022	3439563	11.83	10
9/30/2022	8483868	66.41	12



## CSO Outfall 019

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	0	0	0
Maximum	108477	31.8	6
Median	626.5	0.165	1
No. of Violations	N/A	N/A	N/A
10/31/2017	108477	31.8	6
11/30/2017	NODI: C	NODI: C	0
12/31/2017	NODI: C	NODI: C	NODI: C
1/31/2018	1047	10.9	2
2/28/2018	NODI: C	NODI: C	0
3/31/2018	0	0	0
4/30/2018	210	1	1
5/31/2018	0	0	0
6/30/2018	6116	3.41	3
7/31/2018	17243	3.25	6
8/31/2018	979	0.41	4
9/30/2018	18427	9.83	5
10/31/2018	5644	1.3	2
11/30/2018	0	0	0
12/31/2018	0	0	0
1/31/2019	2248	3.33	1
2/28/2019	0	0	0
3/31/2019	0	0	0
4/30/2019	0	0	0
5/31/2019	554	0.08	1
6/30/2019	0	0	0
7/31/2019	5131	3.75	2
8/31/2019	4020	6.5	3
9/30/2019	272	0.16	2
10/31/2019	4065	1.75	2
11/30/2019	NODI: C	NODI: C	NODI: C
12/31/2019	NODI: C	NODI: C	NODI: C
1/31/2020	NODI: C	NODI: C	NODI: C
2/29/2020	0	0	0
3/31/2020	NODI: C	NODI: C	NODI: C
4/30/2020	NODI: C	NODI: C	NODI: C
5/31/2020	699	0.16	1
6/30/2020	3840	0.75	4

## CSO Outfall 019

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	25846	6.16	5
8/31/2020	6260	1	2
9/30/2020	12123	1.91	3
10/31/2020	51	0.08	1
11/30/2020	4193	1.25	1
12/31/2020	NODI: C	NODI: C	NODI: C
1/31/2021	NODI: C	NODI: C	NODI: C
2/28/2021	NODI: C	NODI: C	NODI: C
3/31/2021	NODI: C	NODI: C	NODI: C
4/30/2021	1530	0.5	2
5/31/2021	1122	0.16	2
6/30/2021	NODI: C	NODI: C	NODI: C
7/31/2021	3457	10	3
8/31/2021	7107	1.16	3
9/30/2021	10924	5	1
10/31/2021	0	0	0
11/30/2021	3098	0.5	1
12/31/2021	2519	1.83	6
1/31/2022	NODI: C	NODI: C	NODI: C
2/28/2022	4193	2.5	3
3/31/2022	80	0.17	1
4/30/2022	3147	2.83	2
5/31/2022	787	0.25	1
6/30/2022	124	0.08	1
7/31/2022	16057	3.67	5
8/31/2022	10829	3.08	4
9/30/2022	9332	3.17	5



## CSO Outfall 020

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	130536	1.15	1
Maximum	3311739	554.58	17
Median	698584	26	6
No. of Violations	N/A	N/A	N/A
10/31/2017	1673640	50.3	5
11/30/2017	130536	1.15	2
12/31/2017	220951	11.58	3
1/31/2018	2352307	16.04	2
2/28/2018	2413290	260.08	16
3/31/2018	499912	192.25	3
4/30/2018	361547	44.41	6
5/31/2018	177550	13.83	5
6/30/2018	942577	28.66	6
7/31/2018	924772	24.25	9
8/31/2018	642509	35.75	15
9/30/2018	2871424	177.16	8
10/31/2018	1186293	146.25	12
11/30/2018	2810382	554.58	8
12/31/2018	2822910	437	16
1/31/2019	2242447	279.17	14
2/28/2019	708735	137.8	15
3/31/2019	311167	110	9
4/30/2019	3311739	341.83	11
5/31/2019	1178221	357.67	17
6/30/2019	475778	13.33	5
7/31/2019	688433	18.58	6
8/31/2019	559164	17.5	6
9/30/2019	343012	6.83	6
10/31/2019	1317275	20.25	6
11/30/2019	575000	16.5	5
12/31/2019	1194937	87.16	3
1/31/2020	395701	10.58	3
2/29/2020	568578	87.5	4
3/31/2020	437332	23.16	8
4/30/2020	1617116	70.25	11
5/31/2020	616912	48.6	5
6/30/2020	316182	6.92	6

## CSO Outfall 020

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	669459	12.8	7
8/31/2020	207847	3.8	5
9/30/2020	793531	13.8	7
10/31/2020	1253880	31.75	8
11/30/2020	1569468	28.25	5
12/31/2020	1858088	127.67	6
1/31/2021	644211	23.75	2
2/28/2021	262732	7.08	2
3/31/2021	321664	15.5	4
4/30/2021	2337014	53.66	5
5/31/2021	1481783	63.75	10
6/30/2021	259952	9.42	4
7/31/2021	2830875	206.25	7
8/31/2021	1376086	27.75	5
9/30/2021	1688461	5.3	3
10/31/2021	2102317	52.8	5
11/30/2021	432249	7.1	2
12/31/2021	678039	23.33	9
1/31/2022	298607	4.58	1
2/28/2022	2851030	49.58	5
3/31/2022	341020	16.6	7
4/30/2022	1498756	43.41	8
5/31/2022	300580	4.83	4
6/30/2022	325210	4.5	2
7/31/2022	714815	18.3	5
8/31/2022	538568	6.08	5
9/30/2022	2339122	33.67	6



## CSO Outfall 021

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	405.316	0.33	0
Maximum	14044630	490.67	25
Median	1302475.5	19.5	8
No. of Violations	N/A	N/A	N/A
10/31/2017	7771643	63.8	10
11/30/2017	NODI: C	NODI: C	0
12/31/2017	327219	6.66	5
1/31/2018	5010398	76.5	2
2/28/2018	7059943	86.67	10
3/31/2018	2195967	41.58	2
4/30/2018	6909995	70.66	10
5/31/2018	791615	15.3	9
6/30/2018	3761993	32.08	14
7/31/2018	5145743	39.16	18
8/31/2018	4626885	30.25	25
9/30/2018	14044630	108	19
10/31/2018	6467013	67.41	12
11/30/2018	6730342	111.25	13
12/31/2018	2434079	53.16	10
1/31/2019	2572813	35.17	10
2/28/2019	297425	15.16	5
3/31/2019	63863	7.32	6
4/30/2019	4521617	160.83	16
5/31/2019	755021	18.25	12
6/30/2019	426021	7.5	8
7/31/2019	774336	29.92	10
8/31/2019	938936	18.08	8
9/30/2019	394339	7.75	8
10/31/2019	1105278	20.67	10
11/30/2019	192939	13.66	2
12/31/2019	628675	27.41	4
1/31/2020	405.316	7.17	4
2/29/2020	312527	12.05	5
3/31/2020	120500	4.6	3
4/30/2020	1301163	54.66	9
5/31/2020	833198	17.16	8
6/30/2020	522835	4.75	8

## CSO Outfall 021

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	2077305	14.5	9
8/31/2020	678641	5.5	6
9/30/2020	1666470	13	8
10/31/2020	1307770	18.33	11
11/30/2020	4940056	38.25	9
12/31/2020	9895134	37.08	6
1/31/2021	2971351	13.66	3
2/28/2021	112508	1.17	1
3/31/2021	14968	0.33	1
4/30/2021	1459458	28	9
5/31/2021	2662518	37.08	16
6/30/2021	824037	6.25	5
7/31/2021	8411847	490.67	10
8/31/2021	2666470	25.75	10
9/30/2021	3680472	32.17	5
10/31/2021	1077421	48.6	9
11/30/2021	1303788	9.7	4
12/31/2021	258474	4.25	7
1/31/2022	34940	1.67	2
2/28/2022	3107013	40.5	4
3/31/2022	184648	3.6	8
4/30/2022	2385710	32.25	8
5/31/2022	441071	1.66	3
6/30/2022	310612	4.08	3
7/31/2022	1351805	27.3	11
8/31/2022	920101	8.25	10
9/30/2022	2117000	50.5	10



## CSO Outfall 023

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
Minimum	0	0	0
Maximum	439264	60.33	9
Median	27167.5	3.125	2
No. of Violations	N/A	N/A	N/A
10/31/2017	113148	12.25	4
11/30/2017	NODI: C	NODI: C	0
12/31/2017	NODI: C	NODI: C	NODI: C
1/31/2018	175490	12.58	2
2/28/2018	5770	8.75	3
3/31/2018	0	0	0
4/30/2018	2755	1.66	1
5/31/2018	5257	0.91	1
6/30/2018	78026	5.75	5
7/31/2018	158653	5	8
8/31/2018	27798	2.66	9
9/30/2018	180343	20.25	6
10/31/2018	97044	11.33	4
11/30/2018	18241	5	3
12/31/2018	91718	9.83	3
1/31/2019	167386	7.91	2
2/28/2019	0	0	0
3/31/2019	0	0	0
4/30/2019	72172	21.67	7
5/31/2019	15343	0.58	2
6/30/2019	8142	0.83	4
7/31/2019	17886	11.8	5
8/31/2019	92884	5.41	3
9/30/2019	19099	2.33	3
10/31/2019	124427	6.67	5
11/30/2019	392	5.25	1
12/31/2019	31116	1.41	1
1/31/2020	28870	3	2
2/29/2020	183	2.25	1
3/31/2020	183	2.25	1
4/30/2020	20504	3.08	5
5/31/2020	28953	2.41	3
6/30/2020	69410	1.5	4

## CSO Outfall 023

Parameter	Flow	Duration of discharge	Number of Events
	MO TOTAL	MO TOTAL	MO TOTAL
Units	gal/mo	hr/mo	#
Effluent Limit	Report	Report	Report
7/31/2020	301722	7.3	6
8/31/2020	63972	1.5	4
9/30/2020	259697	7.41	2
10/31/2020	138	0.16	1
11/30/2020	128606	6.33	4
12/31/2020	22731	11.42	3
1/31/2021	16560	3.58	1
2/28/2021	3649	0.58	1
3/31/2021	299	0.25	1
4/30/2021	34982	1.92	4
5/31/2021	26537	10.25	4
6/30/2021	69097	2.5	2
7/31/2021	439264	60.33	6
8/31/2021	309811	4.33	5
9/30/2021	195319	5.5	2
10/31/2021	5456	5.8	2
11/30/2021	61384	1.8	2
12/31/2021	7829	0.42	1
1/31/2022	NODI: C	NODI: C	NODI: C
2/28/2022	19231	12.33	2
3/31/2022	9232	0.4	2
4/30/2022	33186	7.42	2
5/31/2022	16110	0.33	1
6/30/2022	885	0.33	1
7/31/2022	148193	13.75	5
8/31/2022	186489	3.17	4
9/30/2022	118377	7.25	4



A reasonable potential analysis is completed using a single set of critical conditions for flow and pollutant concentration that will ensure the protection of water quality standards. To determine the critical condition of the effluent, EPA projects an upper bound of the effluent concentration based on the observed monitoring data and a selected probability basis. EPA generally applies the quantitative approach found in Appendix E of EPA's *Technical Support Document for Water Quality-based Toxics Control* (TSD)<sup>1</sup> to determine the upper bound of the effluent data. This methodology accounts for effluent variability based on the size of the dataset and the occurrence of non-detects (i.e., samples results in which a parameter is not detected above laboratory detection limits). For datasets of 10 or more samples, EPA uses the upper bound effluent concentration at the 95<sup>th</sup> percentile of the dataset. For datasets of less than 10 samples, EPA uses the maximum value of the dataset.

EPA uses the calculated upper bound of the effluent data, along with a concentration representative of the parameter in the receiving water, the critical effluent flow, and the critical upstream flow to project the downstream concentration after complete mixing using the following simple mass-balance equation:

$$C_s Q_s + C_e Q_e = C_d Q_d$$

Where:

$C_s$  = upstream concentration (median value of available ambient data)

$Q_s$  = upstream flow (7Q10 flow upstream of the outfall)

$C_e$  = effluent concentration (95<sup>th</sup> percentile or maximum of effluent concentration)

$Q_e$  = effluent flow of the facility (design flow)

$C_d$  = downstream concentration

$Q_d$  = downstream flow ( $Q_s + Q_e$ )

Solving for the downstream concentration results in:

$$C_d = \frac{C_s Q_s + C_e Q_e}{Q_d}$$

When both the downstream concentration ( $C_d$ ) and the effluent concentration ( $C_e$ ) exceed the applicable criterion, there is reasonable potential for the discharge to cause, or contribute to an excursion above the water quality standard. *See* 40 C.F.R. § 122.44(d). When EPA determines that a discharge causes, has the reasonable potential to cause, or contribute to such an excursion, the permit must

contain WQBELs for the parameter. *See* 40 C.F.R. § 122.44(d)(1)(iii). Limits are calculated by using the criterion as the downstream concentration ( $C_d$ ) and rearranging the mass balance equation to solve for the effluent concentration ( $C_e$ ).

For any pollutant(s) with an existing WQBEL, EPA notes that the analysis described in 40 CFR § 122.44(d)(1)(i) has already been conducted in a previous permitting action demonstrating that there is reasonable potential to cause or contribute to an excursion of WQS. Given that the permit already contains a WQBEL based on the prior analysis and the pollutant(s) continue to be discharged from the facility, EPA has determined that there is still reasonable potential for the discharge of this pollutant(s) to cause or contribute to an excursion of WQS. Therefore, the WQBEL will be carried forward unless it is determined that a more stringent WQBEL is necessary to continue to protect WQS or that a less stringent WQBEL is allowable based on anti-backsliding regulations at CWA §§ 402(o) and 303(d)(4) and 40 CFR § 122.44(l). For these pollutant(s), if any, the mass balance calculation is not used to determine whether there is reasonable potential to cause or contribute to an excursion of WQS, but rather is used to determine whether the existing limit needs to be more stringent in order to continue to protect WQS.

From a technical standpoint, when a pollutant is already being controlled as a result of a previously established WQBEL, EPA has determined that it is not appropriate to use new effluent data to reevaluate the need for the existing limit because the reasonable potential to cause or contribute to an excursion of WQS for the uncontrolled discharge was already established in a previous permit. If EPA were to conduct such an evaluation and find no reasonable potential for the controlled discharge to cause or contribute to an excursion of WQS, that finding could be interpreted to suggest that the effluent limit should be removed. However, the new permit without the effluent limit would imply that existing controls are unnecessary, that controls could be removed and then the pollutant concentration could rise to a level where there is, once again, reasonable potential for the discharge to cause or contribute to an excursion of WQS. This could result in an illogical cycle of applying and removing pollutant controls with each permit reissuance. EPA's technical approach on this issue is in keeping with the Act generally and the NPDES regulations specifically, which reflect a precautionary approach to controlling pollutant discharges.

The table below presents the reasonable potential calculations and, if applicable, the calculation of the limits required in the permit. Refer to the pollutant-specific section of the Fact Sheet for a detailed discussion of these calculations, any assumptions that were made and the resulting permit requirements.



# Appendix B – Reasonable Potential and Limits Calculations

NPDES Permit No. MA0101630

Pollutant	Conc. Units	Q <sub>s</sub> (MGD)	C <sub>s</sub> <sup>1</sup>	Q <sub>e</sub> (MGD)	C <sub>e</sub> <sup>2</sup>		Q <sub>d</sub> (MGD)	C <sub>d</sub>		Criteria		Reasonable Potential		Limits	
					Acute	Chronic		Acute	Chronic	Acute	Chronic	C <sub>e</sub> & C <sub>d</sub> > Acute Criteria	C <sub>e</sub> & C <sub>d</sub> > Chronic Criteria	Acute	Chronic
Aluminum	µg/L	1274.56	79	17.5	63.4	87.0	1292.058	78.8	79.1	600.0	290.0	N	Y	N/A	87.0
Cadmium	µg/L	1274.56	0	17.5	0.5	0.5	1292.058	0.007	0.007	0.7	0.3	N	N	N/A	N/A
Copper	µg/L	1274.56	0	17.5	4.7	3.5	1292.058	0.06	0.05	5.2	3.8	Y	Y	4.7	3.5
Lead	µg/L	1274.56	0	17.5	1.6	0.7	1292.058	0.021	0.010	21.3	0.8	N	Y	N/A	0.73
Nickel	µg/L	1274.56	0	17.5	72.0	72.0	1292.058	1.0	1.0	191.9	21.3	N	N	N/A	N/A
Zinc	µg/L	1274.56	0	17.5	48.6	48.6	1292.058	0.66	0.66	48.9	48.9	N	N	N/A	N/A
Ammonia (Cold)	mg/L	1274.56	0	17.5	11.2	11.2	1292.058	0.15	0.15	17.5	3.7	N	N	N/A	N/A
Ammonia (Warm)	mg/L	1274.56	0	17.5	10.3	10.3	1292.058	0.14	0.14	8.0	1.2	N	N	N/A	N/A
Phosphorus	mg/L	1274.56	0.021	17.5	N/A	0.7	1292.058	N/A	0.030	N/A	0.1	N	N	N/A	N/A

<sup>1</sup>Median concentration for the receiving water just upstream of the facility's discharge taken from the WET testing data during the review period (see Appendix A).

<sup>2</sup>Values represent the 95<sup>th</sup> percentile (for n ≥ 10) or maximum (for n < 10) concentrations from the DMR data and/or WET testing data during the review period (see Appendix A). If the pollutant already has a limit (for either acute or chronic conditions), the value represents the existing limit.

# APPENDIX C

## NH, VT, MA Nitrogen Discharges to Long Island Sound Watershed

### Summary of Massachusetts Out-Of-Basin Wastewater Treatment Plant and Industrial Discharger Total Nitrogen Effluent Data

Permit #	Name	Type	Design Flow (MGD)	2014-2018 Avg Flow (MGD)	2014 Average Load (lb/day)	2015 Average Load (lb/day)	2016 Average Load (lb/day)	2017 Average Load (lb/day)	2018 Average Load (lb/day)	2014-2018 Avg Load (lb/day)
Total Massachusetts Out-of-Basin Load			262	146	11,528	11,215	9,767	10,557	10,631	10,740
Total Massachusetts Connecticut River Load			179.6	98	9,184	8,945	7,695	8,390	8,341	8,511
MA0101613	SPRINGFIELD REGIONAL WTP	POTW	67.00	36.26	2,303	2,377	1,643	1,953	1,684	1,992
MA0101508	CHICOPEE WPC	POTW	15.50	7.83	2,220	2,092	1,854	1,872	1,895	1,987
MA0101630	HOLYOKE WPCF	POTW	17.50	8.05	584	644	687	747	593	651
MA0101214	GREENFIELD WPCF	POTW	3.20	3.23	436	467	460	386	482	446
MA0100994	GARDNER WWTF	POTW	5.00	2.89	413	470	377	455	404	424
MA0101818	NORTHAMPTON WWTP	POTW	8.60	3.85	489	412	355	393	453	420
MA0100218	AMHERST WWTP	POTW	7.10	3.76	456	411	335	342	377	384
MA0100455	SOUTH HADLEY WWTF	POTW	4.20	2.37	393	325	288	364	315	337
MA0101478	EASTHAMPTON WWTP	POTW	3.80	3.44	202	186	262	329	639	324
MA0101800	WESTFIELD WWTP	POTW	6.10	2.88	276	225	221	189	211	224
MA0110264	AUSTRALIS AQUACULTURE, LLC	IND	0.30	0.13	149	138	116	107	74	117
MA0101168	PALMER WPCF	POTW	5.60	1.47	142	92	84	100	125	109
MA0100137	MONTAGUE WWTF	POTW	1.80	0.84	107	78	55	215	78	107
MA0100099	HADLEY WWTP	POTW	0.54	0.38	73	76	65	109	67	78
MA0100889	WARE WWTP	POTW	1.00	0.55	62	89	87	72	78	77
MA0101257	ORANGE WWTP	POTW	1.10	0.98	72	62	58	91	91	75
MA00003697	BARNHARDT MANUFACTURING	IND	0.89	0.33	58	78	49	54	96	67
MA0103152	BARRE WWTF	POTW	0.30	0.19	77	81	50	50	49	61
MA0101567	WARREN WWTP	POTW	1.50	0.26	45	42	124	38	55	61
MA00000469	SEAMAN PAPER OF MASSACHUSETTS	IND	1.10	0.83	26	97	53	62	46	57
MA0100005	ATHOL WWTF	POTW	1.75	0.79	76	56	40	39	44	51
MA0101061	NORTH BROOKFIELD WWTP	POTW	0.62	0.32	62	51	40	47	50	50
MA0110043	MCLAUGHLIN STATE TROUT HATCHERY	IND	7.50	7.12	39	44	43	41	37	41
MA0100919	SPENCER WWTP	POTW	1.08	0.35	28	33	31	29	71	38



# NH, VT, MA Nitrogen Discharges to Long Island Sound Watershed

Summary of Massachusetts Out-Of-Basin Wastewater Treatment Plant and Industrial Discharger Total Nitrogen Effluent Data

Permit #	Name	Type	Design Flow (MGD)	2014-2018 Avg Flow (MGD)	2014 Average Load (lb/day)	2015 Average Load (lb/day)	2016 Average Load (lb/day)	2017 Average Load (lb/day)	2018 Average Load (lb/day)	2014-2018 Avg Load (lb/day)
MA0100862	WINCHENDON WPCF	POTW	1.10	0.50	25	33	29	48	40	35
MA0101290	HATFIELD WWTF	POTW	0.50	0.17	51	37	28	28	27	34
MA0101052	ERVING WWTP #2	POTW	2.70	1.78	35	38	38	33	25	34
MA0100340	TEMPLETON WWTF	POTW	2.80	0.27	19	35	18	21	35	26
MAGS80004	SOUTH DEERFIELD WWTP	POTW	0.85	0.37	15	33	18	18	27	22
MA0040207	CHANG FARMS INC	IND	0.65	0.22	22	15	34	20	20	22
MA0110035	MCLAUGHLIN/SUNDERLAND STATE FISH HATCHERY	IND	2.10	2.16	25	22	19	20	25	22
MA0102148	BELCHERTOWN WRF	POTW	1.00	0.36	61	13	11	11	5.6	20
MAG580002	SHELBURNE WWTF	POTW	0.25	0.16	15	13	17	17	21	17
MAG580005	SUNDERLAND WWTF	POTW	0.50	0.17	20	12	13	10	9.3	13
MAG580001	OLD DEERFIELD WWTP	POTW	0.25	0.068	13	14	13	12	12	13
MA0110051	MCLAUGHLIN/BITZER STATE TROUT HATCHERY	IND	1.43	1.70	23	12	12	8.2	8.2	13
MA0032573	NORTHFIELD MT HERMON SCHOOL WWTP	POTW	0.45	0.072	22	7.6	15	10	10	13
MA0100102	HARDWICK WPCF	POTW	0.23	0.12	8.2	5.9	13	4.3	17	10
MA0100200	NORTHFIELD WWTF	POTW	0.28	0.080	3.8	6.8	6.5	10	14	8.1
MA0101516	ERVING WWTP #1	POTW	1.02	0.14	7.2	6.1	3.7	10	7.5	6.9
MA0102776	ERVING WWTP #3	POTW	0.010	0.0049	6.1	2.9	6.9	8.0	7.5	6.3
MA0102431	HARDWICK WWTP	POTW	0.040	0.016	7.4	1.5	11	6.9	2.3	5.9
MAG580003	CHARLEMONT WWTF	POTW	0.050	0.016	7.5	4.2	4.8	4.8	4.8	5.2
MA0101265	HUNTINGTON WWTP	POTW	0.20	0.067	4.6	4.1	5.6	4.3	5.2	4.7
MA0100188	MONROE WWTF	POTW	0.020	0.013	1.4	1.4	1.2	2.3	1.7	1.6
MA0000272	PAN AM RAILWAYS YARD	IND	0.015	0.011	0.06	0.13	0.12	0.47	0.18	0.19
MA0001350	LS STARRETT PRECISION TOOLS	IND	0.025	0.014	0.03	0.0	0.08	0.07	0.04	0.05
MA0100161	ROYALSTON WWTP	POTW	0.039	0.01298	0.9	0.49	0.43	0.49	0.60	0.59
<b>Total Massachusetts Housatonic Load</b>										
MA0101681	PITTSFIELD WWTF	POTW	17.00	10.55	1,179	1,176	1,145	1,245	1,319	1,213
MA0000671	CRANE WWTP	POTW	3.10	3.07	155	142	108	116	107	126

# NH, VT, MA Nitrogen Discharges to Long Island Sound Watershed

## Summary of Massachusetts Out-Of-Basin Wastewater Treatment Plant and Industrial Discharger Total Nitrogen Effluent Data

Permit #	Name	Type	Design Flow (MGD)	2014-2018 Avg Flow (MGD)	2014 Average Load (lb/day)	2015 Average Load (lb/day)	2016 Average Load (lb/day)	2017 Average Load (lb/day)	2018 Average Load (lb/day)	2014-2018 Avg Load (lb/day)
MA0101524	GREAT BARRINGTON WWTF	POTW	3.20	0.97	110	120	100	99	124	111
MA0100935	LENEX CENTER WWTF	POTW	1.19	0.61	49	67	59	71	78	65
MA0001848	ONYX SPECIALTY PAPERS INC - WILLOW MILL	IND	1.10	0.94	51	39	44	33	22	38
MA0005011	PAPERLOGIC TURNERS FALLS MILL(6)	IND	0.70	0.73	85	17	12	6.5	Term	30
MA0100153	LEE WWTF	POTW	1.25	0.64	18	17	14	15	35	20
MA0101087	STOCKBRIDGE WWTP	POTW	0.30	0.15	10	15	16	13	10	13
MA0103110	WEST STOCKBRIDGE WWWTf	POTW	0.076	0.014	5.3	3.8	4.3	5.0	3.7	4.4
MA0001716	MEADWESTVACO CUSTOM PAPERS LAUREL MILL	IND	1.5	0.34	4.3	7.9	5.7	7.2	7.8	6.6
<b>Total Massachusetts Thames River Load</b>			<b>11.8</b>	<b>6</b>	<b>677</b>	<b>666</b>	<b>564</b>	<b>556</b>	<b>583</b>	<b>609</b>
MA0100439	WEBSTER WWTF	POTW	6.00	2.97	389	393	328	292	344	349
MA0100901	SOUTHBRIDGE WWTF	POTW	3.77	1.97	178	149	154	151	130	152
MA0101141	CHARLTON WWTF	POTW	0.45	0.21	40	75	41	68	70	59
MA0100421	STURBRIDGE WPCF	POTW	0.75	0.51	44	21	18	19	20	24
MA0101796	LEICESTER WATER SUPPLY WWTF	POTW	0.35	0.19	24	27	22	26	19	24
MA0100170	OXFORD ROCHDALE WWTP	POTW	0.50	0.24	2.4	1.0	0.23	0.57	0.49	0.9

NOTES:

- 1) *italics* = estimated load based on average conc & flow from other years, or if no data for any years, assumed concentration of 19.6 mg/L.
- 2) The loads represent annual totals, based on annual daily average flow and daily average nitrogen concentration.
- 3) Term = Permit was terminated in that year
- 4) This summary only includes POTWs and Industrial sources for which there was nitrogen monitoring at the outfalls for treated effluent and/or process wastewater.



# NH, VT, MA Nitrogen Discharges to Long Island Sound Watershed

Summary of New Hampshire Out-Of-Basin Wastewater Treatment Plant and Industrial Discharger Total Nitrogen Effluent Data

Permit #	Name	Type	Design Flow (MGD)	2014-2018 Avg Flow (MGD)	2014 Average Load (lb/day)	2015 Average Load (lb/day)	2016 Average Load (lb/day)	2017 Average Load (lb/day)	2018 Average Load (lb/day)	2014-2018 Avg Load (lb/day)
<b>Total New Hampshire Out-of-Basin Load</b>										
NH0000621	BERLIN STATE FISH HATCHERY	IND	6.1	6.30	8.8	13	13	15	8.7	12
NH0000744	NH DES (TWIN MTN STATE FISH HATCHERY)	IND	1.0	0.78	2.0	5.8	6.2	5.5	5.1	4.9
NH0100099	HANOVER WWTF	POTW	2.3	1.30	<u>341</u>	<u>341</u>	313	350	361	341
NH0100145	LANCASTER WWTF	POTW	1.2	0.79	84	78	45	72	63	68
NH0100153	LITTLETON WWTP	POTW	1.5	0.69	32	36	24	31	45	34
NH0100200	NEWPORT WWTF	POTW	1.3	0.59	97	63	80	80	79	80
NH0100366	LEBANON WWTF	POTW	3.2	1.49	<u>136</u>	<u>136</u>	132	127	152	137
NH0100382	HINSDALE WWTP	POTW	0.3	0.19	<u>18</u>	17	11	20	16	16
NH0100510	WHITEFIELD WWTF	POTW	0.2	0.08	35	22	15	18	24	23
NH0100544	SUNABEE WWTF	POTW	0.6	0.40	<u>32</u>	<u>32</u>	<u>32</u>	50	33	35
NH0100765	CHARLESTOWN WWTP	POTW	1.1	0.28	22	13	12	19	22	17
NH0100790	KEENE WWTF	POTW	6.0	2.89	<u>533</u>	<u>397</u>	<u>394</u>	<u>452</u>	<u>40</u>	363
NH0101052	TROY WWTF	POTW	0.3	0.08	23	15	12	13	25	18
NH0101150	WEST SWANZEY WWTP	POTW	0.2	0.07	6.1	6.4	7.8	7.8	15	8.7
NH0101168	MERIDEN VILLAGE WATER DISTRICT	POTW	0.1	0.03	0.53	2.5	1.4	2.9	1.3	1.7
NH0101257	CLAREMONT WWTF	POTW	3.9	1.51	<u>161</u>	<u>161</u>	<u>161</u>	163	146	158
NH0101392	BETHLEHEM VILLAGE WWTP (1)	POTW	0.3	0.21	25	26	25	29	25	26
NHG580226	GROVETON WWTP	POTW	0.4	0.12	18	13	10	12	14	13
NHG580315	COLEBROOK WWTP	POTW	0.5	0.22	26	23	21	31	31	26
NHG580391	CHESHIRE COUNTY MAPLEWOOD NURSING HOME	POTW	0.040	0.02	2.1	1.6	1.3	1.5	1.3	1.5
NHG580404	WINCHESTER WWTP	POTW	0.28	0.14	6.1	11	3.9	13	8.3	8.3
NHG580421	USBON WWTF	POTW	0.3	0.12	26	23	19	17	17	20
NHG580536	STRATFORD VILLAGE SYSTEM	POTW	0.1	0.01	2.2	1.9	3.9	2.5	2.8	2.7
NHG580978	WOODSVILLE WWTF	POTW	0.3	0.19	22	15	19	19	13	18
NHG581206	NORTHUMBERLAND VILLAGE WPCF	POTW	0.1	0.04	2.7	3.3	3.5	2.6	3.1	3.0
NHG581214	STRATFORD-MILL HOUSE	POTW	0.0	0.01	1.4	1.5	2.2	1.8	2.3	1.8
NHG581249	LANCASTER GRANGE WWTP	POTW	0.0	0.00	0.45	0.53	0.45	0.49	0.44	0.47

NOTES:

- 1) *italics* = estimated load based on average conc & flow from other years, or if no data for any years, assumed concentration of 19.6 mg/L.
- 2) The loads represent annual totals, based on annual daily average flow and daily average nitrogen concentration.
- 3) Term = Permit was terminated in that year
- 4) This summary only includes POTWs and Industrial sources for which there was nitrogen monitoring at the outfalls for treated effluent and/or process wastewater.

# NH, VT, MA Nitrogen Discharges to Long Island Sound Watershed

Summary of Vermont Out-Of-Basin Wastewater Treatment Plant and Industrial Discharger Total Nitrogen Effluent Data

Permit #	Name	Type	Design Flow (MGD)	2014-2018 Avg Flow (MGD)	2014 load (lb/day)	2015 load (lb/day)	2016 load (lb/day)	2017 load (lb/day)	2018 load (lb/day)	2014-2018 Avg Load (lb/day)
	<b>Total Vermont Out-of-Basin Load</b>		<b>18.3</b>	<b>7.8</b>	<b>1,273</b>	<b>1,255</b>	<b>1,146</b>	<b>1,221</b>	<b>1,421</b>	<b>1,263</b>
VT0000019	WEIDMANN ELECTRICAL TECHNOLOGY INC	IND	0.25	0.15	2.4	1.4	1.4	1.2	1.7	1.6
VT0000108	PUTNEY PAPER COMPANY MILL & LAGOONS	IND	0.28	0.16	22	26	20	22	17	22
VT0000248	FIBERMARK	IND	2.00	1.06	117	82	89	106	92	97
VT0100013	BELLOWS FALLS WWTF	POTW	1.40	0.44	136	136	136	102	179	138
VT0100048	BETHEL	POTW	0.13	0.06	10.4	4.0	2.4	6.5	3.5	5.4
VT0100064	BRATTLEBORO WWTF	POTW	3.01	1.27	487	487	446	501	421	469
VT0100081	CHESTER MTP	POTW	0.19	0.16	16	5.0	4.5	5.6	7.6	7.6
VT0100145	LUDLOW WWTF	POTW	0.71	0.37	35	27	35	41	42	36
VT0100277	PUTNEY	POTW	0.09	0.05	16	16	11	16	21	16
VT0100285	RANDOLPH	POTW	0.41	0.17	23	23	21	20	28	23
VT0100374	SPRINGFIELD WWTF	POTW	2.20	0.98	133	133	133	120	130	130
VT0100447	WINDSOR-WESTON HEIGHTS	POTW	0.02	0.01	0.40	0.53	1.2	0.88	1.0	0.8
VT0100579	ST JOHNSBURY	POTW	1.60	0.83	34	23	13	24	146	48
VT0100595	LYNDON WWTP	POTW	0.76	0.15	21	21	16	24	21	20
VT0100625	CANAAN MTP	POTW	0.19	0.10	17	15	16	19	17	17
VT0100633	DANVILLE WPCF	POTW	0.07	0.03	2.9	3.5	7.6	4.4	4.3	4.5
VT0100706	WILMINGTON WWTP	POTW	0.15	0.08	3.8	15.9	10.0	4.7	17.2	10
VT0100731	READSBORO WPC	POTW	0.76	0.04	3.6	3.2	2.8	3.8	4.0	3.5
VT0100749	S. WOODSTOCK WWTF	POTW	0.06	0.01	1.9	1.9	0.7	1.2	3.9	1.9
VT0100757	WOODSTOCK WWTP	POTW	0.46	0.22	25	23	24	26	22	24
VT0100765	WOODSTOCK - TAFTSVILLE	POTW	0.02	0.00	0.32	0.24	0.20	0.55	0.87	0.44
VT0100803	BRADFORD WPCP	POTW	0.15	0.08	9.1	9.1	7.7	9.4	8.5	8.8
VT0100846	BRIDGEWATER WWTF	POTW	0.05	0.01	1.1	0.91	1.0	1.1	1.1	1.1
VT0100854	ROYALTON WWTF	POTW	0.08	0.02	5.2	4.6	4.7	7.7	5.0	5.4
VT0100862	CAVENDISH WWTF	POTW	0.16	0.06	15	10	9	11	15	12
VT0100919	WINDSOR WWTF	POTW	1.13	0.25	69	69	66	65	71	68
VT0100943	CHELSEA WWTF	POTW	0.07	0.02	8.2	8.2	4.8	8.9	9.9	8.0
VT0100951	RYEGATE FIRE DEPARTMENT #2	POTW	0.01	0.00	0.55	1.1	1.9	2.1	0.76	1.3
VT0100978	HARTFORD - QUECHEE	POTW	0.31	0.22	24	53	12	12	10	22
VT0101010	HARTFORD WWTF	POTW	1.23	0.61	11	31	30	34	89	39
VT0101044	WHITTINGHAM(JACKSONVILLE)	POTW	0.06	0.02	3.2	3.5	3.4	2.8	3.1	3.2
VT0101061	LUNENBURG FIRE DISTRICT #2	POTW	0.09	0.06	7.6	6.9	5.6	3.2	7.8	6.2
VT0101109	WHITTINGHAM	POTW	0.02	0.01	1.2	1.4	1.5	1.2	3.0	1.7
VT0101141	SHERBURNE WPCF	POTW	0.31	0.08	8.9	8.3	7.7	10	16	10

## NOTES:

1) *Italics* = estimated load based on average conc & flow from other years, or if no data for any years, assumed concentration of 19.6 mg/L.

2) The loads represent annual totals, based on annual daily average flow and daily average nitrogen concentration.

3) Term = Permit was terminated in that year

4) This summary only includes POTWs, and Industrial sources for which there was nitrogen monitoring at the outfalls for treated effluent and/or process wastewater.



UNITED STATES ENVIRONMENTAL  
PROTECTION AGENCY – REGION 1 (EPA)  
WATER DIVISION  
5 POST OFFICE SQUARE  
BOSTON, MASSACHUSETTS 02109

MASSACHUSETTS DEPARTMENT OF  
ENVIRONMENTAL PROTECTION (MASSDEP)  
COMMONWEALTH OF MASSACHUSETTS  
100 CAMBRIDGE STREET, SUITE 900  
BOSTON, MASSACHUSETTS 02114

EPA PUBLIC NOTICE OF A DRAFT NATIONAL POLLUTANT DISCHARGE ELIMINATION  
SYSTEM (NPDES) PERMIT TO DISCHARGE INTO WATERS OF THE UNITED STATES UNDER  
SECTION 402 OF THE CLEAN WATER ACT (CWA), AS AMENDED, AND MASSDEP PUBLIC  
NOTICE OF EPA REQUEST FOR STATE CERTIFICATION UNDER SECTION 401 OF THE CWA.

PUBLIC NOTICE PERIOD: **April 6, 2023 - May 5, 2023**

NAME AND MAILING ADDRESS OF APPLICANT:

City of Holyoke  
Department of Public Works  
63 Canal Street  
Holyoke, MA 01040

NAME AND ADDRESS OF THE FACILITY WHERE DISCHARGE OCCURS:

Holyoke Water Pollution Control Facility  
1 Berkshire Street  
Holyoke, Massachusetts 01040

And

Combined Sewer Overflow (CSO) discharges at 10 locations

RECEIVING WATER AND CLASSIFICATION:

Connecticut River (Class B)

PREPARATION OF THE DRAFT PERMIT AND EPA REQUEST FOR CWA § 401 CERTIFICATION:

EPA is issuing for public notice and comment the Draft NPDES Permit for the Holyoke WPCF, which discharges treated domestic and industrial wastewater. Sludge from this facility is transported to the Synagro facility in Waterbury, CT for incineration. The effluent limits and permit conditions have been drafted pursuant to, and assure compliance with, the CWA, including EPA-approved State Surface Water Quality Standards at 314 CMR 4.00. MassDEP cooperated with EPA in the development of the Draft NPDES Permit. MassDEP retains independent authority under State law to publish for public notice and issue a separate Surface Water Discharge Permit for the discharge, not the subject of this notice, under the Massachusetts Clean Waters Act, M.G.L. c. 21, §§ 26-53.

In addition, EPA has requested that MassDEP grant or deny certification of this Draft Permit pursuant to Section 401 of the CWA and implementing regulations. Under federal regulations governing the NPDES program at 40 Code of Federal Regulations (CFR) § 124.53(e), state certification shall contain conditions that are necessary to assure compliance with the applicable provisions of CWA sections 208(e), 301, 302, 303, 306, and 307 and with appropriate requirements of State law, including any conditions more stringent

than those in the Draft Permit that MassDEP finds necessary to meet these requirements. Furthermore, MassDEP may provide a statement of the extent to which each condition of the Draft Permit can be made less stringent without violating the requirements of State law.

#### INFORMATION ABOUT THE DRAFT PERMIT:

The Draft Permit and explanatory Fact Sheet may be obtained at no cost at <https://www.epa.gov/npdes-permits/massachusetts-draft-individual-npdes-permits> or by contacting:

Michele Duspiva  
U.S. Environmental Protection Agency – Region 1  
5 Post Office Square, Suite 100 (06-4)  
Boston, MA 02109-3912  
Telephone: (617) 918-1682  
Email: [duspiva.michele@epa.gov](mailto:duspiva.michele@epa.gov)

Following U.S. Centers for Disease Control and Prevention (CDC) and U.S. Office of Personnel Management (OPM) guidance and specific state guidelines impacting our regional offices, EPA's workforce has been directed to telework to help prevent transmission of the coronavirus. While in this workforce telework status, there are practical limitations on the ability of Agency personnel to allow the public to review the administrative record in person at the EPA Boston office. However, any electronically available documents that are part of the administrative record can be requested from the EPA contact above.

#### PUBLIC COMMENT AND REQUESTS FOR PUBLIC HEARINGS:

All persons, including applicants, who believe any condition of this Draft Permit is inappropriate must raise all reasonably ascertainable issues and submit all reasonably available arguments supporting their position by May 5, 2023, which is the close of the public comment period. Comments, including those pertaining to EPA's request for CWA § 401 certification, should be submitted to the EPA contact at the address or email listed above. Upon the close of the public comment period, EPA will make all comments available to MassDEP. All commenters who want MassDEP to consider their comments in the state decision-making processes (i.e., the separate state permit and the CWA § 401 certification) must submit such comments to MassDEP during the state comment period for the state Draft Permit and CWA § 401 certification. For information on submitting such comments to MassDEP, please follow the instructions found in the state public notice at: <https://www.mass.gov/service-details/massdep-public-hearings-comment-opportunities>.

Any person, prior to the close of the EPA public comment period, may submit a request in writing to EPA for a public hearing on the Draft Permit under 40 CFR § 124.10. Such requests shall state the nature of the issues proposed to be raised in the hearing. A public hearing may be held after at least thirty days public notice if the Regional Administrator finds that response to this notice indicates significant public interest. In reaching a final decision on this Draft Permit, the Regional Administrator will respond to all significant comments and make the responses available to the public.

Due to the COVID-19 National Emergency, if comments are submitted in hard copy form, please also email a copy to the EPA contact above.

#### FINAL PERMIT DECISION:

Following the close of the comment period, and after a public hearing, if such hearing is held, the Regional Administrator will issue a final permit decision and notify the applicant and each person who has submitted written comments or requested notice.



KEN MORAFF, DIRECTOR  
WATER DIVISION  
UNITED STATES ENVIRONMENTAL  
PROTECTION AGENCY – REGION 1

LEALDON LANGLEY, DIRECTOR  
DIVISION OF WATERSHED MGMT  
MASSACHUSETTS DEPARTMENT OF  
ENVIRONMENTAL PROTECTION

