

**AUTHORIZATION TO DISCHARGE UNDER THE  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 et seq.; the "CWA", and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

**PSG/USFilter  
825 West Water Street  
Taunton, MA 02780**

**And The City of Taunton  
Department of Public Works  
90 Ingell Street  
Taunton, MA 02780-3507**

PSG/USFilter and the City of Taunton shall be jointly responsible (co-permittees) for the operation of the treatment plant and for the one combined sewer overflow. The City of Taunton alone shall be responsible for the collection system.

are authorized to discharge from the facility located at

**Taunton Wastewater Treatment Plant  
825 West Water Street  
Taunton, MA 02780  
and one combined sewer overflow (CSO)**

to receiving water named **Taunton River** (Taunton River Basin - MA62-02)

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective on the date of issuance.

This permit and the authorization to discharge expire at midnight, five (5) years from the effective date.

This permit supersedes the permit issued on September 26, 1995.

This permit consists of 13 Pages in Part I including effluent limitations, monitoring requirements, etc., Attachment A, Freshwater Chronic Toxicity Test Procedure and Protocol, Attachments B through D (not available electronically), the Sludge Compliance Document, and 35 pages in Part II including General Conditions and Definitions.

Signed this 27<sup>th</sup> day of March, 2001

/Signature on File/

Linda M. Murphy, Director  
Office of Ecosystem Protection  
Environmental Protection Agency  
Boston, MA

Glenn Haas, Acting Assistant Commissioner  
Bureau of Resource Protection  
Department of Environmental Protection  
Commonwealth of Massachusetts  
Boston, MA

PART I

1.A. During the period beginning the effective date and lasting through expiration, the permittee is authorized to discharge from outfall serial number **001**, treated industrial and sanitary wastewater and storm water to the Taunton River. Such discharges shall be limited and monitored as specified below.

<u>EFFLUENT CHARACTERISTIC</u>		<u>EFFLUENT LIMITS</u>			<u>MONITORING REQUIREMENTS</u>		
<u>PARAMETER</u>	<u>AVERAGE MONTHLY</u>	<u>AVERAGE WEEKLY</u>	<u>AVERAGE MONTHLY</u>	<u>AVERAGE WEEKLY</u>	<u>MAXIMUM DAILY</u>	<u>MEASUREMENT FREQUENCY</u>	<u>SAMPLE<sup>3</sup> TYPE</u>
FLOW	*****	*****	8.4 MGD <sup>1,2</sup>	***** *	Report MGD	CONTINUOUS	RECORDER
CBOD <sub>5</sub> <sup>3</sup> (April 1-October 31)	1051 lbs/Day 478 kgs/Day	1051 lbs/Day 478 kgs/Day	15 mg/l	15 mg/l	Report mg/l <sup>1</sup>	3/WEEK	24-HOUR COMPOSITE <sup>4</sup>
BOD <sub>5</sub> <sup>3</sup> (November 1 - March 31)	2102 lbs/Day 955 kgs/Day	3153 lbs/Day 1463 kgs/Day	30 mg/l	45 mg/l	Report mg/l <sup>1</sup>	3/WEEK	24-HOUR COMPOSITE <sup>4</sup>
TSS <sup>3</sup> (April 1-October 31)	1401 lbs/Day 637 kgs/Day	1401 lbs/Day 637 kgs/Day	20 mg/l	20 mg/l	Report mg/l <sup>1</sup>	3/WEEK	24-HOUR COMPOSITE <sup>4</sup>
TSS <sup>3</sup> (November 1 - March 31)	2102 lbs/Day 955 kgs/Day	3153 lbs/Day 1463 kgs/Day	30 mg/l	45 mg/l	Report mg/l <sup>1</sup>	3/WEEK	24-HOUR COMPOSITE <sup>4</sup>
SETTLABLE SOLIDS <sup>1</sup>	*****	*****	***** *	Report ml/l	Report ml/l	1/DAY	GRAB
pH RANGE <sup>1</sup>	6.5 - 8.3 SU SEE PERMIT PAGE 5 OF 15, PARAGRAPH I.A.1.b.					1/DAY	GRAB
TOTAL CHLORINE RESIDUAL <sup>1,7</sup>	*****	*****	0.046 mg/l	***** *	0.08 mg/l	3/DAY	GRAB
FECAL COLIFORM <sup>1,6</sup>	*****	*****	200/100 ml	***** *	400/100 ml	2/WEEK	GRAB
DISSOLVED OXYGEN (April 1 <sup>st</sup> -October 31 <sup>st</sup> )	NOT LESS THAN 6.0 mg/l					1/DAY	GRAB
WHOLE EFFLUENT TOXICITY SEE FOOTNOTES 9, 10 and 11	Acute LC <sub>50</sub> ≥ 100% Chronic C-NOEC ≥ 24%					4/YEAR	24-HOUR COMPOSITE



CONTINUED FROM PREVIOUS PAGE

1.A. During the period beginning the effective date and lasting through expiration, the permittee is authorized to discharge from outfall serial number **001**, treated industrial and sanitary wastewater and storm water to the Taunton River. Such discharges shall be limited and monitored as specified below.

<u>EFFLUENT CHARACTERISTIC</u>		<u>EFFLUENT LIMITS</u>			<u>MONITORING REQUIREMENTS</u>		
<u>PARAMETER</u>	<u>AVERAGE MONTHLY</u>	<u>AVERAGE WEEKLY</u>	<u>AVERAGE MONTHLY</u>	<u>AVERAGE WEEKLY</u>	<u>MAXIMUM DAILY</u>	<u>MEASUREMENT FREQUENCY</u>	<u>SAMPLE<sup>3</sup> TYPE</u>
AMMONIA-NITROGEN (June 1 - September 30)	Report lbs/Day Report kgs/Day	Report lbs/Day Report kgs/Day	1 mg/l	1 mg/l	2 mg/l	3/WEEK	24-HOUR COMPOSITE
AMMONIA-NITROGEN (October 1 - May 31)	Report lbs/Day Report kgs/Day	***** ***** **	Report mg/l	***** ***** **	Report mg/l	1/MONTH	24-HOUR COMPOSITE
TOTAL KJELDAHL NITROGEN	Report lbs/Day Report kgs/Day	***** ***** **	Report mg/l	***** ***** **	Report mg/l	1/MONTH	24-HOUR COMPOSITE
TOTAL NITRATE	Report lbs/Day Report kgs/Day	***** ***** **	Report mg/l	***** ***** **	Report mg/l	1/MONTH	24-HOUR COMPOSITE
TOTAL NITRITE	Report lbs/Day Report kgs/Day	***** ***** **	Report mg/l	***** ***** **	Report mg/l	1/MONTH	24-HOUR COMPOSITE
TOTAL COPPER <sup>8</sup>	1.1 lbs/Day 0.5 kgs/Day	***** ***** **	0.016 mg/l	***** ***** **	0.022 mg/l	1/MONTH	24-HOUR COMPOSITE

## Footnotes:

1. Required for State Certification.
2. For flow, report maximum and minimum daily rates and total flow for each operating date. The flow limit is an annual average. The annual average flow shall be reported each month as a rolling average and shall be calculated using the monthly average flow from the reporting month and the monthly average flows from the preceding 11 months.
3. All required effluent samples shall be collected at the point specified in Permit Attachment B. Any change in sampling location must be reviewed and approved in writing by EPA and MADEP. All samples shall be tested using the analytical methods found in 40 CFR §136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136. All samples shall be 24 hour composites unless specified as a grab sample in 40 CFR §136.
4. Sampling required for influent and effluent.
5. A 24-hour composite sample will consist of at least twenty four (24) grab samples taken during one working day.
6. Fecal coliform monitoring will be conducted year round. This is a State certification requirement. The monthly average limit is expressed as a geometric mean.
7. The minimum level (ML) for total residual chlorine is defined as 0.05 mg/l. This value is the minimum level for chlorine using EPA approved methods found in Standard Methods for the Examination of Water and Wastes, 20th Edition, Method 4500 CL-E and G, or USEPA Manual of Methods of Analysis of Water and Wastes, Method 330.5. One of these methods must be used to determine total residual chlorine. For effluent limitations less than 0.05 mg/l, compliance/non-compliance will be determined based on the ML. Sample results of 0.05 mg/l or less shall be reported as zero on the discharge monitoring report.
8. The minimum level (ML) for copper is defined as 5 ug/l. This value is the minimum level for copper using the Furnace Atomic Absorption analytical method (EPA Method 220.2). For effluent limitations less than 5 ug/l, compliance/non-compliance will be determined based on the ML. Sample results of 5 ug/l or less shall be reported as zero on the Discharge Monitoring Report.
9. The permittee shall conduct chronic (and modified acute) toxicity tests four times per year. The chronic test may be used to calculate the acute LC<sub>50</sub> at the 48 hour exposure interval. The permittee shall test the daphnid, Ceriodaphnia dubia, only. Toxicity test samples shall be collected on the second Tuesday during the months of February, May, August and November. The test results shall be submitted by the last day of the month following the completion of the test. The results are due March 30<sup>th</sup>, June 30<sup>th</sup>, September 30<sup>th</sup> and December 30<sup>th</sup>, respectively. The tests must be performed in accordance with test procedures and protocols specified in **Attachment A** of this permit.

Test Dates Second Tuesday in	Submit Results By:	Test Species	Acute Limit LC <sub>50</sub>	Chronic Limit C-NOEC
February May August November	March 30 <sup>th</sup> June 30 <sup>th</sup> September 30 <sup>th</sup> December 30 <sup>th</sup>	<u>Ceriodaphnia dubia</u> (Daphnid)  See Attachment A	≥ 100%	≥24%

10. The LC<sub>50</sub> is the concentration of effluent which causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a sample of 100% effluent (no dilution) shall cause no more than a 50% mortality rate.
11. The "24% or greater" C-NOEC limit is defined as a sample which is composed of 24% (or greater) effluent, the remainder being dilution water. This is a maximum daily limit derived as a percentage of the inverse of the dilution factor of 4.2.

Part I.A.1. (Continued)

- a. **The discharge shall not cause a violation of the water quality standards of the receiving waters.**
- b. The pH of the effluent shall not be less than 6.5 nor greater than 8.3 at any time, unless these values are exceeded due to natural causes or as a result of the approved treatment processes.
- c. The discharge shall not cause objectionable discoloration of the receiving waters.
- d. The effluent shall contain neither a visible oil sheen, foam, nor floating solids at any time.
- e. The permittee's treatment facility shall maintain a minimum of 85 percent removal of both total suspended solids and biochemical oxygen demand. The percent removal shall be based on monthly average values.
- f. When the effluent discharged for a period of 90 consecutive days exceeds 80 percent of the designed flow, the permittee shall submit to the permitting authorities a projection of loadings up to the time when the design capacity of the treatment facility will be reached, and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.
- g. The permittee shall minimize the use of chlorine while maintaining adequate bacterial control.

A.2. All POTWs must provide adequate notice to the Director of the following:

- a. Any new introduction of pollutants into that POTW from an indirect discharger in a primary industry category discharging process water; and
- b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.

- c. For purposes of this paragraph, adequate notice shall include information on:
- (1) the quantity and quality of effluent introduced into the POTW; and
  - (2) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

B.1. Limitations for Industrial Users:

- a. Pollutants introduced into POTW's by a non-domestic source (user) shall not pass through the POTW or interfere with the operation or performance of the works.
- b. The permittee shall develop and enforce specific effluent limits (local limits) for Industrial User(s), and all other users, as appropriate, which together with appropriate changes in the POTW Treatment Plant's Facilities or operation, are necessary to ensure continued compliance with the POTW's NPDES permit or sludge use or disposal practices. Specific local limits shall not be developed and enforced without individual notice to persons or groups who have requested such notice and an opportunity to respond. Within ( 120 days of the effective date of this permit), the permittee shall prepare and submit a written technical evaluation to the EPA analyzing the need on whether or not to revise its current local limits. As part of this evaluation, the permittee shall assess how the POTW performs with respect to influent and effluent of pollutants, water quality concerns, sludge quality, sludge processing concerns/inhibition, biomonitoring results, activated sludge inhibition, worker health and safety and collection system concerns. Justifications and conclusions should be based on actual plant data if available and should be included in the evaluation. Should the evaluation reveal the need to revise local limits, the permittee shall complete the revisions within 180 days of notification by EPA and submit the revisions to EPA for approval. The Permittee shall carry out the local limits revisions in accordance with EPA's Guidance Manual for the Development and Implementation of Local Discharge Limitations Under the Pretreatment Program (December, 1987).

B.2. Industrial Pretreatment Program

- a. The permittee shall implement the Industrial Pretreatment Program in accordance with the legal authorities, policies, procedures, and financial provisions described in the permittee's approved Pretreatment Program, and the General Pretreatment Regulations, 40 CFR 403. At a minimum, the permittee must perform the following duties to properly implement the Industrial Pretreatment Program (IPP):
  1. Carry out inspection, surveillance, and monitoring procedures which will determine, independent of information supplied by the industrial user, whether the industrial user is in compliance with the Pretreatment Standards. At a minimum, all significant industrial users shall be sampled and inspected at the frequency established in the approved IPP but in no case less than once per year. The permittee shall maintain adequate records.
  2. Issue or renew all necessary industrial user control mechanisms within 90 days of their expiration date or within 180 days after the industry has been determined to be a significant industrial user.

3. Obtain appropriate remedies for noncompliance by any industrial user with any pretreatment standard and/or requirement.
  4. Maintain an adequate revenue structure for continued implementation of the Pretreatment Program.
- b. The permittee shall provide the EPA (and the MA DEP) with an annual report describing the permittee's pretreatment program activities for the twelve month period ending 60 days prior to the due date in accordance with 403.12(i). The annual report shall be consistent with the format described in Attachment C of this permit and shall be submitted **no later than (October 1)** of each year.
  - c. The permittee must obtain approval from EPA prior to making any significant changes to the industrial pretreatment program in accordance with 40 CFR 403.18(c).
  - d. The permittee must assure that applicable National Categorical Pretreatment Standards are met by all categorical industrial users of the POTW. These standards are published in the Federal Regulations at 40 CFR 405 et. seq.
  - e. The permittee must modify its pretreatment program to conform to all changes in the Federal Regulations that pertain to the implementation and enforcement of the industrial pretreatment program. The permittee must provide EPA, in writing, within 180 days of this permit's effective date proposed changes, IF APPLICABLE, to the permittee's pretreatment program deemed necessary to assure conformity with current Federal Regulations. At a minimum, the permittee must address in its written submission the following areas: (1) enforcement response plan; (2) revised sewer use ordinances; and (3) slug control evaluations. The permittee will implement these proposed changes pending EPA Region I's approval under 40 CFR 403.18. This submission is separate and distinct from any local limits analysis submission described in Part I.A.3.b.

### C.1. Toxics Control

- a. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
- b. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.
- c. EPA or DEP may use the results of the toxicity tests and chemical analyses conducted pursuant to this permit, as well as national water quality criteria developed pursuant to Section 304(a)(1) of the Clean Water Act (CWA), state water quality criteria, and any other appropriate information or data, to develop numerical effluent limitations for any pollutants, including but not limited to those pollutants listed in Appendix D of 40 CFR Part 122.

### D. COMBINED SEWER OVERFLOWS (CSO)

1. During wet weather, the permittee is authorized to discharge storm water/wastewater from combined sewer **Outfall 004 (West Water Street, South of Fifth)**, subject to the following effluent limitations:



- a. The discharges shall receive treatment at a level providing Best Practicable Control Technology Currently Available (BPT), Best Conventional Pollutant Control Technology (BCT) to control and abate conventional pollutants and Best Available Technology Economically Achievable (BAT) to control and abate non-conventional and toxic pollutants. The EPA has made a Best Professional Judgement (BPJ) determination that BPT, BCT, and BAT for combined sewer overflows (CSOs) include the implementation of Nine Minimum Controls (NMC) specified below.
  - b. The permittee shall continue to implement the Nine Minimum Control Program (NMC) as documented on December 26, 1996. **The permittee shall submit to EPA and DEP an updated NMC within one year of the effective date of the permit** (See Permit Attachment D). The updated NMC shall be implemented upon completion. Thereafter, the permittee may modify its NMC program to enhance its effectiveness, but the NMC program shall at all times include the following minimum implementation levels:
    - (1) Proper operation and regular maintenance programs for the sewer system and the combined sewer overflows.
    - (2) Maximum use of the collection system for storage.
    - (3) Review and modification of the pretreatment program to assure CSO impacts are minimized.
    - (4) Maximization of flow to the POTW for treatment.
    - (5) Prohibition of dry weather overflows from CSOs.
    - (6) Control of solid and floatable materials in CSOs.
    - (7) Pollution prevention programs that focus on contaminant reduction activities.
    - (8) Public notification to ensure that the public receives adequate notification of CSO occurrences and CSO impacts.
    - (9) Monitoring to effectively characterize CSO impacts and the efficacy of CSO controls.
  - c. This permit may be reopened to add additional technology-based requirements based on information assembled during Taunton's development of a long-term CSO control plan.
2. The permittee may consolidate CSO reports which are on similar reporting schedules.
  3. The Permittee shall implement paragraphs a. through j. listed below, by the effective date of this permit:
    - a. Each CSO structure/regulator, pumping station and/or tidegate shall be routinely inspected to insure that they are in good working condition and adjusted to minimize combined sewer discharges and tidal surcharging. Such inspections shall occur monthly unless EPA approves a site specific inspection program

which has been determined by EPA to provide an equal level of effectiveness.(NMC #1, 2, and 4).

- b. The following inspection results shall be recorded: the date and time of the inspection, the general condition of the facility, and whether the facility is operating satisfactorily. If maintenance is necessary, the permittee shall record: the description of the necessary maintenance, the date the necessary maintenance was performed, and whether the observed problem was corrected. The permittee shall maintain all records of inspections for at least three (3) years.
- c. **Annually, no later than January 15th**, the permittee shall submit a certification to the State and EPA which states that the previous calendar year's monthly inspections were conducted, results recorded, and records maintained.
- d. The State and EPA have the right to inspect any CSO related structure or outfall, without prior notification to the permittee.
- e. Discharges to the combined system of septage, holding tank wastes or other material which may cause a visible oil sheen or containing floatable material are prohibited during wet weather when CSO discharges may be active. (NMC# 3, 6, and 7).
- f. Dry weather overflows (DWOs) are prohibited (NMC# 5). All dry weather sanitary and/or industrial discharges from CSOs must be reported to EPA and the State within twenty four (24) hours in accordance with the reporting requirements for plant bypass (Paragraph D.1.e. of Part II of this permit).
- g. The permittee shall quantify and record all Taunton discharges from the combined sewer outfall (NMC# 9). Quantification may be through direct measurement or estimation. When estimating, the permittee shall make reasonable efforts (i.e., gaging, measurements) to verify the validity of the estimation technique. The following information must be recorded for each combined sewer outfall for each discharge event:
  - (1) Estimated duration (hours) of discharge;
  - (2) Estimated volume (gallons) of discharge; and
  - (3) National Weather Service precipitation data from the nearest gage where precipitation is available at daily (twenty four (24) hour) intervals and the nearest gage where precipitation is available at one-hour intervals.
- h. Cumulative precipitation per discharge event shall be calculated.
- i. The permittee shall maintain all records of discharges for at least six (6) years after the effective date of this permit, as it is collected, on an ongoing basis.
- j. Within 12 months of the effective date of this permit, the permittee shall install and maintain identification signs for all combined sewer outfall structures. The signs must be located at or near the combined sewer outfall structures and easily readable by the public. These signs shall be a minimum of twelve x eighteen (12 x 18) inches in size, with white lettering against a green background, and shall contain the following information:

**WARNING:**

**WET WEATHER  
SEWAGE DISCHARGE  
TAUNTON OUTFALL (No. 004)**

**E.1. UNAUTHORIZED DISCHARGES**

The permittee is authorized to discharge only in accordance with the terms and conditions of this permit and only from outfalls listed in Part I A.1. of this permit and CSO number 004. Discharges of wastewater from any other point sources, including sanitary sewer overflows (SSOs) are not authorized by this permit and shall be reported in accordance with Section D.1.e. (1) of the General Requirements of this permit (Twenty-four hour reporting).

**F.1. OPERATION AND MAINTENANCE**

Operation and maintenance of the sewer system shall be in compliance with the General Requirements of Part II and the following terms and conditions:

1. Maintenance Staff

The permittee shall provide an adequate staff to carry out the operation, maintenance, repair, and testing functions required to ensure compliance with the terms and conditions of this permit.

2. Infiltration/Inflow

The permittee shall eliminate excessive infiltration/inflow to the sewer system. A summary report of all actions taken to minimize infiltration/inflow during the previous calendar year shall be submitted to EPA and the MA DEP by February 28<sup>th</sup> of each year. This report shall also include a graph of flows to the treatment plant during the year and an analysis of I/I trends (i.e. is I/I being reduced) If there have been any unauthorized discharges from the collection system during the previous calendar year which were caused by inadequate sewer system capacity, the permittee shall also include in this report an evaluation of actions necessary to restore adequate capacity.

3. Alternate Power Source

In order to maintain compliance with the terms and conditions of this permit, the permittee shall continue to provide an alternative power source with which to sufficiently operate its treatment works (as defined at 40 CFR §122.2).

4. Chlorination System Report

**Within 3 months of the effective date of the permit**, the permittee will submit a report documenting the effectiveness of the chlorination and dechlorination systems. The report will specifically address how flow variability and chlorine demand variability affect compliance with the TRC and fecal coliform limits at all times. Sampling data shall be provided to support conclusions on how hourly and daily flow and chlorine demand variability affects permit compliance. The report will include a description of the chlorination and dechlorination systems and the methods for dosage control.

The report will identify all changes necessary to ensure compliance with the TRC and fecal coliform limits at all times, including equipment modifications and upgrades, operational procedures (including calibration procedures and alarm/response procedures), and sampling protocols. The report will include a schedule for implementing all of the necessary changes. **An**

**annual report shall be submitted on November 30 of each year** summarizing all exceedances of the TRC and fecal coliform effluent limits during the previous year, the estimated or measured fecal coliform and chlorine discharge levels during the exceedance, and measures taken to fix the problem and to prevent future occurrences.

### G.1. SLUDGE CONDITIONS

- a. The permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices and with the CWA Section 405(d) technical standards.
- b. The permittee shall comply with the more stringent of either the state or federal (40 CFR part 503), requirements.
- c. The requirements and technical standards of 40 CFR part 503 apply to facilities which perform one or more of the following use or disposal practices.
  - d. Land application - the use of sewage sludge to condition or fertilize the soil
  - e. Surface disposal - the placement of sewage sludge in a sludge only landfill
  - f. Sewage sludge incineration in a sludge only incinerator
2. **The 40 CFR part 503 conditions do not apply to facilities which place sludge within a municipal solid waste landfill.** These conditions also do not apply to facilities which do not dispose of sewage sludge during the life of the permit but rather treat the sludge (lagoons- reed beds), or are otherwise excluded under 40 CFR 503.6.
3. The permittee shall use and comply with the attached compliance guidance document to determine appropriate conditions. Appropriate conditions contain the following elements.
  - General requirements
  - Pollutant limitations
  - Operational standards (pathogen reduction requirements and vector attraction reduction requirements)
  - Management practices
  - Record keeping
  - Monitoring
  - Reporting

Depending upon the quality of material produced by a facility, all conditions may not apply to the facility.
4. The permittee shall monitor the pollutant concentrations, pathogen reduction and vector attraction reduction at the following frequency. This frequency is based upon the volume of sewage sludge generated at the facility in dry metric tons per year
 

less than 290	1/ year
290 to less than 1500	1 /quarter
1500 to less than 15000	6 /year
15000 +	1 /month
5. The permittee shall sample the sewage sludge using the procedures detailed in 40 CFR 503.8.

6. The permittee shall submit an annual report containing the information specified in the guidance. **Reports are due annually by February 19.** Reports shall be submitted to the address contained in the reporting section of the permit.

#### H.1. MONITORING AND REPORTING

a. Reporting

Monitoring results obtained during the previous month shall be summarized for each month and reported on separate Discharge Monitoring Report Form(s) postmarked no later than the 15th day of the month following the effective date of the permit.

Signed and dated originals of these, and all other reports required herein, shall be submitted to the Director and the State at the following addresses:

Environmental Protection Agency  
Water Technical Unit (SEW)  
P.O. Box 8127  
Boston, Massachusetts 02114

The State Agency is:

Massachusetts Department of Environmental Protection  
Southern Regional Office  
20 Riverside Drive  
Lakeville, Massachusetts 02347

Signed and dated Discharge Monitoring Report Forms and toxicity test reports required by this permit shall also be submitted to the State at:

Massachusetts Department of Environmental Protection  
Division of Watershed Management  
Surface discharge Permit Program  
627 Main Street, 2nd Floor  
Worcester, Massachusetts 01608

#### I.1. STATE PERMIT CONDITIONS

This Discharge Permit is issued jointly by the U. S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (DEP) under Federal and State law, respectively. As such, all the terms and conditions of this permit are hereby incorporated into and constitute a discharge permit issued by the Commissioner of the MA DEP pursuant to M.G.L. Chap.21, §43.

Each Agency shall have the independent right to enforce the terms and conditions of this Permit. Any modification, suspension or revocation of this Permit shall be effective only with respect to the Agency taking such action, and shall not affect the validity or status of this Permit as issued by the other Agency, unless and until each Agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this Permit is declared, invalid, illegal or otherwise issued in violation of State law such permit shall remain in full force and effect under Federal law as an NPDES Permit issued by the U.S. Environmental Protection Agency. In the event this Permit is declared invalid, illegal or otherwise issued in violation of Federal law, this Permit shall remain in full force and effect under State law as a Permit issued by the Commonwealth of Massachusetts.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

TABLE OF CONTENTS

A. GENERAL CONDITIONS	Page
1. <u>Duty to Comply</u>	2
2. <u>Permit Actions</u>	2
3. <u>Duty to Provide Information</u>	2
4. <u>Reopener Clause</u>	3
5. <u>Oil and Hazardous Substance Liability</u>	3
6. <u>Property Rights</u>	3
7. <u>Confidentiality of Information</u>	3
8. <u>Duty to Reapply</u>	4
9. <u>State Authorities</u>	4
10. <u>Other laws</u>	4
 B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS	
1. <u>Proper Operation and Maintenance</u>	4
2. <u>Need to Halt or Reduce Not a Defense</u>	4
3. <u>Duty to Mitigate</u>	4
4. <u>Bypass</u>	4
5. <u>Upset</u>	5
 C. MONITORING AND RECORDS	
1. <u>Monitoring and Records</u>	6
2. <u>Inspection and Entry</u>	7
 D. REPORTING REQUIREMENTS	
1. <u>Reporting Requirements</u>	7
a. Planned changes	7
b. Anticipated noncompliance	7
c. Transfers	7
d. Monitoring reports	8
e. Twenty-four hour reporting	8
f. Compliance schedules	9
g. Other noncompliance	9
h. Other information	9
2. <u>Signatory Requirement</u>	9
3. <u>Availability of Reports</u>	9
 E. DEFINITIONS AND ABBREVIATIONS	
1. <u>Definitions for Individual NPDES Permits including Storm Water Requirements</u>	9
2. <u>Definitions for NPDES Permit Sludge Use and Disposal Requirements</u>	17
3. <u>Commonly Used Abbreviations</u>	23

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

## PART II. A. GENERAL REQUIREMENTS

1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act (CWA) and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

- a. The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirements.
- b. The CWA provides that any person who violates Section 301, 302, 306, 307, 308, 318, or 405 of the CWA or any permit condition or limitation implementing any of such sections in a permit issued under Section 402, or any requirement imposed in a pretreatment program approved under Section 402 (a)(3) or 402 (b)(8) of the CWA is subject to a civil penalty not to exceed \$25,000 per day for each violation. Any person who negligently violates such requirements is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than 1 year, or both. Any person who knowingly violates such requirements is subject to a fine of not less than \$5,000 nor more than \$50,000 per day of violation, or by imprisonment for not more than 3 years, or both.
- c. Any person may be assessed an administrative penalty by the Administrator for violating Section 301, 302, 306, 307, 308, 318, or 405 of the CWA, or any permit condition or limitation implementing any of such sections in a permit issued under Section 402 of the CWA. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.

Note: See 40 CFR §122.41(a)(2) for complete “Duty to Comply” regulations.

2. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or notifications of planned changes or anticipated noncompliance does not stay any permit condition.

3. Duty to Provide Information

The permittee shall furnish to the Regional Administrator, within a reasonable time, any information which the Regional Administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Regional Administrator, upon request, copies of records required to be kept by this permit.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)4. Reopener Clause

The Regional Administrator reserves the right to make appropriate revisions to this permit in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the CWA in order to bring all discharges into compliance with the CWA.

For any permit issued to a treatment works treating domestic sewage (including “sludge-only facilities”), the Regional Administrator or Director shall include a reopener clause to incorporate any applicable standard for sewage sludge use or disposal promulgated under Section 405 (d) of the CWA. The Regional Administrator or Director may promptly modify or revoke and reissue any permit containing the reopener clause required by this paragraph if the standard for sewage sludge use or disposal is more stringent than any requirements for sludge use or disposal in the permit, or contains a pollutant or practice not limited in the permit.

Federal regulations pertaining to permit modification, revocation and reissuance, and termination are found at 40 CFR §122.62, 122.63, 122.64, and 124.5.

5. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from responsibilities, liabilities or penalties to which the permittee is or may be subject under Section 311 of the CWA, or Section 106 of the Comprehensive Environmental Response, Compensation and Liability Act of 1980 (CERCLA).

6. Property Rights

The issuance of this permit does not convey any property rights of any sort, nor any exclusive privileges.

7. Confidentiality of Information

- a. In accordance with 40 CFR Part 2, any information submitted to EPA pursuant to these regulations may be claimed as confidential by the submitter. Any such claim must be asserted at the time of submission in the manner prescribed on the application form or instructions or, in the case of other submissions, by stamping the words “confidential business information” on each page containing such information. If no claim is made at the time of submission, EPA may make the information available to the public without further notice. If a claim is asserted, the information will be treated in accordance with the procedures in 40 CFR Part 2 (Public Information).
- b. Claims of confidentiality for the following information will be denied:
  - (1) The name and address of any permit applicant or permittee;
  - (2) Permit applications, permits, and effluent data as defined in 40 CFR §2.302(a)(2).
- c. Information required by NPDES application forms provided by the Regional Administrator under 40 CFR §122.21 may not be claimed confidential. This includes information submitted on the forms themselves and any attachments used to supply information required by the forms.



NPDES PART II STANDARD CONDITIONS  
(January, 2007)

8. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee must apply for and obtain a new permit. The permittee shall submit a new application at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Regional Administrator. (The Regional Administrator shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)

9. State Authorities

Nothing in Part 122, 123, or 124 precludes more stringent State regulation of any activity covered by these regulations, whether or not under an approved State program.

10. Other Laws

The issuance of a permit does not authorize any injury to persons or property or invasion of other private rights, nor does it relieve the permittee of its obligation to comply with any other applicable Federal, State, or local laws and regulations.

PART II. B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS

1. Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit and with the requirements of storm water pollution prevention plans. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when the operation is necessary to achieve compliance with the conditions of the permit.

2. Need to Halt or Reduce Not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

3. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

4. Bypass

a. Definitions

- (1) *Bypass* means the intentional diversion of waste streams from any portion of a treatment facility.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

- (2) *Severe property damage* means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can be reasonably expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

b. Bypass not exceeding limitations

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provision of Paragraphs B.4.c. and 4.d. of this section.

c. Notice

- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in paragraph D.1.e. of this part (Twenty-four hour reporting).

d. Prohibition of bypass

Bypass is prohibited, and the Regional Administrator may take enforcement action against a permittee for bypass, unless:

- (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance; and
- (3) i) The permittee submitted notices as required under Paragraph 4.c. of this section.  
ii) The Regional Administrator may approve an anticipated bypass, after considering its adverse effects, if the Regional Administrator determines that it will meet the three conditions listed above in paragraph 4.d. of this section.

5. Upset

- a. Definition. *Upset* means an exceptional incident in which there is an unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- b. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of paragraph B.5.c. of this section are met. No determination made during

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.

- c. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
  - (2) The permitted facility was at the time being properly operated;
  - (3) The permittee submitted notice of the upset as required in paragraphs D.1.a. and 1.e. (Twenty-four hour notice); and
  - (4) The permittee complied with any remedial measures required under B.3. above.
- d. Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

PART II. C. MONITORING REQUIREMENTS

1. Monitoring and Records

- a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. Except for records for monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application except for the information concerning storm water discharges which must be retained for a total of 6 years. This retention period may be extended by request of the Regional Administrator at any time.
- c. Records of monitoring information shall include:
  - (1) The date, exact place, and time of sampling or measurements;
  - (2) The individual(s) who performed the sampling or measurements;
  - (3) The date(s) analyses were performed;
  - (4) The individual(s) who performed the analyses;
  - (5) The analytical techniques or methods used; and
  - (6) The results of such analyses.
- d. Monitoring results must be conducted according to test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, unless other test procedures have been specified in the permit.
- e. The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.

2. Inspection and Entry

The permittee shall allow the Regional Administrator or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the CWA, any substances or parameters at any location.

PART II. D. REPORTING REQUIREMENTS

1. Reporting Requirements

- a. Planned Changes. The permittee shall give notice to the Regional Administrator as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:
  - (1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR§122.29(b); or
  - (2) The alteration or addition could significantly change the nature or increase the quantities of the pollutants discharged. This notification applies to pollutants which are subject neither to the effluent limitations in the permit, nor to the notification requirements at 40 CFR§122.42(a)(1).
  - (3) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition or change may justify the application of permit conditions different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Anticipated noncompliance. The permittee shall give advance notice to the Regional Administrator of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- c. Transfers. This permit is not transferable to any person except after notice to the Regional Administrator. The Regional Administrator may require modification or revocation and reissuance of the permit to change the name of the permittee and

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

incorporate such other requirements as may be necessary under the CWA. (See 40 CFR Part 122.61; in some cases, modification or revocation and reissuance is mandatory.)

- d. Monitoring reports. Monitoring results shall be reported at the intervals specified elsewhere in this permit.
- (1) Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Director for reporting results of monitoring of sludge use or disposal practices.
  - (2) If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, or as specified in the permit, the results of the monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Director.
  - (3) Calculations for all limitations which require averaging or measurements shall utilize an arithmetic mean unless otherwise specified by the Director in the permit.
- e. Twenty-four hour reporting.
- (1) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances.  
  
A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
  - (2) The following shall be included as information which must be reported within 24 hours under this paragraph.
    - (a) Any unanticipated bypass which exceeds any effluent limitation in the permit. (See 40 CFR §122.41(g).)
    - (b) Any upset which exceeds any effluent limitation in the permit.
    - (c) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Regional Administrator in the permit to be reported within 24 hours. (See 40 CFR §122.44(g).)
  - (3) The Regional Administrator may waive the written report on a case-by-case basis for reports under Paragraph D.1.e. if the oral report has been received within 24 hours.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

- f. Compliance Schedules. Reports of compliance or noncompliance with, any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
  - g. Other noncompliance. The permittee shall report all instances of noncompliance not reported under Paragraphs D.1.d., D.1.e., and D.1.f. of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in Paragraph D.1.e. of this section.
  - h. Other information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Administrator, it shall promptly submit such facts or information.
2. Signatory Requirement
- a. All applications, reports, or information submitted to the Regional Administrator shall be signed and certified. (See 40 CFR §122.22)
  - b. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 2 years per violation, or by both.
3. Availability of Reports.

Except for data determined to be confidential under Paragraph A.8. above, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the State water pollution control agency and the Regional Administrator. As required by the CWA, effluent data shall not be considered confidential. Knowingly making any false statements on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the CWA.

PART II. E. DEFINITIONS AND ABBREVIATIONS

1. Definitions for Individual NPDES Permits including Storm Water Requirements

*Administrator* means the Administrator of the United States Environmental Protection Agency, or an authorized representative.

*Applicable standards and limitations* means all, State, interstate, and Federal standards and limitations to which a “discharge”, a “sewage sludge use or disposal practice”, or a related activity is subject to, including “effluent limitations”, water quality standards, standards of performance, toxic effluent standards or prohibitions, “best management practices”, pretreatment standards, and “standards for sewage sludge use and disposal” under Sections 301, 302, 303, 304, 306, 307, 308, 403, and 405 of the CWA.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

*Application* means the EPA standard national forms for applying for a permit, including any additions, revisions, or modifications to the forms; or forms approved by EPA for use in “approved States”, including any approved modifications or revisions.

*Average* means the arithmetic mean of values taken at the frequency required for each parameter over the specified period. For total and/or fecal coliforms and Escherichia coli, the average shall be the geometric mean.

*Average monthly discharge limitation* means the highest allowable average of “daily discharges” over a calendar month calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month.

*Average weekly discharge limitation* means the highest allowable average of “daily discharges” measured during the calendar week divided by the number of “daily discharges” measured during the week.

*Best Management Practices (BMPs)* means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of “waters of the United States.” BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

*Best Professional Judgment (BPJ)* means a case-by-case determination of Best Practicable Treatment (BPT), Best Available Treatment (BAT), or other appropriate technology-based standard based on an evaluation of the available technology to achieve a particular pollutant reduction and other factors set forth in 40 CFR §125.3 (d).

*Coal Pile Runoff* means the rainfall runoff from or through any coal storage pile.

*Composite Sample* means a sample consisting of a minimum of eight grab samples of equal volume collected at equal intervals during a 24-hour period (or lesser period as specified in the section on Monitoring and Reporting) and combined proportional to flow, or a sample consisting of the same number of grab samples, or greater, collected proportionally to flow over that same time period.

*Construction Activities* - The following definitions apply to construction activities:

- (a) Commencement of Construction is the initial disturbance of soils associated with clearing, grading, or excavating activities or other construction activities.
- (b) Dedicated portable asphalt plant is a portable asphalt plant located on or contiguous to a construction site and that provides asphalt only to the construction site that the plant is located on or adjacent to. The term dedicated portable asphalt plant does not include facilities that are subject to the asphalt emulsion effluent limitation guideline at 40 CFR Part 443.
- (c) Dedicated portable concrete plant is a portable concrete plant located on or contiguous to a construction site and that provides concrete only to the construction site that the plant is located on or adjacent to.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

- (d) Final Stabilization means that all soil disturbing activities at the site have been complete, and that a uniform perennial vegetative cover with a density of 70% of the cover for unpaved areas and areas not covered by permanent structures has been established or equivalent permanent stabilization measures (such as the use of riprap, gabions, or geotextiles) have been employed.
- (e) Runoff coefficient means the fraction of total rainfall that will appear at the conveyance as runoff.

*Contiguous zone* means the entire zone established by the United States under Article 24 of the Convention on the Territorial Sea and the Contiguous Zone.

*Continuous discharge* means a “discharge” which occurs without interruption throughout the operating hours of the facility except for infrequent shutdowns for maintenance, process changes, or similar activities.

CWA means the Clean Water Act (formerly referred to as the Federal Water Pollution Control Act or Federal Water Pollution Control Act Amendments of 1972) Pub. L. 92-500, as amended by Pub. L. 95-217, Pub. L. 95-576, Pub. L. 96-483, and Pub. L. 97-117; 33 USC §§1251 et seq.

*Daily Discharge* means the discharge of a pollutant measured during the calendar day or any other 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the “daily discharge” is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurements, the “daily discharge” is calculated as the average measurement of the pollutant over the day.

*Director* normally means the person authorized to sign NPDES permits by EPA or the State or an authorized representative. Conversely, it also could mean the Regional Administrator or the State Director as the context requires.

*Discharge Monitoring Report Form (DMR)* means the EPA standard national form, including any subsequent additions, revisions, or modifications for the reporting of self-monitoring results by permittees. DMRs must be used by “approved States” as well as by EPA. EPA will supply DMRs to any approved State upon request. The EPA national forms may be modified to substitute the State Agency name, address, logo, and other similar information, as appropriate, in place of EPA’s.

*Discharge of a pollutant* means:

- (a) Any addition of any “pollutant” or combination of pollutants to “waters of the United States” from any “point source”, or
- (b) Any addition of any pollutant or combination of pollutants to the waters of the “contiguous zone” or the ocean from any point source other than a vessel or other floating craft which is being used as a means of transportation (See “Point Source” definition).

This definition includes additions of pollutants into waters of the United States from: surface runoff which is collected or channeled by man; discharges through pipes, sewers, or other conveyances owned by a State, municipality, or other person which do not lead



NPDES PART II STANDARD CONDITIONS  
(January, 2007)

to a treatment works; and discharges through pipes, sewers, or other conveyances leading into privately owned treatment works.

This term does not include an addition of pollutants by any “indirect discharger.”

*Effluent limitation* means any restriction imposed by the Regional Administrator on quantities, discharge rates, and concentrations of “pollutants” which are “discharged” from “point sources” into “waters of the United States”, the waters of the “contiguous zone”, or the ocean.

*Effluent limitation guidelines* means a regulation published by the Administrator under Section 304(b) of CWA to adopt or revise “effluent limitations”.

*EPA* means the United States “Environmental Protection Agency”.

*Flow-weighted composite sample* means a composite sample consisting of a mixture of aliquots where the volume of each aliquot is proportional to the flow rate of the discharge.

*Grab Sample* – An individual sample collected in a period of less than 15 minutes.

*Hazardous Substance* means any substance designated under 40 CFR Part 116 pursuant to Section 311 of the CWA.

*Indirect Discharger* means a non-domestic discharger introducing pollutants to a publicly owned treatment works.

*Interference* means a discharge which, alone or in conjunction with a discharge or discharges from other sources, both:

- (a) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
- (b) Therefore is a cause of a violation of any requirement of the POTW’s NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act (CWA), the Solid Waste Disposal Act (SWDA) (including Title II, more commonly referred to as the Resources Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to Subtitle D of the SDWA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection Research and Sanctuaries Act.

*Landfill* means an area of land or an excavation in which wastes are placed for permanent disposal, and which is not a land application unit, surface impoundment, injection well, or waste pile.

*Land application unit* means an area where wastes are applied onto or incorporated into the soil surface (excluding manure spreading operations) for treatment or disposal.

*Large and Medium municipal separate storm sewer system* means all municipal separate storm sewers that are either: (i) located in an incorporated place (city) with a population of 100,000 or more as determined by the latest Decennial Census by the Bureau of Census (these cities are listed in Appendices F and 40 CFR Part 122); or (ii) located in the counties with unincorporated urbanized

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

populations of 100,000 or more, except municipal separate storm sewers that are located in the incorporated places, townships, or towns within such counties (these counties are listed in Appendices H and I of 40 CFR 122); or (iii) owned or operated by a municipality other than those described in Paragraph (i) or (ii) and that are designated by the Regional Administrator as part of the large or medium municipal separate storm sewer system.

*Maximum daily discharge limitation* means the highest allowable “daily discharge” concentration that occurs only during a normal day (24-hour duration).

*Maximum daily discharge limitation (as defined for the Steam Electric Power Plants only) when applied to Total Residual Chlorine (TRC) or Total Residual Oxidant (TRO)* is defined as “maximum concentration” or “Instantaneous Maximum Concentration” during the two hours of a chlorination cycle (or fraction thereof) prescribed in the Steam Electric Guidelines, 40 CFR Part 423. These three synonymous terms all mean “a value that shall not be exceeded” during the two-hour chlorination cycle. This interpretation differs from the specified NPDES Permit requirement, 40 CFR § 122.2, where the two terms of “Maximum Daily Discharge” and “Average Daily Discharge” concentrations are specifically limited to the daily (24-hour duration) values.

*Municipality* means a city, town, borough, county, parish, district, association, or other public body created by or under State law and having jurisdiction over disposal of sewage, industrial wastes, or other wastes, or an Indian tribe or an authorized Indian tribe organization, or a designated and approved management agency under Section 208 of the CWA.

*National Pollutant Discharge Elimination System* means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under Sections 307, 402, 318, and 405 of the CWA. The term includes an “approved program”.

*New Discharger* means any building, structure, facility, or installation:

- (a) From which there is or may be a “discharge of pollutants”;
- (b) That did not commence the “discharge of pollutants” at a particular “site” prior to August 13, 1979;
- (c) Which is not a “new source”; and
- (d) Which has never received a finally effective NPDES permit for discharges at that “site”.

This definition includes an “indirect discharger” which commences discharging into “waters of the United States” after August 13, 1979. It also includes any existing mobile point source (other than an offshore or coastal oil and gas exploratory drilling rig or a coastal oil and gas exploratory drilling rig or a coastal oil and gas developmental drilling rig) such as a seafood processing rig, seafood processing vessel, or aggregate plant, that begins discharging at a “site” for which it does not have a permit; and any offshore rig or coastal mobile oil and gas exploratory drilling rig or coastal mobile oil and gas developmental drilling rig that commences the discharge of pollutants after August 13, 1979, at a “site” under EPA’s permitting jurisdiction for which it is not covered by an individual or general permit and which is located in an area determined by the Regional Administrator in the issuance of a final permit to be in an area of biological concern. In determining whether an area is an area of biological concern, the Regional Administrator shall consider the factors specified in 40 CFR §§125.122 (a) (1) through (10).

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

An offshore or coastal mobile exploratory drilling rig or coastal mobile developmental drilling rig will be considered a “new discharger” only for the duration of its discharge in an area of biological concern.

*New source* means any building, structure, facility, or installation from which there is or may be a “discharge of pollutants”, the construction of which commenced:

- (a) After promulgation of standards of performance under Section 306 of CWA which are applicable to such source, or
- (b) After proposal of standards of performance in accordance with Section 306 of CWA which are applicable to such source, but only if the standards are promulgated in accordance with Section 306 within 120 days of their proposal.

*NPDES* means “National Pollutant Discharge Elimination System”.

*Owner or operator* means the owner or operator of any “facility or activity” subject to regulation under the NPDES programs.

*Pass through* means a Discharge which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW’s NPDES permit (including an increase in the magnitude or duration of a violation).

*Permit* means an authorization, license, or equivalent control document issued by EPA or an “approved” State.

*Person* means an individual, association, partnership, corporation, municipality, State or Federal agency, or an agent or employee thereof.

*Point Source* means any discernible, confined, and discrete conveyance, including but not limited to any pipe ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, landfill leachate collection system, vessel, or other floating craft, from which pollutants are or may be discharged. This term does not include return flows from irrigated agriculture or agricultural storm water runoff (see 40 CFR §122.2).

*Pollutant* means dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, chemical wastes, biological materials, radioactive materials (except those regulated under the Atomic Energy Act of 1954, as amended (42 U.S.C. §§2011 et seq.)), heat, wrecked or discarded equipment, rock, sand, cellar dirt and industrial, municipal, and agricultural waste discharged into water. It does not mean:

- (a) Sewage from vessels; or
- (b) Water, gas, or other material which is injected into a well to facilitate production of oil or gas, or water derived in association with oil and gas production and disposed of in a well, if the well is used either to facilitate production or for disposal purposes is approved by the authority of the State in which the well is located, and if the State determines that the injection or disposal will not result in the degradation of ground or surface water resources.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

*Primary industry category* means any industry category listed in the NRDC settlement agreement (Natural Resources Defense Council et al. v. Train, 8 E.R.C. 2120 (D.D.C. 1976), modified 12 E.R.C. 1833 (D. D.C. 1979)); also listed in Appendix A of 40 CFR Part 122.

*Privately owned treatment works* means any device or system which is (a) used to treat wastes from any facility whose operation is not the operator of the treatment works or (b) not a "POTW".

*Process wastewater* means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.

*Publicly Owned Treatment Works (POTW)* means any facility or system used in the treatment (including recycling and reclamation) of municipal sewage or industrial wastes of a liquid nature which is owned by a "State" or "municipality".

This definition includes sewers, pipes, or other conveyances only if they convey wastewater to a POTW providing treatment.

*Regional Administrator* means the Regional Administrator, EPA, Region I, Boston, Massachusetts.

*Secondary Industry Category* means any industry which is not a "primary industry category".

*Section 313 water priority chemical* means a chemical or chemical category which:

- (1) is listed at 40 CFR §372.65 pursuant to Section 313 of the Emergency Planning and Community Right-To-Know Act (EPCRA) (also known as Title III of the Superfund Amendments and Reauthorization Act (SARA) of 1986);
- (2) is present at or above threshold levels at a facility subject to EPCRA Section 313 reporting requirements; and
- (3) satisfies at least one of the following criteria:
  - (i) are listed in Appendix D of 40 CFR Part 122 on either Table II (organic priority pollutants), Table III (certain metals, cyanides, and phenols), or Table V (certain toxic pollutants and hazardous substances);
  - (ii) are listed as a hazardous substance pursuant to Section 311(b)(2)(A) of the CWA at 40 CFR §116.4; or
  - (iii) are pollutants for which EPA has published acute or chronic water quality criteria.

*Septage* means the liquid and solid material pumped from a septic tank, cesspool, or similar domestic sewage treatment system, or a holding tank when the system is cleaned or maintained.

*Sewage Sludge* means any solid, semisolid, or liquid residue removed during the treatment of municipal wastewater or domestic sewage. Sewage sludge includes, but is not limited to, solids removed during primary, secondary, or advanced wastewater treatment, scum, septage, portable toilet pumpings, Type III Marine Sanitation Device pumpings (33 CFR Part 159), and sewage sludge products. Sewage sludge does not include grit or screenings, or ash generated during the incineration of sewage sludge.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

*Sewage sludge use or disposal practice* means the collection, storage, treatment, transportation, processing, monitoring, use, or disposal of sewage sludge.

*Significant materials* includes, but is not limited to: raw materials, fuels, materials such as solvents, detergents, and plastic pellets, raw materials used in food processing or production, hazardous substance designated under section 101(14) of CERCLA, any chemical the facility is required to report pursuant to EPCRA Section 313, fertilizers, pesticides, and waste products such as ashes, slag, and sludge that have the potential to be released with storm water discharges.

*Significant spills* includes, but is not limited to, releases of oil or hazardous substances in excess of reportable quantities under Section 311 of the CWA (see 40 CFR §110.10 and §117.21) or Section 102 of CERCLA (see 40 CFR § 302.4).

*Sludge-only facility* means any “treatment works treating domestic sewage” whose methods of sewage sludge use or disposal are subject to regulations promulgated pursuant to Section 405(d) of the CWA, and is required to obtain a permit under 40 CFR §122.1(b)(3).

*State* means any of the 50 States, the District of Columbia, Guam, the Commonwealth of Puerto Rico, the Virgin Islands, American Samoa, the Trust Territory of the Pacific Islands.

*Storm Water* means storm water runoff, snow melt runoff, and surface runoff and drainage.

*Storm water discharge associated with industrial activity* means the discharge from any conveyance which is used for collecting and conveying storm water and which is directly related to manufacturing, processing, or raw materials storage areas at an industrial plant. (See 40 CFR §122.26 (b)(14) for specifics of this definition.

*Time-weighted composite* means a composite sample consisting of a mixture of equal volume aliquots collected at a constant time interval.

*Toxic pollutants* means any pollutant listed as toxic under Section 307 (a)(1) or, in the case of “sludge use or disposal practices” any pollutant identified in regulations implementing Section 405(d) of the CWA.

*Treatment works treating domestic sewage* means a POTW or any other sewage sludge or wastewater treatment devices or systems, regardless of ownership (including federal facilities), used in the storage, treatment, recycling, and reclamation of municipal or domestic sewage, including land dedicated for the disposal of sewage sludge. This definition does not include septic tanks or similar devices.

For purposes of this definition, “domestic sewage” includes waste and wastewater from humans or household operations that are discharged to or otherwise enter a treatment works. In States where there is no approved State sludge management program under Section 405(f) of the CWA, the Regional Administrator may designate any person subject to the standards for sewage sludge use and disposal in 40 CFR Part 503 as a “treatment works treating domestic sewage”, where he or she finds that there is a potential for adverse effects on public health and the environment from poor sludge quality or poor sludge handling, use or disposal practices, or where he or she finds that such designation is necessary to ensure that such person is in compliance with 40 CFR Part 503.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

*Waste Pile* means any non-containerized accumulation of solid, non-flowing waste that is used for treatment or storage.

*Waters of the United States* means:

- (a) All waters which are currently used, were used in the past, or may be susceptible to use in interstate or foreign commerce, including all waters which are subject to the ebb and flow of tide;
- (b) All interstate waters, including interstate “wetlands”;
- (c) All other waters such as intrastate lakes, rivers, streams (including intermittent streams), mudflats, sandflats, “wetlands”, sloughs, prairie potholes, wet meadows, playa lakes, or natural ponds the use, degradation, or destruction of which would affect or could affect interstate or foreign commerce including any such waters:
  - (1) Which are or could be used by interstate or foreign travelers for recreational or other purpose;
  - (2) From which fish or shellfish are or could be taken and sold in interstate or foreign commerce; or
  - (3) Which are used or could be used for industrial purposes by industries in interstate commerce;
- (d) All impoundments of waters otherwise defined as waters of the United States under this definition;
- (e) Tributaries of waters identified in Paragraphs (a) through (d) of this definition;
- (f) The territorial sea; and
- (g) “Wetlands” adjacent to waters (other than waters that are themselves wetlands) identified in Paragraphs (a) through (f) of this definition.

Waste treatment systems, including treatment ponds or lagoons designed to meet the requirements of the CWA (other than cooling ponds as defined in 40 CFR §423.11(m) which also meet the criteria of this definition) are not waters of the United States.

*Wetlands* means those areas that are inundated or saturated by surface or ground water at a frequency and duration to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

*Whole Effluent Toxicity (WET)* means the aggregate toxic effect of an effluent measured directly by a toxicity test. (See Abbreviations Section, following, for additional information.)

## 2. Definitions for NPDES Permit Sludge Use and Disposal Requirements.

*Active sewage sludge unit* is a sewage sludge unit that has not closed.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

*Aerobic Digestion* is the biochemical decomposition of organic matter in sewage sludge into carbon dioxide and water by microorganisms in the presence of air.

*Agricultural Land* is land on which a food crop, a feed crop, or a fiber crop is grown. This includes range land and land used as pasture.

*Agronomic rate* is the whole sludge application rate (dry weight basis) designed:

- (1) To provide the amount of nitrogen needed by the food crop, feed crop, fiber crop, cover crop, or vegetation grown on the land; and
- (2) To minimize the amount of nitrogen in the sewage sludge that passes below the root zone of the crop or vegetation grown on the land to the ground water.

*Air pollution control device* is one or more processes used to treat the exit gas from a sewage sludge incinerator stack.

*Anaerobic digestion* is the biochemical decomposition of organic matter in sewage sludge into methane gas and carbon dioxide by microorganisms in the absence of air.

*Annual pollutant loading rate* is the maximum amount of a pollutant that can be applied to a unit area of land during a 365 day period.

*Annual whole sludge application rate* is the maximum amount of sewage sludge (dry weight basis) that can be applied to a unit area of land during a 365 day period.

*Apply sewage sludge or sewage sludge applied to the land* means land application of sewage sludge.

*Aquifer* is a geologic formation, group of geologic formations, or a portion of a geologic formation capable of yielding ground water to wells or springs.

*Auxiliary fuel* is fuel used to augment the fuel value of sewage sludge. This includes, but is not limited to, natural gas, fuel oil, coal, gas generated during anaerobic digestion of sewage sludge, and municipal solid waste (not to exceed 30 percent of the dry weight of the sewage sludge and auxiliary fuel together). Hazardous wastes are not auxiliary fuel.

*Base flood* is a flood that has a one percent chance of occurring in any given year (i.e. a flood with a magnitude equaled once in 100 years).

*Bulk sewage sludge* is sewage sludge that is not sold or given away in a bag or other container for application to the land.

*Contaminate an aquifer* means to introduce a substance that causes the maximum contaminant level for nitrate in 40 CFR §141.11 to be exceeded in ground water or that causes the existing concentration of nitrate in the ground water to increase when the existing concentration of nitrate in the ground water exceeds the maximum contaminant level for nitrate in 40 CFR §141.11.

*Class I sludge management facility* is any publicly owned treatment works (POTW), as defined in 40 CFR §501.2, required to have an approved pretreatment program under 40 CFR §403.8 (a) (including any POTW located in a state that has elected to assume local program responsibilities pursuant to 40 CFR §403.10 (e) and any treatment works treating domestic sewage, as defined in 40 CFR § 122.2,

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

classified as a Class I sludge management facility by the EPA Regional Administrator, or, in the case of approved state programs, the Regional Administrator in conjunction with the State Director, because of the potential for sewage sludge use or disposal practice to affect public health and the environment adversely.

*Control efficiency* is the mass of a pollutant in the sewage sludge fed to an incinerator minus the mass of that pollutant in the exit gas from the incinerator stack divided by the mass of the pollutant in the sewage sludge fed to the incinerator.

*Cover* is soil or other material used to cover sewage sludge placed on an active sewage sludge unit.

*Cover crop* is a small grain crop, such as oats, wheat, or barley, not grown for harvest.

*Cumulative pollutant loading rate* is the maximum amount of inorganic pollutant that can be applied to an area of land.

*Density of microorganisms* is the number of microorganisms per unit mass of total solids (dry weight) in the sewage sludge.

*Dispersion factor* is the ratio of the increase in the ground level ambient air concentration for a pollutant at or beyond the property line of the site where the sewage sludge incinerator is located to the mass emission rate for the pollutant from the incinerator stack.

*Displacement* is the relative movement of any two sides of a fault measured in any direction.

*Domestic septage* is either liquid or solid material removed from a septic tank, cesspool, portable toilet, Type III marine sanitation device, or similar treatment works that receives only domestic sewage. Domestic septage does not include liquid or solid material removed from a septic tank, cesspool, or similar treatment works that receives either commercial wastewater or industrial wastewater and does not include grease removed from a grease trap at a restaurant.

*Domestic sewage* is waste and wastewater from humans or household operations that is discharged to or otherwise enters a treatment works.

*Dry weight basis* means calculated on the basis of having been dried at 105 degrees Celsius (°C) until reaching a constant mass (i.e. essentially 100 percent solids content).

*Fault* is a fracture or zone of fractures in any materials along which strata on one side are displaced with respect to the strata on the other side.

*Feed crops* are crops produced primarily for consumption by animals.

*Fiber crops* are crops such as flax and cotton.

*Final cover* is the last layer of soil or other material placed on a sewage sludge unit at closure.

*Fluidized bed incinerator* is an enclosed device in which organic matter and inorganic matter in sewage sludge are combusted in a bed of particles suspended in the combustion chamber gas.

*Food crops* are crops consumed by humans. These include, but are not limited to, fruits, vegetables, and tobacco.



NPDES PART II STANDARD CONDITIONS  
(January, 2007)

*Forest* is a tract of land thick with trees and underbrush.

*Ground water* is water below the land surface in the saturated zone.

*Holocene time* is the most recent epoch of the Quaternary period, extending from the end of the Pleistocene epoch to the present.

*Hourly average* is the arithmetic mean of all the measurements taken during an hour. At least two measurements must be taken during the hour.

*Incineration* is the combustion of organic matter and inorganic matter in sewage sludge by high temperatures in an enclosed device.

*Industrial wastewater* is wastewater generated in a commercial or industrial process.

*Land application* is the spraying or spreading of sewage sludge onto the land surface; the injection of sewage sludge below the land surface; or the incorporation of sewage sludge into the soil so that the sewage sludge can either condition the soil or fertilize crops or vegetation grown in the soil.

*Land with a high potential for public exposure* is land that the public uses frequently. This includes, but is not limited to, a public contact site and reclamation site located in a populated area (e.g., a construction site located in a city).

*Land with low potential for public exposure* is land that the public uses infrequently. This includes, but is not limited to, agricultural land, forest and a reclamation site located in an unpopulated area (e.g., a strip mine located in a rural area).

*Leachate collection system* is a system or device installed immediately above a liner that is designed, constructed, maintained, and operated to collect and remove leachate from a sewage sludge unit.

*Liner* is soil or synthetic material that has a hydraulic conductivity of  $1 \times 10^{-7}$  centimeters per second or less.

*Lower explosive limit for methane gas* is the lowest percentage of methane gas in air, by volume, that propagates a flame at 25 degrees Celsius and atmospheric pressure.

*Monthly average (Incineration)* is the arithmetic mean of the hourly averages for the hours a sewage sludge incinerator operates during the month.

*Monthly average (Land Application)* is the arithmetic mean of all measurements taken during the month.

*Municipality* means a city, town, borough, county, parish, district, association, or other public body (including an intermunicipal agency of two or more of the foregoing entities) created by or under State law; an Indian tribe or an authorized Indian tribal organization having jurisdiction over sewage sludge management; or a designated and approved management agency under section 208 of the CWA, as amended. The definition includes a special district created under state law, such as a water district, sewer district, sanitary district, utility district, drainage district, or similar entity, or an integrated waste management facility as defined in section 201 (e) of the CWA, as amended, that has as one of its principal responsibilities the treatment, transport, use or disposal of sewage sludge.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

*Other container* is either an open or closed receptacle. This includes, but is not limited to, a bucket, a box, a carton, and a vehicle or trailer with a load capacity of one metric ton or less.

*Pasture* is land on which animals feed directly on feed crops such as legumes, grasses, grain stubble, or stover.

*Pathogenic organisms* are disease-causing organisms. These include, but are not limited to, certain bacteria, protozoa, viruses, and viable helminth ova.

*Permitting authority* is either EPA or a State with an EPA-approved sludge management program.

*Person* is an individual, association, partnership, corporation, municipality, State or Federal Agency, or an agent or employee thereof.

*Person who prepares sewage sludge* is either the person who generates sewage sludge during the treatment of domestic sewage in a treatment works or the person who derives a material from sewage sludge.

*pH* means the logarithm of the reciprocal of the hydrogen ion concentration; a measure of the acidity or alkalinity of a liquid or solid material.

*Place sewage sludge or sewage sludge placed* means disposal of sewage sludge on a surface disposal site.

*Pollutant (as defined in sludge disposal requirements)* is an organic substance, an inorganic substance, a combination of organic and inorganic substances, or pathogenic organism that, after discharge and upon exposure, ingestion, inhalation, or assimilation into an organism either directly from the environment or indirectly by ingestion through the food chain, could on the basis on information available to the Administrator of EPA, cause death, disease, behavioral abnormalities, cancer, genetic mutations, physiological malfunctions (including malfunction in reproduction) or physical deformations in either organisms or offspring of the organisms.

*Pollutant limit (for sludge disposal requirements)* is a numerical value that describes the amount of a pollutant allowed per unit amount of sewage sludge (e.g., milligrams per kilogram of total solids); the amount of pollutant that can be applied to a unit of land (e.g., kilograms per hectare); or the volume of the material that can be applied to the land (e.g., gallons per acre).

*Public contact site* is a land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.

*Qualified ground water scientist* is an individual with a baccalaureate or post-graduate degree in the natural sciences or engineering who has sufficient training and experience in ground water hydrology and related fields, as may be demonstrated by State registration, professional certification, or completion of accredited university programs, to make sound professional judgments regarding ground water monitoring, pollutant fate and transport, and corrective action.

*Range land* is open land with indigenous vegetation.

*Reclamation site* is drastically disturbed land that is reclaimed using sewage sludge. This includes, but is not limited to, strip mines and construction sites.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

*Risk specific concentration* is the allowable increase in the average daily ground level ambient air concentration for a pollutant from the incineration of sewage sludge at or beyond the property line of a site where the sewage sludge incinerator is located.

*Runoff* is rainwater, leachate, or other liquid that drains overland on any part of a land surface and runs off the land surface.

*Seismic impact zone* is an area that has 10 percent or greater probability that the horizontal ground level acceleration to the rock in the area exceeds 0.10 gravity once in 250 years.

*Sewage sludge* is a solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works. Sewage sludge includes, but is not limited to: domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment processes; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in treatment works.

*Sewage sludge feed rate* is either the average daily amount of sewage sludge fired in all sewage sludge incinerators within the property line of the site where the sewage sludge incinerators are located for the number of days in a 365 day period that each sewage sludge incinerator operates, or the average daily design capacity for all sewage sludge incinerators within the property line of the site where the sewage sludge incinerators are located.

*Sewage sludge incinerator* is an enclosed device in which only sewage sludge and auxiliary fuel are fired.

*Sewage sludge unit* is land on which only sewage sludge is placed for final disposal. This does not include land on which sewage sludge is either stored or treated. Land does not include waters of the United States, as defined in 40 CFR §122.2.

*Sewage sludge unit boundary* is the outermost perimeter of an active sewage sludge unit.

*Specific oxygen uptake rate (SOUR)* is the mass of oxygen consumed per unit time per unit mass of total solids (dry weight basis) in sewage sludge.

*Stack height* is the difference between the elevation of the top of a sewage sludge incinerator stack and the elevation of the ground at the base of the stack when the difference is equal to or less than 65 meters. When the difference is greater than 65 meters, stack height is the creditable stack height determined in accordance with 40 CFR §51.100 (ii).

*State* is one of the United States of America, the District of Columbia, the Commonwealth of Puerto Rico, the Virgin Islands, Guam, American Samoa, the Trust Territory of the Pacific Islands, the Commonwealth of the Northern Mariana Islands, and an Indian tribe eligible for treatment as a State pursuant to regulations promulgated under the authority of section 518(e) of the CWA.

*Store or storage of sewage sludge* is the placement of sewage sludge on land on which the sewage sludge remains for two years or less. This does not include the placement of sewage sludge on land for treatment.

*Surface disposal site* is an area of land that contains one or more active sewage sludge units.

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

*Total hydrocarbons* means the organic compounds in the exit gas from a sewage sludge incinerator stack measured using a flame ionization detection instrument referenced to propane.

*Total solids* are the materials in sewage sludge that remain as residue when the sewage sludge is dried at 103 to 105 degrees Celsius.

*Treat or treatment of sewage sludge* is the preparation of sewage sludge for final use or disposal. This includes, but is not limited to, thickening, stabilization, and dewatering of sewage sludge. This does not include storage of sewage sludge.

*Treatment works* is either a federally owned, publicly owned, or privately owned device or system used to treat (including recycle and reclaim) either domestic sewage or a combination of domestic sewage and industrial waste of a liquid nature.

*Unstable area* is land subject to natural or human-induced forces that may damage the structural components of an active sewage sludge unit. This includes, but is not limited to, land on which the soils are subject to mass movement.

*Unstabilized solids* are organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

*Vector attraction* is the characteristic of sewage sludge that attracts rodents, flies, mosquitoes, or other organisms capable of transporting infectious agents.

*Volatile solids* is the amount of the total solids in sewage sludge lost when the sewage sludge is combusted at 550 degrees Celsius in the presence of excess air.

*Wet electrostatic precipitator* is an air pollution control device that uses both electrical forces and water to remove pollutants in the exit gas from a sewage sludge incinerator stack.

*Wet scrubber* is an air pollution control device that uses water to remove pollutants in the exit gas from a sewage sludge incinerator stack.

3. Commonly Used Abbreviations

BOD	Five-day biochemical oxygen demand unless otherwise specified
CBOD	Carbonaceous BOD
CFS	Cubic feet per second
COD	Chemical oxygen demand
Chlorine	
Cl <sub>2</sub>	Total residual chlorine
TRC	Total residual chlorine which is a combination of free available chlorine (FAC, see below) and combined chlorine (chloramines, etc.)

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

TRO	Total residual chlorine in marine waters where halogen compounds are present
FAC	Free available chlorine (aqueous molecular chlorine, hypochlorous acid, and hypochlorite ion)
Coliform	
Coliform, Fecal	Total fecal coliform bacteria
Coliform, Total	Total coliform bacteria
Cont. (Continuous)	Continuous recording of the parameter being monitored, i.e. flow, temperature, pH, etc.
Cu. M/day or M <sup>3</sup> /day	Cubic meters per day
DO	Dissolved oxygen
kg/day	Kilograms per day
lbs/day	Pounds per day
mg/l	Milligram(s) per liter
ml/l	Milliliters per liter
MGD	Million gallons per day
Nitrogen	
Total N	Total nitrogen
NH <sub>3</sub> -N	Ammonia nitrogen as nitrogen
NO <sub>3</sub> -N	Nitrate as nitrogen
NO <sub>2</sub> -N	Nitrite as nitrogen
NO <sub>3</sub> -NO <sub>2</sub>	Combined nitrate and nitrite nitrogen as nitrogen
TKN	Total Kjeldahl nitrogen as nitrogen
Oil & Grease	Freon extractable material
PCB	Polychlorinated biphenyl
pH	A measure of the hydrogen ion concentration. A measure of the acidity or alkalinity of a liquid or material
Surfactant	Surface-active agent

NPDES PART II STANDARD CONDITIONS  
(January, 2007)

Temp. °C	Temperature in degrees Centigrade
Temp. °F	Temperature in degrees Fahrenheit
TOC	Total organic carbon
Total P	Total phosphorus
TSS or NFR	Total suspended solids or total nonfilterable residue
Turb. or Turbidity	Turbidity measured by the Nephelometric Method (NTU)
ug/l	Microgram(s) per liter
WET	“Whole effluent toxicity” is the total effect of an effluent measured directly with a toxicity test.
C-NOEC	“Chronic (Long-term Exposure Test) – No Observed Effect Concentration”. The highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specified time of observation.
A-NOEC	“Acute (Short-term Exposure Test) – No Observed Effect Concentration” (see C-NOEC definition).
LC <sub>50</sub>	LC <sub>50</sub> is the concentration of a sample that causes mortality of 50% of the test population at a specific time of observation. The LC <sub>50</sub> = 100% is defined as a sample of undiluted effluent.
ZID	Zone of Initial Dilution means the region of initial mixing surrounding or adjacent to the end of the outfall pipe or diffuser ports.

**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
NEW ENGLAND****FACT SHEET**

DRAFT NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
PERMIT TO DISCHARGE TO WATERS OF THE UNITED STATES.

NPDES PERMIT NO.: **MA0100897**

Public Notice Date: January 9, 2001 - February 10, 2001

NAME AND ADDRESS OF APPLICANTS:

<b>PSG/USFilter</b>	<b>And</b>	<b>The City of Taunton</b>
<b>825 West Water Street</b>		<b>Department of Public Works</b>
<b>Taunton, MA 02780</b>		<b>90 Ingell Street</b>
		<b>Taunton, MA 02780-3507</b>

PSG/USFilter and the City of Taunton shall be jointly responsible (co-permittees) for the operation of the treatment plant and for the one combined sewer overflow. The City of Taunton alone shall be responsible for the collection system.

NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

**Taunton Wastewater Treatment Plant**  
**825 West Water Street**  
**Taunton, MA 02780**  
**and one combined sewer overflow (CSO)**

RECEIVING WATERS: **Taunton River** (Taunton River Basin - MA62-02)

CLASSIFICATION: **B**

**I. PROPOSED ACTION, TYPE OF FACILITY, AND DISCHARGE LOCATION**

The above named applicant has applied to the U.S. Environmental Protection Agency for re-issuance of its National Pollutant Discharge Elimination System (NPDES) permit to discharge into the designated receiving water. The current permit expired on October 25, 2000 and is still in effect. This permit, after it becomes effective, will expire five years from the effective date. The Taunton Wastewater Treatment Plant is a 8.4 MGD (million gallon per day) advanced secondary treatment plant. The outfall pipe of the treatment plant discharges to the Taunton River. There is one combined sewer overflow(CSO) that also discharges to the Taunton River.

The facility's wastewater discharge outfalls are listed below:

<b>Outfall</b>	<b>Description of Discharge</b>	<b>Outfall Location/Receiving Water</b>
001	Treatment Plant Effluent	Taunton River
004	Combined Sanitary and Storm water Combined Sewer Overflow (CSO)	Taunton River (above treatment plant outfall)

## **II. DESCRIPTION OF THE DISCHARGE**

A quantitative description of the wastewater treatment plant discharge in terms of significant effluent parameters based on recent monitoring data is shown on **Attachment A** of this fact sheet.

## **III. LIMITATIONS AND CONDITIONS**

The effluent limitations of the draft permit and monitoring requirements may be found in the draft NPDES permit.

## **IV. PERMIT BASIS AND EXPLANATION OF EFFLUENT LIMITATION DERIVATION**

### **A. PROCESS DESCRIPTION**

The Taunton Wastewater Treatment Facility is engaged in the collection and treatment of municipal and industrial wastewater including inflow/infiltration. The facility provides advanced treatment and one stage nitrogen removal. The wastewater treatment is as follows:

At the headworks influent passes through two mechanically cleaned bar screens or a third bypass bar rack. After screening the influent passes through a distribution structure and then to the three primary settling tanks. Grit is removed by pumping primary sludge to a cyclone degritter. After settling, the flow continues on through one of two parallel treatment trains. Each treatment train consists of a bank of three aeration tanks and two secondary settling tanks. After settling the flow is sent to the chlorine contact chamber where it is disinfected with the flow paced addition of liquid hypochlorite and dechlorinated with bisulfite. The effluent is discharged through a reaeration cascade. Sludge is dewatered by centrifuge and is sent to a landfill.



## B. OUTFALL 001 EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

### 1. Overview of Federal and State Regulations

Under Section 301(b)(1) of the Clean Water Act ("CWA"), publicly owned treatment works ("POTWs") must achieve effluent limitations based upon Secondary Treatment by July 1, 1977. The secondary treatment requirements are set forth at 40 C.F.R. Part 133.102. In addition, Section 301(b)(1)(c) of the CWA requires that effluent limitations based on water quality considerations be established for point source discharges when such limitations are necessary to meet state or federal water quality standards that are applicable to the designated receiving water.

Pursuant to 40 C.F.R. § 122.44 (d)(1), permittees must achieve water quality standards established under Section 303 of the Clean Water Act (CWA), including state narrative criteria for water quality. Additionally, under 40 C.F.R. § 122.44 (d)(1)(i), "Limitations must control all pollutants or pollutant parameters which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any state water quality standard." When determining whether a discharge causes, or has the reasonable potential to cause or contribute to an in-stream excursion above a narrative or numeric criterion, the permitting authority shall use procedures which account for existing controls on point and non-point sources of pollution, and where appropriate, consider the dilution of the effluent in the receiving water.

### 2. Water Quality Standards; Designated Use; Outfall 001

The Taunton River has been classified as Class B in the Massachusetts Surface Water Quality Standards, 314 Code of Massachusetts Regulations ("CMR") 4.05(3)(b). The Massachusetts Surface Water Quality Standards describes Class B waters as having the following uses: as a habitat for fish, other aquatic life, and wildlife, and for primary and secondary contact recreation. Where designated they shall be suitable as a source of public water supply with appropriate treatment. They shall be suitable for irrigation and other agricultural uses and for compatible industrial cooling and process uses. These waters shall have consistently good aesthetic value.

Section 303(d) of the Federal Clean Water Act (CWA) requires states to identify those waterbodies that are not expected to meet surface water quality standards after the implementation of technology-based controls and, as such require the development of total maximum daily loads (TMDL). The 1998 303(d) report states that Taunton River Segment MA62-02, Route 24 Bridge, Taunton to Berkley Bridge, Dighton/Berkley (Miles 21.2-13.0) is not attaining water quality standards for pathogens.

Available Dilution

Water quality based limitations are established with the use of a calculated available dilution. Title 314 CMR 4.03(3)(a) requires that effluent dilution be calculated based on the receiving water 7Q10. The 7Q10 is the lowest observed mean river flow for 7 consecutive days, recorded over a 10 year recurrence interval. Additionally, the plant design flow is used to calculate available effluent dilution.

The plant design flow is 8.4 MGD or 13.0 CFS as stated in the permit application. Attachment B of the current permit Fact Sheet lists the 7Q10 flow of the Taunton River as 27 MGD or 41.85 CFS at the point of discharge. The nearest USGS river gage station to the discharge is located near Bridgewater (Station No. 0110800). The 7Q10 flow is adjusted to account for the additional drainage area and contributing streams between the river gage and the Taunton Treatment Plant. A review of recent United States Geological Survey (USGS) gage data does not indicate the need for a recalculation of the 7Q10 dilution established for the current permit.

Daily average design effluent flow + river flow (7Q10) = Dilution

Daily average design effluent flow

$$\frac{13.0 \text{ cfs} + 41.9 \text{ cfs}}{13.0 \text{ cfs}} = 4.2$$

## OUTFALL 001 - CONVENTIONAL POLLUTANTS

Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>) - The Secondary Treatment Requirements found in 40 CFR §133.102(a)(4) allow the substitution of Carbonaceous Biological Oxygen Demand (CBOD<sub>5</sub>) in lieu of Biological Oxygen Demand (BOD<sub>5</sub>). The previous NPDES permit utilized CBOD<sub>5</sub> as the measure of oxygen demand due to high nitrogenous oxygen demand in the effluent. The CBOD<sub>5</sub> test reduces the interference from nitrogenous compounds that would otherwise make accurate assessment of the organic (carbonaceous) oxygen demand impossible. The secondary treatment limitations are monthly average CBOD<sub>5</sub> concentrations of 25 mg/l and weekly average concentrations of 40 mg/l. The previous permit limits CBOD<sub>5</sub> seasonally. From November 1 through March 31 the standard secondary treatment requirements for CBOD<sub>5</sub> apply. During the period April 1<sup>st</sup> through October 31<sup>st</sup>, the permit contained more stringent monthly average concentration for CBOD<sub>5</sub>. These were established by the MADEP as a wasteload allocation. The April 1<sup>st</sup> through October 31<sup>st</sup>, CBOD<sub>5</sub> limits and the accompanying monthly mass limitations have been carried forward from previous permit.

The draft permit includes proposed average monthly and average weekly BOD<sub>5</sub> limitations which are based on the requirements set forth at 40 C.F.R. § 133.102(a)(1), (2), (3), and 40 CFR § 122.45(f). During the period from November 1<sup>st</sup> through March 31, the permit will be limited for BOD<sub>5</sub> instead of CBOD<sub>5</sub>, as the facility will discontinue the nitrifying process during the colder season making the use the CBOD<sub>5</sub> tests unnecessary. The draft permit includes average monthly mass limitations recalculated to address the conversion from CBOD<sub>5</sub> to BOD<sub>5</sub>.

The MADEP shall no longer require a daily maximum CBOD<sub>5</sub> or BOD<sub>5</sub> limit as a certification requirement under the provisions of Section 401(d) of the CWA. The daily maximum limit shall be replaced with a reporting requirement.

Total Suspended Solids (nonfilterable) (TSS) - The draft permit includes average monthly and average weekly TSS limitations which are based on secondary treatment requirements set forth at 40 C.F.R. §133.102(b)(1), (2), (3), and 40 CFR § 122.45(f) for the period, November 1 through March 31. From April 1<sup>st</sup> through October 31<sup>st</sup>, the TSS limits are based on the wasteload allocation that has been carried forward from previous permits. The MADEP shall no longer require a daily maximum TSS limit as a certification requirement under the provisions of Section 401(d) of the CWA. The daily maximum limit shall be replaced with a reporting requirement. The draft permit includes average monthly mass limitations calculated based on the concentration and flow limit (see below).

CBOD<sub>5</sub>, BOD<sub>5</sub> and TSS Mass Loading Calculations:

Calculations of maximum allowable loads for average monthly and average weekly BOD<sub>5</sub> and TSS are based on the following equation.

- L = C x DF x 8.34 or L = C x DF x 3.79 where:  
 L = Maximum allowable load in lbs/day (1 lb = 2.2 kg).  
 C = Maximum allowable effluent concentration for reporting period in mg/l.  
 Reporting periods are average monthly and weekly and daily maximum.  
 DF = Design flow of facility in MGD.  
 8.34 = Factor to convert effluent concentration in mg/l and design flow in MGD to lbs/day.  
 3.79 = Factor to convert effluent concentration in mg/l and design flow in MGD to kgs/day.

(Concentration limit) [45] X 8.34 (Constant) X 8.4 (design flow) = 3153 lb/day

(Concentration limit) [45] X 3.79 (Constant) X 8.4 (design flow) = 1463kg/day

(Concentration limit) [30] X 8.34 (Constant) X 8.4 (design flow) = 2102 lb/day

(Concentration limit) [30] X 3.79 (Constant) X 8.4 (design flow) = 955 kg/day

(Concentration limit) [20] X 8.34 (Constant) X 8.4 (design flow) = 1401 lb/day

(Concentration limit) [20] X 3.79 (Constant) X 8.4 (design flow) = 637 kg/day

(Concentration limit) [15] X 8.34 (Constant) X 8.4 (design flow) = 1051 lb/day

(Concentration limit) [15] X 3.79 (Constant) X 8.4 (design flow) = 478 kg/day

Eighty-Five Percent (85%) CBOD<sub>5</sub>, BOD<sub>5</sub> and TSS Removal Requirement - the provisions of 40 CFR §133.102(3) requires that the 30 day average percent removal for BOD (CBOD) and TSS be not less than 85%. The limit is carried forward from the current permit.

pH - The draft permit includes pH limitations which are required by state water quality standards, and are at least as stringent as pH limitations set forth at 40 C.F.R. §133.102(c).

Fecal Coliform Bacteria - The draft permit includes fecal coliform bacteria limitations which are required by state water quality standards for class B waters.

#### OUTFALL 001 - NON-CONVENTIONAL POLLUTANTS

Dissolved Oxygen - The instantaneous minimum effluent dissolved oxygen limit of 6.0 mg/l or greater is carried forward from the current permit. The limit insures that dissolved oxygen levels depleted during wastewater treatment process are restored prior to discharge to the Taunton River. The limit is established to protect the dissolved oxygen minimum Water Quality Criteria of 6.0 mg/l for waters designated by the State as Class B.

Nutrients - Extensive water quality monitoring in Mount Hope Bay has shown a system that is highly eutrophic, with dissolved oxygen concentrations in the bottom waters frequently dropping below 2 mg/l for extended periods over a large area of the bay (New England Power Company data, 1998). Satellite imagery of Mount Hope Bay suggests uniformly high concentrations of chlorophyll-a throughout the bay. The low dissolved oxygen and high chlorophyll-a concentrations are indicative of a eutrophication problem. Dissolved oxygen levels this low are violations of state water quality standards, but more importantly represent a serious threat to the health of the benthic community. Data collected in Long Island Sound shows that persistent low dissolved oxygen concentrations results in a stressed (opportunistic species dominated) benthic community (Long Island Sound Study CCMP, 1994).

In marine systems, nitrogen is usually the limiting nutrient for primary production. Studies done on nitrogen loading to Mount Hope Bay suggest that point source loading accounts from slightly greater than half the nitrogen loading to almost 3/4 of the nitrogen load (Isaac, 1997). The city of Taunton accounts for about 14% of the point source load to Mount Hope Bay (Isaac, 1997).

The draft permit includes monthly monitoring requirements for total Kjeldahl nitrogen, total nitrate, and total nitrite, based on Section 308 of the Clean Water Act. Additionally, ammonia nitrogen shall be monitored (when not limited) as nutrient. Ammonia-nitrogen was previously limited as a toxic pollutant. Discharge monitoring data indicates that the plant removes ammonia to levels below those needed to control ammonia toxicity. The seasonal limits for ammonia shall be retained in the draft permit consistent with the anti-backsliding provisions of 40 CFR §122.44(l)(1). The ammonia limits foster operation of the treatment plant for nitrogen removal.

The permittee is encouraged to evaluate options for optimizing the removal of nitrogen from the wastewater treatment plant. Particular emphasis should be placed on the feasibility of biological nutrient removal retrofits, such as have been implemented successfully at many Connecticut wastewater treatment plants. This is in anticipation of possible future stringent nutrient limits based on continuing refinements in the water quality modeling of Mount Hope Bay.

#### OUTFALL 001 - TOXIC POLLUTANTS

Total Residual Chlorine (TRC) - The draft permit includes total residual chlorine limitations which are based on state water quality standards. Chlorine compounds produced by the chlorination of wastewater can be extremely toxic to aquatic life. The water quality standards established for chlorine are 19 ug/l daily maximum and 11 ug/l monthly average in the receiving water. Given a dilution factor of 4.2:1, the total residual chlorine limitations have been set at 80 ug/l daily maximum and 46 ug/l monthly average. Total Residual Chlorine Limitations:

(acute criteria x dilution factor) = Acute (Maximum Daily)

$$(19 \text{ ug/l} \times 4.2) = 80 \text{ ug/l} = 0.08 \text{ mg/l}$$

(chronic criteria x dilution) = Chronic (Monthly Average)

$$(11 \text{ ug/l} \times 4.2) = 46 \text{ ug/l} = 0.046 \text{ mg/l}$$

The monthly average TRC limit of 46  $\mu\text{g/l}$  or 0.046 mg/l is below the analytical detection limit for this pollutant. In these situations, EPA Region I is following guidance set forth in the Technical Support Document for Water Quality-Based Toxics Control, EPA/505/2-90-001, March 1991, which recommends "... that the compliance level be defined in the permit as the minimum level (ML)." The minimum level of detection for TRC as established by the EPA Region I Quality Assurance Office in a memorandum dated April 30, 1992 is 0.05 mg/l. The limit at which compliance determinations will be based is the ML. The ML may be reduced by permit modification as more sensitive test methods are approved by EPA and the State.

A review of treatment facility effluent Discharge Monitoring Report data submitted to date was conducted to determine if there is a **reasonable potential** for the discharge of any pollutants to cause or contribute to an exceedance of State Water Quality Standards. Where such a "reasonable potential" or an actual exceedance exists, 40 CFR §122.44(d)(1)(i) requires that the pollutant be limited. The reasonable potential analysis is calculated using EPA's Quality Criteria for Water, as of December 10, 1998.

Copper - The draft permit includes a maximum daily limitation of 22 ug/l and an average monthly limitation of 16 ug/l for copper, since a review of the most recent six whole effluent toxicity tests and effluent data (see Fact Sheet Attachment A) indicates that the copper results sporadically exceeded both the calculated and current effluent limits.

The hardness dependent criteria for total copper are calculated as follows, based on a CaCO<sub>3</sub> hardness of 35 mg/l\*:

Chronic Copper Criteria	Acute Copper Criteria
$e^{(0.8545[\ln(35)]+1.702)} = 3.80 \mu\text{g/l}$	$e^{(0.9422[\ln(35)]+1.700)} = 5.21 \mu\text{g/l}$
Chronic Limit (dilution x criteria)	Acute Limit (dilution x criteria)
$(4.2)(3.80) = 15.96 \mu\text{g/l Cu}$	$(4.2)(5.21) = 21.88 \mu\text{g/l Cu}$

\*The hardness used to calculate the criteria is the average of the six most recent whole effluent toxicity test diluent water hardness values. This is consistent with limited USGS data collected down stream of the discharge.

Hardness Data from 6 most Recent WET tests (Average of diluent replicates)	
21.8 mg/l	41.0 mg/l
26.2 mg/l	44.3 mg/l
29.1 mg/l	49.7 mg/l

#### Total Copper Mass Limits

Monthly Ave. [0.016 mg/l] X 8.34 (Constant) X 8.4 (design flow) = 1.1 lb/day

Monthly Ave. [0.016 mg/l] X 3.79 (Constant) X 8.4 (design flow) = 0.5 kg/day

#### OUTFALL 001 - Whole Effluent Toxicity (WET)

Under Section 301(b)(1)(C) of the CWA, discharges are subject to effluent limitations based on water quality standards. The Massachusetts Surface Water Quality Standards include the following narrative statement and requires that EPA criteria established pursuant to Section 304(a)(1) of the CWA be used as guidance for interpretation of the following narrative criteria: All surface waters shall be free from pollutants in concentrations or combinations that are toxic to humans, aquatic life or wildlife.

National studies conducted by the EPA have demonstrated that domestic sources, as well as industrial sources, contribute toxic constituents to POTWs. These constituents include metals, chlorinated solvents, aromatic hydrocarbons and others. Based on the potential for toxicity from domestic and industrial contributions, the state narrative water quality criterion, the level of dilution at the discharge location, and in accordance with EPA national and regional policy and 40 C.F.R. § 122.44(d), the draft permit includes a whole effluent acute toxicity (LC50) limitation and a chronic no observed effluent concentration (C-NOEC) limitation. (See also "Policy for the Development of Water Quality-Based Permit Limitations for Toxic Pollutants", 49 Fed. Reg. 9016 March 9, 1984, and EPA's "Technical Support Document for Water Quality-Based Toxics Control", September, 1991.)

The Massachusetts Department of Environmental Protection's Division of Watershed Management has a current toxics policy which requires toxicity testing for all major dischargers such as the City of Taunton POTW. In addition, EPA recognizes that toxicity testing is required to assure that the synergistic effect of the pollutants in the discharge does not cause toxicity, even though the pollutants may be at low concentrations in the effluent. Thus, the draft permit includes a whole effluent toxicity limitation requirement for the 001 outfall, to assure that the facility does not discharge combinations of toxic compounds into the Taunton River and Mount Hope Bay in amounts which would affect aquatic or human life.

The draft permit includes requirements for quarterly 7-day Chronic (and Modified Acute) toxicity tests using the species Ceriodaphnia dubia. The current permit also requires quarterly WET using the species Pimphales promelas (fathead minnow). The fathead minnow test is discontinued during this permit reissuance based on EPA/MADEP policy and the results of the nine most recent WET tests. All nine tests recorded LC<sub>50</sub> and C-NOEC values of  $\geq 100\%$  for the fathead minnow. The tests must be performed in accordance with the test procedures and protocols specified in **Permit Attachment A**. The tests will be conducted four times a year.

The chronic no observable effects concentration (C-NOEC) limit is calculated to be greater than or equal to the effluent concentration in the receiving water. The inverse of the receiving water concentration (chronic dilution factor) multiplied by one hundred is used to calculate the chronic C-NOEC as a percent limit.

$$(1/4.2)(100) \geq 23.8\% \approx 24\% \text{ C-NOEC.}$$

The LC<sub>50</sub> of  $\geq 100\%$  is established by EPA/MADEP policy for facilities with less than 20:1 dilution.

## V. INDUSTRIAL PRETREATMENT PROGRAM

The permittee is required to administer a pretreatment program based on the authority granted under 40 CFR §122.44(j), 40 CFR Part 403 and section 307 of the Act. The Permittee's pretreatment program received EPA approval on September 31, 1982 and, as a result, appropriate pretreatment program requirements were incorporated into the previous permit which were consistent with that approval and federal pretreatment regulations in effect when the permit was issued.

The Federal Pretreatment Regulations in 40 CFR Part 403 were amended in October 1988, and again in July 1990. Those amendments established new requirements for implementation of pretreatment programs. Upon reissuance of this NPDES permit, the permittee is obligated to modify its pretreatment program to be consistent with current Federal Regulations. Those activities that the permittee must address include, but are not limited to, the following: (1) develop and enforce EPA approved specific effluent limits (technically-based local limits); (2) revise the local sewer-use ordinance or regulation, as appropriate, to be consistent with Federal Regulations; (3) develop an enforcement response plan; (4) implement a slug control evaluation program; (5) track significant noncompliance for industrial users; and (6) establish a definition of and track significant industrial users.

These requirements are necessary to ensure continued compliance with the POTW's NPDES permit and its sludge use or disposal practices.

In addition to the requirements described above, the draft permit requires the permittee to submit to EPA in writing, within 180 days of the permit's effective date, a description of proposed changes to permittee's pretreatment program deemed necessary to assure conformity with current federal pretreatment regulations. These requirements are included in the draft permit to ensure that the pretreatment program is consistent and up-to-date with all pretreatment requirements in effect. Lastly, the permittee must continue to submit, annually by October 1, a pretreatment report detailing the activities of the program for the twelve month period ending 60 days prior to the due date.

## **VI. COMBINED SEWER OVERFLOWS (CSO)**

### **1. Background**

Combined Sewer Overflows (CSOs) are overflows from a combined sewer system that are discharged into a receiving water without going to the headworks of a publicly owned treatment works (POTWs). CSOs occur when the flow in the combined sewer system exceeds interceptor or regulator capacity. CSOs are distinguished from bypasses which are "intentional diversions of waste streams from any portion of a treatment facility" (40 CFR §122.41(m)).

Flows in combined sewers can be classified into two categories: wet weather flow and dry weather flow. Wet weather flow is a combination of domestic and industrial sewage, infiltration from groundwater, and storm water flow including snow melt. Dry weather flow is the flow in a combined sewer that results from domestic sewage, groundwater infiltration and industrial wastes with no contribution from storm water runoff or storm water induced infiltration.

Dry weather overflows from CSOs are illegal. They must be reported immediately to EPA and the MADEP and eliminated as expeditiously as possible.



The objectives of the National CSO Control Policy are:

- 1) To ensure that if the CSO discharges occur, they are only as a result of wet weather,
- 2) To bring all wet weather CSO discharge points into compliance with the technology based requirements of the CWA and applicable federal and state water quality standards, and
- 3) To minimize water quality, aquatic biota, and human health impacts from wet weather flows.

## **2. Effluent Standards**

CSOs are point sources subject to NPDES permit requirements for both water quality based and technology based requirements but are not subject to secondary treatment regulations applicable to publicly owned treatment works.

Section 301(b)(1)(C) of the Clean Water Act (CWA) of 1977 mandated compliance with water quality standards by July 1, 1977. Technology based permit limits must be established for best conventional pollutant control technology (BCT) and best available technology economically achievable (BAT) based on best professional judgment (BPJ) in accordance with Section 301(b) and Section 402(a) of the Water Quality Act Amendments of 1987 (WQA).

## **3. Conditions for Discharge**

The draft permit prohibits dry weather discharges from the CSO outfall. During wet weather, the discharges must not cause any exceedance of water quality standards. Dry weather discharges must be reported immediately to EPA and the MADEP. Wet weather discharges must be monitored and reported as specified in the permit.

## **4. Nine Minimum Controls (NMC)**

The permittee must comply with BPJ derived BCT/BAT controls, which at a minimum include the following: (1) proper operation and maintenance of the sewer system and outfalls; (2) maximum use of the collection systems for storage; (3) review pretreatment programs to assure CSO impacts are minimized; (4) maximization of flow to the POTW for treatment; (5) prohibition of dry weather overflows; (6) control of solid and floatable materials in the discharge; (7) pollution prevention programs which focus on contaminant reduction activities; (8) public notification to ensure that the public receives adequate notification of CSO occurrences and CSO impacts; and (9) monitoring to effectively characterize CSO impacts and the efficacy of CSO controls.

## **5. Nine Minimum Controls Documentation**

On December 26, 1996, the permittee submitted documentation for the Nine Minimum Controls. The draft permit requires the permittee to implement the nine minimum controls as documented by the permittee and as listed and described within Taunton's permit. The nine minimum control documentation needs be updated to reflect changes since the time it was first submitted to EPA. The City must update the NMCP within one year of effective date of the permit.

## **6. Reopener/Additional CSO Control Measures**

The permit is conditioned to require an annual certification, no later than January 15th of each year, that states that all discharges from combined sewer outfalls were recorded, and other appropriate records and reports maintained for the previous calendar year.

The permit may be modified or reissued upon the completion of a long-term CSO control plan. Such modification may include performance standards for the selected controls, a post construction water quality assessment program, monitoring for compliance with water quality standards, and a reopener clause to be used in the event that the selected CSO controls fail to meet water quality standards. Section 301(b)(1)(C) requires that a permit include limits that may be necessary to protect water quality standards.

## **7. Required Treatment**

EPA's national CSO policy ("CSO policy"), which was published in the Federal Register on April 19, 1994 (59 FR 18688), states: ***Permittees with CSOs are responsible for developing and implementing long-term CSO control plans that will ultimately result in compliance with the requirements of the CWA. The long-term plans should consider the site-specific nature of CSOs and evaluate the cost effectiveness of a range of control options/strategies. The development of a long-term CSO control plan and its subsequent implementation should also be coordinated with the NPDES authority and state authority responsible for reviewing and revising the State's WQS [Water Quality Standards]. The selected controls should be designed to allow cost effective expansion or cost effective retrofitting if additional controls are subsequently determined necessary to meet WQS, including designated uses.***

USFilter has agreed to maximize flow to the treatment plant to reduce or possibly eliminate the occurrence of combined sewer overflows. If monitoring demonstrates that CSO discharges do occur that cause violations of State WQS, EPA will likely take an enforcement action to require the implementation of a long-term control plan that will insure compliance with the WQS.

## VII. UNAUTHORIZED DISCHARGES; BYPASSES

The draft permit prohibits bypasses unless all of the following conditions occur: (1) bypass was unavoidable to prevent loss of life, severe injury, or severe property damage; (2) there were no feasible alternatives to the bypass (e.g., adequate backup equipment, auxiliary treatment facilities, maintenance, etc.); and (3) the permittee submitted notice of the need for an anticipated bypass at least 10 days prior to the bypass within 24 hours from the time the permittee became aware of the discharges to be followed by a written submission within 5 days of discovery.

The draft permit makes it clear that even wet weather bypasses can be unlawful: discharges from any point source, regardless of ownership, which result from past, present, or future failure to properly design, operate, or maintain the permittee's POTW, or appurtenant facilities, or to adequately control or limit incoming flows to the permittee's POTW will be considered unauthorized discharges by the Taunton WWTP. Thus bypasses will be considered unlawful if, for example, they could be avoided through upgrading and expansion of treatment facilities.

Pursuant to 40 C.F.R. § 122.41(e), the draft permit also requires the permittee in cooperation with its member communities to operate and improve its POTW and total sewer system to minimize the discharge of pollutants from bypasses or CSOs. The draft permit requires that the Taunton WWTP minimize infiltration/in flow.

## VII. SLUDGE CONDITIONS

Section 405(d) of the CWA requires that EPA develop technical regulations regarding the use and disposal of sewage sludge. These regulations are found at 40 CFR part 503 and apply to any facility engaged in the treatment of domestic sewage. The CWA further requires that these conditions be implemented through permits. The sludge conditions in the draft permit are intended to implement these regulations.

The City of Taunton disposes sludge at the Taunton Municipal Solid Waste Landfill. The City generates approximately 1,125 dry tons annually. Domestic sludges which are disposed of in municipal solid waste landfills are in compliance with Part 503 regulations provided the sludge meets the quality criteria of the landfill and the landfill meets the requirements of 40 CFR Part 258.

The draft permit has been conditioned to ensure that sewage sludge use and disposal practices meet the CWA Section 405(d) Technical Standards. In addition, EPA New England has included with the draft permit a 72-page Sludge Compliance Guidance document for use by the permittee in determining their appropriate sludge conditions for their chosen method of sludge disposal.

The permittee is also required to submit to EPA an annual report containing the information specified in the Sludge Compliance Guidance Document for the permittee's chosen method of sludge disposal.

### VIII. ANTIBACKSLIDING

Anti-backsliding as defined at 40 CFR §122.44(l)(1) requires reissued permits to contain limitations as stringent or more stringent than those of the previous permit unless the circumstances allow application of one of the defined exceptions to this regulation. Anti-backsliding does not apply when changes to limits are based on new information not available at the time of the previous permit reissuance (40 CFR §122.44(l)(2)(i)(B)(1)) or when limits are changed as a result of material and substantial additions or alterations to the permitted facility which occurred after permit issuance which justify the application of less stringent limitations, as defined at 40 CFR § 122.44(l)(2)(i)(A). A discussion of the proposed changes to existing limits follows.

The November 1<sup>st</sup> through March 31<sup>st</sup> CBOD<sub>5</sub> limits are replaced with BOD<sub>5</sub> limits which are considered to be equivalent secondary treatment. The daily maximum CBOD<sub>5</sub> and BOD<sub>5</sub> limits are discontinued in this draft permit. The change from a daily maximum limit to a reporting requirement reflects the high flow management plan to bring more flow to the plant rather than discharge it from the combined sewer overflow. This also reflects the change in plant operation from treating flows in series to operating two parallel treatment trains. The monthly average limit for total copper has been increased from 15 ug/l in the current permit to 16 ug/l in the draft permit. The daily maximum limit for total copper is increased from 20 ug/l to 22 ug/l based on new information. EPA published revised acute and chronic criteria for total copper on December 12, 1998. Additionally, the available in-stream hardness data included in recent whole effluent toxicity reports was used in the recalculation of the total copper limits. The proposed total residual chlorine limits are more stringent than those in the current permit (0.048 mg/l from 0.05 mg/l). The nutrient ammonia limits in the draft permit have been scaled back to the summer season, May 1<sup>st</sup> through September 30<sup>th</sup>. Additional nitrogen and ammonia monitoring requirements have been added year round.

### IX. ANTIDegradation

The Massachusetts Antidegradation Policy is found at Title 314 CMR 4.04. All existing uses of the Taunton River and Mt. Hope Bay must be protected. This draft permit is being reissued with allowable discharge limits as or more stringent than the current permit with the same parameter coverage and no change in outfall location. The public is invited to participate in the antidegradation finding through the permit public notice procedure.

### X. COASTAL ZONE MANAGEMENT (CZM) CONSISTENCY REVIEW

40CFR §122.49 (d) states: *The Coastal Zone Management Act, 16 U.S.C. 1451 et seq. section 307(c) of the Act and implementing regulations (15 CFR part 930) prohibit EPA from issuing a permit for an activity affecting land or water use in the coastal zone until the applicant certifies that the proposed activity complies with the State Coastal Zone Management program, and the State or its designated agency concurs with the certification (or the Secretary of Commerce overrides the State's nonconcurrence).*

The discharge is just upstream of the defined CZM boundaries. As of the 1990 reauthorization of the Coastal Zone Management Act, CZM also has authority over projects/facilities outside of the coastal zone delineation that "may affect land or water resources or uses of the coastal zone" (e.g., projects/facilities whose waste travels down current to the CZ). This language has been interpreted to include all projects within coastal watersheds. The permittee has submitted a letter dated October 31, 2000 to the Massachusetts Coastal Zone Management Program stating their intention to abide by the CZM water quality and habitat policies. The CZM shall review the draft permit and it will only be issued after CZM certification.

#### **XI. MONITORING AND REPORTING**

The permittee is obligated to monitor and report sampling results to EPA and the MADEP within the time specified within the permit. The effluent monitoring requirements have been established to yield data representative of the discharge by the authority under Section 308(a) of the CWA in accordance with 40 CFR 122.41(j), 122.44, and 122.48.

The remaining general and special conditions of the permit are based on the NPDES regulations 40 CFR Parts §122 through §125 and consist primarily of management requirements common to all permits.

#### **XII. STATE PERMIT CONDITIONS**

The NPDES Permit is issued jointly by the U. S. Environmental Protection Agency and the Massachusetts Department of Environmental Protection under federal and state law, respectively. As such, all the terms and conditions of the permit are, therefore, incorporated into and constitute a discharge permit issued by the MEDEP Commissioner who designates signature authority to the Director of the Division of Watershed Management pursuant to M.G.L. Chap. 21, §43.

#### **XIII. GENERAL CONDITIONS**

The general conditions of the permit are based on 40 C.F.R. Parts 122, Subparts A and D and 40 C.F.R. § 124, Subparts A, D, E, and F and are consistent with management requirements common to other permits.

#### **XIV. STATE CERTIFICATION REQUIREMENTS**

The staff of the Massachusetts Department of Environmental Protection ("MADEP") has reviewed the draft permit. EPA has requested permit certification by the State pursuant to 40 C.F.R. § 124.53 and expects that the draft permit will be certified.

**XV. PUBLIC COMMENT PERIOD AND PROCEDURES FOR FINAL DECISION**

All persons, including applicants, who believe any condition of the draft permit is inappropriate must raise all issues and submit all available arguments and all supporting material for their arguments in full by the close of the public comment period, to the U.S. EPA, Office of Ecosystem Protection, MA Unit, One Congress Street, Suite-1100, Boston, Massachusetts 02114. Any person, prior to such date, may submit a request in writing for a public hearing to consider the draft permit to EPA and the State Agency. Such requests shall state the nature of the issues proposed to be raised in the hearing. Public hearings may be held after at least thirty days public notice whenever the Regional Administrator finds that response to this notice indicates a significant public interest. In reaching a final decision on the draft permit, the Regional Administrator will respond to all significant comments and make these responses available to the public at EPA's Boston office.

Following the close of the comment period and after a public hearing, if such a hearing is held, the Regional Administrator will issue a final permit decision and forward a copy of the final decision to the applicant and each person who has submitted written comments or requested notice.

Within 30 days following the service of notice of the Director's final permit decision, any interested person may submit an adjudicatory hearing request along with a valid check payable to the Commonwealth of Massachusetts in the amount of \$100 which must be mailed to the following address:

Commonwealth of Massachusetts  
Department of Environmental Protection  
P.O. Box 4062  
Boston, MA 02211

The hearing request to the Commonwealth will be dismissed if the filing fee is not paid, unless the appellant is exempt or granted a waiver.

The filing fee is not required if the appellant is a city, town (or municipal agency), county, district of the Commonwealth of Massachusetts, or a municipal housing authority. The Department may waive the adjudicatory hearing filing fee for a permittee who shows that paying the fee will create an undue financial hardship. A permittee seeking a waiver must file, along with the hearing request, an affidavit setting forth the facts believed to support the claim of undue financial hardship.

**XVI. EPA CONTACT**

Additional information concerning the draft permit may be obtained between the hours of 9:00 a.m. and 5:00 p.m., Monday through Friday, excluding holidays from:

Douglas M. Corb  
U.S. Environmental Protection Agency  
Office of Ecosystem Protection  
One Congress Street  
Suite-1100 - CPE  
Boston, MA 02114-2023  
Telephone: (617) 918-1565  
Facsimile: (617) 918-0565  
e-mail: corb.doug@epa.gov

December 4, 2000

Date

Linda M. Murphy, Director  
Office of Ecosystem Protection  
U.S. Environmental Protection Agency

Attachments - Not available electronically