

- A. Dry Weather Flows Through Secondary Treatment (16 mgd)
- B.1. Wet Weather Flows Through Secondary (up to 32 mgd) and C.2. Bypass 18 mgd up to 6 hours
- B.2. Wet Weather Flows Through Secondary (24 mgd) and C.2. Bypass 26 mgd for 6-12 hours
- B.3. Wet Weather Flows Through Secondary (18 mgd) and C.3. Bypass 32 mgd for 12+ hours
- D. When Flows reach 50 mgd at the influent gate (Wet Well), up to 60 mgd is diverted to the Wet Weather Flow Treatment Facility

