

**AUTHORIZATION TO DISCHARGE UNDER THE  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 et seq.;) the "CWA", and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

**South Essex Sewerage District**

is authorized to discharge from the facility located at

**South Essex Wastewater Treatment Facility  
50 Fort Avenue  
Salem, MA 01970**

to the receiving water named

**Salem Sound**

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective sixty (60) days after the date of signature.

This permit and the authorization to discharge expire at midnight, four (4) years from the effective date.

This permit supersedes the permit issued on September 26, 1994 and modified on September 15, 1999.

This permit consists of 11 pages in Part I including effluent limitations, monitoring requirements; Attachment A, Marine Acute Toxicity Test Procedure & Protocol; Attachment B, local limits; Attachment C, Pretreatment Requirements; Sludge Guidance; and 35 pages in Part II including General Conditions and Definitions.

Signed this 9<sup>th</sup> day of February, 2001

/Signature on File/

Linda M. Murphy  
Director  
Office of Ecosystem Protection  
Environmental Protection Agency  
Boston, MA

Acting Assistant Commissioner  
Bureau of Resource Protection  
Department of Environmental Protection  
Commonwealth of Massachusetts  
Boston, MA

## PART I

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning the effective date and lasting through expiration, the permittee is authorized to discharge treated effluent from outfall serial number 001. Such discharge shall be limited and monitored by the permittee as specified below.

<u>Effluent Characteristic</u>	<u>Units</u>	<u>Discharge Limitation</u>			<u>Monitoring Requirement</u>	
		Average <u>Monthly</u> Y	Average <u>Weekly</u>	Maximum <u>Daily</u>	Measurement <u>Frequency</u>	<u>Sample Type</u>
Flow	MGD	29.71 <sup>1</sup>	----	Report	Continuous <sup>2</sup>	Recorder
CBOD <sub>5</sub>	mg/l	25	40	Report	1/Day <sup>3</sup>	24-Hour Composite <sup>4</sup>
TSS	mg/l	30	45	Report	1/Day <sup>3</sup>	24-Hour Composite <sup>4</sup>
pH	S.U.	(See Condition I.A.1.b on Page 4)			1/Day	Grab
Oil & grease <sup>5</sup>	mg/l	----	---	Report	1/Month	Grab
Fecal Coliform Bacteria <sup>6</sup>	cfu/100 ml	200	----	400	3/Day	Grab
Total Residual Chlorine <sup>7</sup>	mg/l	0.24	----	0.338	3/Day	Grab
Total Nitrate	mg/l	----	----	Report	1/Month <sup>3,5</sup>	24-Hour Comp. <sup>4</sup>
Total Ammonia Nitrogen, as N	mg/l	----	----	Report	1/Month <sup>3,5</sup>	24-Hour Comp. <sup>4</sup>
Total Kjeldahl Nitrogen	mg/l	----	----	Report	1/Month <sup>3,5</sup>	24-Hour Comp. <sup>4</sup>
LC <sub>50</sub> <sup>8</sup>	%	----	----	≥ 100	4/year <sup>9</sup>	24-Hour Comp. <sup>4</sup>

Effluent samples shall be taken after dechlorination and prior to discharge to the effluent pipe for the parameters oil and grease, pH,

TRC and fecal coliform. Sampling for all other parameters can be taken prior to chlorination.

## Footnotes:

1. This is an annual average limit, which shall be reported as a rolling average. The first value will be calculated using the monthly average flow for the first full month ending after the effective date of the permit and the eleven previous monthly average flows. (e.g. If the permit is effective on 9/15/00, the first reported annual average will be taken from the October 2000 DMR and the previous eleven monthly average flows.) Each subsequent month's DMR will report the annual average flow for the previous 12 months.
2. For flow, report maximum and minimum daily rates and total flow for each operating date.
3. Sampling required for influent and effluent.
4. A 24-hour composite sample will consist of at least twenty four (24) grab samples taken during a consecutive 24 hour period.
5. US EPA Test Method 1664 shall be used for oil & grease analysis. After at least one year of monitoring for oil & grease, nitrate, ammonia nitrogen and Kjeldahl nitrogen under this permit, the permittee may submit a written request to remove any of these monitoring requirements from the permit if there is sufficient data to indicate that the levels of these parameters in the discharge will not cause or contribute to any water quality standards violations. The permittee shall continue testing for these parameters until the EPA approves of such modification request in writing.
6. Fecal coliform monitoring will be conducted year round. This is a State certification requirement. The monthly average limit is expressed as a geometric mean. The geometric mean of the three daily values shall be reported as the maximum daily result.
7. The minimum detection level (ML) for total residual chlorine is defined as 50 ug/l. This value is the minimum detection level for chlorine using EPA approved methods found in Standard Methods for the Examination of Water and Wastewater, 20th Edition, Method 4500 CL-E and G, or USEPA Manual of Methods of Analysis of Water and Wastes, Method 330.5. One of these methods must be used to determine total residual chlorine. Sample results of 50 ug/l or less shall be reported as zero on the discharge monitoring report.
8. The LC<sub>50</sub> is the concentration of effluent which causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a sample of 100% effluent (no dilution) shall cause no more than a 50% mortality rate.
9. The permittee shall conduct acute toxicity tests four times per year. The chronic test may be used to calculate the acute LC<sub>50</sub> at the 48 hour exposure interval. The permittee shall test the Mysid shrimp, Mysidopsis bahia and the Inland silverside, Menidia beryllina. Toxicity test samples shall be collected during the months of February, April, June and August. Results are to be submitted by the 30th day of the month after the sample i.e. March, May, July, and September. See Permit Attachment A, Toxicity Test Procedure and Protocol.

## Part I.A. (Continued)

- a. The discharge shall not cause a violation of the water quality standards of the receiving waters.
- b. The pH of the effluent shall not be less than 6.5 nor greater than 8.5 at any time, unless these values are exceeded due to natural causes or as a result of the approved treatment processes.
- c. The discharge shall not cause objectionable discoloration of the receiving waters.
- d. The effluent shall contain neither a visible oil sheen, foam, nor floating solids at any time.
  - e. The permittee's treatment facility shall maintain a minimum of 85 percent removal of both total suspended solids and biochemical oxygen demand during dry weather. The percent removal shall be based on monthly average values. The permittee may use CBOD values to calculate the percent removal.
  - f. The permittee shall minimize the use of chlorine while maintaining adequate bacterial control.

## 2. All POTWs must provide adequate notice to the Director of the following:

- a. Any new introduction of pollutants into that POTW from an indirect discharger in a primary industry category discharging process water; and
- b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- c. For purposes of this paragraph, adequate notice shall include information on:
  - (1) the quantity and quality of effluent introduced into the POTW; and
  - (2) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

## 3. Prohibitions Concerning Interference and Pass-Through:

- a. Pollutants introduced into POTW's by a non-domestic source (user) shall not pass through the POTW or interfere with the operation or performance of the works.
- b. If, within 30 days after notice of an interference or pass through violation has been sent by EPA to the POTW, and to persons or groups who have requested such notice,

the POTW fails to commence appropriate enforcement action to correct the violation, EPA may take appropriate enforcement action.

#### 4. Limitations for Industrial Users:

The permittee shall develop and enforce specific effluent limits (local limits) for Industrial User(s), and all other users, as appropriate, which together with appropriate changes in the POTW's Facilities or operation, are necessary to ensure continued compliance with the POTW's NPDES permit or sludge use or disposal practices. Specific local limits shall not be developed and enforced without individual notice to persons or groups who have requested such notice and an opportunity to respond. Within 180 days after the effective date of this permit, the permittee shall prepare and submit a written technical report to EPA analyzing local limits. In preparing this evaluation, the permittee may use the attached form, **Attachment B**, to assist in developing local limits. Justifications and conclusions should be based on actual plant data if available and should be included in the report. As part of this analysis, the permittee shall sample and assess the impacts of toxic pollutants on its effluent, sludge and receiving waters. The Permittee shall carry out the local limits analysis in accordance with EPA Guidance Manual for the Development and Implementation of Local Discharge Limitations Under the Pretreatment Program (December, 1987).

#### 5. Toxics Control

- a. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
- b. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.

#### 6. Numerical Effluent Limitations for Toxicants

EPA or DEP may use the results of the toxicity tests and chemical analyses conducted pursuant to this permit, as well as national water quality criteria developed pursuant to Section 304(a)(1) of the Clean Water Act (CWA), state water quality criteria, and any other appropriate information or data, to develop numerical effluent limitations for any pollutants, including but not limited to those pollutants listed in Appendix D of 40 CFR Part 122.

### **B. UNAUTHORIZED DISCHARGES**

The permittee is authorized to discharge only in accordance with the terms and conditions of this permit and only from outfalls listed in Part I A.1. of this permit. Discharges of wastewater from any other point sources, including sanitary sewer overflows (SSOs) are not authorized by this permit and shall be reported in accordance with Section D.1.e. (1) of the General Requirements of

this permit (Twenty-four hour reporting).

## **C. OPERATION AND MAINTENANCE OF THE SEWER SYSTEM**

### **1. Infiltration/Inflow**

Operation and maintenance of the sewer system shall be in compliance with the General Requirements of Part II and the following terms and conditions:

- a. A summary report of all actions taken to reduce infiltration/inflow by permittee and its member communities during the previous twelve (12) months shall be submitted to EPA and the MADEP by the 28<sup>th</sup> day of February of each year.
- b. The permittee shall develop and implement an operation and maintenance program for its sewer system and shall require, through appropriate agreements, that all member sewer communities develop and implement a routine operation and maintenance program. The operation and maintenance programs shall be designed to provide an understanding of the sewerage system, identify all potential and actual sanitary sewer overflow points and prevent sanitary sewer overflows (SSOs) due to equipment malfunction or failure. Documentation of the operation and maintenance program shall be required within one year of the effective date of the permit and annual implementation assessments shall be required each year thereafter.
- c. The permittee shall provide written reports of all SSOs from its collection system to DEP and EPA in accordance with requirements found at 40 C.F.R. §122.41(l)(6). The information reported shall include the date, location, duration, and volume of discharge as well as the cause of the overflow and the receiving water. The permittee shall require that each of its member sewer communities provide written reports of all SSOs to the permittee on at least a quarterly basis and to DEP within 24 hours of the event.
- d. The permittee shall develop and make available to all sewer communities, an education and outreach program/curriculum on ways to reduce I/I and shall continue to support I/I reduction demonstration projects.

### **3. Alternate Power Source**

In order to maintain compliance with the terms and conditions of this permit, the permittee shall continue to provide an alternative power source with which to sufficiently operate its treatment works (as defined at 40 CFR §122.2).

### **4. Chlorination System Report**

Within 3 months of the effective date of the permit, the permittee will submit a report documenting the effectiveness of the chlorination and dechlorination systems. The report will specifically address how flow variability and chlorine demand variability affect compliance

with the TRC and fecal coliform limits at all times. Sampling data shall be provided to support conclusions on how hourly and daily flow and chlorine demand variability affect permit compliance. The report will include a description of the chlorination and dechlorination systems and the methods for dosage control. The report will identify all changes necessary to ensure compliance with the TRC and fecal coliform limits at all times, including equipment modifications and upgrades, operational procedures (including calibration procedures and alarm/response procedures), and sampling protocols. The report will include a schedule for implementing all of the necessary changes. An annual report shall be submitted on November 30th of each year summarizing all exceedances of the TRC and fecal coliform effluent limits during the previous year, the estimated or measured fecal coliform and chlorine discharge levels during the exceedance, and measures taken to fix the problem(s) and to prevent future occurrences.

#### **D. INDUSTRIAL PRETREATMENT PROGRAM**

1. The permittee shall implement the Industrial Pretreatment Program in accordance with the legal authorities, policies, procedures, and financial provisions described in the permittee's approved Pretreatment Program, and the General Pretreatment Regulations, 40 CFR 403. At a minimum, the permittee must perform the following duties to properly implement the Industrial Pretreatment Program ("IPP"):
  - a. Carry out inspection, surveillance, and monitoring procedures which will determine, independent of information supplied by the industrial user, whether the industrial user is in compliance with the Pretreatment Standards. At a minimum, all significant industrial users shall be sampled and inspected at the frequency established in the approved IPP but in no case less than once per year and maintain adequate records.
  - b. Issue or renew all necessary industrial user control mechanisms within 120 days of their expiration date or within 180 days after the industry has been determined to be a significant industrial user.
  - c. Obtain appropriate remedies for noncompliance by any industrial user with any pretreatment standard and/or requirement; and
  - d. Maintain an adequate revenue structure for continued implementation of the Pretreatment Program.
2. The permittee shall provide the EPA and the MA DEP with an annual report describing the permittee's pretreatment program activities over the twelve month period ending 60 days prior to the due date in accordance with 40 CFR 403.12(I). The annual report shall be consistent with the format described in **Attachment C** of this permit and shall be submitted no later than March 1 of each year.
3. The permittee must obtain approval from EPA prior to making any significant changes to the industrial pretreatment program in accordance with 40 CFR 403.18(c).

4. The permittee must assure that applicable National Categorical Pretreatment Standards are met by all categorical industrial users of the POTW. These standards are published in the Federal Regulations at 40 CFR 405 et. seq.

## **E. AMBIENT MONITORING PROGRAM**

An ambient monitoring program will be conducted in Salem Sound and shall focus on the benthic community in the vicinity of Outfall 001. Previous monitoring data have shown that the benthic community in the vicinity of the discharge was degraded. This monitoring will be a follow up to previous studies to assess whether the benthic community has improved in recent years, especially since the permittee has initiated secondary wastewater treatment. The permittee will propose a study which will be similar to previous studies it has conducted in Salem Sound. This proposal will be submitted to EPA and DEP for review within ninety (90) days after the effective date of the permit. This plan shall specifically include sample collection and preservation techniques and sample processing methods.

This sampling will be done during within the first year after the effective date of the permit and once every two years thereafter. This sampling shall be conducted in June, August and October of each of these years. An effort shall be made to collect samples from the coordinates provided in the revised 301(h) waiver application of 1986. Samples shall be taken from at least 6 locations which shall include the existing outfall location, a reference station and the following locations relative to the existing outfall: 50 meters south, 500 meters south, 50 meters north and 500 meters north.. In the 301(h) application, these locations are labeled as B9, B5, B4, B3, B1 and B2 respectively. At a minimum , the parameters to be sampled for shall include benthic infaunal species diversity, benthic infaunal biomass, sediment grain size and total organic carbon content of the sediment.

## **F. SLUDGE CONDITIONS**

1. The permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices and with the CWA Section 405(d) technical standards.
2. The permittee shall comply with the more stringent of either the state or federal (40 CFR part 503), requirements.
3. The requirements and technical standards of 40 CFR part 503 apply to facilities which perform one or more of the following use or disposal practices.
  - a. Land application - the use of sewage sludge to condition or fertilize the soil
  - b. Surface disposal - the placement of sewage sludge in a sludge only landfill
  - c. Sewage sludge incineration in a sludge only incinerator

4. The 40 CFR part 503 conditions do not apply to facilities which place sludge within a municipal solid waste landfill. These conditions also do not apply to facilities which do not dispose of sewage sludge during the life of the permit but rather treat the sludge (lagoons- reed beds), or are otherwise excluded under 40 CFR 503.6.
5. The permittee shall use and comply with the attached compliance guidance document to determine appropriate conditions. Appropriate conditions contain the following elements:
  - General requirements
  - Pollutant limitations
  - Operational Standards (pathogen reduction requirements and vector attraction reduction requirements)
  - Management practices
  - Record keeping
  - Monitoring
  - Reporting

Depending upon the quality of material produced by a facility, all conditions may not apply to the facility.

6. The permittee shall monitor the pollutant concentrations, pathogen reduction and vector attraction reduction at the following frequency. This frequency is based upon the volume of sewage sludge generated at the facility in dry metric tons per year

less than 290	1/ year
290 to less than 1500	1 /quarter
1500 to less than 15000	6 /year
15000 +	1 /month

7. The permittee shall sample the sewage sludge using the procedures detailed in 40 CFR 503.8.
8. The permittee shall submit an annual report containing the information specified in the guidance. Reports are due annually by February 19. Reports shall be submitted to the address contained in the reporting section of the permit.

## **G. MONITORING AND REPORTING**

### **1. Reporting**

Monitoring results obtained during the previous month shall be summarized for each month and reported on separate Discharge Monitoring Report Form(s) postmarked no later than the 15th day of the month following the effective date of the permit.

Signed and dated originals of these, and all other reports required herein, shall be submitted to the Director and the State at the following addresses:

Environmental Protection Agency  
Water Technical Unit (SEW)  
P.O. Box 8127  
Boston, Massachusetts 02114

The State Agency is:

Massachusetts Department of Environmental Protection  
Bureau of Resource Protection  
Northeast Regional Office  
205A Lowell Street  
Wilmington, MA 01887

Signed and dated Discharge Monitoring Report Forms and toxicity test reports required by this permit shall also be submitted to the State at:

Massachusetts Department of Environmental Protection  
Division of Watershed Management  
Surface Water Discharge Permit Program  
627 Main Street, 2nd Floor  
Worcester, Massachusetts 01608

Notification to United States Food and Drug Administration (USFDA) and Massachusetts Division of Marine Fisheries (MADMF):

The permittee shall notify the Shellfish Program Specialist at the USFDA's Northeast Regional Office and the Director of the MADMF Office in Gloucester, MA of any chlorination system failure at the SESD facility within twenty four (24) hours of its occurrence, by telephone, specifying the time and relevant details of the event and the approximate volume and duration of the wastewater discharged during such event.

## **H. STATE PERMIT CONDITIONS**

This discharge permit is issued jointly by the U. S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (DEP) under Federal and State law, respectively. As such, all the terms and conditions of this permit are hereby incorporated into and constitute a discharge permit issued by the Commissioner of the MA DEP pursuant to M.G.L. Chap.21, §43.

Each Agency shall have the independent right to enforce the terms and conditions of this Permit. Any modification, suspension or revocation of this Permit shall be effective only with respect to

the Agency taking such action, and shall not affect the validity or status of this Permit as issued by the other Agency, unless and until each Agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this Permit is declared, invalid, illegal or otherwise issued in violation of State law such permit shall remain in full force and effect under Federal law as an NPDES Permit issued by the U.S. Environmental Protection Agency. In the event this Permit is declared invalid, illegal or otherwise issued in violation of Federal law, this Permit shall remain in full force and effect under State law as a Permit issued by the Commonwealth of Massachusetts.

## **Response to Public Comments**

From April 27, 2000 to May 26, 2000, the United States Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (DEP) solicited Public Comments on a draft NPDES permit developed pursuant to an application from the South Essex Sewerage District (SESD) in Salem, Massachusetts for the reissuance of a permit to discharge sanitary and industrial wastewater from outfall 001 to Salem Sound. There was a public hearing requested and held on this draft permit on August 3, 2000 and the comment period was extended to August 18, 2000.

After a review of the comments received, the EPA has made a final decision to issue this permit authorizing this discharge. The following response to comments describes the changes that have been made to these permits from the drafts and the reasons for these changes and briefly describes and responds to the comments on the draft permits during the public comment period and the public hearing. Copies of the final permit may be obtained by writing or calling EPA's Massachusetts NPDES Permits Program (CPE), 1 Congress Street, Suite 1100, Boston, MA 02114-2023; Telephone: (617) 918-1579.

We would like to thank all those that provided comments on this draft permit and we ask that you stay involved in all future permit developments. The following parties commented on the permit and the responses to each one's comments begin on the following pages:

### **PAGE**

A) South Essex Sewerage District	1
B) Salem Sound 2000	4
C) Massachusetts Coastal Zone Management	7
D) The Whale Center of New England	8
E) Massachusetts Audubon Society	8
F) Commonwealth of Massachusetts - DMF	10
G) Safer Waters in Massachusetts (SWIM)	12
H) Coastal Advocacy Network	13
I) William Crawford	13

#### **A) Comments submitted by the SESD:**

Comment #1: The District requests that the permit be effective for five years.

Response: This permit will be issued for four years, which will bring it in line with the MA DEP's North Coastal watershed cycle for permit issuance.

Comment #2: The limit on average monthly flow (29.71 MGD) was not in the prior permit. Neither the draft permit nor the fact sheet provides the basis or necessity for the flow limitation. The District notes that this value is the annual average design flow of the plant and the plant can be expected to exceed the annual average 6 months out of 12.

Response: It is common practice to employ a flow limit for municipal permits. The flow limit is typically established at the design flow of the facility and serves to ensure that the permittee does not allow flows to the facility in excess of its design capacity. A flow limit can also be used as an incentive to intensify infiltration/inflow efforts and to encourage water conservation measures. As you state, the flow limit is an annual average limit, so a monthly average flow can exceed the limit without incurring a violation of the annual average. In addition, the Ipswich River, one of the main tributaries to Salem Sound, has had low flow situations during dry years and limiting the flow coming to SESD is one measure which would serve to minimize the occurrence of these conditions which have lead to water bans or restrictions in several communities.

Comment #3: The draft permit contains an average monthly limit for total residual chlorine (TRC) of 0.24 mg/l. This limit was derived by multiplying the chronic water quality criterion value for chlorine by a dilution of 32:1 which is the dilution achieved at a flow rate of 46 MGD. No explanation of the use of 46 MGD as a flow rate is provided in the fact sheet. In order to calculate such a limit properly ... one should use the average dilution, which is 58:1 according to the SESD Final EIR/Facilities Plan (May, 1992). Using this flow would result a limit of 0.42 mg/l, which is higher than the maximum daily limit of 0.338 mg/l and should therefore be deleted from the permit.

Response: The fact sheet states that the estimated flow dilution of 32:1 at the effluent flow of 46 MGD is considered appropriate and protective. Water quality criteria are derived from a 4 hour exposure so we would prefer to calculate the limit using a maximum four hour flow. Since this flow was not available from previous modeling efforts, the value of 46 MGD was used. We considered the fact that a fairly conservative dilution model was used in the previous facilities planning documents to derive these flows and chose to use the 46 MGD, which seems to roughly represent the midpoint between the monthly average and hourly maximum flows. The acute limit dilution is based on the maximum hourly flow of 76 MGD.

Comment #4: A new permit requirement reads “Effluent samples shall be taken after chlorination and prior to discharge to the effluent pipe.” This blanket requirement is contrary to the District’s practice and should be modified as set forth below. The District currently monitors the following parameters prior to chlorination: CBOD5, TSS, Total Nitrate, Total Ammonia Nitrogen, as N, Total Kjeldahl Nitrogen and LC50. The District currently monitors the following parameters after dechlorination: Oil and grease, pH, TRC and fecal coliform bacteria.

Response: This sentence is typically added for coding purposes for our Permit Compliance System (PCS) and the blanket statement used here was an oversight. The final permit has been changed to reflect the District’s practices.

Comment #5: With respect to the parameter CBOD5, the influent should be tested on the basis of BOD. See memorandum to the District from Camp, Dresser & McKee dated May 5, 1998.

Response: The regulations at 40 CFR 133.102 require that 85% removal of BOD is required of secondary treatment facilities such as this. Alternatively, this removal percentage can be calculated based on CBOD. As such, since the effluent limit is in the form of CBOD, the percent removal must be based on CBOD, thus requiring influent CBOD monitoring. If the permittee can show through sampling that the influent levels of BOD and CBOD are similar, then we may modify the permit to allow for the percent removal figure to be based on influent BOD levels instead of influent CBOD levels.

Comment #6: Footnote 6 on Page 3 states “The average of the three daily values (for fecal coliform) shall be reported as the maximum daily result.” To be consistent with the calculation requirements for the monthly average limit and EPA instructions for preparing DMRs, the maximum daily result should be the geometric mean of the three daily samples taken.

Response: This understanding is correct and the appropriate language change has been made to the permit which notes that the geometric mean of the three samples taken shall be reported as the daily maximum value.

Comment #7: Subparagraph f. on Page 4 requires the District to submit a report when the 90 day average flow to the facility exceeds 80% of the design flow. This provision is inapplicable to the District and should be deleted. The design flow of the recently completed secondary treatment facilities was established in the SESD Final EIR/Facilities Plan. The flow during the 1990's, when planning was being conducted, was 28.8 MGD, which is 97% of the design flow of 29.71. This exceeds 80% of the design flow and because the plant was designed and approved to exceed 80% of the design flow from the outset, the requirement of 1.A.1.f. is not applicable to the District.

Response: Based on these facts, this requirement has been waived from this permit. It is noted that the Facilities Plan and the permitted flow represent more than 95% of the designated service area.

Comment #8: The draft permit imposes requirements concerning the control of infiltration and inflow from the District's member community collection systems as well as requirements concerning operation and maintenance of those systems and sanitary sewer overflows (SSOs). The authority or basis for these new requirements is not included in the permit or the fact sheet. The proposed requirements are inconsistent with the District's legal authority and its legal relationship with its members. Under the District's 1925 enabling legislation, each community, not the District, retained ownership of its own collection system and responsibility for its operation and maintenance. This paragraph should be deleted from the draft permit in its entirety.

Response: This permit requirement has been routinely included in municipal permits. We believe that the District does have some authority to direct its member communities to undertake certain operational and maintenance activities which would limit overall I/I to the collection system. According to the enabling legislation of 1925, “if it (SESD board of directors) deems it necessary or advisable for the proper and reasonable operation of the works may make regulations as to the character of any sewage, drainage or other wastes discharged into any sewer under its control or any

sewer tributary thereto, and may also make regulations governing the rate of discharge of any such sewage, drainage, or other waste; ..." Therefore, this requirement has remained and the District is responsible for collecting and reporting all pertinent information regarding I/I work from its own as well as its' member communities collection systems. If the District and its member communities cannot cooperatively develop methods to comply with the requirements, the District should report this to the EPA and DEP. Based on this information, we may modify the permit to include the member communities as co-permittees for the purpose of complying with these requirements.

Comment #9: The Ambient Monitoring Program is a new requirement, for which a basis is not included. The District's discharge is meeting all applicable requirements. There is no suggestion that the regulated activity, the District's discharge, is having any adverse effect on the benthos. The prior data, which was not "monitoring data," was gathered many years ago, initially in connection with a 301(h) waiver application, at times when secondary treatment was not in effect.

Response: See response to Comment B.3 below.

Comment #10: The discussion in the body of the fact sheet and the water quality based calculation in Attachment A regarding TRC should be revised to reflect our related comments above.

Response: As mentioned earlier, there will be no change in the final permit for TRC.

Comment #11: Although the District has eliminated the three referenced CSOs, there are still believed to be combined sewers in the tributary systems owned and operated by the member communities.

Response: The permit does not authorize the discharge from any CSOs but it does not prohibit combined sewers. If the combined sewers are causing overflows, the permit requires reporting of these overflows and requires SESD to work with its communities as specified in Section C of the permit and to work towards eliminating or minimizing these discharges, where necessary to prevent unauthorized discharges or to eliminate excessive I/I.

B) Comments submitted by Karen Hopkins of Salem Sound 2000:

Comment #1: Salem Sound 2000 requests that the dilution factors used to calculate permit limits for the SESD discharge be reevaluated based on the pollutant dispersion model currently being developed by Applied Science Associates under a grant from EOEA. The public comment process should be extended and formalized in a public hearing in order to allow time for this new information to provide valuable refinement to the draft permit limits.

Response: The dilution as specified in the draft permit will remain in the final permit. The next permit will consider alternative dilution calculations based on completed studies.

Comment #2: The fact sheet states that "EPA has determined that a formal EFH consultation with NMFS is not required because the proposed discharge will not adversely affect EFH". What was

the basis for this decision?

Response: EPA has reviewed the 1997 Division of Marine Fisheries report on water quality and marine resources in Salem Sound. This report, which contains the most current and comprehensive source of data for Salem Sound, suggests that no violations of water quality standards were occurring around the existing discharge. The only evidence of the outfall is an elevation of nitrogen and turbidity in the surface waters in a small area around the outfall. Since that data collection was completed, SESD has upgraded their treatment plant to full secondary. Historic data on the benthic community has shown that a stressed benthic community exists in the vicinity of the outfall. Thus, we are requiring SESD to monitor the changes in this community with the change to secondary treatment. EPA will carefully review SESD's toxicity testing results and determine if a Toxicity Reduction Evaluation is required. EPA's obligation under the Magnuson-Stevens Act is to minimize impacts to EFH. Based on the data available, the proposed monitoring, the upgrade to secondary treatment and additional toxicity testing, EPA has determined that no significant impact to essential fish habitat was occurring and that SESD was taking reasonable steps to minimize the impact of the discharge on the marine environment.

Comment #3: Salem Sound 2000 applauds the inclusion of a required ambient monitoring program (AMP) in the draft permit. Given the potential impact of the discharge of waterborne contaminants on pelagic organisms, water column monitoring for chlorophyll a, phytoplankton, dissolved oxygen, turbidity, toxics and nutrients should also be included. In addition, bulk sediment chemistry for toxic parameters including metals should be considered.

Response: EPA's authority to require ambient monitoring is limited to circumstances where there are documented water quality impacts which are caused by a particular discharge. Water quality data collected in the vicinity of the discharge in 1997, prior to the completion of secondary treatment, did not indicate any significant water quality impacts. Historic benthic community data showed a stressed community and thus the need to build secondary treatment and the need to monitor the community's recovery. If the benthic community shows no signs of recovery and the presence of the outfall is suspected for retarding the recovery, additional treatment options may need to be considered.

Comment #4: The fact sheet states that the LC50 limit of 100% was violated three times for each of the two test species between 5/98 and 10/99, most of which was during operation of the secondary wastewater treatment system. Frequent violation of the LC50 limit for both organisms indicates that there is a potential toxic impact to marine organisms in the receiving waters. SS2000 urges action be taken to address this problem. One action could be to conduct a toxicity reduction evaluation (TRE). The EPA and DEP should also consider more frequent toxicity testing, a chronic toxicity limit, and permit limits for toxic constituents such as heavy metals.

Response: We are aware of WET violations. EPA enforcement staff intend to fully review the record in conjunction with plant performance and effluent data. Based on this review, they may initiate a compliance action which may indeed include the conducting of a TRE, among other items.

Comment #5: The requirements for the chlorination system report are much too general to be

effective and should include specific thresholds and triggers for specific actions to be taken within a specified time period.

Response: This requirement is a fairly recent one for municipal dischargers and requires an annual report. It is somewhat general due to the variety of the types of plants that are subject to it, and we intend on requesting additional information if the submittals are inadequate. The goal is for this analysis to determine whether or not additional measures are needed to ensure compliance with these limits on an ongoing basis.

Comment #6: Chlorine concentrations below the detection limit of 50 ug/l should be reported as < 50 ug/l and not 0 ug/l on the DMR to accurately reflect the limit of detection for this constituent.

Response: Our permit compliance system (PCS) requires that these values are reported as zeroes for data processing purposes, since an entry of < 50 generates an error message in the system.

Comment #7: Nitrogen is recognized for its importance in the eutrophication of coastal embayments and efforts are underway to develop nutrient criteria based on these observations. Therefore, it seems inappropriate to allow the discharger to apply for removal of these (nutrient) monitoring requirements after only one year. This permit should include ambient monitoring for both nitrogen in various forms and chlorophyll a.

Response: One year of nutrient monitoring under this permit would give us about 2 years worth of data, since these monitoring requirements went into effect with the permit modification in October of 1999. If data show that there are consistently low levels of nutrients in the discharge, we may have enough justification to remove these requirements or reduced their testing frequency. We have not added ambient monitoring of nitrogen at this time. See response to comment B.3. for further discussion of this issue.

Comment #8: SS2000 would like to see a monitoring requirement for a measure of petroleum hydrocarbons other than "oil and grease" since the potential toxicity of these constituents is a greater concern than the development of a sheen.

Response: Toxicity results have dramatically improved with the upgrade to secondary treatment, but problems remain. EPA is reviewing the past toxicity data, in conjunction with plant performance and effluent quality data. Based on this review, EPA may require a TRE, which may identify a class of chemicals or geographic location that is responsible for the toxicity results. Based on the results of this evaluation, appropriate control mechanisms can be employed. EPA believes that this would be a more effective way of reducing the toxicity problem, than by adding monitoring requirements.

Comment #9: While the effluent toxicity tests will provide toxicity data, they will not provide information on the levels of copper in the effluent.

Response: The quarterly, whole effluent toxicity testing required by this permit does include analytical monitoring of the effluent for several parameters, including copper.

Comment #10: The draft permit includes no language about water conservation efforts through public outreach and education. Given the very severe impacts of water withdrawal on the Ipswich River in recent years, this should also be incorporated into the permit.

Response: Although we do not typically require such measures in our municipal permits, we would certainly encourage SESD to conduct outreach efforts which would serve to provide a greater appreciation of the function of the plant and should result in its users being more cognizant of how their everyday activities, collectively, could have a negative impact on the plant and water resources. We would encourage the continuation of any efforts which the District is currently involved with, such as a recent, local cable TV program featuring a tour of the facility. Also refer to the response to comment A.2.

C) Comments submitted by Todd Callaghan of the Coastal Zone Management office of the Massachusetts Executive Office of Environmental Affairs:

Comment #1: Whole effluent toxicity testing results from 5/98 to 8/99 signify that a toxicity problem exists at the SESD plant and the ambient monitoring program should reflect this concern. Shouldn't the facility evaluate the cause of this toxicity so that it can take steps to reduce the pollutant of concern?

Response: See the responses to Comments B.4 and B.8.

Comment #2: In an effort to be as protective of the environment as possible, shouldn't the acute TRC limit be calculated using the observed maximum flow?

Response: According to EPA's water quality criteria document (Gold Book), it is appropriate to use a maximum hourly flow to calculate an acute limit. The dilution calculated from the maximum hourly flow of 76 MGD has been used.

Comment #3: Under the AMP, shouldn't the word "population" be replaced with "community"? What is the community that will be monitored? Are plants included? What are the invertebrates of interest? This section states that ambient monitoring will be conducted in years 1, 3 and 5 of the permit but the permit will expire in four years. Given that the SESD has failed many of its toxicity tests, it may be necessary to expand monitoring to include plankton and other pelagic species.

Response: The word population has been replaced with "community" as the intent of the AMP was to measure effects to the entire benthic community instead of a few particular species. We would expect that the study which is proposed by the District will look at a variety of plants and invertebrates and we would assure this with our review and feedback before approving such a study. The final permit language has been changed slightly, and the ambient monitoring is required within the first year of the permit and every other year thereafter, since there is no year 5 of the permit and

the permittee would be required to continue monitoring in the instance that the next permit was not issued in a timely manner. Also refer to response to comment B.8.

D) Comments submitted by Mason Weinrich of the Whale Center of New England:

Comment #1: We are concerned with the extent of the proposed monitoring system, especially in the water column.

Response: See response to comment B.3.

Comment #2: There is no consideration of the Essential Fish Habitat requirements of the Magnuson-Stevens Sustainable Fisheries Act.

Response: See response to Comment B.2.

Comment #3: There is no monitoring of total petroleum hydrocarbons despite their toxicity to the system.

Response: There is no evidence that these constituents are in the discharge at levels that would violate water quality standards. Also see response to comment B.8.

E) Comments submitted by Robert Buchsbaum of the Massachusetts Audubon Society:

Comment #1: We urge that the monitoring plan for SESD include, at a minimum, ambient water monitoring for temperature, salinity, dissolved oxygen, turbidity, total suspended solids, chlorophyll a, total Kjeldahl N, ammonia-N, and nitrate-N.

Response: See the response to comment B.3.

Comment #2: We also urge that SESD work together with the Massachusetts Division of Marine Fisheries in periodic sampling of the important biological components of Salem Sound. DMF's recently completed survey should be followed up in future years to determine the impacts, if any, of secondary treatment on the overall ecological health of the Sound.

Response: The Massachusetts EOEA watershed team is the mechanism to best direct this cooperative effort. The EPA and DEP will be working on this issue through the EOEA basin team and will encourage the inclusion of all federal and state agencies, as well as local entities, including SESD, to work together in identifying and prioritizing the basin's water quality and water management issues and solutions, including those of Salem Sound.

Comment #3: We urge that a scientific advisory panel be set up to provide a similar function for SESD as that for the MWRA under its NPDES permit. This panel could also provide advice on special studies needed to fully understand the impact of the effluent on Salem Sound.

Response: We would expect that ongoing studies and efforts such as those in the previous response will serve to increase our understanding of the health of Salem Sound and will assist the agencies in future decision making regarding permitting. I think that due to Federal Committee Advisory Act (FACA) issues, we are backing away from advisory panels and technical advisory committees.

Comment #4: A model of the Sound's flushing dynamics and effluent dilution is currently being developed and it would make sense to wait until this study is completed before finalizing the permit.

Response: This permit has been finalized and the findings of this report will be considered in future permit modification or reissuance efforts.

F) Comments submitted by the Massachusetts Division of Marine Fisheries:

Comment #1: Concerns have been raised on benthic habitat impacts due to effluent discharge, phytoplankton community alterations due to elevated nutrients in the effluent, the contribution of effluent fecal coliform bacteria to violations of surface water quality criteria for designated uses, and toxicity impacts from effluent discharge (PCBs and petroleum hydrocarbons in particular) on surrounding marine life. The current draft contains a provision for ambient monitoring of benthic habitat that is acceptable. But there are no other provisions to this section.

Response: See the response to Comment B.3.

Comment #2: A DMF study of the marine resources of Salem Sound in 1997 identified higher concentrations of fecal coliform bacteria at the Haste outfall station (outfall 001) than other stations in the Sound. To address concerns on fecal coliform bacteria and other pollutant dispersion, we recommend that dye studies are required for the discharge. If conducted in association with ongoing modeling efforts, it may be possible to address long-standing questions of dilution and dispersion patterns. These efforts would be important to meet the public's interest in maintaining swimming beaches and the long term goal of opening shellfish beds, both located only a few kilometers from the discharge.

Response: This is another opportunity for SESD and interested parties to work together. The permit contains ongoing monitoring for many parameters, including fecal coliform and dye testing is typically outside the scope of our requirements. The State has a beach monitoring program which would indicate high levels of coliform bacteria which may lead to beach closures. SESD's chlorination and de-chlorination capabilities should work towards reducing fecal coliform and chlorine residual in the effluent and the permit includes a requirement to report on these matters. In addition, this report was conducted prior to SESD putting secondary treatment on line. We would like to give the District the opportunity to show that there will be effluent improvements before creating additional monitoring requirements. Since secondary treatment went on line, SESD has routinely met its effluent bacteria limit. The bacteria discharge limit is equivalent to the ambient shellfish standard number, thus shellfish bed or beach closures due to high concentrations of bacteria should not be attributable to the SESD effluent.

Comment #3: We request that the permit include requirements that SESD notify DMF of plant malfunctions, overflows, or other conditions which result in increases to normal bacterial discharges to Salem Sound. We would like to work with SESD to develop a Memorandum of Understanding for communicating during such events. The cooperation will be necessary to meet long term goals of opening parts of Salem Sound for shellfish harvest.

Response: Although DMRs are available for review during business hours at EPA and DEP offices, we believe that the permittee should notify DMF and the USFDA of any chlorination system failures, as this type of information is critical to obtain as quickly as it is known. The final permit has included language which requires the permittee to notify DMF and the USFDA of chlorination system failures.

Comment #4: In regards to the EFH determination in the fact sheet, we find the determination that the proposed discharge will not adversely impact EFH is an arbitrary decision. The only support to this statement is Table 2, which contains flawed information and is not sufficient to allow the concluded determination.

Response: The permit's effluent limits and monitoring, toxicity testing, ambient monitoring program and other requirements will serve as ongoing measures of any effects on aquatic life. EPA and DEP feel that these measures are adequate to address EMF issues and do not feel like there is sufficient documentation with which to allow for additional requirements. Also see response to comment B.2.

Comment #5: The 1997 DMF study found much higher concentrations of dissolved inorganic nitrogen and orthophosphate near the Haste outfall than at other sampling stations in the sound. These concentrations raise questions on the impacts to local populations of phytoplankton, submerged vegetation and benthic algae. It will not be possible to understand the relationship of nutrient inputs to the health of aquatic resources without baseline monitoring.

Response: While we would expect to see elevated nutrient levels near the outfall, documented effects to the aquatic and benthic life need to be documented before an NPDES permit could require such baseline monitoring. As discussed earlier, the AMP will re-evaluate the previously degraded benthic community near the outfall to determine whether the change to secondary treatment has resulted in improvements. The 1997 DMF study was conducted prior to the upgrade to secondary treatment and showed elevated nutrient levels in the immediate vicinity of the outfall. Submerged aquatic vegetation is sensitive to high concentrations of nutrients. A study of eelgrass meadows along the northern shoreline of Salem Sound by the New England Aquarium, EPA and Massachusetts Audubon in 1996 showed that those populations were healthy and did appear to be impaired. In addition, the presence of eelgrass growing within Inner Salem Harbor in several locations where flushing is more limited and the absence of low dissolved oxygen concentrations suggests that eutrophication is not a severe problem.

G) Comments submitted by Polly Bradley of Safer Waters in Massachusetts (SWIM):

Comment #1: The effect of chlorine and dechlorination chemicals on juvenile lobsters will not be addressed.

Response: The permit includes effluent limits on TRC and fecal coliform and we feel that these requirements are adequate to protect aquatic life.

Comment #2: We are glad to see that monitoring will continue for oil & grease and for nitrate, ammonia nitrogen and Kjeldahl monitoring. We are sad to see that these requirements may possibly be dropped after a year.

Response: The permittee can request a permit modification at any time for reduced pollutant monitoring. If such a request had merit, we would public notice such a draft modification and issue it if there was no considerable comment against such an action. In the case of these parameters, there may come a time during this permit life where we have developed a good database of sampling and where we may be justified to reduce or eliminate the testing frequency. In this case, we would also consider other data sources, such as pretreatment reports and toxicity test reports which could provide an ongoing source of sampling for some of these parameters.

H) Comments submitted by the Coastal Advocacy Network:

Comment #1: This draft permit for SESD, the second largest discharger to Massachusetts Bay, includes only a benthic monitoring requirement. This level of monitoring is not adequate to monitor potential impacts to the embayment as it does nothing to investigate changes in the phytoplankton community that result from nutrient enrichment, loading of pathogens, or the impact of toxic discharges on sensitive marine life.

Response: See the response to comments B.3, B.8 and F.5.

Comment #2: The previous EPA Region 1 Administrator stated that the MWRA's NPDES permit, which includes ambient water quality requirements and outside review by a team of independent scientists, was going to be the model for all future permits. CAN strongly supports the MWRA model of a scientific advisory panel to oversee monitoring programs for industrial and wastewater discharges. Such a panel with meetings open to the public would go a long way to addressing the concerns raised by citizens, so would be beneficial for all.

Response: The MWRA permit is clearly a substantially larger and much more complex permit and we feel that the measures prescribed in the SESD permit are appropriate with which to monitor the discharge and its effects. Also see response to comment E.3.

I) William, Emily, Erika and Carol Crawford

Comment #1: We believe that water quality monitoring for this permit should take a broader view, not just looking at end of pipe discharges, but, instead, be used to determine the effects of those

discharges on the marine ecology. We believe that SESD should be held responsible to establish that the Salem plant does not negatively affect the marine environment of the waters off the North Shore.

Response: We believe that this permit does address these concerns and future Salem Sound efforts and studies are planned which will take a broader view. SESD's recent addition of secondary treatment and chlorination and the monitoring requirements, toxicity testing and ambient monitoring requirement in the permit should provide us with enough information to determine whether this discharge is affecting aquatic life and resources.

Comment #2: We live in Nahant, near Short Beach and we are plagued with a free-floating form of algae, which decays on our beaches, releasing gases with an obnoxious odor. This algae, *Pilayella littoralis*, is apparently nitrogen limited, such that nitrogen in the water is of particular concern to SESD's neighbors. We urge that the EPA require SESD to monitor nitrogen at various locations downstream of its discharge. Other pollutants, such as grease and oil, ammonia and chlorine should also be monitored. Monitoring to determine the effect of species such as juvenile lobsters should also be required of this permittee.

Response: We acknowledge your concerns, but see reasoning for our permit decisions in response to comments B.3, B.8 and F.5.