



Table 6-13. Results of the NMU NO_x SIL Modeling Analysis (01-05 SAW MET)

Averaging Period	NMU Maximum Impact ¹ ($\mu\text{g}/\text{m}^3$)	Year of Maximum Impact	Impact UTM Easting (meters)	Impact UTM Northing (meters)	Significant Impact Level ($\mu\text{g}/\text{m}^3$)	NMU Impact As % Of SIL
Annual	0.974	2005	468,960.8	5,157,154.0	1	97.40%

¹ Consistent with how the standards are applied, the maximum annual impact is based upon the highest of the 1st high impacts determined using five discrete years of meteorological data (2001 through 2005).

6.6 TAC MODELING ANALYSIS RESULTS

In addition to the criteria pollutant modeling analyses, a TAC modeling analysis has been conducted to demonstrate that the emissions of TACs from the new CFB boiler (Unit #10) will be in compliance with the Michigan AQD's air toxics regulations. Refined modeling for TACs was performed to determine the ambient, off-property impact from trace metals and organic compounds emitted from the new boiler.

Modeling was performed in accordance with the same methodology used for the criteria pollutant modeling and followed all regulations, guidelines and policies established by U.S. EPA and MDEQ, and again utilized the ISC-AERMOD (PRIME) model Version 04300. Michigan Rule 225 states that emissions from the new or modified source shall not cause a violation of the Initial Threshold Screening Level (ITSL) for non-carcinogens or Initial Risk Screening Level (IRSL) for carcinogenic compounds.

The results were determined by scaling the emission rate for each TAC by model predicted impacts based on a 1.0 gram/second model run for the averaging period associated with each TAC's applicable screening. Using this methodology, it is possible to determine the ambient impacts for multiple pollutants based on one model run instead of running a model for each TAC individually.

The emission rate of each TAC was determined by taking the maximum short term emission rate of each compound for the various fuel types that could potentially be used in the proposed CFB boiler. Table B-2 of Appendix B shows the maximum short term emission rates on a compound-



by-compound basis, which were then converted into gram/second emission rates for scaling purposes. The emission rates and calculated ambient impacts for all TACs (which includes HAPs) are presented in Table C-1 of Appendix C.

The following is a brief description of the procedure for using the gram per second modeled impacts to determine a specific pollutant's maximum ground level concentration.

Worst Case Acetaldehyde Impact, 24-Hour Averaging Period

CFB Boiler Stack Acetaldehyde Emission Rate = 2.47E-02 gram/sec

Gram/Second Modeled Impact for 24-hour averaging period = 1.589 ($\mu\text{g}/\text{m}^3$)/(g/sec)

$$\text{Acetaldehyde Impact} = \frac{1.589 (\mu\text{g}/\text{m}^3)}{(1 \text{ gram/second})} \times \frac{2.47E-02 \text{ grams}}{\text{second}}$$

$$\text{Acetaldehyde Impact} = \frac{0.0392 \mu\text{g Acetaldehyde}}{\text{m}^3}$$

As shown in the preceding calculations, the acetaldehyde emissions from the new CFB boiler exhaust stack results in a 24-hour impact of $0.0392 \mu\text{g}/\text{m}^3$, which is approximately 0.44% of the acetaldehyde screening level of $9 \mu\text{g}/\text{m}^3$ on a 24-hour basis.

The modeled impacts associated with the annual, 1-hour, 8-hour, and 24-hour modeled averaging periods for the new CFB boiler exhaust stack are presented in Table 6-14.

Table 6-14. 1.0 Gram Per Second Modeled Impacts for the New CFB Boiler

Averaging Period	Modeled Impact ($\mu\text{g}/\text{m}^3$)/(g/sec)	X (East) Impact Location ¹ (meters)	Y (North) Impact Location ¹ (meters)	Receptor Elevation (meters)
Annual	0.211	468,960.8	5,157,204.0	193.79
24-Hour	1.589	468,760.8	5,156,254.0	201.88
8-Hour	2.712	466,860.8	5,151,904.0	283.74
1-Hour	15.779	466,860.8	5,151,904.0	283.74

¹ These distances are referenced from the site ordinate (UTM coordinate Easting = 468,874.0 meters, and Northing = 5,156,608.0 meters).



Table C-1 of Appendix C presents the results of applying the modeled impacts of Table 6-14 to the maximum TAC emission rates. Table C-1 shows that the TAC emitted at the highest hourly rate, hydrochloric acid (HCl), results in an ambient impact of $0.24 \mu\text{g}/\text{m}^3$ when scaled by the 24-hour modeled impact. This impact is approximately 1.2% of the allowable screening level (SL) of $20 \mu\text{g}/\text{m}^3$ on a 24-hour averaging period basis. Similarly, the TAC that is expected to have the highest ambient impacts versus its screening level is formaldehyde, which has been predicted to result in a maximum annual ambient impact of $0.028 \mu\text{g}/\text{m}^3$ - approximately 34% of the allowable screening level (SL) of $0.08 \mu\text{g}/\text{m}^3$ on an annual averaging period basis. (Note that although the impact for chromium VI is predicted to be approximately 26% of its screening level, the emission rate quantified for Cr VI is uncontrolled and is expected to be much less than the rate presented in Table C-1, and thus result in a much lower impact after considering control efficiency of the baghouse).

Overall, the results presented in Table C-1 show that all TACs will comply with the applicable screening levels at the maximum predicted emission rates and thus comply with the Michigan AQD air toxics rules.

It should be noted that although the Michigan AQD ITSL for lead (Pb) has a 3-month averaging period, a 24-hour ambient impact has been determined and compared to the ITSL of $1.5 \mu\text{g}/\text{m}^3$ on a 3-month basis. This represents a conservative approach because it over predicts the ambient impact that would occur on a 3-month basis.

In conclusion, the proposed operation of the NMU facility expansion will be in compliance with all applicable federal and state ambient air quality standards for both criteria pollutants and TAC emissions.

6.7 DISPERSION MODELING FILES

Table 6-15 lists the ISC AERMOD files that have been included in Appendix C on compact disc. These include the complete Lakes Environmental project files for all modeling runs. The Marquette OE East and Marquette 7.5-minute DEM files utilized in determining elevated terrain through AERMAP are also included electronically.



Table 6-18. Summary of the NMU Modeling Files

ISC AERMOD View Files	File Description	Meteorological Data
NMU01_CO through NMU05_CO	CO SIL Models	2001-2005
NMUPM_P1 through NMUPM_P5	PM ₁₀ SIL Models	2001-2005
NMU01SO2 through NMU05SO2	SO ₂ PSD and NAAQS Models	2001-2005
NMU_NOx1 through NMU_NOx5	NO _x SIL Models	2001-2005
NMU_GPS2	TAC modeling Gram/Second Model	2005



7.0 SECONDARY IMPACT ANALYSIS

An additional impact analysis is required for major new sources or major modifications at existing major sources pursuant to 40 CFR Part 52.21(o). In addition, Section 7(a) of the Endangered Species Act (ESA) requires review of threatened and endangered species in the area surrounding the proposed projects. Therefore, the additional impact analysis is necessary to evaluate the impacts from the proposed project on:

- Associated growth
- Soils, vegetation, and wildlife
- Visibility impairment
- Threatened and Endangered Species

The proposed project is considered a major modification and will result in emissions of particulate matter ($PM_{10}/PM_{2.5}$), nitrogen oxides (NO_x), sulfur dioxide (SO_2) and carbon monoxide (CO) greater than the major source significant level. Consequently, an additional impact analysis addressing the effects of PM, NO_x , SO_2 , and CO in these areas is required.

Additionally, MDEQ has requested a quantitative analysis regarding the impact of the 7 MW cooling tower on fogging and icing. Fogging occurs as a result of evaporative moisture from the cooling tower and result in reduced visibility and increased humidity directly adjacent to the cooling tower. Icing when the ambient temperature is below freezing the cooling tower fog freezes on road surfaces.

7.1 ASSOCIATED GROWTH

The purpose of the growth impact analysis is to quantify the impact from growth resulting from the construction and operation of the proposed project and to assess air quality impacts that would result from that growth. Impacts on the ambient air and surrounding community resulting from the installation of the new CFB will be minor.

Northern Michigan University will be receiving solid fuels for the new boiler via 40 ton trucks delivered approximately once per day, Monday through Friday. While an increase in vehicle traffic as a result of fuel truck delivery will increase, both Sugarloaf and Wright Avenues are



currently major transportation routes. Specifically, Sugarloaf Avenue is currently heavily traveled by logging trucks delivering fibers to facilities from processing plants north and west of Marquette. Consequently, the increase in truck traffic as a result of the new solid fuel boiler will be relatively insignificant.

NMU is proposing to construct and install a new CFB boiler and steam turbine in response to increased demand for power and steam at the Marquette campus. The proposed project also includes construction of a new boiler building. Due to abundant supplies of solid fuel, including coal and wood waste, the project is not expected to affect the fuel supply or impact the fuel markets within the upper peninsula of Michigan or the Midwest.

7.2 SOILS, VEGETATION, AND WILDLIFE

Additional increases in pollutant levels resulting from a specific emission source can have an impact on air quality-related values (AQRVs). However, it is important to evaluate the level of the expected increase. AQRVs can include visibility, odor, flora, fauna, and geographic resources; archeological, historical, and other cultural resources; and soil and water resources.

NMU has performed a modeling demonstration for PM₁₀/PM_{2.5}, NO_x, SO₂, and CO emissions resulting from the installation of the new CFB boiler. This ambient impact analysis addressed emissions from the all units at NMU, including the three (3) existing natural gas/oil-fired boilers, and compared the model results with both the primary and secondary National Ambient Air Quality Standards. Note that the primary and secondary standards for PM₁₀, NO_x, SO₂, and CO have the same NAAQS and that the impacts associated with the proposed project will be minor.

The highest predicted NO_x concentration increases resulting from the proposed project at NMU are less than the ambient health standards allowed in the NAAQS. Specifically, AERMOD predicted the following PM₁₀ impacts from the facility as a result of future potential emissions:

- Annual concentration of 0.97 $\mu\text{g}/\text{m}^3$ (primary NAAQS is 100 $\mu\text{g}/\text{m}^3$)



The highest predicted SO₂ concentration increases resulting from the proposed project at NMU are less than the ambient health standards allowed in the NAAQS. Specifically, AERMOD predicted the following PM₁₀ impacts from the facility as a result of future potential emissions:

- 3-hour concentration of 520.24 $\mu\text{g}/\text{m}^3$ (primary NAAQS is 1,300 $\mu\text{g}/\text{m}^3$)
- 24-hour concentration of 217.39 $\mu\text{g}/\text{m}^3$ (primary NAAQS is 365 $\mu\text{g}/\text{m}^3$)
- Annual concentration of 30.56 $\mu\text{g}/\text{m}^3$ (primary NAAQS is 80 $\mu\text{g}/\text{m}^3$)

Modeling was also performed for PM₁₀ and CO emissions. This modeling showed that the impacts from both PM₁₀ and CO as a result of the proposed project are less than the federal significant impact levels of 1 and 5 $\mu\text{g}/\text{m}^3$, and 500 and 2,000 $\mu\text{g}/\text{m}^3$, respectively.

Based on the modeling results presented above, no impact on soils, vegetation, or wildlife can be expected. Further, these small concentration increases are not likely to have an adverse effect on AQVs within the vicinity of the facility.

7.3 VISIBILITY

NMU is located within 50 km from the Seney National Wildlife Refuge (Seney) Class I area. As such, a visibility analysis using the CALPUFF model was performed to determine whether the emissions from the new CFB will cause a degradation of visibility due to increased relative humidity within Seney.

The visibility modeling demonstration was performed according the modeling protocol submitted to MDEQ on August 18, 2006 and approved via e-mail on August 21, 2006. The results confirm that the potential emissions from the new CFB will not result in visibility impairment at Seney.

While sulfates are a subset of the PM_{2.5} and known to contribute to regional haze problems, the small incremental increase in sulfates from the proposed project are considered to be negligible in comparison to the region's current quality index and have not been quantified. Therefore, no adverse effect on regional haze is expected from the proposed new boiler.



7.4 THREATENED AND ENDANGERED SPECIES

A request for review of threatened and endangered species in the area surrounding the NMU facility was submitted to the Michigan Department of Natural Resources (MDNR) was submitted by NTH Consultants, Ltd. A review by the MDNR – Wildlife Division determined that “the project should have no impact on rare or unique natural features ...” and a copy of the letter from Ms. Lori Sargent, Endangered Species Specialist, is included in Appendix E.

Additionally, a request for review for threatened and endangered species by the U.S. Fish and Wildlife Service was requested as well. Per the letter included in Appendix E, the U.S. Fish and Wildlife Service confirms that no threatened and endangered species are present in the area impacted by the project and no additional review is necessary.

7.5 COOLING TOWER IMPACTS

As requested by MDEQ, a quantitative analysis for impacts of fogging and icing from the proposed 7 MW cooling tower was performed using the Seasonal/Annual Cooling Tower Impact (SACTI) model. This analysis confirmed that impairments to the surrounding community as a result of fogging and icing is not expected. The electronic input and output files from this analysis is included in Appendix C on compact disc, with hardcopy output in Appendix F.




APPENDIX A

Site Drawings

CAMPUS MAP - NORTHERN SECTION

NORTHERN MICHIGAN UNIVERSITY

MARQUETTE, MICHIGAN
DATE: SEPTEMBER 4, 2003



ELECTRICAL LEGEND


SYMBOL	UTILITY
—	BUSING
—	HIGHMAST LIGHTPOLE
—	SINGLE SURFACE LIGHTPOLE
—	DOUBLE SURFACE LIGHTPOLE
—	QUAD SURFACE LIGHTPOLE
—	UPLIGHT POLE
—	COVERED STATION
—	MANHOLE
—	LIGHTED BUILDING SIGNS

STEAM LEGEND

SYMBOL	UTILITY
—	STEAM
○	ABANDONED STEAM
○	MANHOLE
○	STEAM VAULT (SV)

ପ୍ରାଚୀନ ଶାସକିରେ

卷之三



CUMMINS & BARNARD, INC.
6403 DATA COURT

NORTHERN MICHIGAN UNIVERSITY
WOOD/COAL FIRED BOILER
ANN ARBOR, MICHIGAN 48106
(734) 781-8151 Fax (734) 781-8881
www.circumferent-services.com

EQUIPMENT ARRANGEMENT

NOT TO BE USED FOR
CONSTRUCTION

A SECTION PLANT ELEVATION



APPENDIX B

Emission Summary Tables

Northern Michigan University
New CFB Boiler
Toxic Air Contaminant Modeling Results

1.0 Gram/Sec Modeled Impacts

Averaging Period	Impact ($\mu\text{g}/\text{m}^3$ / 1 g/s)
Annual	0.211
24 Hour	1.589
8 Hour	2.712
1 Hour	15.779

Table C-1. TAC Emission Rates and Modeling Impact Results

Compound	CAS No.	Maximum Emission Rates		Modeled Rate (gram/sec)	ITSL ($\mu\text{g}/\text{m}^3$)	IRSL ($\mu\text{g}/\text{m}^3$)	Averaging Period	Ambient Impact ($\mu\text{g}/\text{m}^3$)	% of SL
		(lb/hr)	(tpy)						
Lead	7439-92-1	2.48E-03	1.09E-02	3.12E-04	1.5		24 hour	4.96E-04	0.03%
HCl	7647-01-0	1.20	5.26	1.51E-01	20		24 hour	2.41E-01	1.20%
HF	7664-39-3	0.15	0.66	1.89E-02	26		1 hour	2.99E-01	1.15%
H ₂ SO ₄	7664-93-9	1.13	4.94	1.42E-01	10		8 hour	3.86E-01	3.86%
Total Dioxin/Furan	1746-01-6	4.33E-10	1.90E-09	5.45E-11		2.30E-07	Annual	1.15E-11	0.00%
Metals									
Antimony	7440-36-0	1.68E-03	7.36E-03	2.12E-04	0.2		24 hour	3.37E-04	0.168%
Arsenic	7440-38-2	1.42E-04	6.22E-04	1.79E-05		0.0002	Annual	3.77E-06	1.88%
Barium	7440-39-3	9.18E-04	4.02E-03	1.16E-04	5		8 hour	3.14E-04	0.006%
Beryllium	7440-41-7	3.70E-06	1.62E-05	4.66E-07	0.02		24 hour	7.41E-07	0.004%
Boron	7440-41-7	3.70E-06	1.62E-05	4.66E-07		0.0004	Annual	9.83E-08	0.025%
Cadmium	7440-43-9	2.29E-04	1.00E-03	2.89E-05		0.0006	Annual	6.09E-06	1.02%
Chromium, total	7440-47-3	4.95E-03	2.17E-02	6.24E-04	0.1		Annual	1.31E-04	0.131%
Chromium, hexavalent	18540-29-9	8.25E-04	3.61E-03	1.04E-04	0.1		24 hour	1.65E-04	0.17%
Chromium, hexavalent	18540-29-9	8.25E-04	3.61E-03	1.04E-04		8.30E-05	Annual	2.19E-05	26.40%
Chromium, trivalent	16065-83-1	1.58E-04	6.78E-04	1.95E-05	5		8 hour	5.29E-05	0.001%
Cobalt	7440-48-4	1.25E-03	5.48E-03	1.58E-04	0.2		8 hour	4.28E-04	0.214%
Copper	7440-50-8	1.18E-04	5.06E-04	1.48E-05	2		8 hour	3.95E-05	0.002%
Iron		2.33E-03	1.02E-02	2.94E-04	0.1		Annual	6.20E-05	0.05%
Magnesium	7439-95-4	1.38E-01	6.03E-01	1.73E-02	100		8 hour	4.70E-02	0.047%
Manganese	7439-96-5	3.77E-03	1.65E-02	4.75E-04	0.05		24 hour	7.55E-04	1.51%
Molybdenum		2.29E-04	1.00E-03	2.89E-05	0.1		Annual	6.09E-06	0.006%
Nickel	7440-02-0	3.09E-04	1.35E-03	3.89E-05		0.0042	Annual	8.21E-06	0.20%
Phosphorus	7723-14-0	6.37E-05	2.79E-04	8.02E-06	1		8 hour	2.17E-05	0.002%
Potassium		9.19E-02	4.03E-01	1.16E-02	0.1		Annual	2.44E-03	2.44%
Selenium	7782-49-2	1.63E-02	7.15E-02	2.06E-03	2		8 hour	5.58E-03	0.279%
Silver	7440-22-4	4.01E-03	1.76E-02	5.05E-04	0.1		8 hour	1.37E-03	1.37%
Sodium		8.49E-04	3.72E-03	1.07E-04	0.1		Annual	2.25E-05	0.02%
Strontium		2.36E-05	1.03E-04	2.97E-06	0.1		Annual	6.26E-07	0.001%
Tin	7440-31-5	5.42E-05	2.37E-04	6.83E-06	20		8 hour	1.85E-05	0.000%
Titanium		4.72E-05	2.07E-04	5.94E-06	0.1		Annual	1.25E-06	0.001%
Vanadium		4.80E-04	2.10E-03	6.04E-05	0.1		Annual	1.27E-05	0.013%
Yttrium		7.07E-07	3.10E-06	8.91E-08	0.1		Annual	1.88E-08	0.000%
Zinc (as ZnO)	1314-13-2	5.23E-02	2.29E-01	6.59E-03	50		8 hour	1.79E-02	0.036%
Organic Toxic Air Contaminants (TACs)									
Acetaldehyde	75-07-0	1.96E-01	8.57E-01	2.47E-02	9		24 hour	3.92E-02	0.435%
Acetaldehyde	75-07-0	1.96E-01	8.57E-01	2.47E-02		0.5	Annual	5.20E-03	1.04%
Acetophenone	98-86-2	1.88E-04	8.22E-04	2.37E-05	490		8 hour	6.41E-05	0.000%
Acrolein	107-02-8	2.39E-02	1.05E-01	3.01E-03	0.02		Annual	6.34E-04	3.17%
Acrolein	107-02-8	2.39E-02	1.05E-01	3.01E-03	0.5		1 hour	4.75E-02	9.50%
Benzene	71-43-2	9.90E-01	4.34E+00	1.25E-01	30		24 hour	1.98E-01	0.66%
Benzene	71-43-2	9.90E-01	4.34E+00	1.25E-01		0.1	Annual	2.63E-02	26.30%
Benzyl chloride	100-44-7	8.76E-03	3.84E-02	1.10E-03		0.02	Annual	2.33E-04	1.16%
Benzoic acid	65-85-0	1.11E-05	4.85E-05	1.40E-06	0.1		Annual	2.94E-07	0.000%
Biphenyl	92-52-4	2.13E-05	9.32E-05	2.68E-06	15		8 hour	7.27E-06	0.000%
Bis(2-Ethylhexyl)phthalate	117-81-7	9.14E-04	4.00E-03	1.15E-04		0.2	Annual	2.43E-05	0.012%
Bromoform	75-25-2	4.88E-04	2.14E-03	6.15E-05		0.9	Annual	1.30E-05	0.001%
Carbon disulfide	75-15-0	1.63E-03	7.13E-03	2.05E-04	700		24 hour	3.26E-04	0.000%
Carbazole	86-74-8	4.24E-04	1.86E-03	5.35E-05	0.1		Annual	1.13E-05	0.011%
Carbon tetrachloride	56-23-5	1.08E-02	4.65E-02	1.34E-03		0.07	Annual	2.82E-04	0.40%
Chlorine	7782-50-5	1.86E-01	8.16E-01	2.35E-02	15		8 hour	6.36E-02	0.42%
2-Chloroacetophenone	532-27-4	8.76E-05	3.84E-04	1.10E-05	0.03		24 hour	1.75E-05	0.058%
Chlorobenzene	108-90-7	7.78E-03	3.41E-02	9.80E-04	70		24 hour	1.56E-03	0.002%
Chloroform	67-66-3	6.60E-03	2.89E-02	8.32E-04		0.4	Annual	1.75E-04	0.044%
2-Chloronaphthalene	91-58-7	5.66E-07	2.48E-06	7.13E-08	0.1		Annual	1.50E-08	0.000%
2-Chlorophenol	95-57-8	5.66E-06	2.48E-05	7.13E-07	0.1		Annual	1.33E-06	0.000%
Cumene	98-82-8	6.63E-05	2.91E-04	8.36E-06	400		24 hour	1.33E-05	0.000%
Cyanide	57-12-5	3.13E-02	1.37E-01	3.94E-03	50		1 hour	6.22E-02	0.12%
1,4-Dichlorobenzene	106-46-7	2.50E-04	1.10E-03	3.15E-05	800		24 hour	5.01E-05	0.000%
1,4-Dichlorobenzene	106-46-7	2.50E-04	1.10E-03	3.15E-05		0.14	Annual	6.65E-06	0.005%
2,4-Dinitrophenol	51-28-5	4.24E-05	1.86E-04	5.35E-06	0.1		Annual	1.13E-06	0.001%
2,4-Dinitrotoluene	121-14-2	3.50E-06	1.53E-05	4.42E-07	2		8 hour	1.20E-06	0.000%
2,4-Dinitrotoluene	121-14-2	3.50E-06	1.53E-05	4.42E-07		0.009	Annual	9.31E-08	0.001%
Dimethyl sulfate	77-78-1	6.01E-04	2.63E-03	7.57E-05	0.5		8 hour	2.05E-04	0.041%
Ethylbenzene	100-41-4	7.31E-03	3.20E-02	9.21E-04	1000		24 hour	1.46E-03	0.000%
Ethylbenzene	100-41-4	7.31E-03	3.20E-02	9.21E-04		3	Annual	1.94E-04	0.006%
Ethylchloride	75-00-3	5.26E-04	2.30E-03	6.62E-05	10000		24 hour	1.05E-04	0.000%
Ethylene dichloride	107-06-2	5.01E-04	2.19E-03	6.31E-05		0.04	Annual	1.33E-05	0.033%
Ethylene dibromide	106-93-4	1.50E-05	6.58E-05	1.89E-06	9		24 hour	3.01E-06	0.000%
Ethylene dibromide	106-93-4	1.50E-05	6.58E-05	1.89E-06		0.002	Annual	3.99E-07	0.020%
Formaldehyde	50-00-0	1.04E+00	4.54E+00	1.31E-01		0.08	Annual	2.75E-02	34.44%

Northern Michigan University
New CFB Boiler
Toxic Air Contaminant Modeling Results

1.0 Gram/Sec Modeled Impacts

Averaging Period	Impact ($\mu\text{g}/\text{m}^3$ / 1 g/s)
Annual	0.211
24 Hour	1.589
8 Hour	2.712
1 Hour	15.779

Table C-1. TAC Emission Rates and Modeling Impact Results

Compound	CAS No.	Maximum Emission Rates		Modeled Rate (gram/sec)	ITSL ($\mu\text{g}/\text{m}^3$)	IRSL ($\mu\text{g}/\text{m}^3$)	Averaging Period	Ambient impact ($\mu\text{g}/\text{m}^3$)	% of SL
		(lb/hr)	(tpy)						
Heptachlorobiphenyl	28655-71-2	1.56E-08	6.82E-08	1.96E-09	0.1		Annual	4.13E-10	0.000%
Hexachlorobiphenyl	26601-64-9	1.30E-07	5.68E-07	1.63E-08	0.1		Annual	3.44E-09	0.000%
Hexanal	66-25-1	1.65E-03	7.23E-03	2.08E-04	2		Annual	4.38E-05	0.002%
Hexane	110-54-3	3.75E-01	1.64E+00	4.73E-02	700		24 hour	7.52E-02	0.011%
Isobutyraldehyde	78-84-2	2.83E-03	1.24E-02	3.56E-04	160		24 hour	5.66E-04	0.000%
Isophorone	78-59-1	7.26E-03	3.18E-02	9.15E-04	280		1 hour	1.44E-02	0.005%
Isophorone	78-59-1	7.26E-03	3.18E-02	9.15E-04		3.7	Annual	1.93E-04	0.005%
1,2-Methylnaphthalene	91-57-6	3.77E-05	1.65E-04	4.75E-06	10		Annual	1.00E-06	0.000%
1,3-Methylchloranthrene		3.75E-07	1.64E-06	4.73E-08	0.1		Annual	9.97E-09	0.000%
Monochlorobiphenyl		5.19E-08	2.27E-07	6.53E-09	0.1		Annual	1.38E-09	0.000%
Methyl bromide	74-83-9	3.54E-03	1.55E-02	4.46E-04	5		24 hour	7.08E-04	0.014%
Methyl chloride	74-87-3	6.63E-03	2.91E-02	8.36E-04	90		24 hour	1.33E-03	0.001%
Methyl chloride	74-87-3	6.63E-03	2.91E-02	8.36E-04		1.6	Annual	1.76E-04	0.011%
Methyl ethyl ketone	78-93-3	4.88E-03	2.14E-02	6.15E-04	5000		24 hour	9.77E-04	0.000%
Methyl hydrazine	60-34-4	2.13E-03	9.32E-03	2.68E-04	0.1		Annual	6.65E-05	0.057%
Methyl methacrylate	80-62-6	2.50E-04	1.10E-03	3.15E-05	700		24 hour	5.01E-05	0.000%
Methyl tert butyl ether	1634-04-4	4.38E-04	1.92E-03	5.52E-05	3000		24 hour	8.77E-05	0.000%
Methylene chloride	75-09-2	6.84E-02	2.99E-01	8.61E-03		2	Annual	1.82E-03	0.091%
Naphthalene	91-20-3	2.29E-02	1.00E-01	2.88E-03	3		24 hour	4.58E-03	0.15%
Naphthalene	91-20-3	2.29E-02	1.00E-01	2.88E-03		0.08	Annual	6.07E-04	0.76%
2-Nitrophenol	88-75-5	5.66E-05	2.48E-04	7.13E-06	0.1		Annual	1.50E-06	0.002%
4-Nitrophenol	100-02-7	2.59E-05	1.14E-04	3.27E-06	0.1		Annual	6.89E-07	0.001%
Pentachlorobiphenyl		2.83E-07	1.24E-06	3.56E-08	0.1		Annual	7.51E-09	0.000%
Pentachlorophenol	87-86-5	1.20E-05	5.27E-05	1.51E-06	100		24 hour	2.41E-06	0.000%
Pentachlorophenol	87-86-5	1.20E-05	5.27E-05	1.51E-06		0.03	Annual	3.19E-07	0.001%
Perylene	198-55-0	1.23E-07	5.37E-07	1.54E-08	0.1		Annual	3.26E-09	0.000%
Phenol	108-95-2	1.20E-02	5.27E-02	1.51E-03	600		1 hour	2.39E-02	0.004%
Propionaldehyde	123-38-6	1.44E-02	6.30E-02	1.81E-03	4		Annual	3.82E-04	0.010%
Propanal	123-38-6	7.54E-04	3.30E-03	9.51E-05	4		Annual	2.00E-05	0.001%
Styrene	100-42-5	4.48E-01	1.96E+00	5.64E-02	1000		24 hour	8.97E-02	0.009%
Styrene	100-42-5	4.48E-01	1.96E+00	5.64E-02		1.7	Annual	1.19E-02	0.70%
Tetrachlorobiphenyl		5.89E-07	2.58E-06	7.43E-08	0.1		Annual	1.57E-08	0.000%
Tetrachloroethylene	127-18-4	8.96E-03	3.92E-02	1.13E-03	0.1		Annual	2.38E-04	0.24%
Toluene	108-88-3	2.17E-03	9.50E-01	2.73E-02	5000		24 hour	4.34E-02	0.001%
o-Toulualdehyde	529-20-4	1.70E-03	7.43E-03	2.14E-04	440		24 hour	3.40E-04	0.000%
p-Toulualdehyde	104-87-0	2.59E-03	1.14E-02	3.27E-04	0.1		Annual	6.89E-05	0.069%
Trichlorobiphenyl		6.13E-07	2.68E-06	7.72E-08	0.1		Annual	1.63E-08	0.000%
Trichlorofluoromethane	75-69-4	9.67E-03	4.23E-02	1.22E-03	56200		1 hour	1.92E-02	0.000%
Trichlorethane	79-01-6	7.07E-03	3.10E-02	8.91E-04		0.6	Annual	1.88E-04	0.031%
1,1,1-Trichloroethane	71-55-6	7.31E-03	3.20E-02	9.21E-04	1000		24 hour	1.46E-03	0.000%
2,4,6-Trichlorophenol	88-06-2	5.19E-06	2.27E-05	6.53E-07		0.3	Annual	1.38E-07	0.000%
Vinyl acetate	108-05-4	9.51E-04	4.17E-03	1.20E-04	200		24 hour	1.90E-04	0.000%
Vinyl Chloride	75-01-4	4.24E-03	1.86E-02	5.35E-04	100		24 hour	8.50E-04	0.001%
Vinyl Chloride	75-01-4	4.24E-03	1.86E-02	5.35E-04		0.11	Annual	1.13E-04	0.10%
Xylenes	1330-20-7	4.63E-04	2.03E-03	5.83E-05	100		24 hour	9.27E-05	0.000%
o-Xylene	95-47-6	5.89E-03	2.58E-02	7.43E-04	100		24 hour	1.18E-03	0.001%
Polynuclear Aromatic Hydrocarbons (PAH)									
Acenaphthene	83-32-9	2.15E-04	9.40E-04	2.70E-05	210		24 hour	4.30E-05	0.000%
Acenaphthylene	208-98-8	1.18E-03	5.16E-03	1.49E-04	35		24 hour	2.36E-04	0.001%
Acetone	67-84-1	4.48E-02	1.96E-01	5.64E-03	5900		8 hour	1.53E-02	0.000%
Anthracene	120-12-7	7.07E-04	3.10E-03	8.91E-05	1000		24 hour	1.42E-04	0.000%
Benzaldehyde	100-52-7	2.00E-04	8.78E-04	2.52E-05		0.4	Annual	5.32E-06	0.001%
Benz(a)anthracene	56-55-3	1.53E-05	6.71E-05	1.93E-06	0.1		Annual	4.07E-07	0.000%
Benz(a)pyrene	50-32-8	6.13E-04	2.68E-03	7.72E-05		0.0005	Annual	1.63E-05	3.26%
Benz(e)pyrene	192-97-2	6.13E-07	2.68E-06	7.72E-08	0.1		Annual	1.63E-08	0.000%
Benz(b)fluoranthene	205-99-2	2.36E-05	1.03E-04	2.97E-06	0.1		Annual	6.26E-07	0.001%
Benz(f,k)fluoranthene		3.77E-05	1.65E-04	4.75E-06	0.1		Annual	1.00E-06	0.001%
Benz(k)fluoranthene	205-02-3	8.49E-06	3.72E-05	1.07E-06	0.1		Annual	2.25E-07	0.000%
Benz(b,j)fluoranthene		2.36E-05	1.03E-04	2.97E-06	0.1		Annual	6.26E-07	0.001%
Chrysene	218-01-9	8.96E-06	3.92E-05	1.13E-06	0.1		24 hour	4.39E-06	0.000%
Crotonaldehyde	4170-30-3	2.33E-03	1.02E-02	2.94E-04	9		1 hour	4.64E-03	0.052%
Decachlorobiphenyl	2051-24-3	6.37E-08	2.79E-07	8.02E-09	0.1		Annual	1.69E-09	0.000%
Dibenz(a,h)anthracene	53-70-3	2.15E-06	9.40E-06	2.70E-07	0.1		Annual	5.70E-08	0.000%
1,2-Dibromoethene	540-49-8	1.30E-02	5.68E-02	1.63E-03	0.1		Annual	3.44E-04	0.34%
Dichlorobiphenyl		1.74E-07	7.64E-07	2.20E-08	0.1		Annual	4.63E-09	0.000%
1,2-Dichloroethane	107-06-2	6.84E-03	2.99E-02	8.61E-04		0.04	Annual	1.82E-04	0.45%
1,2-Dichloropropane	78-87-5	7.78E-03	3.41E-02	9.80E-04	4		24 hour	1.56E-03	0.039%
7,12-Dimethylbenz(a)anthracene		3.34E-06	1.46E-05	4.20E-07	0.1		Annual	8.86E-08	0.000%
Fluoranthene	206-44-0	3.77E-04	1.65E-03	4.75E-05	140		24 hour	7.55E-05	0.000%
Fluorene	86-73-7	8.02E-04	3.51E-03	1.01E-04	140		24 hour	1.60E-04	0.000%
Indeno(1,2,3-c,d)pyrene	193-39-5	2.05E-05	8.98E-05	2.58E-06	0.1		Annual	5.45E-07	0.001%
Phenanthrene	85-01-8	1.65E-03	7.23E-03	2.08E-04	0.1		Annual	4.38E-05	0.044%
Pyrene	129-00-0	8.72E-04	3.82E-03	1.10E-04	100		24 hour	1.75E-04	0.000%
5-Methyl chrysene	3697-24-3	2.75E-07	1.21E-06	3.47E-08	0.1		Annual	7.31E-09	0.000%

Note: An ITSL of 0.1 that is red bolded is a default screening level per AQD air toxics policy



APPENDIX C

Dispersion Modeling Support Information




NMU Campus
Modeling Building Layouts

(with Building Heights)

PROJECT TITLE:


Northern Michigan University - Powerhouse Modification PTI
Building Layout



COMMENTS: NMU Power Plant Building Layout:	SOURCES: 2 RECEPTORS: 7537	COMPANY NAME: NTH Consultants, Ltd MODELER: Edward Bishop, Asst Project Engineer
		SCALE: 1:800 0 0.02 km
	DATE: 1/25/2007	PROJECT NO.: 16-060504

PROJECT TITLE:

Northern Michigan University - Powerhouse Modification PT1
Building Layout




COMMENTS: NMU Power Plant Building Layout:	SOURCES: 2 RECEPTORS: 7537	COMPANY NAME: NTH Consultants, Ltd MODELER: Edward Bishop, Asst Project Engineer SCALE: 1:1,500 0 0.05 km	PROJECT NO.: 16-060504
--	---	---	----------------------------------



Stack Layout

PROJECT TITLE:

Northern Michigan University - Powerhouse Modification PTI
Stack Identification Layout



COMMENTS: NMU Power Plant Building Layout:	SOURCES: 2	COMPANY NAME: NTH Consultants, Ltd
	RECEPTORS: 7537	MODELER: Edward Bishop, Asst Project Engineer
		SCALE: 1:500 0 0.01 km
	DATE: 1/25/2007	PROJECT NO.: 16-060504



**Existing Facility, New
Structures, and Stack Coordinates
(Internal Coordinates)**

Northern Michigan University - Modeling Analysis Layout for Proposed Boiler Project

**Coordinate System Layout for Northern Michigan University Located in Marquette, MI
The Southwest Corner of the Existing Ripley Heating Plant Bldg Equals Site Coordinate (0,0)**

Building	Corner I.D.	Coordinates (feet)		Height (feet)	Coordinates (meters)		Height (meters)	
		X (E)	Y (N)		X (E)	Y (N)		
Ripley Heating Plant	A1	0.00	0.00	79.00	0.00	0.00	24.08	
	A2	0.00	102.92	79.00	0.00	31.37	24.08	
	A3	66.92	102.92	79.00	20.40	31.37	24.08	
	A4	66.92	0.00	79.00	20.40	0.00	24.08	
	A5	0.00	0.00	79.00	0.00	0.00	24.08	
New Boiler Main Building	B1	-101.53	42.82	110.00	-30.95	13.05	33.53	
	B2	-101.53	153.12	110.00	-30.95	46.67	33.53	
	B3	-36.53	153.12	110.00	-11.14	46.67	33.53	
	B4	-36.53	42.82	110.00	-11.14	13.05	33.53	
	B5	-101.53	42.82	110.00	-30.95	13.05	33.53	
New Steam Turbine Bldg	C1	-101.53	-4.19	30.00	-30.95	-1.28	9.14	
	C2	-101.53	42.82	30.00	-30.95	13.05	9.14	
	C3	-36.53	42.82	30.00	-11.14	13.05	9.14	
	C4	-36.53	-4.19	30.00	-11.14	-1.28	9.14	
	C5	-101.53	-4.19	30.00	-30.95	-1.28	9.14	
New Control Room	D1	-36.53	0.00	30.00	-11.14	0.00	9.14	
	D2	-36.53	39.13	30.00	-11.14	11.93	9.14	
	D3	0.00	39.13	30.00	0.00	11.93	9.14	
	D4	0.00	0.00	30.00	0.00	0.00	9.14	
	D5	-36.53	0.00	30.00	-11.14	0.00	9.14	
Coal Containment Structure	E1	-145.96	167.00	8.00	-44.49	50.90	2.44	
	E2	-145.96	169.00	8.00	-44.49	51.51	2.44	
	E3	-90.29	169.00	8.00	-27.52	51.51	2.44	
	E4	-90.29	229.00	8.00	-27.52	69.80	2.44	
	E5	-145.96	229.00	8.00	-44.49	69.80	2.44	
	E6	-145.96	231.00	8.00	-44.49	70.41	2.44	
	E7	-88.29	231.00	8.00	-26.91	70.41	2.44	
	E8	-88.29	167.00	8.00	-26.91	50.90	2.44	
	E9	-145.96	167.00	8.00	-44.49	50.90	2.44	
Wood Handling Building	F1	-151.12	-4.43	22.00	-46.06	-1.35	6.71	
	F2	-151.12	39.14	22.00	-46.06	11.93	6.71	
	F3	-127.87	39.14	22.00	-38.98	11.93	6.71	
	F4	-127.87	-4.43	22.00	-38.98	-1.35	6.71	
	F5	-151.12	-4.43	22.00	-46.06	-1.35	6.71	
New Baghouse Structure	G1	-80.76	168.12	63.00	-24.62	51.24	19.20	
	G2	-80.76	204.76	63.00	-24.62	62.41	19.20	
	G3	-53.75	204.76	63.00	-16.38	62.41	19.20	
	G4	-53.75	168.12	63.00	-16.38	51.24	19.20	
	G5	-80.76	168.12	63.00	-24.62	51.24	19.20	
Cooling Tower Structure	H1	-233.86	-46.48	28.00	-71.28	-14.17	8.53	
	H2	-233.86	-22.48	28.00	-71.28	-6.85	8.53	
	H3	-191.86	-22.48	28.00	-58.48	-6.85	8.53	
	H4	-191.86	-46.48	28.00	-58.48	-14.17	8.53	
	H5	-233.86	-46.48	28.00	-71.28	-14.17	8.53	
Existing Nearby Bldg #1	I1	-237.56	222.84	40.00	-72.41	67.92	12.19	
	I2	-237.56	323.23	40.00	-72.41	98.52	12.19	
	I3	-191.52	323.23	40.00	-58.37	98.52	12.19	
	I4	-191.52	222.84	40.00	-58.37	67.92	12.19	
	I5	-237.56	222.84	40.00	-72.41	67.92	12.19	
Existing Nearby Bldg #2	J1	-230.95	62.16	40.00	-70.39	18.95	12.19	
	J2	-230.95	93.06	40.00	-70.39	28.37	12.19	
	J3	-196.64	93.06	40.00	-59.94	28.37	12.19	
	J4	-196.64	62.16	40.00	-59.94	18.95	12.19	
	J5	-230.95	62.16	40.00	-70.39	18.95	12.19	
Gunther C. Meyland Hall (NE Section of Quad 2)	K1	-242.84	-412.65	120.00	-74.02	-125.78	36.58	
	K2	-242.84	-250.26	120.00	-74.02	-76.28	36.58	
	K3	-198.80	-250.26	120.00	-60.59	-76.28	36.58	
	K4	-198.80	-368.41	120.00	-60.59	-112.29	36.58	
	K5	-75.38	-368.41	120.00	-22.98	-112.29	36.58	
	K6	-75.38	-250.26	120.00	-22.98	-76.28	36.58	
	K7	-30.78	-250.26	120.00	-9.38	-76.28	36.58	
	K8	-30.78	-412.65	120.00	-9.38	-125.78	36.58	
	K9	-242.84	-412.65	120.00	-74.02	-125.78	36.58	
Circular Strutures	Center I.D.	Coordinates (feet)		Height (feet)	Coordinates (meters)		Diameter (meters)	Height (meters)
		X (E)	Y (N)	(feet)	X (E)	Y (N)	(meters)	(meters)
New Ash Silo	O1	-30.54	221.91	81.00	-9.31	67.84	6.10	24.69
	P1	-138.44	97.43	80.00	-42.19	29.70	10.65	24.38
Stacks	I.D.	Coordinates (feet)		Height (feet)	Coordinates (meters)		Diameter (meters)	Height (meters)
		X (E)	Y (N)	(feet)	X (E)	Y (N)	(meters)	(meters)
	NewBHSIck	-67.25	250.08	165.00	-20.50	76.22	1.83	50.29
New Baghouse Stack	ExistSIck	-19.02	51.28	150.00	-5.80	15.63	1.52	45.72



**Existing Facility, New
Structures, and Stack Coordinates**

(UTM Coordinates)

Northern Michigan University - Modeling Analysis Layout for Proposed Boiler Project

Coordinate System Layout for Northern Michigan University Located in Marquette, MI

The Southwest Corner of the Ripley Heating Plant Bldg Equals UTM Coordinate (468,874 E; 5,156,608 N)


Building	Corner I.D.	Coordinates (meters)		Height (feet)	UTM Coordinates (meters)		Elevation (meters)
		X (E)	Y (N)		Eastng	Northing	
Ripley Heating Plant	A1	0.00	0.00	79.00	468874.00	5156608.00	195.38
	A2	0.00	31.37	79.00	468874.00	5156639.37	195.38
	A3	20.40	31.37	79.00	468894.40	5156639.37	195.38
	A4	20.40	0.00	79.00	468894.40	5156608.00	195.38
	A5	0.00	0.00	79.00	468874.00	5156608.00	195.38
New Boiler Main Building	B1	-30.95	13.05	110.00	468843.05	5156621.05	195.38
	B2	-30.95	46.67	110.00	468843.05	5156654.67	195.38
	B3	-11.14	46.67	110.00	468862.86	5156654.67	195.38
	B4	-11.14	13.05	110.00	468862.86	5156621.05	195.38
	B5	-30.95	13.05	110.00	468843.05	5156621.05	195.38
New Steam Turbine Bldg	C1	-30.95	-1.28	30.00	468843.05	5156606.72	195.38
	C2	-30.95	13.05	30.00	468843.05	5156621.05	195.38
	C3	-11.14	13.05	30.00	468862.86	5156621.05	195.38
	C4	-11.14	-1.28	30.00	468862.86	5156606.72	195.38
	C5	-30.95	-1.28	30.00	468843.05	5156606.72	195.38
New Control Room	D1	-11.14	0.00	30.00	468862.86	5156608.00	195.38
	D2	-11.14	11.93	30.00	468862.86	5156619.93	195.38
	D3	0.00	11.93	30.00	468874.00	5156619.93	195.38
	D4	0.00	0.00	30.00	468874.00	5156608.00	195.38
	D5	-11.14	0.00	30.00	468862.86	5156608.00	195.38
Coal Containment Structure	E1	-44.49	50.90	8.00	468829.51	5156658.90	195.38
	E2	-44.49	51.51	8.00	468829.51	5156659.51	195.38
	E3	-27.52	51.51	8.00	468846.48	5156659.51	195.38
	E4	-27.52	69.80	8.00	468846.48	5156677.80	195.38
	E5	-44.49	69.80	8.00	468829.51	5156677.80	195.38
	E6	-44.49	70.41	8.00	468829.51	5156678.41	195.38
	E7	-26.91	70.41	8.00	468847.09	5156678.41	195.38
	E8	-26.91	50.90	8.00	468847.09	5156658.90	195.38
	E9	-44.49	50.90	8.00	468829.51	5156658.90	195.38
Wood Handling Building	F1	-46.06	-1.35	22.00	468827.94	5156606.65	195.38
	F2	-46.06	11.93	22.00	468827.94	5156619.93	195.38
	F3	-38.98	11.93	22.00	468835.02	5156619.93	195.38
	F4	-38.98	-1.35	22.00	468835.02	5156606.65	195.38
	F5	-46.06	-1.35	22.00	468827.94	5156606.65	195.38
New Baghouse Structure	G1	-24.62	51.24	63.00	468849.38	5156659.24	195.38
	G2	-24.62	62.41	63.00	468849.38	5156670.41	195.38
	G3	-16.38	62.41	63.00	468857.62	5156670.41	195.38
	G4	-16.38	51.24	63.00	468857.62	5156659.24	195.38
	G5	-24.62	51.24	63.00	468849.38	5156659.24	195.38
Cooling Tower Structure	H1	-71.28	-14.17	28.00	468802.72	5156593.83	195.38
	H2	-71.28	-6.85	28.00	468802.72	5156601.15	195.38
	H3	-58.48	-6.85	28.00	468815.52	5156601.15	195.38
	H4	-58.48	-14.17	28.00	468815.52	5156593.83	195.38
	H5	-71.28	-14.17	28.00	468802.72	5156593.83	195.38
Existing Nearby Bldg #1	I1	-72.41	67.92	40.00	468801.59	5156675.92	196.90
	I2	-72.41	98.52	40.00	468801.59	5156706.52	196.90
	I3	-58.37	98.52	40.00	468815.63	5156706.52	196.90
	I4	-58.37	67.92	40.00	468815.63	5156675.92	196.90
	I5	-72.41	67.92	40.00	468801.59	5156675.92	196.90
Existing Nearby Bldg #2	J1	-70.39	18.95	40.00	468803.61	5156626.95	195.38
	J2	-70.39	28.37	40.00	468803.61	5156636.37	195.38
	J3	-59.94	28.37	40.00	468814.06	5156636.37	195.38
	J4	-59.94	18.95	40.00	468814.06	5156626.95	195.38
	J5	-70.39	18.95	40.00	468803.61	5156626.95	195.38
Gunther C. Meyland Hall (NE Section of Quad 2)	K1	-74.02	-125.78	120.00	468799.98	5156482.22	195.38
	K2	-74.02	-76.28	120.00	468799.98	5156531.72	195.38
	K3	-60.59	-76.28	120.00	468813.41	5156531.72	195.38
	K4	-60.59	-112.29	120.00	468813.41	5156495.71	195.38
	K5	-22.98	-112.29	120.00	468851.02	5156495.71	195.38
	K6	-22.98	-76.28	120.00	468851.02	5156531.72	195.38
	K7	-9.38	-76.28	120.00	468864.62	5156531.72	195.38
	K8	-9.38	-125.78	120.00	468864.62	5156482.22	195.38
	K9	-74.02	-125.78	120.00	468799.98	5156482.22	195.38

Northern Michigan University - Modeling Analysis Layout for Proposed Boiler Project

Coordinate System Layout for Northern Michigan University Located in Marquette, MI

The Southwest Corner of the Ripley Heating Plant Bldg Equals UTM Coordinate (468,874 E; 5,156,608 N)

Building	Corner I.D.	Coordinates (meters)		Height (feet)	UTM Coordinates (meters)		Elevation (meters)
		X (E)	Y (N)		Easting	Northing	
Circular Strutures	Center I.D.	Coordinates (feet)		Height	UTM Coordinates (meters)		Diameter
		X (E)	Y (N)	(feet)	UTM Easting	UTM Northing	(meters)
New Ash Silo	O1	-9.31	67.64	81.00	468864.69	5156675.64	6.10
Wood Silo	P1	-42.19	29.70	80.00	468831.81	5156637.70	10.65
							24.38
Stacks	I.D.	Coordinates (feet)		Height	UTM Coordinates (meters)		Diameter
		X (E)	Y (N)	(feet)	UTM Easting	UTM Northing	(meters)
New Baghouse Stack	NewBHStk	-20.50	76.22	165.00	468853.50	5156684.22	1.83
Existing Boiler Stack	ExistStk	-5.80	15.63	150.00	468868.20	5156623.63	1.52
							50.29
							45.72


160' 



Receptor Grid Layout Diagrams

PROJECT TITLE:


**Northern Michigan University - Powerhouse Modification PTI
Receptor Grid Layout**



COMMENTS: NMU Receptor Grid Layout: Inner Grid: 1 km x 1 km 50-m spacing Middle Grid: 3 km x 3 km 100-m spacing Outer Grid: 5 km x 5 km 250-m spacing	SOURCES: 2	COMPANY NAME: NTH Consultants, Ltd
	RECEPTORS: 7537	MODELER: Edward Bishop, Asst Project Engineer
		SCALE: 1:69,000 0 2 km
		DATE: 1/25/2007 PROJECT NO.: 16-060504

PROJECT TITLE:

Northern Michigan University - Powerhouse Modification PTI
Receptor Grid Layout - Zoomed



COMMENTS:	SOURCES:	COMPANY NAME:
NMU Receptor Grid Layout: Inner Grid: 1 km x 1 km 50-m spacing Middle Grid: 3 km x 3 km 100-m spacing	2	NTH Consultants, Ltd
	RECEPTORS:	MODELER:
	7537	Edward Bishop, Asst Project Engineer
	SCALE:	1:25,000 0 0.5 km
	DATE:	PROJECT NO.:
	1/25/2007	16-060504



Existing Source Emission Rates

Pre Permit 126-05 Emission Estimates

NMU Boiler Project - Existing Source Emission Rates

	Basis:			
	1,020 Btu/scf nat gas Btu/gallon fuel oil			
Year	Nat Gas (MM scf)	Fuel Oil (gal)	Heat Input: Nat Gas (MM Btu)	Total Fuel Oil (MM Btu)
2000	368,057	1313	362,118	177,3
2001	363,933	363	371,212	49,0
2002	401,341	0	409,368	0,0
2003	377,819	22471	385,375	3033,6
2004	384,185	25836	391869	3496,0
				395,365

Past Actual - Estimated Annual Emissions

Pollutant	Tons/Year			
	NOx	CO	PM	SO2
2000	17.92	15.04	1.36	0.16
2001	18.20	15.29	1.38	0.12
2002	20.07	16.86	1.53	0.12
2003	19.12	15.92	1.48	0.93
2004	19.47	16.20	1.51	1.06
Maximum	20.07	16.86	1.53	1.10

lb/hour 4.582 3.848 0.348 0.242 0.252 annual average lb/hour

Permit 126-05 Equipment - Potential Emissions (Based on Two Boilers @ Rated Capacities)

2 Boilers Capacity (MM Btu/hr)	Annual Operation With Fuel Type			
	Nat Gas	Fuel Oil	Nat Gas (lb/mm Btu)	Fuel Oil (lb/mm Btu)
Nat Gas	167.2	0.1639	1,057.14	6449.1
Fuel Oil	159.6	0.1639	1,182.22	2,732,040
				2310.9

Pollutant	Potential Emissions (Tons/Year)			
	NOx	CO	PM	SO2
Nat Gas	26.43	4.02	0.32	2.91
Fuel Oil	18.44	25.77	5.53	0.37
Maximum	n/a	n/a	n/a	n/a
Totals	44.87	73.17	9.85	3.28

Oil Only (max hourly) Limited Oil Use (annual ave hourly)	Low NOx/AP42 Factors			
	NOx	CO	PM	VOC
Nat Gas	8.186	13,759	1,246	0.098
Fuel Oil	15,060	24,898	4,788	0.902
Maximum	10,244	16,705	2,180	0.319
Totals	44.87	73.17	9.85	3.28

Oil Only (max hourly) Limited Oil Use (annual ave hourly)	Wt% Sulfur in Fuel Oil			
	NOx	CO	PM	SO2
PSD Increment	0.714		0.559	10,829
NAAQS	1.291	3.137	0.603	10,859
Emission rates above given in units of gram/second				

Modeled Emission Rates for Existing Boilers (based on two operating at maximum capacity)

	NOx	CO	PM	SO2
PSD Increment	0.714		0.559	10,829
NAAQS	1.291	3.137	0.603	10,859



Summary of TAC Analysis Results



Background Concentrations

BACKGROUND (AUG 21 06)

BACKGROUND CONCENTRATIONS

CITY	ADDRESS	TYPE	YEAR	Distance	3-HR	24-HR	ANNUAL
SO2 Escanaba	County Road 414	Rural	2003	65.3 km	45.2	13.3	2.7
SO2 Escanaba	County Road 414	Rural	2004	65.3 km	34.6	10.6	2.7
SO2	Seney Nat'l Wildlife Refuge, Hcr2,	Rural	2005	158.5 km	29.3	13.3	2.7

CITY	ADDRESS	TYPE	YEAR	Distance	3-HR	24-HR	ANNUAL
NO2 Two Rivers	Harrington Beach State Park, 531 Hwy Rural	2003	225.4 km	11.5	—	—	—
NO2 Two Rivers	Manitowoc/Woodlnd Dunes, 2315 Goodw Rural	2004	176.5 km	5.7	—	—	—
NO2 Two Rivers	Manitowoc/Woodlnd Dunes, 2315 Goodw Rural	2005	176.5 km	5.7	—	—	—

CITY	ADDRESS	TYPE	YEAR	Distance	3-HR	24-HR	ANNUAL
PWLD Green Bay	Brangeway, 1300 N Quincy Street	Urban	2003	160.8 km	—	—	19.0
PWLD Green Bay	Brangeway, 1300 N Quincy Street	Urban	2004	160.8 km	—	—	15.0
PWLD Green Bay	Brangeway, 1300 N Quincy Street	Urban	2005	160.8 km	—	—	22.0

CITY	ADDRESS	TYPE	YEAR	Distance	3-HR	24-HR	ANNUAL
CO Milwaukee	Dnr Ser Hdgrts, 2300 N W. L. King J Urban	2003	258.5 km	440.8	301.6	—	—
CO Milwaukee	Dnr Ser Hdgrts, 2300 N W. L. King J Urban	2004	258.5 km	452.4	348.0	—	—
CO	Seney Nat'l Wildlife Refuge, Hcr2, Rural	2005	158.5 km	81.2	46.4	—	—

CITY	ADDRESS	TYPE	YEAR	Distance	3-HR	24-HR	ANNUAL
Pb Milwaukee	Health Center, 1337 So 16th St	Urban	2003	262.1 km	0.03	—	—
Pb	Mayville, Near N6705 Madison Rd	Rural	2004	256.2 km	0.01	—	—
Pb	1769 S Jeffs Rd	Rural	2005	316.5 km	0.01	—	—

CITY	ADDRESS	TYPE	YEAR	Distance	3-HR	24-HR	ANNUAL
Pb Milwaukee	Health Center, 1337 So 16th St	Urban	2003	262.1 km	0.03	—	—
Pb	Mayville, Near N6705 Madison Rd	Rural	2004	256.2 km	0.01	—	—
Pb	1769 S Jeffs Rd	Rural	2005	316.5 km	0.01	—	—

0.03



APPENDIX D

RACT/BACT/LAER Clearinghouse Results

Northern Michigan University
RBLC

NBLCID	FACILITY NAME	STATE	PERMIT NO.	PERMIT DATE	DESCRIPTION	PROCESS NAME	FUEL	THROUGHPUT	UNIT	PROCESS NOTES		POLLUTANT	EMIS LIMIT	UNIT	AVG TIME	BASIS
MN-0058	VIRGINIA DEPARTMENT OF PUBLIC UTILITIES	MN	13700028-005	6/30/2005		BOILER, WOOD FIRED	WOOD	230	mmbtuh			Particulate Matter (PM)	0.025	LB/MMBTU	3-HR TEST	BACT+PSD
MN-0068	VIRGINIA DEPARTMENT OF PUBLIC UTILITIES	MN	13700028-005	6/30/2005		BOILER, WOOD FIRED	WOOD	230	mmbtuh			Particulate Matter < 10 μ (PM10)	0.025	LB/MMBTU	3-HR TEST	BACT+PSD
MN-0058	VIRGINIA DEPARTMENT OF PUBLIC UTILITIES	MN	13700028-005	6/30/2005	WOOD FIRED BOILER, 230 MMBTU/H HEAT INPUT, SPREADER STOKER	BOILER, WOOD FIRED	WOOD	230	mmbtuh			Carbon Monoxide	0.3	LB/MMBTU	4-HOUR BLOCK AVERAGE	BACT+PSD
MN-0058	VIRGINIA DEPARTMENT OF PUBLIC UTILITIES	MN	13700028-005	6/30/2005	230 MMBTU/H HEAT INPUT, SPREADER STOKER	BOILER, WOOD FIRED	WOOD	230	mmbtuh			Nitrogen Oxides (NOx)	0.15	LB/MMBTU	30 DAY AVERAGE	BACT+PSD
MN-0059	HIBBING PUBLIC UTILITIES	MN	13700027-003	6/30/2005		BOILER, WOOD FIRED	WOOD	230	mmbtuh			Particulate Matter < 10 μ (PM10)	0.026	LB/MMBTU	3-HR TEST	BACT+PSD
MN-0059	HIBBING PUBLIC UTILITIES	MN	13700027-003	6/30/2005		BOILER, WOOD FIRED	WOOD	230	mmbtuh			Carbon Monoxide	0.3	LB/MMBTU	4-HOUR BLOCK AVERAGE	BACT+PSD
MN-0059	HIBBING PUBLIC UTILITIES	MN	13700027-003	6/30/2005		BOILER, WOOD FIRED	WOOD	230	mmbtuh			Nitrogen Oxides (NOx)	0.15	LB/MMBTU	30-DAY ROLLING AVERAGE	BACT+PSD
MN-0059	HIBBING PUBLIC UTILITIES	MN	13700027-003	6/30/2005		BOILER, WOOD FIRED	WOOD	230	mmbtuh			Particulate Matter (PM)	0.026	LB/MMBTU	3-HR TEST	BACT+PSD
MN-0059	HIBBING PUBLIC UTILITIES	MN	13700027-003	6/30/2005		BOILER, WOOD FIRED	WOOD	230	mmbtuh			Carbon Monoxide	0.3	LB/MMBTU	4-HOUR BLOCK AVERAGE	BACT+PSD
MN-0059	HIBBING PUBLIC UTILITIES	MN	13700027-003	6/30/2005		BOILER, WOOD FIRED	WOOD	230	mmbtuh			Nitrogen Oxides (NOx)	0.15	LB/MMBTU	30-DAY ROLLING AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		BOILER, COAL-FIRED	LIGNITE	250	MMBTU/H			Particulate Matter < 10 μ (PM10)	0.022	LB/MMBTU	3-HOUR AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		BOILER, COAL-FIRED	LIGNITE	250	MMBTU/H			Sulfur Oxides (SOx)	0.09	LB/MMBTU	30 DAY ROLLING AVG.	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		BOILER, COAL-FIRED	LIGNITE	250	MMBTU/H			Nitrogen Oxides (NOx)	0.1	LB/MMBTU	30 DAY ROLLING AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		BOILER, COAL-FIRED	LIGNITE	250	MMBTU/H			Carbon Monoxide	0.11	LB/MMBTU	3-HOUR ROLLING AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004	ETHANOL PRODUCTION PLANT RATED AT 65 MILLION GALLONS PER YEAR.	BOILER, COAL-FIRED	LIGNITE	250	MMBTU/H			Particulate Matter (PM)	0.048	LB/MMBTU	3 HOUR AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		BOILER, COAL-FIRED	LIGNITE	250	MMBTU/H			Particulate Matter < 10 μ (PM10)	0.004	GRDSDF	3 HOUR AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		DIGS COOLING		22	T/H			Particulate Matter < 10 μ (PM10)	0.004	GRDSDF	3 HOUR AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		GRAIN RECEIVING		420	T/H			Particulate Matter < 10 μ (PM10)	0.004	GRDSDF	3 HOUR AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		HAMMERMILLING		76	T/H			Particulate Matter < 10 μ (PM10)	0.004	GRDSDF	3 HOUR AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		DOGS LOADOUT		420	T/H			Particulate Matter < 10 μ (PM10)	0.004	GRDSDF	3 HOUR AVERAGE	BACT+PSD
ND-0020	RICHARDTON PLANT	ND	4004	8/4/2004		COAL HANDLING		27	T/H			Particulate Matter < 10 μ (PM10)	0.004	GRDSDF	3 HOUR AVERAGE	BACT+PSD

Northern Michigan University
RBL/C

RBL/CID	FACILITY NAME	STATE	PERMIT No.	PERMIT DATE	DESCRIPTION	PROCESS NAME	FUEL	THROUGHPUT	UNIT	PROCESS NOTES	POLLUTANT	EMIS. LIMIT	UNIT	Avg TIME	Basis
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), COAL FIRED	COAL	238	MMBTU/H		Nitrogen Oxides (NOx)	0.7	LB/MMBTU		BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), COAL FIRED	COAL	238	MMBTU/H		Carbon Monoxide	5.2	LB/H	EACH BOILER	BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), COAL FIRED	COAL	238	MMBTU/H		Sulfur Dioxide (SO2)	1.6	LB/MMBTU		BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), COAL FIRED	COAL	238	MMBTU/H		Particulate Matter < 10 μ (PM10)	0.01	GR/ACF		BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004	THIS FACILITY BREWS AND PACKAGES BEER. EACH BOILER NOT TO EXCEED 160,000 LB STEAM/H OR 288 MMBTU/H. BOTH BOILERS TOGETHER NOT TO EXCEED 125,682 TONS COAL/ROLLING 12-MONTHS. THIS PTI, 14-05816, IS A MODIFICATION TO PTI 11/16/01 FOR THE ADDITION OF AN 8.5 MW STEAM TURBINE GENERATOR TO AN EXISTING COAL FIRED BOILER (THERE WERE NO CHANGES MADE TO THE EXISTING COAL FIRED BOILER). THIS MODIFICATION WAS TO INCREASE THE HCL HOURLY AND SO2/MMBTU LIMIT. THE TYP FACILITYWIDE LIMITS HAVE NOT CHANGED, EXCEPT FOR HCL WHICH HAS INCREASED BY 46.1 TWR IN THIS NEW PERMIT.	BOILER (2), NO. 6 FUEL OIL	NO. 6 FUEL OIL	238	MMBTU/H		Carbon Monoxide	8.15	LB/H	EACH BOILER	BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NO. 6 FUEL OIL	NO. 6 FUEL OIL	238	MMBTU/H		Sulfur Dioxide (SO2)	1.6	LB/MMBTU		BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NO. 6 FUEL OIL	NO. 6 FUEL OIL	238	MMBTU/H		Particulate Matter < 10 μ (PM10)	0.01	GR/ACF		BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NO. 2 FUEL OIL	NO. 2 FUEL OIL	238	MMBTU/H		Nitrogen Oxides (NOx)	0.7	LB/MMBTU		BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NO. 2 FUEL OIL	NO. 2 FUEL OIL	238	MMBTU/H		Volatile Organic Compounds (VOC)	0.38	LB/H	EACH BOILER	BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NO. 2 FUEL OIL	NO. 2 FUEL OIL	238	MMBTU/H		Carbon Monoxide	8.6	LB/H	EACH BOILER	BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NO. 2 FUEL OIL	NO. 2 FUEL OIL	238	MMBTU/H		Sulfur Dioxide (SO2)	1.6	LB/MMBTU		BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NATURAL GAS	NATURAL GAS	238	MMBTU/H		Particulate Matter < 10 μ (PM10)	0.01	GR/ACF		BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NATURAL GAS	NATURAL GAS	238	MMBTU/H		Nitrogen Oxides (NOx)	0.7	LB/MMBTU		BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NATURAL GAS	NATURAL GAS	238	MMBTU/H		Carbon Monoxide	20	LB/H	EACH BOILER	BACT+PSD
OH-0241	MILLER BREWING COMPANY - TRENTON	OH	14-05515	5/27/2004		BOILER (2), NATURAL GAS	NATURAL GAS	238	MMBTU/H		Sulfur Dioxide (SO2)	1.6	LB/MMBTU		BACT+PSD

Northern Michigan University
RBLIC

PRCLID	FACILITY NAME	STATE	PERMIT No.	PERMIT DATE	DESCRIPTION	PROCESS NAME	FUEL	THROUGHPUT	UNIT	PROCESS NOTES	POLLUTANT	EMIS. UNIT	UNIT	Avg Time	Basis
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		WOOD FIRED BOILERS (7)	WOOD	775	MMBTU/H		Particulate Matter < 10 μ (PM10)	3.57	LB/H		BACT+PSD
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		WOOD FIRED BOILERS (7)	WOOD	775	MMBTU/H		Nitrogen Oxides (NOx)	27.38	LB/H		N/A
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		WOOD FIRED BOILERS (7)	WOOD	775	MMBTU/H		Carbon Monoxide	31.8	LB/H		BACT+PSD
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		WOOD FIRED BOILERS (7)	WOOD	775	MMBTU/H		Sulfur Dioxide (SO2)	22.13	LB/H		N/A
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		WOOD FIRED BOILERS (7)	WOOD	775	MMBTU/H		Particulate Matter < 10 μ (PM10)	6.71	LB/H		BACT+PSD
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		WOOD HANDLING SYSTEM		130495	ACFM		Nitrogen Oxides (NOx)	43.13	LB/H	ON FUEL OIL	N/A
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		AUXILIARY BOILER	FUEL OIL #2	227	MMBTU/H		Carbon Monoxide	27.24	LBT/H	WITH FUEL OIL	BACT+PSD
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		AUXILIARY BOILER	FUEL OIL #2	227	MMBTU/H	Oxidation catalyst, selective catalytic reduction, sodium bicarbonate injection, sodium revenue air baghouse w/99% control.	Particulate Matter < 10 μ (PM10)	9.08	LBT/H	WITH FUEL OIL	BACT+PSD
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004	SEVEN BOILERS PURCHASED FROM AN ETHANOL PLANT REBUILDING TO BURN WOOD AND TO GENERATE POWER, USING WOOD WASTE	AUXILIARY BOILER	FUEL OIL #2	227	MMBTU/H		Sulfur Dioxide (SO2)	2.84	LBT/H	FOR FUEL OIL	N/A
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		AUXILIARY BOILER	FUEL OIL #2	227	MMBTU/H		Nitrogen Oxides (NOx)	14.82	LBT/H	WITH NATURAL GAS	N/A
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		AUXILIARY BOILER	NATURAL GAS	247	MMBTU/H		Carbon Monoxide	27.17	LBT/H	WITH NATURAL GAS	BACT+PSD
*OH-0269	BIO MASS ENERGY, LLC-SOUTH POINT POWER	OH	07-00534	1/5/2004		AUXILIARY BOILER	NATURAL GAS	247	MMBTU/H		Particulate Matter < 10 μ (PM10)	1.73	LBT/H	WITH NATURAL GAS	BACT+PSD

Northern Michigan University
RBLC

RBLCID	FACILITY NAME	STATE	PERMIT No.	PERMIT DATE	DESCRIPTION	PROCESS NAME	FUEL	THROUGHPUT	UNIT	PROCESS NOTES	POLLUTANT	EMIS. UNIT	UNIT	Avg TIME	Basis
*OH-0268	BIO MASS ENERGY, LLC-SOUTH POWER	OH	07-00534	1/15/2004		AUXILIARY BOILER	NATURAL GAS	247	MMBTU/H		Sulfur Dioxide (SO2)	0.15	LB/H	WITH NATURAL GAS	N/A
LA-0126	JOYCE MILL	LA	PSD-LA-679	4/24/2002	JOYCE MILL PRODUCES LUMBER AND WOOD WASTES, SUCH AS WOOD CHIPS, SHAVINGS, SAWDUST AND BARK. THE WOOD WASTE IS USED FOR FUEL IN THE BOILERS TO PRODUCE STEAM FOR THE MILL.	KIPPER BOILERS NO.1 AND NO.2 (EACH)	WOOD WASTE	88.3	MMBTU/H EACH	EMISSION POINTS 74A (NO.1) AND 74B (NO.2)	Carbon Monoxide	105.5	LB/H	EACH	Other Case-by-Case
LA-0126	JOYCE MILL	LA	PSD-LA-679	4/24/2002		MCBURNEY BOILER NO.4	WOOD WASTE	154.2	MMBTU/H	EMISSION POINT 75A.	Carbon Monoxide	279.1	LB/H		Other Case-by-Case
VA-0268	THERMAL VENTURES	VA	30529	2/15/2002		BOILER, STEAM	WOOD	120	MMBTU/H		Particulate Matter (PM)	0.15	LB/MMBTU		Other Case-by-Case
VA-0268	THERMAL VENTURES	VA	30529	2/15/2002		BOILER, STEAM	WOOD	120	MMBTU/H	Wood limit 70% Mixture, Wood/char, excluding any wood which contains chemical treatments or has derived thermal paint and/or finishing materials or paper or plastic laminates; Average annual heat content: 5,000 Btu/lb HHV	Particulate Matter < 10 μ (PM10)	0.14	LB/MMBTU		Other Case-by-Case
VA-0268	THERMAL VENTURES	VA	30529	2/15/2002		BOILER, STEAM	WOOD	120	MMBTU/H		Sulfur Dioxide (SO2)	0.47	LB/MMBTU		Other Case-by-Case
VA-0268	THERMAL VENTURES	VA	30529	2/15/2002	STEAM PRODUCTION FACILITY	BOILER, STEAM	WOOD	120	MMBTU/H		Nitrogen Dioxide (NO2)	0.4	LB/MMBTU		Other Case-by-Case
VA-0268	THERMAL VENTURES	VA	30529	2/15/2002		BOILER, STEAM	WOOD	120	MMBTU/H		Carbon Monoxide	0.44	LB/MMBTU		Other Case-by-Case
VA-0268	THERMAL VENTURES	VA	30529	2/15/2002		BOILER, STEAM	COAL	120	MMBTU/H	In order to meet the annual emission limitations included in this permit, the wood/coal mixture shall not exceed 30% coal by BTU content on an annual basis.	Particulate Matter (PM)	0.15	LB/MMBTU		Other Case-by-Case

Northern Michigan University
RBL C

REFID	FACILITY NAME	STATE	PERMIT No.	PERMIT DATE	DESCRIPTION	PROCESS NAME	FUEL	THROUGHPUT	UNIT	PROCESS NOTES	POLLUTANT	EMIS LIMIT	UNIT	AVG TIME	BASIS
VA-0268	THERMAL VENTURES	VA	30529	2/15/2002		BOILER, STEAM	COAL	120	MMBTU/H	Average annual heat content 13,000 Btu/lb HHV. Average sulfur content per shipment 0.3% and average ash content per shipment 7%.	Particulate Matter < 10 μ (PM10)	0.14	LB/MMBTU		Other Case-by-Case
VA-0268	THERMAL VENTURES	VA	30529	2/15/2002		BOILER, STEAM	COAL	120	MMBTU/H	In order to meet the annual emission limitations included in this permit, the woody/coal mixture shall not exceed 30% coal by BTU content on an annual basis. Average annual heat content 13,000 Btu/lb HHV. Average sulfur content per shipment 0.3% and average ash content per shipment 7%.	Sulfur Dioxide (SO2) 0.47		MMBTU		Other Case-by-Case
VA-0268	THERMAL VENTURES	VA	30529	2/15/2002	STEAM PRODUCTION FACILITY	BOILER, STEAM	COAL	120	MMBTU/H	Average annual heat content 13,000 Btu/lb HHV. Average sulfur content per shipment 0.3% and average ash content per shipment 7%.	Nitrogen Oxides (NOx)	0.4	MMBTU		Other Case-by-Case
VA-0268	THERMAL VENTURES	VA	30529	2/16/2002		BOILER, STEAM	COAL	120	MMBTU/H		Carbon Monoxide	0.44	MMBTU		Other Case-by-Case
LA-0126	WILLAMETTE INDUSTRIES, INC.	LA	PSD-LA-627 (M-1)	1/7/2002	WILLAMETTE INDUSTRIES REQUESTED A PSD MODIFICATION TO INSTALL A REGENERATIVE THERMAL OXIDIZER OR CATALYTIC OXIDIZER (RTO/RCO). REMOVE THE PRODUCTION LIMIT IMPOSED BY PART 70 OPERATING PERMIT NO. 32404-00010-02, AND MODERNIZE THE PLYWOOD MANUFACTURING PROCESS AT THE DODSON DIVISION.	WOOD FIRED BOILER	WOOD	233	MMBTU/H	EIO NO. 017. NO PHYSICAL MODIFICATION TO THE BOILERS WILL BE NEEDED (FIRING RATES WILL BE INCREASED) SO BACT IS NOT REQUIRED FOR EMISSIONS FROM BOILERS.	Nitrogen Oxides (NOx)	47.91	LB/H		Other Case-by-Case
LA-0125	WILLAMETTE INDUSTRIES, INC.	LA	PSD-LA-627 (M-1)	1/7/2002		VENNER DRYER	NATURAL GAS				Carbon Monoxide	191.68	LB/H		Other Case-by-Case
LA-0125	WILLAMETTE INDUSTRIES, INC.	LA	PSD-LA-627 (M-1)	1/7/2002		NO.1 COOLING ZONE	NATURAL GAS			EIO NO. 028. SCC FOR GAS VENEER DRYER, PINES, NO THROUGHPUT GIVEN.	Nitrogen Oxides (NOx)	0.37	LB/H		BACT+PSD
LA-0125	WILLAMETTE INDUSTRIES, INC.	LA	PSD-LA-627 (M-1)	1/7/2002		VENNER DRYER	NATURAL GAS			EIO NO. 029. SCC FOR GAS VENEER DRYER, PINES, NO THROUGHPUT GIVEN.	Carbon Monoxide	0.09	LB/H		BACT+PSD
LA-0125	WILLAMETTE INDUSTRIES, INC.	LA	PSD-LA-627 (M-1)	1/7/2002		NO.1 COOLING ZONE	NATURAL GAS			EIO NO. 029. SCC FOR GAS VENEER DRYER, PINES, NO THROUGHPUT GIVEN.	Nitrogen Oxides (NOx)	0.39	LB/H		BACT+PSD
LA-0125	WILLAMETTE INDUSTRIES, INC.	LA	PSD-LA-627 (M-1)	1/7/2002		VENNER DRYER	NATURAL GAS			Emissions	Carbon Monoxide	0.22	LB/H		BACT+PSD
LA-0125	WILLAMETTE INDUSTRIES, INC.	LA	PSD-LA-627 (M-1)	1/7/2002		NO.2 COOLING ZONE	NATURAL GAS			Information in the permit is organized under the Regeneratorative Thermal Oxidizer Cap	Nitrogen Oxides (NOx)	10.27	LB/H		BACT+PSD
LA-0126	WILLAMETTE INDUSTRIES, INC.	LA	PSD-LA-627 (M-1)	1/7/2002		VENNER DRYER	NATURAL GAS				Carbon Monoxide	9.31	LB/H		BACT+PSD

Northern Michigan University
RBLIC

BBLCID	FACILITY NAME	STATE	PERMIT NO.	PERMIT DATE	DESCRIPTION	PROCESS NAME	FUEL	THROUGHPUT	UNIT	PROCESS NOTES	POLLUTANT	Emissions Limit	UNIT	Avg Time	Basis
VA-0267	VPI POWER STATION	VA	20124	8/31/2001		BOILER, OVERFEED STOKER	COAL	146.7	MMBTU/H		Particulate Matter < 10 μ (PM10)	2.9	LB/H		BACT-PSD
VA-0267	VPI POWER STATION	VA	20124	8/30/2001	Steam generation for electricity.	BOILER, OVERFEED STOKER	COAL	146.7	MMBTU/H		Sulfur Dioxide (SO2)	23.6	LB/H		BACT-PSD
VA-0267	VPI POWER STATION	VA	20124	8/30/2001		BOILER, OVERFEED STOKER	COAL	146.7	MMBTU/H	No. 11 boiler. Boiler produces steam for generation of electricity.	Nitrogen Dioxide (NO2)	36.1	LB/H		BACT-PSD
VA-0267	VPI POWER STATION	VA	20124	8/30/2001		BOILER, OVERFEED STOKER	COAL	146.7	MMBTU/H		Carbon Monoxide	33.2	LB/H		BACT-PSD
VA-0267	VPI POWER STATION	VA	20124	8/30/2001		BOILER, OVERFEED STOKER	COAL	146.7	MMBTU/H		Particulate Matter (PM)	2.9	LB/H		BACT-PSD
AR-0045	COLUMBIAN CHEMICALS • EL DORADO	AR	906-AOP-R1 (70-0014)	8/9/2001	This plant makes carbon black using the oil furnace process. This determination is modification. Emission increases of SO2 and NOx will exceed the PSD significance levels. Increases of PM10 emissions are less than the PSD threshold. Other pollutants' proposed emissions are lower than the past actual emissions because of the addition of new control equipment.	COAL-FIRED BOILERS (2)	SUB-BITUMINOUS COAL	8700	MMBTU/H FOR EACH		Carbon Monoxide	100	PPM	24 hr. average	Other Cause-by-Case
AR-0045	COLUMBIAN CHEMICALS • EL DORADO	AR	906-AOP-R1 (70-0014)	8/9/2001	Carbon Disulfide 87.76 Carbonyl Sulfide 13.46 Hydrogen 117.76 TRS 219.04	CARBON BLACK MFG. UNIT D STACK & VENT	NATURAL GAS				Sulfur Dioxide (SO2)	0.2	LB/H		BACT-PSD
AR-0045	COLUMBIAN CHEMICALS • EL DORADO	AR	906-AOP-R1 (70-0014)	8/9/2001	Throughput is confidential. This carbon black mg process is being added. New stacks: SN-31, SN-44B, SN-45. BACT determination for SO2 and NOx only.	CARBON BLACK MFG. UNIT D STACK & VENT	NATURAL GAS				Nitrogen Oxides (NOx)	7.7	LB/H		BACT-PSD
AR-0046	COLUMBIAN CHEMICALS • EL DORADO	AR	906-AOP-R1 (70-0014)	8/9/2001	CARBON BLACK MFG. UNITS A, B, & C FEEDSTOCK OIL	CARBON BLACK MFG. UNITS A, B, & C FEEDSTOCK OIL				Sulfur Dioxide (SO2)	2530	LB/H	combined	BACT-PSD	
AR-0046	COLUMBIAN CHEMICALS • EL DORADO	AR	906-AOP-R1 (70-0014)	8/9/2001		CARBON BLACK MFG. UNITS A, B, & C FEEDSTOCK OIL				Nitrogen Oxides (NOx)	246	LB/H	combined	BACT-PSD	
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001		BOILER, POWER, COAL-FIRED	COAL	249	MMBTU/H		Particulate Matter (PM)	0.16	LB/MMBTU		BACT-PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	MODIFICATION FOR INSTALLATION OF NEW EQUIPMENT TO INCREASE PRODUCTION CAPACITY.	BOILER, POWER, COAL-FIRED	COAL	249	MMBTU/H		Sulfur Dioxide (SO2)	0.8	LB/MMBTU		BACT-PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001		POWER BOILER CAN FIRE COAL, NO. 6 FUEL OIL, OR BARK/WOOD FIBER SLUDGE.				Nitrogen Oxides (NOx)	0.4	LB/MMBTU		BACT-PSD	
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001		Boiler, Power, Coal-Fired	COAL	249	MMBTU/H		Carbon Monoxide	0.208	LB/MMBTU		BACT-PSD

Northern Michigan University
RBLIC

RBLICID	FACILITY NAME	STATE	PERMIT No.	PERMIT DATE	DESCRIPTION	PROCESS NAME	FUEL	THROUGHPUT	UNIT	PROCESS NOTES	POLLUTANT		EMIS. LIMIT	UNIT	AVG TIME	BASIS
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	BOILER, POWER, OIL-FIRED	NO. 6 FUEL OIL	249	MMBTU/H		Particulate Matter (PM)	0.0562	LB/MMBTU				BACT+PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	BOILER, POWER, OIL-FIRED	NO. 6 FUEL OIL	249	MMBTU/H		Sulfur Dioxide (SO2)	0.8	LB/MMBTU				BACT+PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	BOILER, POWER, OIL-FIRED	NO. 6 FUEL OIL	249	MMBTU/H		Nitrogen Oxides (NOx)	0.367	LB/MMBTU				BACT+PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	BOILER, POWER, OIL-FIRED	NO. 6 FUEL OIL	249	MMBTU/H		Carbon Monoxide	0.038	LB/MMBTU				BACT+PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	POWER BOILER CAN FIRE COAL, NO. 6 FUEL, OIL, OR BAGASSA/WOOD FIBER SLUDGE.				Particulate Matter (PM)	0.25	LB/MMBTU				BACT+PSD	
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	BOILER, POWER, WOODWASTE, WOODWASTE-FIRED	WOODWASTE E	600	MMBTU/H		Sulfur Dioxide (SO2)	0.024	LB/MMBTU				BACT+PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	BOILER, POWER, WOODWASTE, WOODWASTE-FIRED	WOODWASTE E	600	MMBTU/H		Nitrogen Oxides (NOx)	0.35	LB/MMBTU				BACT+PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	MODIFICATION FOR INSTALLATION OF NEW EQUIPMENT TO INCREASE PRODUCTION CAPACITY.				Carbon Monoxide	0.5	LB/MMBTU				BACT+PSD	
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	RECOVERY BOILER	NO. 6 FUEL OIL	557	MMBTU/H		Sulfur Dioxide (SO2)	975.2	LB/H				BACT+PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	RECOVERY BOILER	NO. 6 FUEL OIL	557	MMBTU/H		Nitrogen Dioxide (NO2)	588.5	LB/H				BACT+PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	RECOVERY BOILER	NO. 6 FUEL OIL	557	MMBTU/H		Carbon Monoxide	357.1	GRDSCE @ 8% O2				BACT+PSD
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	RECOVERY BOILER	NO. 6 FUEL OIL	557	MMBTU/H		Particulates Matter (PM)	0.044	GRDSCE @ 8% O2				N/A
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	SMELT TANKS				Sulfur Dioxide (SO2)	6.2	LB/H				BACT+PSD	
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	LIME KILN	NO. 6 FUEL OIL	212	LB/MMBTU		Particulate Matter (PM)	0.13	GRDSCE @ 10% O2				N/A
NC-0092	RIEGELWOOD MILL	NC	03138R16	5/10/2001	LIME KILN	NO. 6 FUEL OIL	212	LB/MMBTU		Total Reduced Sulfur	8	PPM @ 10% O2				N/A



APPENDIX E

ESA Documentation



STATE OF MICHIGAN

JENNIFER M. GRANHOLM
GOVERNOR

DEPARTMENT OF NATURAL RESOURCES
LANSING

REBECCA A. HUMPHRIES
DIRECTOR

August 8, 2006

Mr. Jeffrey Jaros
NTH Consultants, Ltd.
608 S. Washington
Lansing, MI 48933

RE: Two proposed air permit locations in Holland and Marquette, Michigan submitted to DNR Endangered Species Assessment web application

Dear Mr. Jaros:

The location of the proposed projects were checked against known localities for rare species and unique natural features, which are recorded in a statewide database. This continuously updated database is a comprehensive source of existing data on Michigan's endangered, threatened, or otherwise significant plant and animal species, natural plant communities, and other natural features. Records in the database indicate that a qualified observer has documented the presence of special natural features at a site. The absence of records in the database for a particular site may mean that the site has not been surveyed. Records are not always up-to-date, and may require verification. In some cases, the only way to obtain a definitive statement on the status of natural features is to have a competent biologist perform a complete field survey.

Under Act 451 of 1994, the Natural Resources and Environmental Protection Act, Part 365, Endangered Species Protection, "a person shall not take, possess, transport, ...fish, plants, and wildlife indigenous to the state and determined to be endangered or threatened," unless first receiving an Endangered Species Permit from the Department of Natural Resources, Wildlife Division. *Responsibility to protect endangered and threatened species is not limited to the list below. Other species may be present that have not been recorded in the database.*

The presence of threatened or endangered species does not preclude activities or development, but may require alterations in the project plan. Special concern species are not protected under endangered species legislation, but recommendations regarding their protection may be provided. Protection of special concern species will help prevent them from declining to the point of being listed as threatened or endangered in the future.

The following is a summary of the results for the project in Ottawa County, City of Holland, T5N R16W section 36 and Marquette County, City of Marquette, T48N R25W section 11:

The project should have no impact on rare or unique natural features at the location specified above if it proceeds according to the plans provided. Please contact me for an evaluation if the project plans are changed.

Thank you in for your coordination in addressing the protection of Michigan's natural resource heritage. Responses and correspondence can be sent to: Michigan Department of Natural Resources, Wildlife Division - Natural Heritage Program, PO Box 30180, Lansing, MI 48909. If you have further questions, please call me at 517-373-1263 or e-mail at SargentL2@michigan.gov.

Sincerely,

Lori G. Sargent
Endangered Species Specialist
Wildlife Division

NATURAL RESOURCES COMMISSION

Keith J. Charters, Chair • Mary Brown • Darnell Earley • Bob Garner • Gerald Hall • John Madigan • Frank Wheatlake

STEVENS T. MASON BUILDING • P.O. BOX 30028 • LANSING, MICHIGAN 48909-7528
www.michigan.gov/dnr • (517) 373-2329



United States Department of the Interior

FISH AND WILDLIFE SERVICE
East Lansing Field Office (ES)
2651 Coolidge Road, Suite 101
East Lansing, Michigan 48823-6316

IN REPLY REFER TO:

November 24, 2006

Mr. Jeffrey P. Jaros
NTH Consultants, Ltd.
608 S. Washington Avenue
Lansing, MI 48933

Re: Endangered Species List Request, Proposed Construction of Solid Fuel Fired Boiler,
Northern Michigan University, Marquette, Marquette County, Michigan

Dear Mr. Jaros:

Thank you for your October 24, 2006 request for information regarding federally listed and proposed threatened and endangered species, candidate species, or critical habitat near your proposed project. Your request and this response are made pursuant to the Endangered Species Act of 1973, as amended (Act). Under this project, Northern Michigan University proposes to install a cogeneration of coal/wood/natural gas fired circulating fluidized bed boiler on the north end of its campus, next to the existing Ripley Heating Plant.

Our records do not indicate the presence of federally listed species or critical habitat near your proposed project. This precludes the need for further action on this project as required by the Act. If, however, more than six months pass, project plans change, or new information becomes available that indicates listed species or proposed species may be affected, you should conduct further consultation with this office.

We appreciate your concern for endangered and threatened species. Any questions can be directed to Tameka Dandridge of this office at Tameka_Dandridge@fws.gov or 517/351-8315.

Sincerely,

Craig A. Czarnecki
Field Supervisor

cc: MDNR-Wildlife Division, Lansing, MI (Attn: Lori Sargent)

s: admin/archives/nov06/se list/NTH-NMU~solidfuel.ind.doc



APPENDIX F

Cooling Tower Modeling Output

prep

***** EPRI PLUME AND DRIFT ANALYSIS SYSTEM PREPROCESSOR CODE, PRE-RELEASE VERSION 09-01-90
***** SITE STUDY: Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTH)

INPUT INFORMATION

SURFACE TAPE TYPE:	CD144
TOWER TYPE:	LINEAR MECHANICAL DRAFT
TOWER HEIGHT (M):	12.50
TOWER DIAMETER (M):	47.03
TOWER HEAT (KW):	7000.00
TOWER AIR FLOW (KG/S):	679.50
SITE LATITUDE:	46.60
SITE LONGITUDE:	87.40
SITE TIME ZONE:	EASTERN
ROUGHNESS HEIGHT (CM):	0.07
REFERENCE HEIGHT (M):	10.00
RECORD STOPPING SWITCH:	8760
RECORD SKIPPING FACTOR:	1
HOURLY RECORD PRINT LOG:	NOT SELECTED
BI-DAILY MIXING HEIGHT TAPE:	SELECTED
MIXING HEIGHT TYPE:	RURAL
FOGGING/ICING OPTION:	SELECTED
DRIFT OPTION:	SELECTED

MONTHLY CLEARNES INDEX

JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
---	---	---	---	---	---	---	---	---	---	---	---
.460	.490	.520	.490	.530	.550	.560	.550	.530	.500	.420	.420

**TOTAL DAILY SOLAR ENERGY DEPOSITION
(LONG-TERM AVERAGE FOR MONTH)**

JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
---	---	---	---	---	---	---	---	---	---	---	---
5.74	8.79	13.10	16.08	20.47	22.69	22.52	19.34	14.78	10.05	5.82	---

*****WIND SPEED FREQUENCY

Northern Michigan University - MARQUETTE - COOLING

WIND ***** * WIND

FROM*****

SPEED N NNE NE ENE E NEW NW W SWW S SWW SW NW

WNW NW NNW ***** WIND

HEADED***** C SW SSW SW WSW W WNW NW N NW NNE NE ENE E

~~SW SSW SWW NW N NE E~~

ESE SE 558 561

0 TO 1 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
 0.000 0.000 0.000 0.000
 1 TO 2 0.009 0.003 0.003 0.003 0.004 0.002 0.003 0.004 0.008 0.009 0.008 0.005 0.007
 0.003 0.004 0.005 0.081

prep

2 TO 3	0.017	0.009	0.011	0.007	0.009	0.004	0.007	0.010	0.022	0.017	0.012	0.015	0.022
0.011	0.009	0.010	0.192										
3 TO 4	0.016	0.015	0.012	0.006	0.007	0.003	0.006	0.012	0.026	0.021	0.015	0.007	0.019
0.013	0.015	0.009	0.202										
4 TO 5	0.014	0.019	0.015	0.005	0.002	0.002	0.007	0.010	0.031	0.016	0.013	0.008	0.011
0.012	0.011	0.008	0.183										
5 TO 6	0.012	0.012	0.010	0.002	0.001	0.001	0.006	0.008	0.030	0.016	0.007	0.006	0.006
0.006	0.007	0.008	0.139										
6 TO 7	0.012	0.006	0.004	0.001	0.000	0.001	0.002	0.005	0.017	0.007	0.004	0.003	0.004
0.004	0.006	0.005	0.083										
7 TO 8	0.008	0.006	0.001	0.000	0.000	0.000	0.001	0.003	0.013	0.006	0.002	0.002	0.002
0.003	0.005	0.002	0.056										
8 TO 9	0.005	0.003	0.000	0.000	0.000	0.000	0.001	0.005	0.003	0.002	0.001	0.001	0.001
0.001	0.002	0.002	0.025										
9 TO 10	0.005	0.002	0.000	0.000	0.000	0.000	0.001	0.003	0.003	0.001	0.001	0.001	0.001
0.000	0.002	0.001	0.019										
10 TO 11	0.005	0.002	0.000	0.000	0.000	0.000	0.001	0.001	0.000	0.000	0.001	0.000	0.000
0.000	0.000	0.000	0.011										
11 TO 12	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000
0.000	0.000	0.000	0.005										
12 TO 13	0.001	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.003										
13 TO 14	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.001										
14 TO 15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.001										
15 TO 20	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000										
20 TO 25	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000										
25 TO 30	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000										
30 TO OVER	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000										

AVERAGE	4.47699	VARIANCE	4.52228	STD DEV	2.12657
STD ERR	0.02459	SKEWNESS	1.31718	KURTOSIS	2.01213

1 ***** RELATIVE HUMIDITY FREQUENCY

TABLE*****

Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTH)

RELATIVE ***** WIND

FROM*****

HUMIDITY	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W
----------	---	-----	----	-----	---	-----	----	-----	---	-----	----	-----	---

WNW NW NNW

RANGE(%) ***** WIND

HEADED*****

S	SSW	SW	WSW	W	NNW	NW	NNW	N	NNE	NE	ENE	E
---	-----	----	-----	---	-----	----	-----	---	-----	----	-----	---

ESE SE SSE SUM

0 TO 10	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000										
10 TO 20	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.001	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.003										
20 TO 30	0.000	0.001	0.000	0.000	0.000	0.001	0.002	0.003	0.003	0.001	0.001	0.001	0.001
0.000	0.000	0.000	0.015										
30 TO 40	0.001	0.003	0.004	0.002	0.002	0.004	0.005	0.007	0.004	0.004	0.004	0.004	0.004
0.003	0.001	0.001	0.050										
40 TO 50	0.002	0.005	0.007	0.002	0.001	0.000	0.002	0.005	0.013	0.007	0.007	0.004	0.005
0.003	0.002	0.002	0.066										
50 TO 60	0.008	0.008	0.008	0.004	0.001	0.001	0.005	0.020	0.011	0.008	0.006	0.008	0.008
0.005	0.005	0.004	0.103										

prep

60 TO 70	0.014	0.010	0.009	0.003	0.003	0.001	0.002	0.007	0.018	0.012	0.008	0.007	0.010
0.009	0.011	0.006	0.130										
70 TO 80	0.015	0.012	0.008	0.003	0.002	0.001	0.003	0.006	0.026	0.016	0.009	0.010	0.014
0.014	0.013	0.012	0.152										
80 TO 90	0.029	0.014	0.009	0.006	0.006	0.003	0.005	0.009	0.026	0.020	0.016	0.010	0.022
0.014	0.018	0.014	0.221										
90 TO 100	0.027	0.016	0.009	0.004	0.004	0.004	0.007	0.009	0.029	0.020	0.009	0.007	0.007
0.005	0.010	0.009	0.175										
100 TO OVER	0.012	0.009	0.003	0.002	0.002	0.001	0.004	0.005	0.011	0.008	0.004	0.002	0.003
0.001	0.003	0.003	0.074										

AVERAGE	74.66025	VARIANCE	402.23911	STD DEV	20.05590
STD ERR	0.23196	SKEWNESS	1.08593	KURTOSIS	1.22048

*****DEW POINT TEMPERATURE FREQUENCY*****

1 TABLE*****

Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTH)

DEW POINT ***** WIND

FROM*****

TEMP	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W
WNW	NW	NNW											
RANGE (C)	***** WIND												
HEADED*****													
	S	SSW	SW	NSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E
ESE	SE	SSE	SUM										
-45 TO -40	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000										
-40 TO -35	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000										
-35 TO -30	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000	0.000	0.001										
-30 TO -25	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.002	0.001	0.004	
0.002	0.000	0.000	0.010										
-25 TO -20	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.002	0.003	
0.001	0.001	0.001	0.010										
-20 TO -15	0.001	0.000	0.001	0.001	0.001	0.000	0.000	0.003	0.004	0.004	0.005	0.009	
0.006	0.008	0.004	0.047										
-15 TO -10	0.016	0.007	0.003	0.001	0.002	0.002	0.004	0.003	0.005	0.011	0.008	0.006	0.011
0.008	0.015	0.010	0.111										
-10 TO -5	0.016	0.012	0.008	0.003	0.001	0.002	0.007	0.007	0.013	0.007	0.005	0.003	0.005
0.006	0.008	0.005	0.108										
-5 TO 0	0.021	0.015	0.009	0.004	0.005	0.005	0.005	0.007	0.025	0.014	0.011	0.006	0.009
0.006	0.008	0.007	0.158										
0 TO 5	0.018	0.014	0.008	0.004	0.003	0.001	0.004	0.007	0.019	0.012	0.004	0.003	0.009
0.007	0.010	0.012	0.138										
5 TO 10	0.021	0.015	0.013	0.004	0.004	0.002	0.004	0.010	0.024	0.013	0.007	0.008	
0.006	0.006	0.007	0.150										
10 TO 15	0.014	0.010	0.012	0.004	0.003	0.001	0.004	0.012	0.030	0.014	0.011	0.008	0.012
0.009	0.004	0.003	0.151										
15 TO 20	0.003	0.004	0.003	0.002	0.001	0.002	0.007	0.033	0.021	0.012	0.007	0.003	
0.002	0.002	0.001	0.106										
20 TO 25	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.003	0.002	0.001	0.001	0.001	
0.001	0.000	0.000	0.010										
25 TO 30	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
0.000	0.000	0.000	0.000										
30 TO 35	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
0.000	0.000	0.000	0.000										
35 TO 40	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
0.000	0.000	0.000	0.000										
40 TO 45	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	
0.000	0.000	0.000	0.000										

prep

1 *****STABILITY CLASS FREQUENCY
TABLE*****Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTH)
STABILITY *****WIND
FROM*****
CLASS N NNE NE ENE E ESE SE SSE S SSW SW WSW W
WNW NW NNW *****WIND
HEADED*****
S SSW SW NSW W WNW NW NNW N NNE NE ENE E
ESE SE SSE SUM

1 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.002
2 0.003 0.003 0.004 0.003 0.002 0.002 0.003 0.003 0.003 0.002 0.002 0.002 0.002 0.003
0.001 0.001 0.001 0.037
3 0.007 0.011 0.016 0.005 0.002 0.001 0.003 0.005 0.016 0.009 0.009 0.008 0.007
0.005 0.004 0.003 0.113
4 0.072 0.053 0.028 0.010 0.010 0.006 0.017 0.029 0.085 0.049 0.029 0.024 0.032
0.030 0.041 0.030 0.545
5 0.015 0.007 0.007 0.005 0.006 0.004 0.006 0.011 0.035 0.019 0.012 0.009 0.014
0.011 0.011 0.009 0.180
6 0.009 0.002 0.002 0.001 0.002 0.001 0.002 0.004 0.014 0.015 0.009 0.005 0.016
0.006 0.005 0.006 0.102
7 0.003 0.000 0.000 0.000 0.000 0.000 0.000 0.001 0.003 0.002 0.003 0.002 0.003
0.001 0.001 0.001 0.021

AVERAGE 4.25201 VARIANCE 0.99227 STD DEV 0.99613
STD ERR 0.01152 SKEWNESS 1.07871 KURTOSIS 1.21936

1 *****K FREQUENCY
TABLE*****Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTH)
K *****WIND
FROM*****
(UA/VE) N NNE NE ENE E ESE SE SSE S SSW SW NSW W
WNW NW NNW *****WIND
RANGE*****
HEADED*****
S SSW SW NSW W WNW NW NNW N NNE NE ENE E
ESE SE SSE SUM

0.0 TO 0.1 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
0.1 TO 0.2 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
0.2 TO 0.3 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
0.3 TO 0.4 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
0.4 TO 0.5 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
0.5 TO 0.6 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
0.6 TO 0.7 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
0.7 TO 0.8 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
0.8 TO 0.9 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000

prep

0.000	0.000	0.000	0.000											
0.9	TO 1.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		
0.000	0.000	0.000	0.000											
1.0	TO 1.2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		
0.000	0.000	0.000	0.000											
1.2	TO 1.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		
0.000	0.000	0.000	0.000											
1.4	TO 1.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		
0.000	0.000	0.000	0.000											
1.6	TO 1.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		
0.000	0.000	0.000	0.000											
1.8	TO 2.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		
0.000	0.000	0.000	0.000											
2.0	TO 2.5	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		
0.000	0.000	0.000	0.000											
2.5	TO 3.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		
0.000	0.000	0.000	0.000											
3.0	TO OVER	0.110	0.078	0.058	0.024	0.022	0.014	0.031	0.054	0.155	0.098	0.064	0.050	0.075
0.054	0.062	0.051	1.000											

AVERAGE 3.50000 VARIANCE 0.00000 STD DEV 0.00000
STD ERR 0.00000 SKEWNESS 1.00000 KURTOSIS 1.00000

prep

```

0.000 0.000 0.000 0.000
14 TO 15 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
15 TO 20 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
20 TO 25 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
25 TO 30 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000
0.000 0.000 0.000 0.000
30 TO OVER 0.012 0.009 0.003 0.002 0.002 0.001 0.004 0.005 0.005 0.011 0.008 0.004 0.002 0.003
0.001 0.003 0.003 0.074

```

AVERAGE 4.03170 VARIANCE 76.75311 STD DEV 8.76089
STD ERR 0.10132 SKEWNESS 3.54087 KURTOSIS 12.83027

 ***** PLUME LENGTH PARAMETER FREQUENCY
 1 *****
 TABLE *****

 Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTH)

prep

***** PLUME LENGTH PARAMETER FREQUENCY *****

prep
 Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTB)
 *****WIND*****

PLUME FROM***** LENGTH WNW NW NWW RANGE (M) ***** HEADED***** ESE SE SSE SUM	*****WIND*****												
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W
10.0 TO 10.4 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.000												
10.4 TO 10.8 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.000												
10.8 TO 11.2 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
11.2 TO 11.6 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
11.6 TO 12.0 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
12.0 TO 12.4 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.000												
12.4 TO 12.8 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.000												
12.8 TO 13.2 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
13.2 TO 13.6 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
13.6 TO 14.0 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.000												
14.0 TO 14.4 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.000												
14.4 TO 14.8 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.000												
14.8 TO 15.2 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.000												
15.2 TO 15.6 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
15.6 TO 16.0 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
16.0 TO 16.4 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.002												
16.4 TO 16.8 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
16.8 TO 17.2 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
17.2 TO 17.6 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.000												
17.6 TO 18.0 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.001 0.000 0.003												
18.0 TO 18.4 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
18.4 TO 18.8 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
18.8 TO 19.2 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
19.2 TO 19.6 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	0.000 0.000 0.000 0.001												
19.6 TO 20.0 0.001 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.001 0.001 0.001 0.000 0.000	0.000 0.000 0.000 0.004												
20.0 TO 21.0 0.000 0.001 0.000 0.000 0.000 0.000 0.000 0.001 0.000 0.000 0.000 0.000 0.001 0.000	0.000 0.000 0.000 0.003												
21.0 TO 22.0 0.000 0.001 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.001 0.001 0.000 0.000	0.000 0.000 0.000 0.004												
22.0 TO 23.0 0.001 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.001 0.001 0.001 0.001 0.000 0.000	0.000 0.000 0.000 0.004												
23.0 TO 24.0 0.001 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.001 0.000 0.000 0.000													

prep

AVERAGE 1.55888 VARIANCE 31.63983 STD DEV 5.62493
 STD ERR 0.05506 SKEWNESS 4.17934 KURTOSIS 18.08287

*****PLUME HEIGHT PARAMETER FREQUENCY

PROBLEMS FOR ANALYSIS (NTH)

Northern Michigan University - MARQUETTE - COOLING

WIND														
PLUME FROM*****	HEIGHT WNW	N NW	NNE NNW	NE RANGE (M)	ENE *****	E *****	ESE *****	SE *****	SSE *****	S *****	SSW *****	SW *****	WSW *****	W *****
HEADED*****	S ESE	SSW SE	SW SSE	WSW SUM	W *****	WNW *****	NW *****	NNW *****	N *****	NNE *****	NE *****	ENE *****	E *****	
0.0 TO 0.1 0.100 0.071 0.055 0.023 0.020 0.012 0.027 0.049 0.147 0.091 0.061 0.048 0.072														
0.053 0.060 0.048 0.937														
0.1 TO 0.2 0.001 0.001 0.000 0.000 0.001 0.000 0.000 0.001 0.001 0.001 0.000 0.000 0.000 0.001														
0.001 0.000 0.000 0.007														
0.2 TO 0.3 0.001 0.001 0.000 0.000 0.000 0.000 0.001 0.001 0.001 0.001 0.000 0.000 0.000 0.001														
0.000 0.001 0.000 0.008														
0.3 TO 0.4 0.001 0.001 0.001 0.000 0.000 0.000 0.000 0.000 0.002 0.001 0.000 0.000 0.000 0.000														
0.000 0.000 0.000 0.007														
0.4 TO 0.5 0.001 0.001 0.000 0.001 0.000 0.000 0.001 0.001 0.002 0.001 0.000 0.000 0.000 0.000														
0.000 0.000 0.000 0.008														
0.5 TO 0.6 0.001 0.001 0.000 0.000 0.000 0.000 0.001 0.000 0.001 0.001 0.001 0.001 0.000 0.000														

prep

prep

3.9	TO 4.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.0	TO 4.1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.1	TO 4.2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.2	TO 4.3	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.3	TO 4.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.4	TO 4.5	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.5	TO 4.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.6	TO 4.7	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.7	TO 4.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.8	TO 4.9	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
4.9	TO 5.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												

1 *****PLUME HEIGHT PARAMETER FREQUENCY

TABLE*****

Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTH)

PLUME FROM*****	*****WIND														
	HEIGHT WNW	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	
RANGE (M) HEADED*****	WNW	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	
S ESE	S SE	SSW SSE	SW SUM	WSW W	W WNW	WNW NW	NW NNE	N NE	NNE NE	NE ENE	ENE E	E ESE	E SE	E S	
5.0	TO 5.2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
5.2	TO 5.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
5.4	TO 5.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
5.6	TO 5.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
5.8	TO 6.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
6.0	TO 6.2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
6.2	TO 6.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
6.4	TO 6.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
6.6	TO 6.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
6.8	TO 7.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
7.0	TO 7.2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
7.2	TO 7.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
7.4	TO 7.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
7.6	TO 7.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
7.8	TO 8.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
8.0	TO 8.2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000	0.000	0.000												
8.2	TO 8.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

prep

AVERAGE 0.08216 VARIANCE 0.02140 STD DEV 0.14628
 STD ERR 0.00169 SKEWNESS 4.76015 KURTOSIS 27.32819

prep

 ***** PLUME LENGTH-K-STABILITY FREQUENCY
 1

TABLE*****
 Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTH)

CATEGORY 3 PLUME	STABILITY CATEGORY 1			STABILITY CATEGORY 2			STABILITY
	K1	K2	K3	K1	K2	K3	
K2	K3	--	--	--	--	--	--
-- --							
0.0 TO 0.2	0.000	0.000	0.152	0.000	0.000	0.668	0.000
0.000 0.112							
0.2 TO 0.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
0.4 TO 0.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
0.6 TO 0.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
0.8 TO 1.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
1.0 TO 1.2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
1.2 TO 1.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
1.4 TO 1.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
1.6 TO 1.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
1.8 TO 2.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
2.0 TO 2.2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
2.2 TO 2.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
2.4 TO 2.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
2.6 TO 2.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
2.8 TO 3.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
3.0 TO 3.2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
3.2 TO 3.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
3.4 TO 3.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
3.6 TO 3.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
3.8 TO 4.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
4.0 TO 4.2	0.000	0.000	0.000	0.000	0.000	0.001	0.000
0.000 0.000							
4.2 TO 4.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
4.4 TO 4.6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
4.6 TO 4.8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							
4.8 TO 5.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.000 0.000							

				prep				
5.0 TO 5.2	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
5.2 TO 5.4	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
5.4 TO 5.6	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
5.6 TO 5.8	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
5.8 TO 6.0	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
6.0 TO 6.2	0.000	0.000	0.000		0.000	0.000	0.001	0.000
0.000 0.000								
6.2 TO 6.4	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
6.4 TO 6.6	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
6.6 TO 6.8	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
6.8 TO 7.0	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
7.0 TO 7.2	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
7.2 TO 7.4	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
7.4 TO 7.6	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
7.6 TO 7.8	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
7.8 TO 8.0	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
8.0 TO 8.2	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
8.2 TO 8.4	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
8.4 TO 8.6	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
8.6 TO 8.8	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
8.8 TO 9.0	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
9.0 TO 9.2	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
9.2 TO 9.4	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
9.4 TO 9.6	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
9.6 TO 9.8	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								
9.8 TO 10.0	0.000	0.000	0.000		0.000	0.000	0.000	0.000
0.000 0.000								

1 *****PLUME LENGTH-K-STABILITY FREQUENCY

TABLE*****

Northern Michigan University - MARQUETTE - COOLING TOWER ANALYSIS (NTH)

CATEGORY 3 PLUME	STABILITY CATEGORY 1			STABILITY CATEGORY 2			STABILITY K1
	K1	K2	K3	K1	K2	K3	
LENGTH RANGE (M)	K1	K2	K3	K1	K2	K3	K1
K2 K3	--	--	--	--	--	--	--
-- --							
10.0 TO 10.4	0.000	0.000	0.000	0.000	0.000	0.000	0.000

prep						
0.000	0.000					
10.4 TO 10.8	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000					
10.8 TO 11.2	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
11.2 TO 11.6	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
11.6 TO 12.0	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
12.0 TO 12.4	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000					
12.4 TO 12.8	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000					
12.8 TO 13.2	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
13.2 TO 13.6	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
13.6 TO 14.0	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000					
14.0 TO 14.4	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000					
14.4 TO 14.8	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000					
14.8 TO 15.2	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000					
15.2 TO 15.6	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
15.6 TO 16.0	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
16.0 TO 16.4	0.000	0.000	0.000	0.000	0.000	0.002
0.000	0.000					
16.4 TO 16.8	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000					
16.8 TO 17.2	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
17.2 TO 17.6	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.000					
17.6 TO 18.0	0.000	0.000	0.000	0.000	0.000	0.003
0.000	0.000					
18.0 TO 18.4	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
18.4 TO 18.8	0.000	0.000	0.000	0.000	0.000	0.000
0.000	0.001					
18.8 TO 19.2	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
19.2 TO 19.6	0.000	0.000	0.000	0.000	0.000	0.001
0.000	0.000					
19.6 TO 20.0	0.000	0.000	0.000	0.000	0.000	0.002
0.000	0.001					
20.0 TO 21.0	0.000	0.000	0.000	0.000	0.000	0.003
0.000	0.000					
21.0 TO 22.0	0.000	0.000	0.000	0.000	0.000	0.002
0.000	0.003					
22.0 TO 23.0	0.000	0.000	0.000	0.000	0.000	0.003
0.000	0.001					
23.0 TO 24.0	0.000	0.000	0.000	0.000	0.000	0.002
0.000	0.002					
24.0 TO 25.0	0.000	0.000	0.000	0.000	0.000	0.005
0.000	0.001					
25.0 TO 26.0	0.000	0.000	0.000	0.000	0.000	0.004
0.000	0.000					
26.0 TO 27.0	0.000	0.000	0.000	0.000	0.000	0.003
0.000	0.000					
27.0 TO 28.0	0.000	0.000	0.000	0.000	0.000	0.004
0.000	0.000					
28.0 TO 29.0	0.000	0.000	0.000	0.000	0.000	0.003
0.000	0.000					

					prep					
29.0 TO 30.0		0.000	0.000	0.000		0.000	0.000	0.004		0.000
0.000 0.000										
30.0 TO 31.0		0.000	0.000	0.000		0.000	0.000	0.001		0.000
0.000 0.000										
31.0 TO 32.0		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
32.0 TO 33.0		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
33.0 TO 34.0		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
34.0 TO 35.0		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
35.0 TO 36.0		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
36.0 TO 37.0		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
37.0 TO 38.0		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
38.0 TO 39.0		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
39.0 TO 40.0		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
40.0 TO OVER		0.000	0.000	0.000		0.000	0.000	0.000		0.000
0.000 0.000										
1 CAT NUM TYPE UH WX DBT DTDZ DPT VE TE MXHT PLGT										
FREQ	REFERENCE HEIGHT=		10. M							

0.0012	1	FOG	10.0	0.25	263.1	-0.010	262.6	0.3	270.1	500.	6.24
0.0004	2	FOG	15.0	0.25	263.1	-0.010	262.6	0.3	270.1	500.	0.00
0.0037	3	FOG	12.0	0.25	263.1	-0.010	261.1	0.3	269.8	500.	0.00
0.0004	4	FOG	17.0	0.25	263.1	-0.010	261.1	0.3	269.8	500.	0.00
0.0003	5	FOG	15.0	0.25	263.1	-0.010	258.6	0.3	269.4	500.	0.00
0.0036	6	FOG	12.5	0.25	273.1	-0.010	272.4	0.3	278.5	500.	0.00
0.0009	7	FOG	16.5	0.25	273.1	-0.010	269.4	0.3	277.6	500.	0.00
0.0007	8	FOG	15.0	0.25	283.1	-0.010	282.4	0.3	286.9	500.	0.00
0.0001	9	FOG	16.5	0.25	283.1	-0.010	279.4	0.3	285.6	500.	0.00
0.0001	10	FOG	15.5	0.25	293.1	-0.010	291.1	0.3	294.9	500.	0.00
0.1517	11	PLUME	3.9	0.15	289.6	-0.018	279.4	0.3	288.1	868.	0.00
0.6676	12	PLUME	4.9	0.25	278.5	-0.010	273.9	0.3	281.5	850.	9.48
0.1118	13	PLUME	2.2	0.30	277.0	0.030	273.7	0.3	280.8	950.	18.88
0.0001	14	PLUME	8.7	0.25	271.0	-0.010	270.9	0.3	276.9	632.	0.00
0.0001	15	PLUME	7.7	0.25	275.4	-0.010	275.3	0.3	280.6	1120.	1.17
0.0003	16	PLUME	4.6	0.25	292.1	-0.010	292.0	0.3	295.1	996.	1.73
0.0003	17	PLUME	5.7	0.25	285.4	-0.010	285.3	0.3	289.2	730.	2.58
0.0005	18	PLUME	7.7	0.25	274.3	-0.010	274.2	0.3	279.7	984.	3.38
	19	PLUME	5.7	0.25	285.1	-0.010	285.0	0.3	288.9	620.	3.20

prep											
0.0004	20	PLUME	4.6	0.25	290.4	-0.010	290.3	0.3	293.6	426.	4.17
0.0001	21	PLUME	5.8	0.25	283.4	-0.010	283.3	0.3	287.4	671.	4.44
0.0004	22	PLUME	7.2	0.25	276.0	-0.010	275.9	0.3	281.1	689.	5.10
0.0001	23	PLUME	4.6	0.25	285.4	-0.010	285.3	0.3	289.2	800.	11.31
0.0001	24	PLUME	6.2	0.25	281.0	-0.010	280.9	0.3	285.4	782.	5.47
0.0005	25	PLUME	3.6	0.25	292.1	-0.010	292.0	0.3	295.1	923.	10.12
0.0001	26	PLUME	4.9	0.25	287.6	-0.010	287.5	0.3	291.1	836.	6.03
0.0003	27	PLUME	5.1	0.25	285.4	-0.010	285.3	0.3	289.2	904.	7.21
0.0003	28	PLUME	7.7	0.25	272.1	-0.010	272.0	0.3	277.8	766.	7.69
0.0001	29	PLUME	4.1	0.25	291.0	-0.010	290.9	0.3	294.1	496.	7.72
0.0001	30	PLUME	5.7	0.25	282.1	-0.010	282.0	0.3	286.3	1046.	8.15
0.0004	31	PLUME	6.2	0.25	279.3	-0.010	279.2	0.3	283.9	771.	8.39
0.0001	32	PLUME	4.9	0.25	285.7	-0.010	285.6	0.3	289.4	784.	8.93
0.0003	33	PLUME	4.1	0.25	286.0	-0.010	285.9	0.3	289.7	11.	14.07
0.0001	34	PLUME	5.7	0.25	281.0	-0.010	280.9	0.3	285.4	1028.	9.97
0.0001	35	PLUME	5.4	0.25	281.2	-0.010	281.1	0.3	285.5	726.	12.08
0.0007	36	PLUME	5.7	0.25	280.8	-0.010	280.7	0.3	285.2	631.	10.33
0.0007	37	PLUME	4.2	0.25	287.6	-0.010	287.5	0.3	291.1	830.	11.12
0.0005	38	PLUME	3.6	0.25	289.6	-0.010	289.5	0.3	292.8	902.	12.95
0.0003	39	PLUME	4.6	0.25	284.3	-0.010	284.2	0.3	288.2	767.	12.85
0.0004	40	PLUME	5.1	0.25	282.1	-0.010	282.0	0.3	286.3	676.	12.29
0.0005	41	PLUME	5.9	0.25	278.1	-0.010	278.0	0.3	282.9	610.	12.64
0.0005	42	PLUME	3.1	0.25	292.1	-0.010	292.0	0.3	295.1	603.	13.13
0.0003	43	PLUME	3.6	0.25	283.9	-0.010	283.8	0.3	287.9	701.	18.87
0.0127	44	PLUME	2.9	0.25	277.5	-0.010	277.4	0.3	282.4	604.	24.83
0.0298	45	PLUME	3.3	0.25	271.6	-0.010	271.6	0.3	277.4	605.	29.10
0.0174											

MET RECORDS READ : 8760
 RECORDS DISCARDED: 0
 CALM RECORDS: 1284

 TOTAL TO NEW FILE: 8760



APPENDIX G

Visibility Modeling Support Information

Bolter Phantoms	Spinephantom Sagittal View	Cervicalphantom Lateral View
Krämer Bolter (Kraemer, 1998)	145	16
Quintol Cervicalphantom		16

(approximate values usually?)

Beller Phänomene	Stellenbezeichnung	Zeitdauer	Wert
Isotop Typen	Chemikalien	145	
Kontakt mit Eisen (Rost, Rostfarben)			0
Graue Gesteinsarten			

TABLE B-2. MAXIMUM EMISSION RATES

四

Gesetzgebungen	
Basis:	Europäische Union
Maßnahmen:	Europäische Richtlinien, Gesetze, Verordnungen
Wirkung:	Europa
Zeitraum:	1957 -

卷之三

Gesamt-Statistik		Übersicht	
Bestell-Nr.	Bestell-Datum	Warengruppe	Bestell-Bewertung
1234567890	2023-09-15	Warengruppe A	Sehr gut
1234567891	2023-09-16	Warengruppe B	Gut

卷之三

卷之三

KUNO_Uppdraget att utveckla Sjöfartens tillstånd för att en bättre fiskförsörjning

ପ୍ରକାଶକ ପତ୍ର ମହିନେ ପରିଚୟ

BioRxiv

Proposed Circulating Fluidized Bed Boiler Potential Emissions

Burner Type	Gasoline	Gasoline	Gasoline
Maximum Rated Heat Input (MM Btu/Hr)	100000	100000	100000
Gross Output (MM Btu/Hr)	10	10	10

Boiler Parameter	Specification
Burner Type	Circulating Fluidized Bed
Maximum Rated Heat Input (MM Btu/hr)	165
Gross Output (MM Btu/hr)	10

Marker, normally 7)

Proposed Circulating Fluidized Bed Boiler Potential Emissions

Material	Sulfur Content	Metallic Usage (%)	Heat Input BTU/in ²	Heating Value (BTU/in ²)	Metallic Throughput (t/h)	Metallic Throughput (t/h)	Natural Gas Usage Rate (m³/t)	Maximum Burner Size (mm)
St. Chromite	1.50%	0.05%	155	15,500	15.500	7.45	0.153	101.14
St. Si-PFB	0.60%	0.05%	155	15,500	15.500	7.45	0.153	101.14
St. Zinc	0.50%	0.05%	205	20,500	20.500	8.90	0.153	101.14
St. Zinc	0.50%	0.05%	205	20,500	20.500	8.90	0.153	101.14

TABLE B-1. EMISSION RATES OF CRITERIA POLLUTANTS, HAPS, AND TACs FROM THE NEW BOILER, ON A PER-FUEL BASIS

TABLE B-2. MAXIMUM EMISSION RATES						
Compound	Maximum Emission Rates (lb/yr)	Emission Rates (lb/yr)	Rust	Emulsion Factor	Waste Management	
Cation Terephthalate		4,165-02	Wood	5.1E-05	5.1E-05	
Cation Phenoxaphosphine		1,656-01	PRB Coal	4.74E-07	1,656-04	
Chloroethane		7,786-03	3,415-02	Wood	3.00E-05	
Chloroform		8,662-33	2,895-02	Wood	3.22E-05	
2-Chlorophenol		5,686-06	2,485-06	Wood	2.76E-05	
Chlorobiphenol		9,035-06	2,911-04	PRB Coal	3.56E-07	
Quinone		3,135-32	1,337-01	PRB Coal	1,69E-24	
Spirane		5,254-34	1,105-03	Wood	3.35E-05	
1,4-Dichlorobenzene		3,605-09	1,075-03	PRB Coal	1,69E-09	
2,4-Dichlorotoluene		9,015-04	2,635-03	PRB Coal	2.32E-05	
Dinitrophenol		4,245-05	1,385-01	Wood	2.07E-07	
2,4-Dinitrotoluene		7,916-03	3,205-02	Wood	9.07E-24	
Ethylbenzene		5,264-04	2,385-03	PRB Coal	2.8E-08	
Ethylene dichloride		6,015-04	2,195-03	PRB Coal	2.71E-06	
Ethylene dicloride		1,565-05	6,65E-05	PRB Coal	8.12E-08	
Formic acid		1,045-00	3,445-00	Wood	5.00E-03	
Formaldehyde		1,595-05	6,825E-06	Wood	7.55E-11	
Heptachloroheptamethyl		1,320-07	4,88E-07	Wood	3.25E-10	
Heptachloroheptenyl		1,685-03	7,23E-03	Wood	8.03E-08	
Hexane		3,767-01	1,84E-00	Nat Gas	2.03E-03	
Isobutylbenzene		2,875-03	1,24E-02	Wood	1.38E-05	
Isopropylbenzene		7,29E-03	3,16E-02	PRB Coal	3.93E-05	
2,4,4,4-tetrachlorobiphenol		3,777-05	1,68E-04	Wood	1.35E-07	
3-Methylbenzothiophene		3,765-07	1,64E-07	Nat Gas	2.03E-09	
Non-terephthaloyl benzene		5,19E-08	2,27E-07	Wood	2.5E-10	
Nonyl benzoate		3,54E-01	1,65E-02	Wood	1.71E-05	
Methyl chloride		9,63E-03	2,91E-03	PRB Coal	3.05E-05	
Methyl hydroxyacetone		2,13E-03	9,32E-02	PRB Coal	2.64E-05	
Methyl methacrylate		2,50E-04	1,10E-03	PRB Coal	1.15E-05	
Methyl tert-butyl ether		4,13E-04	1,62E-03	PRB Coal	1.30E-06	
Methylene chloride		6,93E-02	2,99E-01	Wood	3.33E-06	
2-Nitrophenol		2,48E-04	1,64E-04	Wood	2.79E-07	
4-Nitrophenol		2,61E-05	1,14E-04	Wood	1.27E-07	
Pentachlorobenzene		2,63E-07	1,24E-05	Wood	1.38E-09	
Pentaethoxybenzene		1,42E-05	6,07E-05	Wood	2.85E-40	
Phenyl ether		1,23E-07	5,37E-05	Wood	6.89E-10	
Phenol		1,20E-02	6,27E-02	Wood	7.02E-05	
Phenylmethanol		1,44E-02	6,36E-02	Wood	7.02E-05	
Sorbitol		7,56E-04	3,30E-03	Wood	3.68E-05	
Tetrahydrofuran		4,48E-01	1,66E-00	Wood	2.47E-05	
Tris(2-chlorophenyl)amine		5,93E-07	2,05E-05	Wood	2.85E-40	
Tetrahydrothiophene		8,88E-03	3,02E-02	Wood	4.37E-03	
Toluene		2,17E-01	9,60E-03	Wood	1.06E-03	
Octahydronaphthalene		1,01E-03	7,45E-03	Wood	8.42E-05	
Octahydronaphthalene		2,95E-03	1,14E-02	Wood	1.21E-05	
Tetrahydroxanthene		6,13E-07	2,94E-03	Wood	2.76E-05	

AMJ Updated Emission Spreadsheets for %S on Bit Coal Future 100%

Boiler Performance:	Specification:
Boiler Type:	Circulating Fluidized Bed
Minimum Boiler Heat Input (MMBtu/h)	185

(Accordance, normally 7)

Material	Sulfur Content	Specification:
Coal, Bituminous	0.07%	10.07% 0.07% 0.07%
Coal, Sub-bituminous	0.10%	10.00% 0.10% 0.10%
Gasoline	0.00%	20.00% 0.00% 0.00%
Gasoline	0.00%	20.00% 0.00% 0.00%

TABLE B-1. EMISSION RATES OF CRITERIA POLLUTANTS, HAPs, AND TAGS FROM THE NEW BOILER ON A PER-FUEL BASIS

Compound	CAS Reference Number	Coal, Bituminous			Catal. PRB			Natural Gas			Waste Wood		
		Emission Factors	Emission Rates										
Acetone	67-64-1	0.003	1.00E-03	0.000	0.00E+00								
Acetophenone	62-73-1	7440685	0.020	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	10102440	0.10	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	650950	0.15	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440681	0.022	0.001	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440687	0.43	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7438979	3.02E-06	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7438979	0.11	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7582018	0.01	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7684939	6.01E-03	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7460116	2.14E-12	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440280	9.05E-07	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440282	7.87E-07	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	74010533	2.10E-07	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440117	9.69E-08	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440123	1.20E-06	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	10520265	3.04E-07	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	18016831	6.37E-07	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440208	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440188	1.27E-02	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440254	9.30E-08	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440256	1.72E-02	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440257	1.67E-02	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440258	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440259	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440260	1.05E-03	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440261	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440262	1.16E-03	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440263	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440264	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440265	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440266	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440267	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440268	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440269	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440270	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440271	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440272	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440273	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440274	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440275	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440276	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440277	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440278	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440279	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440280	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440281	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440282	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440283	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440284	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440285	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440286	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440287	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440288	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440289	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440290	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440291	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440292	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440293	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440294	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00
Acetone	67-64-1	7440295	1.16E-04	1.00E-03	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.00E+00	0.000	0.00E+00

APPENDIX B

Emission Summary Tables



Northern Michigan University
Marquette, MI
FBI Boiler Project

Proposed Circulating Fluidized Bed Boiler Potential Emissions

Boiler Parameter	Specification
Boiler Type	Circulating Fluidized Bed
Maximum Rated heat input (M.M.Btu/hr.)	165.
Gross Output (MW _{th})	10

Crossed Circulating Fluidized Bed Boiler Potential Emissions

4.1.E B-1. EMISSION RATES OF CRITERIA POLLUTANTS, HAPS, AND TACs FROM THE NEW BOILER ON A PER-FUEL BASIS

TABLE B-2. MAXIMUM EMISSION RATES

卷之三十一

Prepared by NTH Consultants, Ltd.

Northern Michigan University
Marquette, MI
FBI Boller Project

Proposed Circulating Fluidized Bed Boiler Potential Emissions

Specification	Boiler Parameter	Operating Fluidized Bed
Boiler Type		
Maximum Fired Fuel Input (MM bht/hr)		195
Gross Capacity (MW/HR)		10

TABLE B-1. EMISSION RATES OF CRITERIA POLLUTANTS, HAPS, AND TACs FROM THE NEW BO

Compound	CAS Reference Number	Coal, Biomass		Coal, PRB		Emission Factors		Natural Gas		Emission Factors		Waste/Wood	
		Emissions Factors		Emissions Rates		Units		Units		Units		Units	
		Value	Units	Value	Units	(kg/t)	(t/t)	(kg/t)	(t/t)	(kg/t)	(t/t)	(kg/t)	(t/t)
benzene	652235	8.65E-06	litton	1.21E+05	2.70E+04	8.60E-06	litton	8.1E-05	3.3E-04	5.1E-05	2.0E-05	5.1E-05	2.0E-05
benzothiophene	7712805	2.63E-06	litton	1.01E+04	2.68E+03	6.80E-06	litton	2.79E-04	1.02E-03	2.0E-06	8.0E-07	1.08E-05	4.88E-05
benzotrichloroethane	105007	6.78E-05	litton	6.32E+04	2.32E+03	6.78E-05	litton	7.93E-04	3.2E+03	3.00E-05	1.27E-03	3.00E-05	1.27E-03
benzyl chloride	916563	9.16E-05	litton	3.08E+04	1.02E+03	9.16E-05	litton	9.16E-04	3.2E+03	3.22E-05	1.26E-03	3.22E-05	1.26E-03
benzyl chloride/methane	916567	6.78E-05	litton	6.32E+04	2.32E+03	6.78E-05	litton	7.93E-04	3.2E+03	3.00E-05	1.27E-03	3.00E-05	1.27E-03
benzyl chloride/wood	955716	8.10E-05	litton	4.74E+04	1.61E+03	8.10E-05	litton	8.10E-05	2.1E+04	2.1E-05	8.40E-06	2.1E-05	8.40E-06
benzyl chloride/water	616230	2.88E-03	litton	2.25E+02	0.87E+02	2.88E+03	litton	3.1E+02	1.12E+01	3.1E+02	1.12E+01	3.1E+02	1.12E+01
benzyl chloride/water	746528	1.08E-07	litton	3.22E+07	1.11E+05	3.22E+07	litton	3.6E+06	1.3E+05	3.6E+06	1.3E+05	3.6E+06	1.3E+05
benzyl chloride/water	121142	6.55E-06	litton	4.45E+04	1.60E+03	6.55E-06	litton	6.0E+04	2.2E+03	6.0E+04	2.2E+03	6.0E+04	2.2E+03
benzyl chloride/water	77781	6.55E-06	litton	4.45E+04	1.60E+03	6.55E-06	litton	6.0E+04	2.2E+03	6.0E+04	2.2E+03	6.0E+04	2.2E+03
benzyl chloride/water	512895	1.08E-04	litton	1.47E+04	5.10E+03	1.08E-04	litton	1.10E-03	5.10E+03	1.10E-03	5.10E+03	1.10E-03	5.10E+03
benzyl chloride/water	1087876	4.83E-05	litton	3.08E+04	1.02E+03	4.83E-05	litton	6.20E-04	2.05E+03	6.20E-04	2.05E+03	6.20E-04	2.05E+03
benzyl chloride/water	78503	4.60E-05	litton	3.08E+04	1.02E+03	4.60E-05	litton	6.01E-04	2.09E+03	6.01E-04	2.09E+03	6.01E-04	2.09E+03
benzyl chloride/water	1070623	1.50E-06	litton	1.08E+05	3.74E+03	1.50E-06	litton	1.50E-05	6.32E+03	1.50E-05	6.32E+03	1.50E-05	6.32E+03
benzyl chloride/water	1070634	2.78E-04	litton	2.10E+05	7.48E+03	2.78E-04	litton	3.00E+05	1.23E+02	3.00E+05	1.23E+02	3.00E+05	1.23E+02
benzyl chloride/water	610000	2.78E-04	litton	2.10E+05	7.48E+03	2.78E-04	litton	3.00E+05	1.23E+02	3.00E+05	1.23E+02	3.00E+05	1.23E+02
benzyl chloride/water	28058712	1.08E-04	litton	3.08E+04	1.02E+03	1.08E-04	litton	3.60E-04	1.27E+03	3.60E-04	1.27E+03	3.60E-04	1.27E+03
benzyl chloride/water	985251	7.71E-05	litton	6.04E-04	2.08E+03	7.71E-05	litton	8.3E-04	3.10E+03	8.3E-04	3.10E+03	8.3E-04	3.10E+03
benzyl chloride/water	785842	6.87E-04	litton	5.12E-03	2.28E+02	6.87E-04	litton	7.20E-03	3.18E+02	7.20E-03	3.18E+02	7.20E-03	3.18E+02
benzyl chloride/water	91578	1.84E-04	litton	1.44E+03	5.00E+02	1.84E-04	litton	2.17E-03	8.00E+02	2.17E-03	8.00E+02	2.17E-03	8.00E+02
benzyl chloride/water	744939	1.84E-04	litton	1.44E+03	5.00E+02	1.84E-04	litton	2.00E-03	8.77E-03	2.00E-03	8.77E-03	2.00E-03	8.77E-03
benzyl chloride/water	74973	6.11E-04	litton	4.74E+03	1.61E+03	6.11E-04	litton	6.69E-03	2.11E+02	6.69E-03	2.11E+02	6.69E-03	2.11E+02
benzyl chloride/water	603344	1.98E-04	litton	1.35E+03	4.58E+02	1.98E-04	litton	2.13E-03	9.32E+02	2.13E-03	9.32E+02	2.13E-03	9.32E+02
benzyl chloride/water	868228	2.30E-05	litton	1.40E+04	4.76E+03	2.30E-05	litton	2.09E-04	7.10E+02	2.09E-04	7.10E+02	2.09E-04	7.10E+02
benzyl chloride/water	1634044	4.01E-05	litton	3.18E+04	1.02E+03	4.01E-05	litton	4.32E-04	1.52E+03	4.32E-04	1.52E+03	4.32E-04	1.52E+03
benzyl chloride/water	785622	3.3E-04	litton	2.61E+03	8.74E+02	3.3E-04	litton	3.63E-03	1.14E+02	3.63E-03	1.14E+02	3.63E-03	1.14E+02
benzyl chloride/water	987165	1.00E-07	litton	3.22E+07	1.11E+05	3.22E+07	litton	3.60E+06	1.23E+03	3.60E+06	1.23E+03	3.60E+06	1.23E+03
benzyl chloride/water	1000277	2.54E-02	litton	2.00E+02	7.33E+01	2.54E-02	litton	3.10E+01	1.10E+01	3.10E+01	1.10E+01	3.10E+01	1.10E+01
benzyl chloride/water	875985	1.08E-05	litton	3.88E+04	1.32E+03	1.08E-05	litton	6.38E-04	2.16E+03	6.38E-04	2.16E+03	6.38E-04	2.16E+03
benzyl chloride/water	1080525	4.37E-04	litton	2.18E+03	7.48E+02	4.37E-04	litton	4.70E-03	1.20E+02	4.70E-03	1.20E+02	4.70E-03	1.20E+02
benzyl chloride/water	123386	2.30E-05	litton	3.22E+04	1.02E+03	2.30E-05	litton	3.00E+03	1.02E+02	3.00E+03	1.02E+02	3.00E+03	1.02E+02
benzyl chloride/water	1034265	2.30E-05	litton	3.22E+04	1.02E+03	2.30E-05	litton	3.00E+03	1.02E+02	3.00E+03	1.02E+02	3.00E+03	1.02E+02
benzyl chloride/water	20914350	4.98E-05	litton	3.88E+04	1.32E+03	4.98E-05	litton	6.38E-04	2.16E+03	6.38E-04	2.16E+03	6.38E-04	2.16E+03
benzyl chloride/water	1237003	1.08E-05	litton	2.18E+03	7.48E+02	1.08E-05	litton	4.70E-03	1.20E+02	4.70E-03	1.20E+02	4.70E-03	1.20E+02
benzyl chloride/water	1008163	2.71E-04	litton	2.18E+03	7.48E+02	2.71E-04	litton	3.00E+03	1.02E+02	3.00E+03	1.02E+02	3.00E+03	1.02E+02
benzyl chloride/water	652924	1.27E-05	litton	3.22E+04	1.02E+03	1.27E-05	litton	3.00E+03	1.02E+02	3.00E+03	1.02E+02	3.00E+03	1.02E+02
benzyl chloride/water	104870	2.60E-06	litton	3.22E+04	1.02E+03	2.60E-06	litton	3.00E+03	1.02E+02	3.00E+03	1.02E+02	3.00E+03	1.02E+02

TABLE B-2. MAXIMUM EMISSION RATES

Compound	Maximum Emission Rate (dB/L)	Maximum Factor	Fuel	Emissions Control
Carbon tetrachloride	1.05E-02	1.05E-01	Wood	5.1B/E-04
Chlorine	1.85E-01	8.1E-01	Wood	S.D/E-04
Chloroform	8.76E-05	3.34E-04	P/B Coal	4.7E-07
Chlorofluorocarbons	7.78E-03	3.41E-02	Wood	3.0E-06
Chlorobenzene	6.60E-03	2.48E-02	Wood	2.9E-06
2-Chloronaphthalene	5.68E-07	2.4E-06	Wood	2.7E-08
Chlorophenol	5.65E-06	2.4E-05	Wood	2.7E-06
Chloroethylene	6.35E-05	2.31E-05	P/B Coal	3.0E-07
Chromane	3.73E-02	1.37E-01	P/B Coal	1.6E-04
Chrysene	2.45E-04	1.10E-03	Gas	1.3E-05
1,4-Dichlorobutene	3.50E-06	1.52E-05	P/B Coal	1.0E-06
2,4-Dichlorobromoethane	6.01E-04	1.00E-03	P/B Coal	3.5E-06
Dinitroethane	4.24E-05	1.08E-04	Wood	2.0E-07
2,4-Dinitrotoluene	7.31E-03	3.20E-03	Wood	3.0E-05
Ethyldibromozinc	5.20E-04	2.00E-03	P/B Coal	2.6E-06
Ethylenediamine	5.30E-04	2.10E-03	P/B Coal	2.1E-06
Formaldehyde	1.04E-01	4.4E-01	Wood	5.0E-03
Formic acid	1.00E-05	6.62E-05	Wood	7.5E-11
Heptachlorodibenzofuran	1.66E-06	6.52E-07	Wood	6.3E-11
Hexachlorobutadiene	1.30E-07	5.68E-07	Wood	5.0E-11
Heptane	1.65E-03	7.25E-03	Wood	8.0E-06
Isobutylbenzene	2.85E-03	1.24E-02	Wood	2.0E-05
Isobutylbenzylphosphine	7.26E-03	3.16E-02	P/B Coal	3.0E-05
Isobutylbenzylamine	3.77E-05	1.55E-04	Wood	4.0E-07
3-Methylbenzothiophene	1.07E-01	1.94E-01	Nit. Gas	2.0E-03
Mercaptochlorobiphenyl	6.18E-08	2.27E-07	Wood	2.0E-10
Methyl bromide	3.54E-03	1.55E-03	Wood	1.7E-05
Methyl chloroform	6.68E-03	2.10E-02	P/B Coal	3.0E-06
Methyl ethyl ketone	4.48E-03	2.14E-02	P/B Coal	2.9E-06
Methyl hydrazine	2.13E-03	0.32E-03	P/B Coal	1.1E-05
Methyl methacrylate	2.50E-04	1.10E-03	P/B Coal	1.3E-05
Methyl naphthalene	5.40E-02	1.80E-02	Nit. Gas	6.0E-04
Monoisobutyl ether	4.38E-06	1.58E-05	P/B Coal	5.0E-08
Methyl keto chloride	6.84E-02	2.28E-02	Wood	8.0E-06
2-Nitrobutane	5.66E-05	1.98E-04	Wood	2.0E-07
4-Nitrophenol	2.56E-05	1.14E-04	Wood	1.2E-07
Pentadichlorobenzene	2.89E-07	1.24E-06	Wood	1.3E-09
Perchloroethoxyethane	1.21E-05	5.37E-05	Wood	6.0E-10
Perchloroethoxyethene	2.52E-05	5.37E-05	Wood	5.0E-10
Toluene	2.17E-01	9.0E-01	Wood	1.0E-03
Propidone	1.44E-02	6.30E-02	Wood	7.0E-05
Propionaldehyde	2.50E-03	7.45E-03	Wood	8.0E-06
Propionaldehyde	2.50E-03	7.45E-03	Wood	1.2E-05
Propionaldehyde	6.13E-07	2.14E-06	Wood	2.0E-08
Tetrachloroethoxyethane	5.68E-07	2.68E-06	Wood	2.0E-09
Tetraethylorthosilicate	3.82E-05	3.82E-02	Wood	4.5E-07
Toluene	2.17E-01	9.0E-01	Wood	1.0E-03
2-Tetrahydroxyphenyl	1.70E-03	7.45E-03	Wood	8.0E-06
2-Tetrahydroxyphenyl	2.50E-03	7.45E-03	Wood	1.2E-05
Trichloroethoxyethane	6.13E-07	2.14E-06	Wood	2.0E-08

APPENDIX A


Site Drawings



CAMPUS MAP - NORTHERN SECTION

NORTHERN MICHIGAN UNIVERSITY

MARQUETTE, MICHIGAN
DATE: SEPTEMBER 4, 2003




ELECTRICAL LEGEND	
SYMBOL	UTILITY
ELECTRIC	
HIGHMANT LIGHTPOLE	
SINGLE SPHERE/DIAPOL	
DOUBLE SPHERE/DIAPOL	
QUAD SPHERE/DIAPOL	
LIGHTPOLE	
CODE BLUE STATION	
MANHOLE	
LIGHTED BUILDING SIGNS	

STEAM LEGEND	
SYMBOL	UTILITY
STEAM	
ABANDONED STEAM	
MANHOLE	
STEAM VAULT (SV)	


ENR, NO. 5048-CCA-M1001A

1

卷之三



CONCEPTUAL WOOD FIRED BOILER PLANT -
PLAN VIEW



(A) SECTION PLANT ELEVATION

卷之三

CUMMINS & BARNARD, INC.
600 DATA COURT
JAN ADDO, MICHIGAN 49445
(734) 781-4130 Fax (734) 781-4081
www.cummbs.com

**NORTHERN MICHIGAN UNIVERSITY
WOOD/COAL FIRED BOILER**

NOT TO BE USED FOR
CONSTRUCTION

RECEIVED 25/1/1970 PROJECT NO. 100001

Compound	CAS No.	(lb/hr)	(lb/day)	Emissions Rates (kg/m ³)	(kg/m ³ ·sec)	Modulated Rate	TSL	Averaging Period	Impacts (kg/m ³)	% of SL
Lead										
Lead	7439-92-1	2.48E-03	1.09E-02	3.12E-04	1.5	24 hour	4.9E-04	0.03%		
Antimony	7440-36-0	1.68E-03	7.36E-03	2.12E-04	0.2	24 hour	3.37E-04	0.169%		
Beryllium	7440-28-2	1.42E-04	6.22E-04	1.18E-05	5	0.0002	3.7E-06	1.68%		
Antimony	7440-36-0	1.68E-03	7.36E-03	2.12E-04	0.2	24 hour	3.37E-04	0.169%		
Beryllium	7440-41-7	3.70E-06	1.68E-05	4.66E-07	0.02	24 hour	7.41E-07	0.004%		
Beryllium	7440-41-7	3.70E-06	1.68E-05	4.66E-07	0.02	24 hour	7.41E-07	0.004%		
Chromium, total	7440-41-7	3.70E-06	1.68E-05	4.66E-07	0.0004	Annual	9.83E-08	0.025%		
Chromium, hexavalent	18540-29-9	8.25E-04	3.81E-03	1.04E-04	0.1	24 hour	1.66E-04	0.117%		
Chromium, hexavalent	7440-41-7	4.95E-03	2.12E-02	6.2E-04	0.1	Annual	1.31E-04	0.111%		
Cobalt	7440-48-4	1.25E-03	5.48E-03	1.58E-04	0.2	8 hour	4.22E-04	0.214%		
Copper	7440-50-8	1.11E-04	5.00E-04	1.04E-05	0.02	8 hour	6.29E-05	0.021%		
Iron	7440-50-8	1.11E-04	5.00E-04	1.04E-05	0.02	8 hour	3.99E-05	0.020%		
Manganese	7440-55-1	1.33E-01	6.30E-01	1.73E-02	100	8 hour	4.72E-02	0.067%		
Manganese	7440-55-1	1.33E-01	6.30E-01	1.73E-02	100	Annual	6.20E-05	0.002%		
Phosphorus	7440-02-0	2.22E-04	1.00E-03	3.28E-05	0.1	8 hour	8.22E-06	0.006%		
Nickel	7440-02-0	2.22E-04	1.00E-03	3.28E-05	0.1	Annual	6.90E-06	0.006%		
Selenium	7728-49-2	9.18E-02	4.16E-01	1.18E-02	2	8 hour	2.44E-03	2.44%		
Sulfur	7728-49-2	9.18E-02	4.16E-01	1.18E-02	0.1	Annual	2.17E-05	0.002%		
Phosphorus	7723-14-0	6.37E-05	2.79E-04	8.02E-06	1	8 hour	2.17E-06	0.002%		
Sodium	7723-14-0	6.37E-05	2.79E-04	8.02E-06	1	Annual	2.25E-05	0.02%		
Sodium	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Strontium	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Strontium	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Strontium	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Strontium	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Strontium	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Strontium	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Strontium	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	8 hour	6.22E-07	0.001%		
Sulfur	7723-14-0	6.37E-05	2.79E-04	8.02E-06	0.1	Annual	2.25E-05	0.02%		
Sulfur</td										

1

Pg: 2 of 2 1/25/2007 4:51 PM

1

Pg: 2 of 2 1/25/2007 4:51 PM

Table C-1. TAC Emission Rates and Modeling Impact Results

Averaging Period Impact	($\text{kg m}^{-2} / \text{t g/s}$)
Annual	0.211
24 Hour	1.599
8 Hour	2.712
1 Hour	15.779

Toxic Air Contaminant Modeling Results New CFB Boiler National Technology Transfer Center