

EXPEDITED SPCC SETTLEMENT AGREEMENT UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 7, 901 N. 5th ST., KANSAS CITY, KANSAS 66101

07 JUL 26 AM 10: 12

ENVIRONMENTAL PROTECTION

DOCKET NO. CWA-07-2007-0029

On ___July 20, 2006

69 Bypass & Country Club Road

AGENCY-REGION VII REGIONAL HEARING CLERK This Expedited Settlement resolves Respondent's liability

Owned or operated by Harvest Industries, Inc. (Respondent) an authorized representative of the United States Environmental Protection Agency (EPA) conducted an inspection to determine compliance with the Oil Pollution an inspection to determine compliance with the Oil Pollution Prevention (SPCC) regulations promulgated at 40 C.F.R. Part 112 under Section 311(j) of the Clean Water Act (33 U.S.C. § 1321(j)) (the Act), and found that Respondent had violated regulations implementing Section 311(j) of the Act by failing to comply with the regulations as noted on the attached SPILL PREVENTION CONTROL AND COUNTERMEASURE INSPECTION FINDINGS, ALLEGED VIOLATIONS, AND PROPOSED PENALTY FORM (Form), which is bereby incorporated by reference FORM (Form), which is hereby incorporated by reference.

This proceeding and the Expedited Settlement are under the authority vested in the Administrator of EPA by Section 311(b) (6) (B) (i) of the Act, 33 U.S.C. § 1321(b) (6) (B) (i), as amended by the Oil Pollution Act of 1990, and by 40 C.F.R. §§ 22.13(b). The parties enter into this Expedited Settlement in order to settle the civil violations described in the Form for a penalty of \$1,450.00.

This settlement is subject to the following terms and conditions:

The EPA finds that Respondent is subject to the SPCC regulations, which are published at 40 C.F.R. Part 112, and has violated the regulations as further described in the Form. Respondent admits that he/she is subject to 40 C.F.R. Part 112 and that EPA has jurisdiction over Respondent and Respondent's conduct as described in the Form. Respondent does not contest the Inspection Findings, and waives any objections it may have to EPA's jurisdiction. Respondent consents to the assessment of the penalty stated above. Respondent certifies, subject to civil and criminal penalties for making a folce submission to the United States for making a false submission to the United States Government, that the violations have been corrected and Respondent has sent a certified check in the amount of \$1,450.00, payable to the "Environmental Protection Agency," via certified mail to:

U.S. Environmental Protection Agency P.O. Box 371099M Pittsburgh, PA 15251

and Respondent has noted on the penalty payment check Docket No. CWA-07-2007-0029 and "OSLTF – 311." The original, signed Settlement Agreement and copy of the penalty payment check must be sent via certified mail to:

> Paula Higbee U.S. Environmental Protection Agency Region 7, ARTD/STOP 901 N. 5th Street Kansas City, KS 66101

for Federal civil penalties for the violations of the SPCC regulations described in the Form. However, EPA does not waive any rights to take any enforcement action for any other past, present, or future violations by Respondent of the SPCC regulations or of any other federal statute or regulations. By its first signature, EPA ratifies the Inspection Findings and Alleged Violations set forth in the Form.

Upon signing and returning this Expedited Settlement to EPA, Respondent waives the opportunity for a hearing or appeal pursuant to Section 311 of the Act, and consents to EPA's approval of the Expedited Settlement without further notice.

This Expedited Settlement is binding on the parties signing below, and is effective upon the Regional Judicial Officer's signature.

APPROVED BY EPA: Date _6/88/ Chief, Storage Tank and Oil Pollution Branch (STOP) Air, RCRA and Toxics Division APPROVED BY RESPONDENT: Name (print): /HOMAS / Title (print):_ Signature: The estimated cost for correcting the violation(s) is:

IT IS SO ORDERED

Robert L. Patrick

Regional Judicial Officer

____ Date July 26, 2067



Spill Prevention Control and Countermeasure Inspection Findings, Alleged Violations, and Proposed Penalty Form

(Note: Do not use this form if there is no secondary containment)

These Findings, Alleged Violations and Penalties are issued by EPA Region 7 under the authority vested in the Administrator of EPA by Section 311(b)(6)(B)(I) of the Clean Water Act, as amended by the Oil Pollution Act of 1990.

Company Name:	Dock	cet Nu	mber:											
Harvest Industries Inc.	C	W A	2	0 0	7_	-	0	0	2	9				ř
Facility Name:	Date	:					_							
Harvest Brand, Inc.			7/20/	06										
Address:	Inspe	ection]	Numb	er:									_	
69 Bypass and Country Club Road	F	Y -	<u> </u>	N S	P	- _								
City:	Inspe	ector's	Name): 					_					
Pittsburg	Katy	Miley	,	·							_			
State: Zip Code:	EPA	Appro	oving	Officia	.l:	_								
KS 66762	Stan	Walke	r, Bra	nch Cl	nief,	ART	TD/S	ТОР			_			
Contact: Enforcement Contacts:														
Paul Lemert	Paul	la Hig	gbee	phon	e (9	13):	551-	702	8					
(Bulk S	storag	ge Fac	CHILLIE	es)										
GENERAL TOPICS: 112.3(a), (c) (When the SPCC Plan review penalty exceeds											00.0	0.)		
	\$1,000	.00 ent	ter on	y the r	ninin	num	allov	wabl	e of	\$1,0			\$1,0	00.00
(When the SPCC Plan review penalty exceeds	\$1,000. lan- //	.00 ent	ter onl	y the r	minin ———	num	allov	wable	e of	\$1,0				00.00
(When the SPCC Plan review penalty exceeds X No Spill Prevention Control and Countermeasure P	\$1,000.	.00 ent	ter onl	y the r	ninin	num	allov	wable	e of	\$1,0		<u></u>	4	
(When the SPCC Plan review penalty exceeds X No Spill Prevention Control and Countermeasure P Plan not certified by a professional engineer- 112.36	\$1,000.	.00 ent	ter onl	y the r	minin	aum	allov	wable	e of	\$1,0			4	00.00
When the SPCC Plan review penalty exceeds X No Spill Prevention Control and Countermeasure P Plan not certified by a professional engineer- 112.3 No management approval of plan- 112.7	\$1,000.	.00 ent	ter onl	y the r	ours	per	allov day)	wable	2.3(d	\$1,0 			3	00.00
(When the SPCC Plan review penalty exceeds X No Spill Prevention Control and Countermeasure P Plan not certified by a professional engineer- 112.3 No management approval of plan- 112.7 Plan not maintained on site (applies if facility is maintained)	\$1,000.	.00 ent	ter onl	y the r	ours	per	day))- 11	2.3(d	\$1,0(4	00.00 00.00 00.00
When the SPCC Plan review penalty exceeds X No Spill Prevention Control and Countermeasure P Plan not certified by a professional engineer- 112.3(No management approval of plan- 112.7	\$1,000. Plan- 11 (d)	.00 ent	t four	y the r	ours ion,	per	day))- //	22.3(\$1,00 			413	00.00 00.00 00.00 00.00 50.00
When the SPCC Plan review penalty exceeds X No Spill Prevention Control and Countermeasure P Plan not certified by a professional engineer- 112.3(No management approval of plan- 112.7	\$1,000. Plan- 11 (d) Anned a perato age in:	at leas	t four	(4) ho	ours	per	day))- //	22.3(\$1,00 			4	00.00 00.00 00.00 00.00 50.00
When the SPCC Plan review penalty exceeds X No Spill Prevention Control and Countermeasure P Plan not certified by a professional engineer- 112.3 (No management approval of plan- 112.7	s1,000. Plan- 11 (d) anned a operato age in: age pote	at leas design ntial-	t four	(4) ho	ours	per	day))- //	2.3(\$1,00 			4	00.00 00.00 00.00 00.00 50.00 50.00
When the SPCC Plan review penalty exceeds X No Spill Prevention Control and Countermeasure P Plan not certified by a professional engineer- 112.3(No management approval of plan- 112.7	s1,000. Plan- 11 (d) anned a operato age in: age poter age roter	designatial-	t four .5(b). 112.5	(4) ho	ours	per	day))- //	2.3(\$1,0°			4	00.00 00.00 00.00 00.00 50.00 00.00

	Plan does not discuss conformance with SPCC requirement- 112.7(a)(1)	50.00
	Plan does not discuss alternative environmental protection to SPCC requirements- 112.7(a)(2)	50.00
	Plan has inadequate or no facility diagram- 112.7(a)(3)	50.00
	Plan has inadequate or no description of the physical layout of the facility- 112.7(a)(3)(i-vi)	100.00
	Plan has inadequate or no information and procedures for reporting a discharge- 112.7(a)(4)	100.00
	Plan has inadequate or no description and procedures to use when a discharge may occur- 112.7(a)(5)	100.00
	Inadequate or no prediction of equipment failure which could result in discharges- 112.7(b)	100.00
	Plan does not discuss appropriate containment/diversionary structures/equipment- 112.7(c)	100.00
	- If claiming impracticability of appropriate containment/diversionary structures:	
	Impracticability has not been clearly denoted and demonstrated- 112.7(d)	400.00
	No contingency plan- 112.7(d)(1)	100.00
	No written commitment of manpower, equipment, and materials- 112.7(d)(2)	100.00
	Plan has inadequate or no discussion of conformance with SPCC rules or applicable State rules, regulations and guidelines- 112.7(j)	50.00
	WRITTEN PROCEDURES AND INSPECTION RECORDS 112.7(e)	
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	50.00
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written	50.00
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	50.00
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	50.00
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	50.00
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	50.00 50.00 50.00
X	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	50.00 50.00 50.00
X	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	

	Plan has inadequate or no discussion of personnel and spill prevention procedures
	SECURITY (excluding Production Facilities) 112.7(g)
	Facility not fully fenced and entrance gates are not locked and/or guarded when plant is unattended or not in production- 112.7(g)(1)
	Master flow and drain valves that permit direct outward flow to the surface are not secured in closed position when in a non-operating or standby status- 112.7(g)(2)
X	Starter controls on pumps are not locked in the "off" position or located at a site accessible only to authorized personnel when pumps are not in a non-operating or standby status- 112.7(g)(3)
X	Loading and unloading connection(s) of piping/pipelines are not capped or blank-flanged when not in service or standby status- 112.7(g)(4)
	Facility lighting not adequate to facilitate the discovery of spills during hours of darkness and to deter vandalism- 112.7(g)(5)
	Plan has inadequate or no discussion of facility security
-	FACILITY TANK CAR AND TANK TRUCK LOADING/UNLOADING RACK 112.7(h)
	Inadequate secondary containment, and/or rack drainage does not flow to catchment basin, treatment system, or quick drainage system- 112.7(h)(1)
	Containment system does not hold at least the maximum capacity of the largest single compartment of any tank car or tank truck- 112.7(h)(1)
	There are no interlocked warning lights, or physical barrier system, or warning signs, or vehicle brake interlock system to prevent vehicular departure before complete disconnect from transfer lines- 112.7(h)(2)200.00
	There is no inspection of lowermost drains and all outlets prior to filling and departure of any tank car or tank truck- 112.7(h)(3)
	Plan has inadequate or no discussion of facility tank car and tank truck loading/unloading rack
	FACILITY DRAINAGE FROM DIKED AREAS 112.8(b) & (c)
	Valves used for drainage from diked storage areas to drainage system, watercourse, or effluent treatment system not controlled to prevent a discharge- 112.8(b)(2)
	Run-off rainwater from diked areas is not inspected- 112.8(c)(3)(ii)
	Valves not opened and resealed under responsible supervision- 112.8(c)(3)(iii)
	Adequate records (or NPDES permit records) of drainage from diked areas not maintained- 112.8(c)(3)(iv) 50.00
	FACILITY DRAINAGE FROM UNDIKED AREAS 112.8(b)
	Drainage from undiked areas do not flow into catchment basins ponds, or lagoons, or no diversion systems to retain or return a discharge to the facility- 112.8(b)(3)&(4)
	Two "lift" pumps are not provided for more that one treatment unit- 112.8(b)(5)
	Plan has inadequate or no discussion of facility drainage

BULK STORAGE CONTAINERS 112.8(c)

	Plan has inadequate or no risk analysis and/or evaluation of field-constructed aboveground tanks for brittle fracture- 112.7(i)
	Material and construction of tanks not compatible to the oil stored and the conditions of storage such as pressure and temperature- 112.8(c)(1)
	Secondary containment appears to be inadequate- 112.8(c)(2)
X	Containment systems, including walls and floors are not sufficiently impervious to contain oil- 112.8(c)(2) 250.00
	Excessive vegetation which affects the integrity and/or walls slightly eroded
	Containment bypass valves are not sealed closed when not draining rainwater- 112.8(c)(3)(i)
	Completely buried tanks are not protected from corrosion or are not subjected to regular pressure testing- 112.8(c)(4)
	Partially buried tanks do not have buried sections protected from corrosion- 112.8(c)(5)
	Aboveground tanks are not subject to visual inspections- 112.8(c)(6)
	Aboveground tanks are not subject to periodic integrity testing, such as hydrostatic, nondestructive methods, etc 112.8(c)(6)
	Records of inspections (or customary business records) do not include inspections of tank supports/foundation, deterioration, discharges and/or accumulations of oil inside diked areas- 112.8(c)(6) 100.00
	Steam return /exhaust of internal heating coils which discharge into an open water course are not monitored, passed through a settling tank, skimmer, or other separation system- 112.8(c)(7)
Cor	ntainer installations are not engineered if:
	No audible or visual high liquid level alarm- 112.8(c)(8)(i), or
	No high liquid level pump cutoff devices- 112.8(c)(8)(ii), or
	No audible or code signal communications between tank gauger and pumping station- 112.8(c)(8)(iii), or300.00
	No fast response system for determining liquid levels, such as computers, telepulse or direct vision gauges- 112.8(c)(8)(iv)
	No testing of liquid level sensing devices to ensure proper operation- 112.8(c)(8)(v)
	Effluent treatment facilities which discharge directly to navigable waters are not observed frequently to detect oil spills- 112.8(c)(9)
	Causes of leaks resulting in accumulations of oil in diked areas are not promptly corrected- 112.8(c)(10) 300.00
	Mobile or portable storage containers are not positioned to prevent discharged oil from reaching navigable water- 112.8(c)(11)
	Secondary containment inadequate for mobile or portable storage tanks- 112.8(c)(11)

	Plan has inadequate or no discussion of bulk storage tanks
•	FACILITY TRANSFER OPERATIONS, PUMPING, AND FACILITY PROCESS 112.8(d)
	Buried piping is not corrosion protected with protective wrapping, coating, or cathodic protection -112.8(d)(1)100.00
	Corrective action is not taken on exposed sections of buried piping when deterioration is found- 112.8(d)(1)300.00
X	Not-in-service or standby piping are not capped or blank-flanged and marked as to origin- 112.8(d)(2)50.00
	Pipe supports are not properly designed to minimize abrasion and corrosion, and allow for expansion and contraction- 112.8(d)(3)
	Aboveground valves, piping and appurtenances are not inspected regularly- 112.8(d)(4)
	Periodic integrity and leak testing of buried piping is not conducted- 112.8(d)(4)
	Vehicle traffic is not warned of aboveground piping or other oil transfer operations- 112.8(d)(5)
	Plan has inadequate or no discussion of facility transfer operations, pumping, and facility process50.00
	, TOTAL 0 1 450 00

IN THE MATTER OF Harvest Industries, Inc., Respondent Docket No. CWA-07-2007-0029

CERTIFICATE OF SERVICE

I certify that a true and correct copy of the foregoing Expedited SPCC Settlement Agreement was sent this day to the following addressees:

Copy hand delivered to Attorney for Complainant:

Kristina Kemp Assistant Regional Counsel Region VII United States Environmental Protection Agency 901 N. 5th Street Kansas City, Kansas 66101

Copy by Certified Mail Return Receipt to:

Thomas Morthorst, President Harvest Industries, Inc. 69 Bypass and Country Club Road Pittsburg, Kansas 66762

Huly 26, 2007

Kathy Robinson

Regional Hearing Clerk