UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 4

IN THE MATTER OF:)	DOCKET NO. : CWA-04-2022-0406(b)
Georgia Power Company – Jack McDonough SP)	SPCC Expedited Settlement Agreement Pursuant to CWA Section 311(b)(6)(B)(i)
Respondent)	
)	

On October 6, 2020, an authorized representative of the United States Environmental Protection Agency conducted an inspection of Respondent's facility located at 5551 South Cobb Drive SE, Atlanta, Georgia 30308 (the Facility), to determine compliance with the Oil Pollution Prevention regulations promulgated at 40 C.F.R. Part 112 under Section 311(j) of the Clean Water Act (CWA), as amended, 33 U.S.C. § 1321(j). The EPA determined that Respondent, as owner or operator of the Facility, violated the Oil Pollution Prevention regulations as noted on the attached "Spill Prevention Control and Countermeasure Plan (SPCC) Inspection Findings, Alleged Violations, and Proposed Penalty Form" (Violations Form), which is incorporated by reference. By its signature below, the EPA ratifies the inspection findings and alleged violations set forth in the Violations Form.

The EPA is authorized to enter into this Expedited Settlement Agreement (ESA) under the authority of Section 311(b)(6)(B)(i) of the CWA, 33 U.S.C. § 1321(b)(6)(B)(i), as amended by the Oil Pollution Act of 1990, and 40 C.F.R. § 22.13(b). The parties enter into this ESA to settle the civil violations described in the Violations Form for a penalty of **\$1,906.**

This ESA is subject to the following terms and conditions:

The EPA finds Respondent is subject to the Oil Pollution Prevention regulations and has violated the regulations as described in the Violations Form. Respondent admits it is subject to the Oil Pollution Prevention regulations and that the EPA has jurisdiction over Respondent and Respondent's conduct as described in the Violations Form. Respondent does not contest the inspection findings and neither admits nor denies the allegations in the Violations Form. Respondent also waives any objections it may have to the EPA's jurisdiction, any rights to contest the allegations, and its right to appeal this ESA and Final Order. Respondent consents to the assessment of the penalty stated above.

Respondent certifies, subject to civil and criminal penalties for making a false submission to the United States Government, that the violations identified in the Violations Form have been corrected and the Facility is now in full compliance with the Oil Pollution Prevention regulations (or that the violations will be corrected, and the Facility

brought into full compliance with the Oil Pollution Prevention regulations within an alternative time frame agreed to by the EPA in writing).

Respondent agrees to pay the penalty assessed within 30 calendar days of the effective date of this ESA. Instructions for making the penalty payment are enclosed with this ESA as Attachment A and incorporated herein by reference. Failure by Respondent to pay the penalty assessed by this ESA in full by its due date may subject Respondent to a civil action to collect the assessed penalty plus interest, attorney's fees, costs and an additional quarterly nonpayment penalty pursuant to CWA § 311(b)(6)(H), 33 U.S.C. § 1321(b)(6)(H). In any such collection action, the validity, amount, and appropriateness of the penalty shall not be subject to review. Any payment made pursuant to this ESA is a penalty within the meaning of Section 162(f) of the Internal Revenue Code, 26 U.S.C. § 162(f), and therefore Respondent shall not claim it as a tax-deductible expenditure for purposes of federal, state or local law.

Upon signing and returning this ESA to the EPA, Respondent waives the opportunity for a hearing or appeal pursuant to Section 311(b)(6)(G) of the CWA, 33 U.S.C. § 1321(b)(6)(G), and consents to the EPA's approval of the ESA without further notice. Moreover, Respondent agrees to bear its own costs and attorney's fees related to this ESA.

After the parties sign this ESA and Respondent pays the civil penalty, the EPA will take no further civil penalty action against Respondent for the alleged violations of the Oil Pollution Prevention regulations described in the Violations Form through the effective date of this ESA. However, the EPA does not waive any rights to take any enforcement action for any other past, present, or future violations by Respondent of the Oil Pollution Prevention regulations or of any other federal statute or regulations.

This ESA is binding on the parties signing below and is effective upon filing with the Regional Hearing Clerk pursuant to 40 C.F.R. § 22.31(b). Each person signing this ESA certifies that he or she has the authority to sign for the party who he or she represents and to bind that party to its terms.

Parties agree to receive service by electronic means at the

following valid email addresses: joyner.william@epa.gov for the EPA and jbwether@southernco.com for Respondent. Once the ESA is signed by the Regional Judicial Officer, the original ESA will be filed with the Regional Hearing Clerk. A copy will then be emailed to Respondent. The ESA shall not affect the EPA's right to pursue appropriate injunctive relief or criminal sanctions for any violations of law and does not waive, extinguish, or otherwise affect Respondent's obligation to comply with all applicable provisions of the CWA and regulations promulgated thereunder.

If Respondent does not sign and return this ESA as presented within 30 days of the date of its receipt, or within an extension timeframe approved by the EPA, this proposed ESA is withdrawn without prejudice to the EPA's ability to file any other enforcement action for the violations identified in the Violations Form.

APPROVED BY RESPONDENT:

Name (print): Burns Wetherington (for Georgia Power Company)

Title (print): Environmental Affairs Principal Engineer

APPROVED BY EPA:

Mary Jo Bragan Chief, Water Enforcement Branch Enforcement and Compliance Assurance Division

FINAL ORDER

Having determined that this Agreement is authorized by law, the foregoing Expedited Settlement Agreement is hereby incorporated into the Final Order.

IT IS SO ORDERED:

Robin B. Allen Regional Judicial Officer

CERTIFICATE OF SERVICE

I hereby certify that I have filed the foregoing Expedited Settlement Agreement and Final Order, in the matter of Georgia Power Company, Docket No. CWA-04-2022-0406(b), and that copies of the same were sent to the parties as indicated below.

Via email to all parties:

To Respondent:

Burns Wetherington Georgia Power Company 241 Ralph McGill Boulevard Atlanta, Georgia 30308 404-506-2533 jbwether@southernco.com

To EPA:

William Joyner
Wastewater Enforcement Section
Enforcement and Compliance Assurance Division
U.S. EPA Region 4
61 Forsyth Street, S.W.
Atlanta, Georgia 30303
(404) 562-8795
Joyner.william@epa.gov

Stephen P. Smith Office of Regional Counsel U.S. EPA Region 4 61 Forsyth Street, S.W. Atlanta, Georgia 30303 (404) 562-9554 Smith.Stephen@epa.gov

Shannon L. Richardson, Regional Hearing Clerk U.S. EPA Region 4 61 Forsyth Street, S.W. Atlanta, Georgia 30303-8960

Spill Prevention Control and Countermeasure Inspection Findings, Alleged Violations, and Proposed Penalty Form

These Findings, Alleged Violations and Penalties are issued by EPA under the authority vested in the Administrator of the EPA by Section 311(b)(6)(B)(I) of the Clean Water Act, as amended by the Oil Pollution Act of 1990.

Company Name

J

Docket Number

UNITED STAKES

Georgia Power Company	CWA-04-2022-0406(b)
Facility Name	Date 10-6-2020
Jack McDonough SP	Date 10-6-2020
Address	Facility ID Number PROTECTION
5551 South Cobb Drive SE	GA2101-001
City	Inspector's Name
Atlanta	Ted Walden
State Zip Code	EPA Approving Official
GA 30	Mary Jo Bragan
Contact	Enforcement Contact
Burns Weatherington	William Joyner
Total Storage Capacity	
54,435 gallons	
GENERAL TOPICS: 4	(Bulk Storage Facilities) 40 C.F.R.112.3(a), (d), (e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d)
Failure to have a Spill Prevention Contr	ol and Countermeasure Plan 112.3 (\$1,750)
	ot certified by a professional engineer * 112.3(d) (\$500) facilities unless a hybrid (PE/QF plan) see Qualified facility 112.6 section
Certification lacks one or more required	elements 112.3(d)(1) (\$125)
Plan not maintained on site (if manned a	at least four hrs/day) or not available for review 112.3(e)(1) (\$350)
No evidence of five-year review of plan	by owner/operator 112.5(b) (\$100)
	s had a change in: design, construction, operation, cility's discharge potential 112.5(a) (\$100)
Amendment(s) not certified by a profess	sional engineer 112.5(c) (\$175)
No management approval of plan 112.7	(\$500)
Plan does not follow sequence of the rul	e and/or cross-reference not provided 112.7 (\$175)
Plan does not discuss additional procedu	ures/methods/equipment not yet fully operational 112.7 (\$100)

	Plan does not discuss alternative environmental protection to SPCC requirements 112.7(a)(2) (\$225)	
	Plan has inadequate or no facility diagram 112.7(a)(3) (\$100)	
	Inadequate or no listing of type of oil and storage capacity of containers 112.7(a)(3)(i) (\$75)	
	Inadequate or no discharge prevention measures 112.7(a)(3)(ii) (\$75)	
	Inadequate or no description of drainage controls 112.7(a)(3)(iii) (\$75)	
	Inadequate or no description of countermeasures for discharge discovery, response and cleanup 112.7(a)(3(iv) (\$75)	
	Methods of disposal of recovered materials not in accordance with legal requirements 112.7(a)(3)(v) (\$75)	
	No contact list & phone numbers for response & reporting discharges 112.7(a)(3)(vi) (\$75)	
	Plan has inadequate or no information and procedures for reporting a discharge 112.7(a)(4) (\$125)	
	Plan has inadequate or no description and procedures to use when a discharge may occur 112.7(a)(5) (\$175)	
7	Inadequate or no prediction of equipment failure which could result in discharges 112.7(b) (\$175)	\$175
7	Plan does not discuss and facility does not implement appropriate containment/diversionary stuctures/ equipment 112.7 (\$450)	\$450
	Inadequate containment or drainage for Loading Area- 112.7(c) (\$450)	
	Plan has no or inadequate discussion of any applicable more stringent State rules, regulations, and guidelines- 112.7(j) (\$100)	
	Plan does not include a signed copy of the Certification of Applicability of the Substantial Harm Criteria per 40 CFR Part 112.20(e) (\$175)	
	If claiming impracticability of contiainment and appropriate diversionary structures: Impracticability has not been clearly denoted and demonstrated in plan 112.7(d) (\$125)	
	No periodic integrity and leak testing 112.7(d) (\$175)	
	No contingency plan 112.7(d)(1) (\$175)	
	No written commitment of manpower, equipment, and materials 112.7(d)(2) (\$175)	
	No periodic integrity and leak testing , if impracticability is claimed 112.7(d) (\$175)	
	Plan has no or inadequate discussion of general requirements not already specified 112.7(j) (\$100)	
	QUALIFIED FACILITY REQUIREMENTS: 40 C.F.R. 112.6	_
	Qualified Facility: No Self certification 112.6(a) (\$500)	_
	Qualified Facility: Self certification lacks required elements 112.6(a) (\$125)	
	Qualified Facility: Technical amendments not certified 112.6(b) (\$175)	
	Qualified Facility: Qualified Facility Plan includes alternative measures not certified by liscensed Professional Engineer 112.6(b) \$175	

	Qualified Facility: Environmental Equivalence or Impracticability not certified by PE 112.6(b)(4) (\$400)	
	WRITTEN PROCEDURES AND INSPECTION RECORDS: 40 C.F.R. 112.7(e)	
<u> </u>	Plan does not include inspections and test procedures in accordance with 40 CFR Part 112 112.7(e) (\$100)	
	Inspections and tests required are not in accordance with written procedures developed for the facility 112.7(e) (\$100)	
	No Inspection records were available for review 112.7(e) (\$225)	
	(Written procedures and/or a record of inspections and/or customary business records) Inspection records are not signed by appropriate supervisor or inspector 112.7(e) (\$100)	
	Inspection records are not maintained for three years 112.7(e) (\$100)	
	PERSONNEL TRAINING AND DISCHARGE PREVENTION PROCEDURES: 40 C.F.R. 112.7(f)	_
	No training on the operation and maintenance of equipment to prevent discharges and/or facility operations 112.7(f)(1) (\$100)	-
	No training on discharge procedure protocols 112.7(f)(1) (\$100)	
	No training on the applicable pollution control laws, rules and regulations, and/or SPCC plan 112.7(f)(1) (\$100)	
	No designated person accountable for spill prevention 112.7(f)(2) (\$100)	
	Spill prevention briefings are not scheduled and conducted at least once a year 112.7(f)(3) (\$100)	
	Plan has inadequate or no discussion of personnel and spill prevention procedures 112.7(a)(1) (\$100)	
	SECURITY (excluding Production Facilities): 40 C.F.R. 112.7(g)	_
	Plan does not describe how the facility secures and controls acces to the oil handling, processing and storage areas 112.7(g)(1) (\$175)	-
	Master flow and drain valves not secured 112.7(g)(2) (\$350)	
	Starter controls on pumps not secured to prevent unauthorized access- 112.7(g) (\$100)	
	Out-of-service and loading/unloading connection(s) of piping/pipelines not adequately secured 112.7(g)(4) (\$100)	
	Plan does not address the appropriateness of security lighting to both prevent acts of vandalism and assist in the discovery of oil discharges 12.7(g) (\$175)	
_	FACILITY TANK CAR AND TANK TRUCK LOADING/UNLOADING: 40 C.F.R. 112.7(c) and/or (h-j)	
	Inadequate secondary containment, and/or rack drainage does not flow to catchment basin treatment system, or quick drainage system 112.7(h)(1) (\$850)	
	Containment system does not hold at least the maximum capacity of the largest single compartment of any tank car or tank truck 112.7(h)(1) (\$525)	
	There are no interlocked warning lights, or physical barrier system, or warning signs, or vehicle brake interlock system to prevent vehicular departure before complete disconnect from transfer lines- 112.7(h)(2) (\$350)	

	There is no inspection of lowermost drains and all outlets prior to filling and departure of any tank car or tank truck- 112.7(h)(3) (\$175)	
	Plan has inadequate or no discussion of facility tank car and tank truck loading/unloading rack 112.7(a)(1) (\$100)	
	QUALIFIED OIL OPERATIONAL EQUIPMENT: 40 C.F.R. 112.7(k)	
	Failure to establish and document procedures for inspections or a monitoring program to detect equipment failure and/or a discharge 112.7(k)(2)(i) (\$175)	
	Failure to provide an oil spill contingency plan 112.7(k)(2)(ii)(A) (\$175)	
	No written commitment of manpower, equipment, and materials 112.7(k)(2)(ii)(B) (\$175)	
	FACILITY DRAINAGE: 40 C.F.R 112.8(b) & (c) and/or 112.12(b) & (c)	
	Secondary Containment circumvented due to containment bypass valves left open and/or pumps and ejectors not manually activated to prevent a discharge 112.8(b)(1)and(2), and 112.8(c)(3)(i) (\$700)	
	Dike water is not inspected prior to discharge and/or valves not open & resealed under responsible supervision 112.8(c)(3)(ii)and(iii) (\$525)	
	Adequate records (or NPDES permit records) of drainage from diked areas not maintained 112.8(c)(3)(iv) (\$100)	
7	Drainage from undiked areas do not flow into catchment basins ponds or lagoons, or no diversion system to retain or return a discharge to the facility 112.8(b)(3)and(4) (\$525)	\$525
	Two "lift" pumps are not provided for more that one treatment unit 112.8(b)(5) (\$75)	
V	Plan has inadequate or no discussion of facility drainage 112.7(a)(1) (\$100)	\$100
	BULK STORAGE CONTAINERS: 40 C.F.R. 112.7(i), 112.8(c) and/or 112.12(c)	
	Failure to conduct evaluation of field-constructed aboveground containers for risk of discharge or failure due to brittle fracture or other catastrophe 112.7(i) \$350	
	Material and construction of containers not compatible to the oil stored and the conditions of storage such as pressure and temperature $112.8(c)(1)$ (\$525)	
	Secondary containment is inadequate 112.8(c)(2) (\$850)	
	Secondary containment systems are not sufficiently impervious to contain oil 112.8(c)(2) (\$425)	
	Completely buried tanks installed after August 16, 2002 are not protected from corrosion or are not subjected to regular pressure testing 112.8(c)(4) (\$175)	
	Buried sections of partially burried metallic tans are not prootected from corrosion 112.8(c)(5) (\$175)	
	Aboveground tanks are not subject to visual inspections 112.8(c)(6) (\$525)	
	Aboveground tanks are not subject to periodic integrity testing techniques such as visual inspections hydrostatic testing, or other nondestructive methods 112.8(c)(6) (\$525)	
	Records of inspections (or customary business records) do not include inspections of container supports/foundation, signes of container deterioration, discharges and/or accumulations of oil inside diked areas 112.8(c)	
	Steam return/exhaust of internal heating coils which discharge into an open water course are not monitored, passed through a settling tank, skimmer or other separation system 112.8(c)(7) (\$175)	

Container installations are not engineered or updated in accordance with good engineering practice because none of the following are present: 112.8(c)(8) (\$525) -high liquid level alarm with audable or visual signal, or audible air vent 112.8(c)(8)(i) -high liquid level pump cutoff devices set to stop flow at a predetermined level 112.8(c)(8)(ii) -direct audible or code signal communication between container gauger and pumping station 112.8(c)(8)(iii) -fast response system for determining liquid level of each bulk storage container, or direct vision gaugues with a person present to monitor gauges and the overall filling of bulk storage containers 112.8(c)(8)(iv)
No testing of liquid level sensing devices to ensure proper operation 112.8(c)(8)(v) (\$100)
Effluent treatment facilities not observed frequently to detect possible system upsets that could cause a discharge as described in §112.1(b)- 112.8(c)(9) (\$175)
Causes of leaks resulting in accumulations of oil in diked areas are not promptly corrected 112.8(c)(10) (\$525)
Mobile or portable storage containers are not positioned or located to prevent discharged oil from reaching navigable water or have inadequate secondary containment 112.8(c)(11) (\$175)
Secondary containment inadequate for mobile or portable storage tanks 112.8(c)(11) (\$600)
Plan has inadequate or no discussion of bulk storage tanks 112.7(a)(1) (\$100)
FACILITY TRANSFER OPERATIONS, PUMPING, AND FACILITY PROCESS: 40 C.F.R. 112.8(d) and 112.12(d)
Buried piping is not corrosion protected with protective wrapping, coating or cathodic protection protection 112.8(d)(1) (\$175)
Corrective action is not taken on exposed sections of buried piping when deterioration is found 112.8(d)(1) (\$525)
Not-in-service or standby piping is not capped or blank-flanged and marked as to origin 112.8(d)(2) (\$100)
Pipe supports are not properly designed to minimize abrasion and corrosion, and allow for expansion and contraction 112.8(d)(3) (\$100)
Aboveground valves, piping and appurtenances are not inspected regularly 112.8(d)(4) (\$350)
Periodic integrity and leak testing of buried piping is not conducted at time of installation, modification, construction, relocation, or replacement 112.8(d)(4) (\$175)
Vehicle traffic is not warned of aboveground piping or other oil transfer operations 112.8(d)(5) (\$175)
Plan has inadequate or no discussion of facility transfer operations, pumping, and facility process 112.7(a)(1) (\$100)
SUB TOTAL \$1,525 Multiplier 1.25

Attachment A SPCC Expedited Settlement Agreement Payment Instructions

Payment shall be in a single payment, due no later than 30 calendar days from the effective date of the Final Order. If the due date for the payment falls on a weekend or federal holiday, then the due date is the next business day. The date the payment is made is considered to be the date processed by U.S. Bank, as described below. Payment must be received by 11:00 a.m. Eastern Standard Time to be considered as received that day.

The payment shall be made by remitting a check or making a wire transfer or on-line payment. The check or other payment shall:

- designate the name and docket number of this case, and
- be payable to "Treasurer, United States of America."

The payment shall be remitted as follows:

If remitted by regular U.S. mail:

U.S. Environmental Protection Agency / Fines and Penalties Cincinnati Finance Center P.O. Box 979077 St. Louis, Missouri 63197

If remitted by any overnight commercial carrier:

U.S. Bank Government Lockbox 979077 1005 Convention Plaza Mail Station SL-MO-C2GL St. Louis, Missouri 63101

If remitted by wire transfer: Any wire transfer must be sent directly to the Federal Reserve Bank in New York City using the following information:

Federal Reserve Bank of New York

ABA = 021030004

Account = 68010727

SWIFT address = FRNYUS33

33 Liberty Street

New York, New York 10045

Field Tag 4200 of the Fedwire message should re-

Field Tag 4200 of the Fedwire message should read "D 68010727 Environmental Protection Agency"

If remitted through the Automated Clearing House (ACH) for receiving US currency:

U.S. Treasury REX / Cashlink ACH Receiver

ABA: 051036706

Account Number: 310006, Environmental Protection Agency

CTX Format Transaction Code 22 – checking

Physical location of U.S. Treasury facility: 5700 Rivertech Court Riverdale, Maryland 20737

If remitted on-line with a debit card or credit card: No user name, password, or account number is necessary for this option. On-line payment can be accessed via www.pay.gov, entering 1.1 in the form search box on the left side of the screen, opening the form, and following the directions on the screen.

At the time of payment, a copy of the check (or notification of other type of payment) shall also be sent by mail and/or email to:

Regional Hearing Clerk
U.S. EPA Region 4
Office of Regional Counsel
61 Forsyth Street, SW
Atlanta, GA 30303-8960
R4_Regional_Hearing_Clerk@epa.gov

and

William Joyner U.S. EPA Region 4 61 Forsyth Street, SW Atlanta, GA 30303-8960 Joyner.william@epa.gov