



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2010 JUN 22 PM 12:43

JUN 22 2010

FILED  
EPA REGION VIII  
HEARING CLERK

Ref: 8ENF-W

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Ken Bousfield, Director  
Division of Drinking Water  
Utah Department of Environmental Quality  
P.O. Box 144830  
Salt Lake City, UT 84114

Re: NOTICE OF VIOLATION

Docket No. SDWA-08-2010-0051

Dalton Springs Campground  
Public Water System  
PWS ID # UTAH19017

Dear Mr. Bousfield:

The public water supply system referenced above (the system) has violated certain provisions of the National Primary Drinking Water Regulations at 40 C.F.R. part 141 (the drinking water regulations) according to records that the United States Environmental Protection Agency (EPA) has obtained from the Utah Department of Environmental Quality.

EPA promulgated the drinking water regulations under the authority of the Safe Drinking Water Act (the Act), 42 U.S.C. §§ 300f, et seq. EPA is issuing this notice of violation pursuant to § 1414(a) of the Act, 42 U.S.C. § 300g-3(a), which authorizes EPA to issue an administrative compliance order or file a lawsuit concerning the system if the State of Utah (the State) does not commence an appropriate enforcement action within 30 days of receiving this notice.

The violations are listed below.

Date(s) of Violation	Violation
2006, 2009	Failure to monitor for nitrate [40 C.F.R. § 141.23]
2 <sup>nd</sup> quarter 2008	Failure to monitor for total coliform [40 C.F.R. § 141.21(a)]


If the State does not commence an appropriate enforcement action concerning the system within 30 days from your receipt of the notification, EPA will likely issue an administrative order to the owner and/or operator of the system.

**Please have your staff notify Mario Mérida at (303) 312-6297 within 20 days** if your records show any discrepancies with the violations cited above, if your staff learns of any change in the system's compliance status, or if there are any questions or comments. Thank you for your assistance.

Sincerely,



Darcy O'Connor, Acting Director  
Technical Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice



*for* David Rochlin, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: Tina Artemis, EPA Regional Hearing Clerk  
Patti Fauver, UT DEQ DW (w/o enclosure)  
Pamela Brown, Forest Supervisor, Manti-La Sal National Forest