

R8 Hearing Clerk

From: Tyson, Elizabeth
Sent: Monday, July 27, 2026 11:55 AM
To: swomservices@gmail.com; dwoodward@dteworld.com
Cc: StClair, Kyle; Parker, Robert; Tourney, Seth; Justin Latham; Ashley Stegeman; Hendon2, Keenan; Kim Parker; Lillian.Freed@usda.gov; lstrong@cnchd.org; sara.budge@wyo.gov; 'Clay Vanhouten'; mchristopher@warws.com; Tyrel Owens; larry.allen@fremontcountywy.gov; Stueckler, Hannes; harringtondubois@gmail.com; R8 Hearing Clerk
Subject: Closure of Emergency Administrative Order - Warm Springs Water District Public Water System (PWSID# WY5600861), Docket No. SDWA-08-2026-0046, Fremont County

Good afternoon,

The EPA has decided to close the Emergency Administrative Order (Order) regarding the public water system specified in the subject line. The EPA has determined that there are no remaining requirements of the Order. The System issued a boil water advisory and made alternate water available to affected users, implemented the corrective actions listed in bullets below, disinfected and flushed the distribution system, and monitored water quality within the distribution system after corrective actions were completed.

Corrective actions:

- Replaced suction line on chlorine pump.
 - Calibrated colorimeter for taking chlorine residuals.
- Screened chlorine pump flush line with 24 mesh screen.
- Gasket installed at tank hatch latch.
- Disinfected sample locations.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141, including all requirements of the Level 2 Assessment and correcting any sanitary defects. Violation of the drinking water regulations may result in a court imposed injunction and/or penalties. If you ever have any questions about your obligations under the drinking water regulations and remaining in compliance, a list of rule manager contact information for EPA Region 8 can be found online, linked [here](#).

We recommend maintaining a residual of between 0.2 mg/L and 2.0 mg/L free chlorine, to lower the likelihood of similar contamination in the future. Per the 2023 sanitary survey of the system, weekly inspection of the chlorination equipment and regular testing of the chlorine residual throughout the system were recommended to help maintain residuals at the desired level.

Thank you for your work to resolve these issues. If you have any questions regarding this enforcement matter, please contact me.

Thank you,

Elizabeth Tyson
Safe Drinking Water Act Enforcement Unit | Enforcement and Compliance Assurance Division
US EPA Region 8 | 1595 Wynkoop St. 8ECA-W-S | Denver, CO 80202
303.312.6646 | tyson.elizabeth@epa.gov