Tribbett, Kate

FILED Apr 18, 2024 2:50 pm

From: Bell, Marlon
Sent: Thursday, April 18, 2024 12:31 PM

U.S. EPA REGION 8
HEARING CLERK

To: Dave.glenn@wyo.gov

Cc: lindaf@crookcounty.wy.gov; kdennis@crookcounty.wy.gov; anthony.ornelas@wyo.gov; R8 Hearing

Clerk; jentry.eatherton@wyo.gov; Lee, Dale; greg.devereaux@wyo.gov; Rivers, Anthony; Ashley Stegeman; Ellis, Bradley; Clay Vanhouten; Lewis, Dennis; Doug Evans; Erica East; Brough, James; Jennifer Escobedo; Justin Latham; Hendon2, Keenan; Kim Parker; Lorraine Werner; Baron, Mark; Matthew Peterson; Ruth Heald; Sara Budge; Sarah Geffre; stanley.miller@wyo.gov; Tyrel Owens; Langenfeld, Matthew; Bloom, Judy; Parker, Robert; StClair, Kyle (he/him/his); Stanton, Noah; Cantor, Tiffany; Rathbone, Colleen (she/her/hers); Wells, Ellen; Detty, Joan; Swanson, Amy; Tourney, Seth

Subject: Closure of Administrative Order – Keyhole State Park Cottonwood CG WY600652, Docket No.

SDWA-08-2024-0012, Crook County

Dave Glenn,

The EPA has decided to close the Administrative Order (Order) regarding the public water system specified in the subject line. The EPA has determined that there are no remaining requirements of the Order.

The Order required the system to complete corrective action and issue PN:

- Cottonwood Well (WL01) SD#1: All openings must be sealed and watertight to prevent contamination of the well. (New well cap was installed).
- Cottonwood Well (WL01) SD#2: The well must be fitted with a functioning sanitary seal and a tightly bolted cap to prevent contamination of the well. (All openings are now watertight).
- Pressure Tank ID: PC02 SD#3: Pressure Tank in Treatment Building The corrosion on the tank must be repaired or the tank must be replaced. Failure to maintain the structural and sanitary integrity of the tank could lead directly to contamination within the tank, illness and/or the loss of property. (New pressure tank was installed).

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

Marlon Bell

Physical Scientist (ENV-OSC)
EPA Region 8 | ECAD | SDWA Enforcement Unit
1595 Wynkoop Street, Denver, CO 80202
303.312.6539 | Bell.Marlon@epa.gov