

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION VII

901 NORTH 5TH STREET

KANSAS CITY, KANSAS 66101

07 SEP -5 PM 1:02

ENVIRONMENTAL PROTECTION
AGENCY-REGION VII
REGIONAL HEARING CLERK

In the Matter of:

City of Kirksville d/b/a
Kirksville Water Treatment Plant
201 South Franklin Street
Kirksville, Missouri 63501

Docket No. CAA-07-2007-0011

Respondent.

FIRST AMENDMENT TO ADMINISTRATIVE ORDER ON CONSENT

Pursuant to the Administrative Order on Consent previously entered into by the Parties,
the Parties hereby agree as follows:

1. Paragraph 20(a), is amended in its entirety to now provide as follows:

- a) Modify and correct deficiencies in the chlorination system control room, including, but not limited to:
 - (i) Remove existing door and frame and installation of window;
 - (ii) Remove existing window and install door and frame;
 - (iii) Install new chlorination system controls and associated mechanisms;
 - (iv) Relocate chlorine dioxide equipment;
 - (v) Construct new office space; and
 - (vi) Implement any other improvements to the facility necessary to comply with recognized and generally accepted good engineering practices, as required by 40 C.F.R. § 68.48(b).

2. All other provisions of the Administrative Order on Consent and Attachments thereto
as previously entered into remain in full force and effect.

to execute and bind legally the Parties to this document.

4. This First Amendment to Administrative Order on Consent shall be effective upon the signature by the representative of both Parties to the Order.

5. This First Amendment to Administrative Order on Consent shall terminate on December 29, 2007.

**U.S. ENVIRONMENTAL PROTECTION AGENCY
REGION VII**

Date: 9/4

Becky Weber
Becky Weber
Director
Air, RCRA and Toxics Division

**CITY OF KIRKSVILLE d/b/a
KIRKSVILLE WATER TREATMENT PLANT**

Date: 8/30/07

By Mark E. Macomber

Title City Manager

Date August 30, 2007