5/30/2023

Tribbett, Katherine (Kate)

2:36 PM

eceived by	
Region VIII	
aring Clerk	
om;	
vyo.gov;	
, ,	
hd.org;	
sara.budge@wyo.gov; geffres@sweet.wy.us; stanley.miller@wyo.gov; Tyler Owens	
: No.	

The EPA has decided to close the Emergency Administrative Order (Order) regarding the public water system specified in the subject line. The EPA has determined that there are no remaining requirements of the Order. System improvements included investigative sampling to pinpoint the area of contamination, a system inspection from the Wyoming Association of Rural Water Systems, updates to sampling procedures to ensure sampling error does not occur, and the replacement of the 24-mesh screen on the overflow pipe of the storage tank.

Please be aware that you are still required to correct all sanitary defects and comply with all other requirements of the Level 2 Assessment. Please also be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

Rachel Brookins, P.E.

EPA Region 8 | ECAD | SDWA Enforcement Unit 303.312.6509 | <u>Brookins.Rachel@epa.gov</u>