



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2011 JUL 27 PM 2: 54

FILED  
EPA REGION VIII  
ENFORCEMENT CLERK

JUL 27 2011

Ref: 8ENF-W

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Bruce and Susan Hendrick  
Star Valley Trailer Court  
POB 1388  
Afton, WY 83110

Re: Administrative Order Violation  
Docket No. SDWA-08-2011-0020  
PWS ID #5601017

Dear Mr. and Mrs. Hendrick:

On February 8, 2011, the U.S. Environmental Protection Agency (EPA) issued an Administrative Order (Order) ordering you to comply with the Safe Drinking Water Act (SDWA), 42 U.S.C. Section 300f *et seq.*, and its implementing regulations, the National Primary Drinking Water Regulations (NPDWRs), 40 C.F.R. Part 141.

Our records indicate that you are in violation of the Order. Among other things, the Order included the following requirement (quoted from item 15 on page 3 of the Order):

Respondents shall collect at least one water sample for E. coli testing from each source in use within 24 hours of notification that a regular, routine total coliform monitoring sample is total coliform-positive, as required by the Groundwater Rule at 40 C.F.R. § 141.402. Respondents shall report analytical results (specifying it is a triggered source sample) to EPA within the first 10 days following the month in which the result is received, as required by 40 C.F.R. § 141.90.

After a total coliform positive sample on March 7, 2011, our records show that a source sample was not taken until March 22, 2011, instead of within the required 24 hours.

EPA is considering additional enforcement action as a result of your non-compliance with the Order. Violating an Administrative Order may lead to (1) a penalty of up to \$37,500 per day per violation of the Order, and/or (2) a court injunction ordering compliance.

If you have any questions you may contact Kathelene Brainich at 1-800-227-8917, extension 6481, or (303) 312-6481. If you are represented by an attorney who has questions, please ask your attorney to direct any legal questions to Jean Belille, Enforcement Attorney, at 1-800-227-8917, extension 6556, or (303) 312-6556 or at the following address:

Jean Belille, Enforcement Attorney  
U.S. EPA, Region 8 (8-ENF-L)  
1595 Wynkoop Street  
Denver, Colorado 80202-1129

We urge your prompt attention to this matter.

Sincerely,

A handwritten signature in black ink, appearing to read 'Lisa Kahn', written in a cursive style.

Lisa Kahn, Team Leader  
Drinking Water Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: WY DOH/DEQ  
Tina Artemis, EPA Regional Hearing Clerk