



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2010 MAR 10 PM 12:00

FILED
EPA REGION VIII
HEARING CLERK

MAR 10 2010

Ref: 8ENF-W

CERTIFIED MAIL LETTER
RETURN RECEIPT REQUESTED

William C. Salisbury, Registered Agent
Power Resources, Inc.
400 E. 1st Street, Ste. 308
Casper, WY 82601

Re: Administrative Order Addendum
Docket No. SDWA-08-2010-0011
Power Resources/Smith Ranch Public
Water System
PWS ID #WY5601500

Dear Mr. Salisbury:

Pursuant to paragraph 14 of the Administrative Order (Order) issued January 14, 2010, to Power Resources, Inc. as owner and operator of the Smith Ranch public water system, this Addendum to the Order incorporates the schedule for actions aimed at ensuring compliance with the total coliform maximum contaminant level (MCL), outlined in Power Resources, Inc. d/b/a Cameco Resource's letter of February 16, 2010 to the EPA, as further clarified by Angelo Kallas of Power Resources, Inc., on February 23, 2010. This letter constitutes the written approval by EPA of that schedule.

The following schedule lists the actions to be taken as set forth in Power Resources, Inc.'s February 16, 2010 plan. EPA recognizes that many of the actions have already been completed. EPA appreciates the ongoing efforts by Power Resources, Inc. to ensure safe drinking water at the Smith Ranch public water system.

Power Resources, Inc. d/b/a Cameco Resources/Smith Ranch
Compliance Plan and Schedule


<u>Action</u>	<u>Status</u>	<u>Completion</u>
Repair chlorinator pump	Completed	September 2, 2009
Sample weekly for residual chlorine	Beginning September 2, 2009	January 20, 2010
Sample daily (M – F) for residual chlorine	Beginning January 21, 2010.	Ongoing
Inspect chlorination system on daily basis (M – F), log results	Ongoing	Ongoing
Report daily residual chlorine results to EPA weekly	Upon receipt of AO Addendum	Until notified by EPA to discontinue

Please be advised that Power Resources, Inc. is required to comply with all provisions of the Order. Penalties for failing to comply are set forth in the Order. Please contact Mario Mérida at (303) 312-6297 if you have any questions concerning this Addendum. Power Resources, Inc.'s attorney may contact David Janik, Enforcement Attorney, at (303) 312-6917 for any legal matters.

Sincerely,



Darcy O'Connor, Acting Director
Technical Enforcement Program
Office of Enforcement, Compliance,
and Environmental Justice



David Rochlin, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ (via email)
WY DOH (via email)
Tina Artemis, EPA Regional Hearing Clerk
Thomas P. Young, VP – Operations, Power Resources, Inc./Smith Ranch
Angelo Kallas, SHEQ Manager, Power Resources, Inc./Smith Ranch