



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, COLORADO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2016 FEB 24 PM 3: 24

FILED
EPA REGION VIII
HEARING CLERK

FEB 24 2016

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Big Valley and Crossed Arrows Improvement District
c/o Wayne McBroom, President
P.O. Box 33
Meeteetse, Wyoming 82433

Re: Administrative Order Addendum #4, Big Valley and Crossed Arrows Improvement District,
PWS ID #5601193, Docket # SDWA-08-2014-0010


Dear Mr. McBroom:

This letter is the fourth addendum to the Administrative Order (Order) issued on March 25, 2014, to the Big Valley and Crossed Arrows Improvement District (District). The purpose of this letter is to approve the schedule from you to the EPA dated January 4, 2016, and updated February 8, 2016. Beginning October 1, 2015, the District shall monthly disinfect the well head and transmission lines and annually test for transmission line backflow leakage from the storage tank to the well head. In order to ensure that total coliform results are representative of typical water in the distribution system, do not collect total coliform compliance samples the same week after monthly disinfection. The monthly disinfection and annual transmission leak test is hereby incorporated into the Order per paragraph 8 (page 2) of the Order.


Dan Chamberlin of the Wyoming Association of Rural Water Systems has been assisting the District and believes the above steps and the previously completed plans have resulted in a secure system. The previous plans consisted of cleaning both tanks, repairing a well house line break, system disinfection and flushing, and replacement of a water storage tank. Pursuant to paragraph 11 of the Order, the System shall achieve compliance with the total coliform maximum contaminant level effective October 1, 2015, as stated in this approved schedule.

Please contact Kathelene Brainich, Environmental Protection Specialist, at (303) 312-6481 or via email at brainch.kathelene@epa.gov if you have any questions concerning this Addendum.

Sincerely,



James H. Eppers, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



Arturo Palomares, Director
Water Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ/DOH (via email)
Dan Chamberlain WARWS (via email)
Tina Artemis, EPA Regional Hearing Clerk