

Tribbett, Katherine (Kate)

FILED

11/30/2023

2:21 PM

U.S. EPA REGION 8
HEARING CLERK

From: Tyson, Elizabeth
Sent: Thursday, November 30, 2023 2:21 PM
To: antelopetruckstop@yahoo.com
Cc: R8 Hearing Clerk; Ellis, Bradley; 'Clay Vanhouten'; Doug Evans; Erica East; Brough, James; Jennifer Escobedo; Justin Latham; Hendon2, Keenan; Kim Parker; Laramie County; Baron, Mark; markp; Matthew Peterson; Ruth Heald; Sara Budge; Sarah Coffre; stanley.miller@wyo.gov; towens@map-inc.org; Fernandez, Jason; Lewis, Dennis; commissioners@laramiecounty.com; Rivers, Anthony; Ashley Stegeman
Subject: Closure of Administrative Order – Antelope Truckstop Public Water System #WY5601027, Docket No. SDWA-08-2023-0025, Laramie County

Dear Mr. Singh,

The EPA has decided to close the Administrative Order (Order) regarding the public water system specified in the subject line. The EPA has determined that there are no remaining requirements of the Order. System improvements included the installation of a new sanitary seal and tightly bolted cap to Well #2.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

Elizabeth Tyson (*she/her*)

Safe Drinking Water Act Enforcement Section Intern | US EPA Region 8 (8ENF-WSD)

1595 Wynkoop St. | Denver, CO 80202

303.312.6646 | tyson.elizabeth@epa.gov