



REGION 8

DENVER, CO 80202

FILED

Jun 27, 2024

4:23 pm

**U.S. EPA REGION 8
HEARING CLERK**

June 27, 2024

Ref: 8ECA-W-S

SENT VIA EMAIL
DIGITAL DELIVERY RECEIPT REQUESTED

S. Christina Korpi, Registered Agent
c/o Nick Orsillo, President/Director
Rivermeadows Homeowners Association Inc.
gtpm@gtpmjh.com

Subj: Administrative Order Addendum, Rivermeadows Homeowners Association
regarding Rivermeadows Water District Public Water System, PWS ID
#WY5600786 Docket # **SDWA-08-2024-0028**

Dear Ms. Korpi and Mr. Orsillo:

This is an Addendum to the Administrative Order (Order) issued to Rivermeadows Homeowners Association (Respondent) on May 28, 2024. The purpose of this letter is to approve the Respondent's June 6, 2024, schedule (Schedule) for coming into consistent compliance with the optimal corrosion control treatment (OCCT) and copper action level requirements. The Schedule is hereby incorporated into the Order pursuant to paragraph 17. Each milestone and deadline specified below is an enforceable provision of the Order.

<u>Milestone</u>	<u>Deadline</u>	<u>Projected Cost</u>
Submit monthly progress reports to brookins.rachel@epa.gov and R8DWU@epa.gov	By the 10 th calendar day of each month	-
Complete Engineering Design/Plans and Specifications for installation of orthophosphate and submit permit application to Wyoming DEQ (WDEQ).	July 12, 2024	\$12,000
Respond to WDEQ comments on the permit application (if applicable).	Within 30 days of receiving WDEQ comments.	-
Receive permit from WDEQ.	August 31, 2024	-
Begin Construction.	September 1, 2024	-

Subj: *Administrative Order Addendum, Rivermeadows Homeowners Association regarding Rivermeadows Water District Public Water System, PWS ID WY5600786, Docket # SDWA-08-2024-0028.*

<u>Milestone</u>	<u>Deadline</u>	<u>Projected Cost</u>
Complete construction and begin system start up testing.	December 31, 2024	\$63,000
Submit one week's worth of orthophosphate residuals to the EPA for review.	January 10, 2025	-
Notify the EPA of construction completion. Complete PWS Inventory Change Form and submit to the EPA. https://www.epa.gov/region8-waterops/epa-r8-public-water-system-inventory-change-form .	Within 10 calendar days after completing all tasks included in the Schedule.	-

Within 10 calendar days of completing all steps included in the above Schedule, please notify the EPA of the project's completion as required by the Order. The Order also requires Respondent to achieve and maintain compliance with the OCCT and copper action level requirements by the final date specified in the approved Schedule. The EPA is authorized to seek penalties if these deadlines are not met. If Respondent has a reasonable basis to believe it may be unable to meet any deadline in the Schedule, it must notify the EPA well in advance of the Scheduled deadline to request an extension. The EPA may, in its discretion, consider granting an extension.

If you have any questions or to request an informal conference with the EPA, please contact Rachel Brookins via email at brookins.rachel@epa.gov, or by phone at (800) 227-8917, extension 6509, or (303) 312-6509. Any questions from the Company's attorney should be directed to Noah Stanton, Assistant Regional Counsel, via email at stanton.noah@epa.gov or by phone at (800) 227-8917, extension 6163, or (303) 312-6163.

Sincerely,

Tiffany Cantor, Acting Manager
Water Enforcement Branch
Enforcement and Compliance Assurance Division

cc: WY DEQ/DOH (via email)
Teton County Commissioners
EPA Regional Hearing Clerk
Nick Orsillo, President/Director, Rivermeadows Homeowners Association Inc.
Robert Ablondi, Operator, Rivermeadows Water District
Matthew Ostdiek, Consulting Engineer, Rendezvous Engineering
Mark Schlosser, Consulting Engineer, Rendezvous Engineering
Bradley Ellis, District Engineer, WY DEQ