

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 8

999 18TH STREET- SUITE 200 DENVER, CO 80202-2466 Phone 800-227-8917 http://www.epa.gov/region08

2006 NOV -8 AM 10: 09

EPA REGION VIII HEARING CLERK

Ref: 8ENF-W

NOV - 8 2006

CERTIFIED MAIL RETURN RECEIPT REQUESTED

Kevin Brown, Director Division of Drinking Water Utah Department of Environmental Quality P.O. Box 144810 Salt Lake City, UT 84114-4810

NOTICE OF VIOLATION

Docket No. SDWA-08-2007-0007 Town of Trenton PO Box 11 Trenton, UT 84338 PWS ID# UTAH03021

Dear Mr. Brown:

The above referenced public drinking water system has violated certain provisions of the Safe Drinking Water Act (SDWA), 42 U.S.C. § 300f, et seq. and the National Primary Drinking Water Regulations at 40 C.F.R. part 141. The violations consist of failure to take five routine samples following a positive total coliform sample in the preceding month, failure to monitor for disinfection byproducts, failure to monitor for chlorine residuals, failure to monitor for synthetic organic chemicals, failure to provide public notice, and failure to notify the State of the violations. Our records, obtained from the Utah Department of Environmental Quality (DEQ), indicate the violations noted below. Please notify Kimberly Pardue Welch of my staff at (303) 312-6983 within 20 days if your records show any discrepancies with these determinations of violation.

Date of Violation	Violation
March 2003	Failure to take five routine samples following a total coliform positive sample the preceding month. [40 C.F.R. § 141.21(b)(5)]
2004	Failure to monitor for disinfection byproducts. [40 C.F.R. § 141.132(b)] (System failed to take sample in correct monitoring period, June – August)
3 rd and 4 th quarters 2005 and 1 st quarter 2006	Failure to monitor for chlorine residuals. [40 C.F.R. § 141.132(c)(1)]
2002 - 2004	Failure to monitor for synthetic organic chemicals. [40 C.F.R. § 141.24(h)]
2002 – 2005	Failure to provide public notice of the above-referenced violations. [40 C.F.R. § 141.201]
2002 – 2005	Failure to report the above-referenced violations to the State. [40 C.F.R. §§ 141.31(b), 141.21(g)(2)]

This NOTICE OF VIOLATION is issued pursuant to section 1414(a) of the SDWA, 42 U.S.C. § 300g-3(a). If the State does not commence appropriate enforcement action within 30 days from the receipt of this notification, the EPA is authorized either to issue an Administrative Order under section 1414(g) of the SDWA, 42 U.S.C. § 300g-3(g) requiring the public water system to comply with the regulations or requirements, or to commence civil action under section 1414(b) of the SDWA, 42 U.S.C. § 300g-3(b).

Please inform EPA of any change in the compliance status of this system. You may wish to confer with my staff to determine the Agency's position concerning this system and to exchange appropriate information. If the State does not commence appropriate enforcement action within 30 days from the receipt of the notification, EPA will proceed with issuance of an administrative order. Our technical contact is Kimberly Pardue Welch at (303) 312-6983.

A copy of this NOTICE OF VIOLATION has been concurrently sent to the system identified above.

Sincerely,

Diane L. Sipe, Director

Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

Michael T. Risner, Director David J. Janik, Supervisory Attorney Legal Enforcement Program Office of Enforcement, Compliance and Environmental Justice

cc: Marla Faye Trowbridge, (via certified mail / return receipt requested)
Ken Bousfield, UT DEQ DW