



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
http://www.epa.gov/region08

2015 JUN -8 AM 8: 58

FILED
EPA REGION VIII
HEARING CLERK

JUN -8 2015

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Kenneth Bousfield, Director
Division of Drinking Water
Utah Department of Environmental Quality
P.O. Box 144830
Salt Lake City, UT 84114-4830

Re: Notice of Violation for Shady Dell-Soapstone Campground, PWS ID # UTAH22050
Docket No. SDWA-08-2015-0018

Dear Mr. Bousfield:

According to records that the United States Environmental Protection Agency (EPA) has obtained from the Utah Department of Environmental Quality (State), the public water supply system referenced above (System) has violated certain provisions of the National Primary Drinking Water Regulations at 40 C.F.R. part 141 (Drinking Water Regulations).

The EPA promulgated the Drinking Water Regulations under the authority of the Safe Drinking Water Act (the Act), 42 U.S.C. §§ 300f, et seq. The EPA is issuing this notice of violation pursuant to section 1414(a) of the Act, 42 U.S.C. § 300g-3(a), which authorizes the EPA to issue an administrative compliance order or file a lawsuit concerning the System if the State does not commence an appropriate enforcement action within thirty days of receiving this notice. The violations are listed below.

Dates of
Violations

Violations

Table with 2 columns: Dates of Violations, Violations. Row 1: April 2010, Failure to address significant deficiency (blow off valve discharges below flood level in pond). Row 2: December 2010, Failure to address significant deficiency (storage facility vent not properly screened).




The EPA is also sending a copy of this notice of violation to the System.

If the State does not commence an appropriate enforcement action concerning the System within 30 days from the State's receipt of the notification, EPA will likely issue an administrative order to the owner and/or operator of the System.


Please have your staff notify Mario Mérida at (303) 312-6297 or [merida.mario@epa.gov](mailto:merida.mario@epa.gov) within 20 days if your records show any discrepancies with the violations cited above, if your staff learns of any change in the System's compliance status, or if there are any questions or comments. Thank you for your assistance.

Sincerely,



---

James H. Eppers, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice



---

Arturo Palomares, Director  
Water Technical Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

- cc: Tina Artemis, EPA Regional Hearing Clerk  
Patti Fauver, UTDEQ Drinking Water Rule Section Manager (by email)  
David Whittekiend Forest Supervisor, Uinta-Wasatch-Cache National Forest  
**(via certified mail/return receipt requested)**  
Kim Martin, Forest Engineer, Uinta-Wasatch-Cache National Forest (via email)