



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, COLORADO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2015 FEB 12 AM 10:45

FILED
EPA REGION VIII
HEARING CLERK

FEB 12 2015

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Big Valley and Crossed Arrows Improvement District
c/o Wayne McBroom, President
P.O. Box 33
Meeteetse, Wyoming 82433

Re: Administrative Order Addendum #2, Big Valley and Crossed Arrows Improvement District,
PWS ID #5601193, Docket # SDWA-08-2014-0010


Dear Mr. McBroom:

This letter is the second addendum to the Administrative Order (Order) issued on March 25, 2014, to the Big Valley and Crossed Arrows Improvement District (District). The purpose of this letter is to approve the plan and schedule from you to the EPA dated January 30, 2015, to address the continuing total coliform maximum contaminant level (MCL) violations. The schedule to install a new water storage tank and retire the old tanks by June 30, 2015, is hereby incorporated into the Order per paragraph 8 (page 2) of the Order.

Pursuant to paragraph 11 of the Order, the System shall achieve compliance with the total coliform MCL by the June 30, 2015, final compliance deadline in this approved schedule. The EPA is authorized to seek penalties if these deadlines are not met. If the District has a reasonable basis to believe it may be unable to meet any deadline in the schedule, it shall notify the EPA well in advance of the scheduled deadline to request an extension. The EPA may, in its discretion, consider granting an extension.

Please contact Kathelene Brainich, Environmental Protection Specialist, at (303) 312-6481 or via email at brainch.kathelene@epa.gov if you have any questions concerning this Addendum.

Sincerely,



James H. Eppers, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



Arturo Palomares, Director
Water Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ/DOH (via email)
Tina Artemis, EPA Regional Hearing Clerk

