



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2010 SEP 27 AM 9:54

FILED
EPA REGION VIII
HEARING CLERK

Ref: 8ENF-W

SEP 27 2010

CERTIFIED MAIL LETTER
RETURN RECEIPT REQUESTED

Joseph Duvall
Craig Bar
50 Main, Craig
Wolf Creek, MT 59648

Re: 3rd Administrative Order Addendum
Docket No. SDWA-08-2007-0053
Craig Bar Public Water System
PWS ID # MT0002077

Dear Mr. Duvall:

This 3rd addendum to the Administrative Order (Order) issued July 11, 2007, to you regarding the Craig Bar Public Water System (the system), incorporates the following schedule for completing drinking water system modifications as outlined in the September 22, 2010, faxed letter to EPA from Kristi Blazer, on your behalf. This letter constitutes the written approval by EPA of the schedule and deadlines as indicated in the chart below. In addition to serving as approval for the schedule, this letter serves to incorporate it into the Order, meaning each deadline in the schedule will be an enforceable part of the Order.


<u>Action</u>	<u>Deadline</u>	<u>Completion (if applicable)</u>
Replace defective chlorinator pump.	October 1, 2010	Completed (notified September 22, 2010)
Install dedicated sampling tap immediately after retention tanks.	October 1, 2010	Completed (notified September 22, 2010)

Install under counter carbon filter on dedicated drinking water tap.	October 15, 2010
Provide operator training on disinfection system and reporting requirements.	October 15, 2010
Notify EPA and the State in writing of Compliance Plan completion.	Within 10 days of completing the compliance plan.


Please note that EPA expects this approved schedule to be met. While not creating any right to an extension, EPA may in its discretion consider granting an extension to any deadline in the schedule under limited circumstances. If unexpected events occur that are beyond the system's control and that may prompt the system to request an extension of these deadlines, the system will be responsible for notifying EPA well in advance of the deadline dates. EPA will not consider extending these deadlines without a clear justification for their need. The system must provide the following information in any request for extensions: a description of the work that has been completed and the additional work that may not be completed by the deadline dates, the unexpected events that occurred and how the system attempted to foresee or overcome these obstacles, the proposed new deadline dates, and an explanation that justifies the new proposed deadline dates.

Please be advised that the system is required to comply with all provisions of the Order. Penalties for failing to comply are set forth in the Order. Please contact Kimberly Pardue Welch at 800-227-8917, extension 6983 or (303) 312-6983 if you have any questions concerning this Addendum. If the system is represented by an attorney, please ask your attorney to call David Janik, Enforcement Attorney, at 1-800-227-8917, extension 6917 or (303) 312-6917.

Sincerely,



Arturo Palomares, Director
Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



David Rochlin, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc:

John Arrigo, MT DEQ
Shelley Nolan, MT DEQ
Kristi Blazer, Missouri River Law Office P.C.
Tina Artemis, EPA Regional Hearing Clerk