



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
INDUSTRIAL STORMWATER
EXPEDITED SETTLEMENT AGREEMENT



Permittee		Site Factors		
Site Name:	Lang Street Facility	Acres of Exposure:	2.25	
Street Address:	10805 Lang Street	Full Time Employees:	3	
City, State, Zip:	Anchorage, Alaska 99515	Environmental Harm:	Med	
Lat/Long:	61.1226332° N, 149.8763131° W	Sector:	D - Asphalt Paving and Roofing Materials and Lubricants	
Permit ID:	AKR06AA82	Receiving Water(s):	Campbell Creek (Impaired)	
Inspection Date:	9/29/2023	Water(s) Status:	Medium Quality	
Permit Section Citation		Magnitude*	Penalty Amount	Duration
2.1.1	Control Measure Selection and Design Considerations			
2.1.2	Non-Numeric Technology-Based Effluent Limits			
3.1	Routine Facility Inspections			
3.2	Quarterly Visual Assessment of Stormwater Discharges			
4.1	Monitoring Procedures			
4.2.2	Benchmark Monitoring			
4.2.3	Effluent Limitations Monitoring	≥ 50%	\$8,438	1/2021 - 1/2024
4.2.5	Impaired Waters Monitoring			
5.1	Corrective Actions			
5.2	Additional Implementation Measures (AIM)			
6	Stormwater Pollution Prevention Plan (SWPPP)			
7	Reporting and Recordkeeping			
		Total:	\$8,438	

* "Magnitude" reflects the severity and/or duration of the violations identified by the Inspector(s) at the time of the Inspection.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
INDUSTRIAL STORMWATER
EXPEDITED SETTLEMENT AGREEMENT



Permit Section Citation	Description of Violations
2.1.1 Control Measure Selection and Design Considerations	
2.1.2 Non-Numeric Technology-Based Effluent Limits	
3.1 Routine Facility Inspections	
3.2 Quarterly Visual Assessment of Stormwater Discharges	
4.1 Monitoring Procedures	
4.2.2 Benchmark Monitoring	
4.2.3 Effluent Limitations Monitoring	Permit Part 11.D.4. Five effluent limits exceedances for total suspended solids (TSS) monthly average and/or daily maximum in 2021, 2022, 2023, and 2024. Effluent limit for TSS monthly average limit is 15 milligrams per Liter (mg/L) and effluent limit for TSS daily maximum is 23 mg/L. Results are 101 mg/L , 299 mg/L, 100 mg/L, 93.7 mg/L, and 187 mg/L.
4.2.5 Impaired Waters Monitoring	
5.1 Corrective Actions	
5.2 Additional Implementation Measures (AIM)	
6 Stormwater Pollution Prevention Plan (SWPPP)	
7 Reporting and Recordkeeping	