



**REGION 8**

DENVER, CO 80202

**FILED**

**Dec 29, 2025**

**4:02 pm**

**U.S. EPA REGION 8  
HEARING CLERK**

December 23, 2025

Ref: 8ECA-W-S

**SENT VIA EMAIL**  
**DIGITAL DELIVERY RECEIPT REQUESTED**

The Honorable Randall Werk Sr., President  
Fort Belknap Indian Community Council  
randall.werk@ftbelknap.org

Ms. Kasey Ramone, Director  
Prairie Mountain Utilities  
kasey.ramone@ftbelknap.org

Subj: Emergency Administrative Order under Section 1431 of the Safe Drinking Water Act, Fort Belknap Agency Public Water System, PWS ID #083090041, Docket No. SDWA-08-2026-0029

Dear President Werk and Director Ramone:

Enclosed is an Emergency Administrative Order (Order) issued by the U.S. Environmental Protection Agency to the Gros Ventre and Assiniboine Tribes of the Fort Belknap Indian Community (FBIC) and Prairie Mountain Utilities (PMU) under section 1431 of the Safe Drinking Water Act (Act), 42 U.S.C. § 300i.

The EPA has determined that conditions exist at the Fort Belknap Agency Public Water System (System) that may present an imminent and substantial endangerment to the persons served by the System. The EPA has made this determination based on notification from Gene Talks Different, Lead Operator at the System, on December 19, 2025, that the System's storage tank lost a roof panel during a high wind event on the same day.

Pursuant to the authority set forth in section 1431 of the Act, 42 U.S.C. § 300i, the EPA is authorized to take actions necessary to protect human health. The Order and its requirements are necessary to ensure adequate protection of public health.

The enclosed Order sets forth the actions that must be taken to ensure that the people served by the System are provided with safe drinking water. The Order requires the FBIC and PMU to, among other things, take the following actions: issue a boil water advisory;

*Subj: Emergency Administrative Order under Section 1431 of the Safe Drinking Water Act, Fort Belknap Agency, PWS ID 083090041*

provide alternate water; submit a plan and schedule to repair the opening; disinfect and flush the System; and take additional total coliform bacteria samples.

The penalties for failing to comply are set forth in the Order. If you have any questions or wish to discuss the Order, please contact Christina Carballal via email at carballal-broome.christina@epa.gov, or by phone at (800) 227-8917, extension 6046, or (303) 312-6046. Any questions from counsel should be directed to Matthew Castelli, Senior Assistant Regional Counsel, via email at castelli.matthew@epa.gov or by phone at (800) 227-8917, extension 6491, or (303) 312-6491.

Thank you for your attention to this matter.

Sincerely,

for Suzanne J. Bohan, Director  
Enforcement and Compliance Assurance Division

**ENCLOSURES**

1. Emergency Administrative Order
2. Public Notice template

cc:

Ina Nex Perce, Environmental Director FBIC (inperce@ftbelknap.org)  
Alan Bigby, Vice-President FBIC (alan.bigby@ftbelknap.org)  
Catherine Aragon, Tribal Attorney (cataragon51@aol.com)  
Gene Talks Different, Lead Operator (gene.talksdifferent@ftbelknap.org)  
Tammy Rider, Financia Manager (tammy.rider@ftbelknap.org)  
EPA Regional Hearing Clerk (r8\_hearing\_clerk@epa.gov)  
Mike Racine, Engineer, Indian Health Service (Richard.racine@ihs.gov)  
Rob Adams, Indian Health Service (rob.adams@ihs.gov)  
Quentin Allen, Indian Health Service (quentin.allen@ihs.gov)  
Todd Rydquist, Indian Health Service (Todd.Rydquist@ihs.gov)