



REGION 8
DENVER, CO 80202

FILED
Jan 16, 2026
2:01 pm

U.S. EPA REGION 8
HEARING CLERK

January 14, 2026

Ref: 8ECA-RO-E

Jack Anderson, Owner/Operator
Jack's Service Center
404 Main Street
Isabel, South Dakota 57633

Re: DELIVERY PROHIBITION at Jack's Service, EPA ID 4020035 RCRA-08-2026-0002

Dear Jack Anderson:

This letter serves as formal notification that delivery of regulated substances (e.g., gasoline, diesel) to the underground storage tanks (USTs) at the above-referenced location is **immediately prohibited**, effective January 14, 2026.

The Resource Conservation and Recovery Act (RCRA), 42 U.S.C. § 6991, *et seq.*, authorizes the U. S. Environmental Protection Agency to issue and enforce regulations concerning USTs. On May 15, 2024, a credentialed inspector on behalf of the EPA conducted an inspection at Jack's Service (Facility) in Isabel, South Dakota, to determine the Facility's compliance with the UST regulations in 40 CFR Part 280. On June 16, 2025, the EPA issued a Compliance Order with the following violations noted:

Violations

1. Failure to comply with the temporary closure requirements in 40 C.F.R. § 280.70(a)
USTs in temporary closure must be empty or the owner must continue to monitor for releases every thirty days. Provide the EPA with proof of release detection monitoring or proof that USTs have been emptied to one inch or less of fluid. If the USTs become operational again, additional testing is required.
2. Failure to designate and train a Class A/B operator as required by 40 C.F.R. § 280.241(a)

EPA did not receive a response to the Compliance Order and subsequently issued a Notice of Intent to Prohibit Delivery (Notice) on December 9, 2025. The Notice required that documentation of corrective actions be submitted within 30 days. As of January 13, 2026, no documentation of corrective actions has been received and therefore the USTs are ineligible to receive deliveries of regulated substances.

Per 42 U.S.C. § 6991k, fuel deliveries must cease until all violations are rectified and documented proof of compliance is submitted and confirmed by the EPA. Making or accepting deliveries to this tank, unless authorized by U.S. EPA, can result in fines up to \$16,000 per day per occurrence.

If you would like to discuss this matter, please contact the EPA technical contact, Roberta Person, at (303) 312-6910 or via email at person.roberta@epa.gov. If you are represented by counsel, your counsel may contact Matt Castelli, Senior Assistant Regional Counsel, at (303) 312-6491 or via email at castelli.matthew@epa.gov.

Sincerely,

Kristin McNeill, Supervisor
RCRA Enforcement Section
Enforcement and Compliance Assurance Division

cc: Bulk Distributors