

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 8

1595 Wynkoop Street
DENVER, COLORADO 80202-1129
Phone 800-227-8917
http://www.epa.gov/region08

2015 JAN 29 AM 9: 55

EPA REGION VIII HEARING CLERK

On-going

JAN 2 9 2015

Ref: 8ENF-W

<u>CERTIFIED MAIL</u> RETURN RECEIPT REQUESTED

Honorable H.H. "Buck" King Mayor, Town of Edgerton P.O. Box 407 Edgerton, Wyoming 82635

Re: Administrative Order Addendum, Town of Edgerton, PWS ID #5600017, Docket No. SDWA-08-2014-0011

Dear Mayor King:

This letter is an addendum to the Administrative Order (Order) issued on March 27, 2014, to the Town of Edgerton (Town). The purpose of this letter is to approve the December 18, 2014, schedule submitted by you, on behalf of the Town, for coming into consistent compliance with the total coliform maximum contaminant level (MCL). The schedule is hereby incorporated into the Order per paragraph 8 (page 2) of the Order.

Action	Date
Construction of a water and sewer extension that decreased stagnation by increasing tank water usage.	Completed October 16, 2014
Construction of two water truck load-outs to increase water usage.	April 30, 2015
Continue routine inspections of the pipeline.	On-going
Adjust incoming flows and tank levels based upon residual levels that are monitored daily to maintain 0.5 mg/l or higher [total chlorine].	On-going
Using a metered flushing trailer, flush water if residual levels start to decline.	On-going
Quarterly sampling for total chlorine, monochloramine, nitrites, total ammonia, pH levels, HPC, total coliform, and temperature at five locations (booster statio Antelope hydrant, surge tank, Rimrock hydrant, and 1.5 MG tank) to establish baseline numbers at different times of the year.	

Weekly check samples for total coliform from at least two locations; any positive

check sample will trigger flushing and daily sampling until safe levels are restored.

Action Date

During October-April, maintain less storage in the 1.5 million gallon storage tank or utilize the smaller 225,000 gallon tank when it is available.

On-going

Sampling/flushing schedule for the months of July through September will increase with weekly total coliform, HPC and nitrate sampling and a heavy flushing event will occur in June to increase the chlorine residual level.

On-going

Pursuant to paragraph 11 of the Order, the System shall achieve compliance with the total coliform MCL by the final compliance deadline in this approved schedule, April 30, 2015. The EPA is authorized to seek penalties if these deadlines are not met. If the Town has a reasonable basis to believe it may be unable to meet any deadline in the schedule, it shall notify the EPA well in advance of the scheduled deadline to request an extension. The EPA may, in its discretion, consider granting an extension.

Please contact Kathelene Brainich, Environmental Protection Specialist, at (303) 312-6481 or via email at brainch.kathelene@epa.gov if you have any questions concerning this Addendum.

Sincerely,

Arturo Palomares, Director

Water Technical Enforcement Program Office of Enforcement, Compliance

and Environmental Justice

David Rolli for JHE

James H. Eppers, Supervisory Attorney

Legal Enforcement Program

Office of Enforcement, Compliance

and Environmental Justice

cc: WY DEQ/DOH (via email)

Tina Artemis, EPA Regional Hearing Clerk