

**R8 Hearing Clerk**

**From:** Bell, Marlon  
**Sent:** Wednesday, December 17, 2025 12:09 PM  
**To:** james.bagwell@k12.sd.us  
**Cc:** fstarcomesout@oglala.org; bob.amiotte@k12.sd.us; stephanie.blackbear@k12.sd.us; Begeman, James (IHS/ABR/OEH); R8 Hearing Clerk; ostwpdls@gwtc.net; Pedro.Rosa@k12.sd.us  
**Subject:** Closure of Emergency Administrative Order - Crazy Horse School ( 084690468) Docket No. SDWA-08-2026-0025

Good afternoon,

The EPA has decided to close the Emergency Administrative Order (Order) regarding the Crazy Horse School Public Water System. The EPA has determined that there are no remaining requirements of the Order. System improvements included temporarily repairing an opening in the tank roof and implementing a new flushing program to reduce water age and increase chlorine residual throughout the distribution system

You may discontinue collecting weekly “special” samples.

Please be aware that the Level 2 Assessment is still open, and you are required to comply with all remaining requirements detailed in it. Please coordinate with Jamie Harris on these requirements.

Please also be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

**Marlon Bell, MACL**

Physical Scientist

EPA Region 8 | ECAD | SDWA Enforcement Unit  
1595 Wynkoop Street, 8ECA-W-S, Denver, CO 80202  
Office: 303.312.6539 | [Bell.Marlon@epa.gov](mailto:Bell.Marlon@epa.gov)