



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2011-MAY 17 AM 9:24

FILED
EPA REGION VIII
HEARING CLERK

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

The Honorable Tracy King, President
Fort Belknap Indian Community
656 Agency Main Street
Harlem, MT 59526

Margaret Nicholson, Director
Prairie Mountain Utilities
164 Agency Main Street
Fort Belknap Agency, MT 59526

RE: Emergency Administrative
Order Addendum
Docket No. SDWA-08-2011-0035
Agnes Leggins PWS
PWS ID #083090049

Dear President King and Ms. Nicholson:


On April 7, 2011, the U.S. Environmental Protection Agency (EPA) issued an Emergency Administrative Order (Order) under section 1431 of the Safe Drinking Water Act (the Act), 40 U.S.C. § 300i, to the Fort Belknap Indian Community (FBIC) and Prairie Mountain Utilities (the Utility) as owner and/or operator of the Agnes Leggins public water system (the system). This letter confirms the email notice provided to Scott Snow, Operator of the system, by Barbara Burkland of EPA on May 12, 2011, regarding reduced monitoring requirements, as explained in more detail below.

This letter serves as written notice that effective May 12, 2011, weekly bacteriological monitoring is no longer required and therefore pursuant to the Order, the system may resume monthly total coliform monitoring. You may also discontinue the twice weekly chlorine residual sampling and collection of water pressure in the distribution system. Please note that chlorine residual sampling is still required with the monthly bacteriological sample.


This notice is based on weekly total coliform monitoring which were analyzed as total coliform negative, as well as twice weekly chlorine residual and water pressure monitoring conducted on April 21, 2011, April 22, 2011, April 26, 2011, May 3, 2011, May 7, 2011, May 9, 2011, and May 11, 2011. You are required to comply with all other provisions of the Order. Penalties for failing to comply are set forth in the Order.

If you have any questions regarding this matter, your staff may contact Barbara Burkland at 406-457-5009 or Kimberly Pardue Welch at 1-800-227-8917, extension 6983. If the FBIC or the Utility is represented by an attorney, the attorney may call Peggy Livingston, Enforcement Attorney, at (800) 227-8917, ext. 6858, with any questions.

Sincerely,



Arturo Palomares, Director
Water Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



Michael Risner, Director
David Janik, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: Scott Snow, Head Operator (via e-mail)
Catherine Aragon, Tribal Attorney (via e-mail)
Tina Artemis, EPA Regional Hearing Clerk