



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8**

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2010 NOV 15 AM 11:21

FILED
EPA REGION VIII
HEARING CLERK

NOV 15 2010

Ref: 8ENF-W

CERTIFIED MAIL/RETURN RECEIPT REQUESTED

The Honorable Matthew Feldmann
Mayor, Town of Dixon
POB 26
Dixon, WY 82323

RE: Emergency Administrative Order Closure
Town of Dixon, PWS ID #5600059
Docket No. SDWA-08-2010-0050

Dear Mayor Feldmann:

This letter is to inform you of the Environmental Protection Agency's (EPA) decision to close the Emergency Order issued to the Town of Dixon (the Town) on June 8, 2010. This decision is based upon the Town's submittal and implementation of a comprehensive compliance plan to prevent future water distribution system loss of pressure events as well as the Town's sampling conducted from June through September demonstrating a detectable chlorine level and safe bacteriological results. This decision has no bearing on the requirements contained in the Administrative Order, Docket No. SDWA-08-2006-0046 issued June 27, 2006, to the Town which remain in effect.

Please be aware that the Town is still required to comply with the National Primary Drinking Water Regulations (NPDWR), 40 C.F.R. Part 141. Violation of the NPDWRs or an administrative order may subject the Town to a court-imposed injunction and penalties of up to \$37,500 per day of violation.

Thank you for your cooperation. If you have any questions you may contact Kathelene Brainich at 1-800-227-8917, extension 6481 or (303) 312-6481. Any questions from the Town's attorney should be directed to Sheldon Muller, Enforcement Attorney, who may be reached at (303) 312-6916.

Sincerely,

Lisa Kahn, Team Lead
Drinking Water Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ/DOH (via e-mail)
Tina Artemis, EPA Regional Hearing Clerk