



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 Wynkoop Street, DENVER, CO 80202-1129

Phone 800-227-8917

<http://www.epa.gov/region08>

2007 NOV -9 AM 11:19

FILED  
EPA REGION VIII  
HEARING CLERK

Ref: 8ENF-W

NOV 9 2007

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

National Park Service  
U.S. Department of the Interior  
Grand Teton National Park  
Attn: Mary Gibson Scott, Superintendent  
P.O. Drawer 170  
Moose, WY 83012

Re: Administrative Order Closure  
Docket No. SDWA-08-2007-0022  
Teton Science School Public Water System  
PWS ID #WY5680099

Dear Superintendent Scott:

This letter is to inform you of the Environmental Protection Agency's (EPA) decision to close the Administrative Order (Order), Docket No. SDWA-08-2007-0022, issued January 30, 2007, to the National Park Service, regarding the Grand Teton National Park Teton Science School Public Water System (System) located in Teton County, Wyoming. This decision is based upon information that a new, deeper well has replaced the previous well that was categorized as being under the influence of surface water. As of September 14, 2007, EPA reclassified the System as solely having a ground water drinking water source, and the System therefore is no longer subject to the surface water treatment rules outlined in the Order.

Please be aware that the National Park Service as owner of the System is required to comply with the National Primary Drinking Water Regulations (NPDWRs), 40 C.F.R. part 141. Violation of the NPDWRs or an administrative order may lead to further enforcement pursuant to section 1447 of the Safe Drinking Water Act.



Thank you for your cooperation in resolving this issue. If you have any questions about this issue, please call Melanie Wasco of my staff at (303) 312-6540.

Sincerely,



Lisa Kahn, Team Leader  
Drinking Water Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice