



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8**

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2008 MAR 27 AM 9:34

EPA REGION VIII
HEADQUARTERS

MAR 27 2008

Ref: ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

George Leys, Chairman
Buffalo Valley Water District
P.O. Box 321
Moran, Wyoming 83013

Re: Administrative Order Addendum
Docket No. SDWA-08-2008-0009
PWS ID #WY5600435

Dear Mr. Leys:

Pursuant to paragraph 10 of the Administrative Order (AO) issued December 11, 2007 to the Buffalo Valley Water District, this Addendum to the AO incorporates the schedule for completing system modifications and operational changes outlined in your February 11, 2008 letter and March 17, 2008 fax to EPA. This letter constitutes the written approval by EPA of the Buffalo Valley Water District actions that have been or will be completed. Please be advised that the Buffalo Valley Water District must continue to meet the total coliform rule maximum contaminant level (MCL) requirements and must additionally submit monthly progress reports to EPA beginning April 11, 2008 outlining the progress made in completing these activities as required in paragraph 11 of the AO.

Paragraph 9 of the AO requires Buffalo Valley Water District to submit detailed plans for bringing the public water system into compliance with the MCL for total coliform bacteria. Buffalo Valley Water District exceeded the MCL for total coliform bacteria during March 2007, April 2007, and August 2007. The following schedule lists the actions to be taken as set forth in your February 11, 2008 and March 17, 2008 plan, and if applicable, the start and completion dates of the actions:

<u>Action</u>	<u>Deadline</u>	<u>Completion</u>
The System will operate its chlorination equipment on a continual basis to prevent total coliform contamination.	May 9, 2008	February 11, 2008 and ongoing
Conduct System review to determine location of cross-connection control installation.	May 9, 2008	March 17, 2008
All lot services which do not currently have back-flow devices at the points of entry into residences will have them installed ahead of any use.	May 9, 2008	
All yard hydrants, outdoor spigots, etc. which are ahead of the residences' entry points will have back-flow devices directly attached to them.	May 9, 2008	

Please be advised that the Buffalo Valley Water District is required to comply with all provisions of the AO. Penalties for failing to comply are set forth in the Order. Please contact Shawn McCaffrey at (303) 312-6515 if you have any questions concerning this Addendum. If you are represented by an attorney, please ask your attorney to call Amy Swanson at the above 800 number, extension 6906, or at (303) 312-6906.

Sincerely,



Diane L. Sipe, Director
Technical Enforcement Program
Office of Compliance, Enforcement,
and Environmental Justice



David J. Janik, Acting Director
Matthew Cohn, Acting Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

Enclosure

cc: WY DEQ (via email)
WY DOH (via email)



Printed on Recycled Paper