

Tribbett, Katherine (Kate)

From: Brown, Christopher
Sent: Thursday, September 28, 2023 2:20 PM
To: Bryan Davidson
Cc: billy.riley@scouting.org; Ben Jordan; Langenfeld, Matthew; StClair, Kyle (he/him/his); Bloom, Judy; 'Justin Latham'; 'Ashley Stegeman'; Hendon2, Keenan; Doug Evans; Brough, James; Rivers, Anthony; Kim Parker; Lorraine Werner; markp; 'Clay Vanhouten'; llivingston@parkcounty.us; casey.mcquiston@usda.gov; R8 Hearing Clerk; Cantor, Tiffany; Rathbone, Colleen (she/her/hers); Wells, Ellen; Detty, Joan; Bearley, Mia
Subject: Closure of Administrative Order – Camp Buffalo Bill PWS #WY5601373, Docket No. SDWA-08-2023-0006, Park County, WY

Mr. Davidson,

The EPA has decided to close the Administrative Order (Order) regarding the public water system specified in the subject line. The EPA has determined that there are no remaining requirements of the Order. System improvements included modification of Gravity Tank ST02 to install a new vent; this resulted in closure of Significant Deficiency (SD#1) from the 2020 Sanitary Survey.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

--

Chris Brown, P.G.
Physical Scientist
U.S. EPA Region 8 | SDWA Enforcement Section
8ENF-W-SD | 1595 Wynkoop Street | Denver, CO 80202
Office: (303) 312-6669

