



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 WYNKOOP STREET
DENVER, COLORADO 80202-1129

Phone 800-227-8917

<http://www.epa.gov/region08>

2008 SEP -9 AM 8:51

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

SEP - 9 2008
EPA REGION VIII
HEARING CLERK

The Honorable Matthew Feldman
Mayor, Town of Dixon
POB 26
Dixon, WY 82323

RE: Emergency Administrative Order Closure
Town of Dixon
Docket No. SDWA-08-2008-0060
PWS ID #5600059

Dear Mayor Feldmann:

This letter is to inform you of the Environmental Protection Agency's (EPA) decision to close the Emergency Order issued to the Town of Dixon (the Town) on May 22, 2008. This decision is based upon turbidity in the filtered water returning to a safe level and weekly special purpose sampling conducted July 27 through August 4, 2008, indicating a detectable chlorine level and safe bacteriological samples. This decision has no bearing on the requirements contained in the Administrative Order, Docket No. SDWA-08-2006-0046 issued June 27, 2006, to the Town which remain in effect.

Please be aware that the Town is still required to comply with the National Primary Drinking Water Regulations (NPDWR), 40 C.F.R. Part 141. Violation of the NPDWRs or an administrative order may subject the Town to a court-imposed injunction and penalties of up to \$32,500 per day of violation.

We appreciate your cooperation. If you have any questions regarding this matter, please contact Kathelene Brainich, Environmental Protection Specialist, at (303) 312-6481.

Sincerely,

Lisa Kahn, Team Lead
Drinking Water Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DOH & DEQ (via email)