

ENVIRONMENT APPEAL BOARD

DATE- 13-10-2021

IN THE MATTER OF
SILKY ASSOCIATES LLC
RESPONDENT

U.S. EPA DOCKET NO RCRA-03-2018-
-0131

REQUEST AGAINST DEFAULT ORDER TO
CANCELE

DEAR SIR/MADAM HONERABLE JUDGES

- ① EPA OFFICE MELISA TOLD ME SEND US PAPERS, REPORT OF CATHODIC PROTECTION MONTHLEY REPORT FOR ONE YEAR
- ② ^HOTER DOCUMENTS OF UNDERGROUND TANK PROTECTION FOR CATHODIC MACHINE REPORT
- ③ LEAK DETECTOR TEST OF LINE
- ④ VEEBOR ~~REPORT~~ ROOT REPORT

Melisa told me if you do not have do it otherwise you will get- Big Penalty. If you get all these Reports we will not Penalise and do it all the leak test every year and UST Test every three year

As Per her intraction I

follow all the Rules and Did all the Test leak Dedector with Pass send her the Report

- ① CATHODIC Protection call UST company they send after doing all Repair work to Melisa and melisa Confirmed me she get the Report-
- ③ On Veebor Root my diesel Pump Prob stop working Few month ago a Technician told me I have to Replace and He given me Prob number I

II

I have Order PETRO SUPPLY and INSTALL which start working and send Report to Melissa.

(4) Melissa last told me need overFLOW system which suppose to install by Previous ~~Owner~~ Owner with was Pilot they should install Overflow Ball ~~with was~~ which was suppose to done long time ago I heard should done by them around ~~2000~~ or Before ^{year} 2000 But they not install Ball in all 5 TANK.

(5) Melissa shutdown all my TANK till I install New type of OVERFLOW Pipe or Tube I have hard time to get them because EVERYBODY want to install and Supplier was not manufacturing those tube. I was Requesting Melissa some EXTENTION but she was very tough to give me time. Finally I talk to Manufacturer Requested then told the Problem the he send specially for me to my Dealer and in ~~DEA~~ front and Presence of ~~DEA~~ OFFICER Technician INSTALLED all the over Flow EQUIPMENT and after told Melissa all the overflow tube job is done then she Release ~~the~~ the Order to open my all TANK.

AS PER Melissa I have done all the Jobs. I do not understand ^{HOW} I have broke ~~in~~ EPA Law.

III

As per Melissa I have done all the work without any delay and she told me clearly that all certificate she got, and there will be no future problem if I keep all the testing as per Rule. I am keeping all the instrument in working condition and keeping test done as per Pack per year.

After one year they have open this subject of violence and penalty over \$189,000 I do not understand where I am wrong.

I already told Melissa if you penalize me I will be the bankrupt and I have to close the store.

She told Sam telling you this as information I am not doing anything penalize you. But after one year they open the case and penalize me almost - 2 hundred thousand

Now because of COVID 19 business is down 70 to 75% Down Hard to pay the Bill. thank to SBA they have paid 6 month and now again 2 month, thank to SBA and Govt. otherwise I have to close to stop and go out of business Board on the Door.

I HOPE this will help to close this case
Sorry me with this amount.

J. S. Bagga
LAKHMIR S. BAGGA
SILKY ASSOCIATES LLC