From:	Minter, Jill
To:	Romero, Frank E -FS; towens@fs.fed.us; patriciadbean@fs.fed.us
Cc:	Haniewicz, Melissa; Cantor, Tiffany; Kahn, Lisa; Copeland, Michael; Livingston, Peggy; Harris, Jamie S.; Alan Huston; Clay Vanhouten; Dan Chamberlain (dchamberlain@warws.com); Doug Evans; Gary Hickman (ghickman@laramiecounty.com); James Brough (james.brough@wyo.gov); Jon Cecil; Karen Farley (karen.farley@wyo.gov); Kevin Schwaiger; Kim Parker; Linda Stratton; Lorraine Werner; Mark Baron (mark.baron@wyo.gov); Mark Pepper; Paul Lohman; Rich Cripe (rich.cripe@wyo.gov); Sarah Geffre; Stan Miller; William Tillman
Subject:	Closure of Emergency Administrative Order - Vedauwoo Campground PWS (ID# 5680068), Docket No. SDWA-08-2016-0016 (Albany County)
Date:	Tuesday, June 19, 2018 3:36:11 PM

This email is to inform you of the EPA's decision to close the Emergency Administrative Order (Order), issued July 26, 2016, regarding drinking water violations at the public water system specified in the subject line. The EPA has determined that the requirements of the Order have been met by the following: 1) the hand pump has been replaced; 2) the concrete pad has been repaired; 3) the system has been disinfected and flushed; 4) a 2018 Seasonal Start-up Checklist has been completed; 5) a special purpose total coliform sample has been collected and analyzed as safe; and 6) a routine total coliform sample has been collected and analyzed as safe.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations). 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

Jill

Jill Minter | Drinking Water Enforcement | USEPA Region 8 (8ENF-W- SDW) | 1595 Wynkoop Street | Denver, CO 80202-8917 | minter.jill@epa.gov | phone: 303-312-6084 | fax: 303-312-7518