



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2008 DEC -5 AM 11:12

Ref: ENF-W

DEC - 5 2008

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Steve Westberg, Owner/Operator
Town and Country Lanes and Bar
6126 Highway 312
Billings, MT 59105

Re: Amended Administrative Order
Addendum
Docket No. SDWA-08-2007-0015
PWS ID #MT0001731

Dear Mr. Westberg:

This letter constitutes an addendum to the Amended Administrative Order issued June 5, 2008 to you (Respondent) as the Owner/Operator of the Town and Country Lanes and Bar public water system (the system). The addendum incorporates the schedule for system improvements and the installation of treatment as outlined in the plans and specifications which the Environmental Protection Agency (EPA) received on July 23, 2008, from Treasure State Engineering on behalf of the Town and Country Lanes and Bar. The Montana Department of Environmental Quality (MDEQ) approved the plans and specifications on August 28, 2008.

This letter constitutes the written approval by EPA of the schedule set forth in this letter. The effect of today's approval is to incorporate the following schedule into the Amended Administrative Order. Each deadline in the schedule will be enforceable as if it were part of the Amended Administrative Order itself. The system is responsible for notifying EPA of any delays with regard to this schedule.


The following schedule lists the action to be taken, deadline date, and completion date if applicable.

<u>Action</u>	<u>Deadline</u>	<u>Completion (if applicable)</u>
Submit to EPA and the State, for review and approval, a compliance plan and schedule for bringing the PWS into compliance with the total coliform maximum contaminant level (MCL).	August 5, 2008	July 23, 2008
Install a wellhead chlorination system.	November 30, 2008	October 31, 2008
Extend well depth and install a new submersible pump in order to increase production.	November 30, 2008	October 31, 2008
Construct a vandal-resistant well protection shed around the well pit.	November 30, 2008	
Install overflow pipe on existing water storage tank.	November 30, 2008	
Notify EPA and the State in writing of completion of system improvements and treatment installation.	Within two weeks of completing improvements and treatment installation	

Please be advised that you are required to comply with all provisions of the Amended Administrative Order. Penalties for failing to comply are set forth in the Order. Please contact Kimberly Pardue Welch at (303) 312-6983 if you have any questions concerning this addendum and/or the schedule set forth herein. If you are represented by an attorney, please ask your attorney

to call Amy Swanson at the above 800 number, extension 6906, or at (303) 312-6906.

Sincerely,



Diane L. Sipe, Director
Technical Enforcement Program
Office of Compliance, Enforcement,
and Environmental Justice



Michael Risner, Director
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc:

Doug Strand, P.E., Treasure State Engineering, PLLC
Jerry Burns, MDEQ
John Arrigo, MDEQ
Shelly Nolan, MDEQ
Tina Artemis, EPA Regional Hearing Clerk (via e-mail)



Printed on Recycled Paper