



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2015 JUN -8 AM 8:57

FILED  
EPA REGION VIII  
HEARING CLERK

Ref: 8ENF-W

JUN -8 2015

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Kenneth Bousfield, Director  
Division of Drinking Water  
Utah Department of Environmental Quality  
P.O. Box 144830  
Salt Lake City, UT 84114-4830

Re: Notice of Violation for Bountiful Peak Campground, PWS ID # UTAH06025  
Docket No. **SDWA-08-2015-0017**

Dear Mr. Bousfield:

According to records that the United States Environmental Protection Agency (EPA) has obtained from the Utah Department of Environmental Quality (State), the public water supply system referenced above (System) has violated certain provisions of the National Primary Drinking Water Regulations at 40 C.F.R. part 141 (Drinking Water Regulations).

The EPA promulgated the Drinking Water Regulations under the authority of the Safe Drinking Water Act (the Act), 42 U.S.C. §§ 300f, et seq. The EPA is issuing this notice of violation pursuant to section 1414(a) of the Act, 42 U.S.C. § 300g-3(a), which authorizes the EPA to issue an administrative compliance order or file a lawsuit concerning the System if the State does not commence an appropriate enforcement action within thirty days of receiving this notice. The violations are listed below.

**Dates of**  
**Violations**

**Violations**

September 2011, July 2013, and September 2014	Exceeding the maximum contaminant level for total coliform bacteria
January 2014	Failure to address significant deficiency (water system plan approval lacking)




Printed on Recycled Paper

The EPA is also sending a copy of this notice of violation to the System.


If the State does not commence an appropriate enforcement action concerning the System within 30 days from the State's receipt of the notification, EPA will likely issue an administrative order to the owner and/or operator of the System.

Please have your staff notify Mario Mérida at (303) 312-6297 or [merida.mario@epa.gov](mailto:merida.mario@epa.gov) within 20 days if your records show any discrepancies with the violations cited above, if your staff learns of any change in the System's compliance status, or if there are any questions or comments. Thank you for your assistance.

Sincerely,



James H. Eppers, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

  
Arturo Palomares, Director  
Water Technical Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: Tina Artemis, EPA Regional Hearing Clerk  
Patti Fauver, UTDEQ Drinking Water Rule Section Manager (by email)  
David Whittekiend Forest Supervisor, Uinta-Wasatch-Cache National Forest  
(via certified mail/return receipt requested)  
Kim Martin, Forest Engineer, Uinta-Wasatch-Cache National Forest (via email)