



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2014 MAR 25 AM 11:19

MAR 25 2014

EPA REGION VIII  
HEARING CLERK

Ref: 8ENF-W

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Cindy F. Buckendorf, Registered Agent  
Eden Saloon, Inc.  
3629 N. US Hwy 191  
Eden, WY 82932

Re: Administrative Order Addendum #2, Eden Saloon Water System  
PWS ID #5600111, Docket No. SDWA-08-2012-0023

Dear Ms. Buckendorf:

This letter is the second addendum to the Administrative Order (Order) issued May 10, 2012, to Eden Saloon, Inc. (Eden). The purpose of this letter is to approve the plan and schedule emailed from you to the EPA on December 31, 2013, updated on February 3, 2014, and an additional action included per a telephone call with Kathelene Brainich and yourself on March 3, 2014. Possible causes of the November and December 2013 total coliform maximum contaminant level violations include poor sampling technique and water deposit build-up in the lines. Dan Chamberlain, Wyoming Association of Rural Water Systems (WARWS), provided on-site technical assistance on December 16, 2013. The plan and schedule shown below are hereby incorporated into the Order per paragraph 17 (page 3) of the Order.

<u>Action</u>	<u>Completion Date</u>
Shock well to clean water deposit build-up in water lines	December 3-20, 2013
Ensure sampling techniques do not compromise samples (training provided by WARWS)	December 16, 2013
Install cover on fitting per WARWS recommendation 12/16/13	January 2014


The EPA concurs with the WARWS recommendation and Eden's commitment to consistently maintain the distribution system and well by chlorinating and flushing.

Please contact Kathelene Brainich, Environmental Specialist, at (303) 312-6481 if you have any questions concerning this Addendum.

Sincerely,

*David Rodin for JHE*

James H. Eppers, Supervisory Attorney  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice



Arturo Palomares, Director  
Water Technical Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

cc: WY DEQ/DOH (via email)  
Tina Artemis, EPA Regional Hearing Clerk