

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

FILED

2016 SEP -7 AM 8:30

REGION 6

REGIONAL HEARING CLERK

IN THE MATTER OF

**South Coast Terminal L.P.  
Wallisville Road Facility  
Harris County, TX**

Respondent.

**CWA SECTION 311 CLASS I  
CONSENT AGREEMENT  
AND FINAL ORDER  
UNDER 40 CFR § 22.13(b)**

Docket No. **CWA-06-2016-4811**

**LEGAL AUTHORITY**

1. This Consent Agreement is proposed and entered into under the authority vested in the Administrator of the U.S. Environmental Protection Agency ("EPA") by Section 311(b)(6)(B)(i) of the Clean Water Act ("Act"), 33 U.S.C. § 1321(b)(6)(B)(i), as amended by the Oil Pollution Act of 1990, and under the authority provided by 40 CFR §§ 22.13(b) and 22.18(b)(2). The Administrator has delegated these authorities to the Regional Administrator of EPA, Region 6, who has in turn delegated them to the Director of the Superfund Division of EPA, Region 6, who has, by his concurrence, re-delegated the authority to act as Complainant to the Associate Director Prevention and Response Branch in Region 6, Delegation No. R6-2-51, dated February 13, 2008 ("Complainant").

**CONSENT AGREEMENT**

**SPCC Stipulations**

The parties, in their own capacity or by their attorneys or other authorized representatives, hereby stipulate:

2. Section 311(j)(1)(C) of the Act, 33 USC § 1321(j)(1)(C), provides that the President shall issue regulations "establishing procedures, methods, and equipment and other requirements

for equipment to prevent discharges of oil from onshore or offshore vessels and from onshore or offshore facilities, and to contain such discharges...."

3. Initially by Executive Order 11548 (July 20, 1970), 35 Fed. Reg. 11677 (July 22, 1970), and most recently by Section 2(b)(1) of Executive Order 12777 (October 18, 1991), 56 Fed. Reg. 54757 (October 22, 1991), the President delegated to EPA his Section 311(j)(1)(C) authority to issue the regulations referenced in the preceding Paragraph for non-transportation-related onshore and offshore facilities.

4. EPA promulgated the Spill Prevention Control & Countermeasure (SPCC) regulations pursuant to delegated statutory authorities, and pursuant to its authorities under the Clean Water Act, 33 USC § 1251 *et seq.*, which established certain procedures, methods and other requirements upon each owner and operator of a non-transportation-related onshore or off-shore facility, if such facility, due to its location, could reasonably be expected to discharge oil into or upon the navigable waters of the United States and their adjoining shorelines in such quantity as EPA has determined in 40 CFR § 110.3 may be harmful to the public health or welfare or the environment of the United States ("harmful quantity").

5. In promulgating 40 CFR § 110.3, which implements Section 311(b)(4) of the Act, 33 USC § 1321(b)(4), EPA has determined that discharges of harmful quantities include oil discharges that cause either (1) a violation of applicable water quality standards or (2) a film, sheen upon, or discoloration of the surface of the water or adjoining shorelines, or (3) a sludge or emulsion to be deposited beneath the surface of the water or upon adjoining shorelines.

6. Respondent is a firm conducting business in the State of Texas, with a place of

business located at 7402 Wallisville Road, TX 77020, and is a person within the meaning of Sections 311(a)(7) and 502(5) of the Act, 33 U.S.C. §§ 1321(a)(7) and 1362(5), and 40 CFR § 112.2.

7. Respondent is the owner within the meaning of Section 311(a)(6) of the Act, 33 USC § 1321(a)(6), and 40 CFR § 112.2 of a bulk liquids terminal, the Wallisville Road facility, located in Harris County, Texas ("the facility"). The approximate coordinates of the facility are 29.78783° N and -95.294731° W. Drainage from the facility travels to the city's drainage system; thence to the Houston Ship Channel.

8. The facility has an aggregate above-ground storage capacity greater than 1320 gallons of oil in containers each with a shell capacity of at least 55 gallons. Facility capacity is approximately 8,334,591 gallons.

9. The Houston Ship Channel is a navigable water of the United States within the meaning of 40 CFR § 112.2.

10. Respondent is engaged in drilling, producing, gathering, storing, processing, refining, transferring, distributing, using or consuming oil or oil products located at the facility.

11. The facility is therefore a non-transportation-related onshore facility which, due to its location, could reasonably be expected to discharge oil to a navigable water of the United States or its adjoining shorelines in a harmful quantity ("an SPCC-regulated facility").

12. Pursuant to Section 311(j)(1)(C) of the Act, E.O. 12777, and 40 CFR § 112.1 Respondent, as the owner of an SPCC-regulated facility, is subject to the SPCC regulations.

13. The facility began operating before August 16, 2002.

**SPCC Allegations**

14. 40 CFR § 112.3 requires that the owner or operator of an SPCC-regulated facility must prepare a SPCC plan in writing, and implement that plan in accordance with 40 CFR § 112.7 and any other applicable section of 40 CFR Part 112.

15. On April 20, 2016 EPA inspected the facility and found that Respondent had failed to develop and implement an SPCC plan for the facility as follows:

- a. Respondent failed to follow sequence of the rule or an equivalent meeting all applicable rule requirements in accordance with 40 CFR § 112.7(a)(1).
- b. Respondent failed to discuss in plan a complete description of the physical layout of the facility and include an accurate diagram in accordance with 40 CFR § 112.7(a)(3).
- c. Respondent failed to include in plan prediction of the direction rate of flow and total quantity of oil that could be discharged for each type of major equipment failure for each major type of equipment failure where potential for equipment failure in accordance with 40 CFR § 112.7(b).
- d. Respondent failed to discuss in the plan appropriate containment and or diversionary structures or equipment to prevent a discharge. The entire containment system are constructed to prevent escape of discharge from the containment system in accordance with 40 CFR § 112.7(c).
- e. Respondent failed to discuss in plan record of inspections or test which are signed by supervisor or inspector and kept with plan for at least 3 years in accordance with 40 CFR § 112.7(e).
- f. Respondent failed to discuss in plan brittle fracture evaluation of field constructed aboveground containers is conducted after tank repair, alteration, reconstruction, or change in service that might affect the risk of a discharge or after a discharge failure due to brittle fracture in accordance with 40 CFR § 112.7(i).
- g. Respondent failed to discuss in plan the facility drainage is equipped with a diversion system to retain oil in the facility in the event of an uncontrolled discharge in accordance with 40 CFR § 112.8(b)(4).

- h. Respondent failed to discuss in plan the construction of all bulk storage tank installations with secondary containment to hold capacity of largest container and sufficient freeboard for precipitation in accordance with 40 CFR § 112.8(c)(2).
- i. Respondent failed to discuss in the plan test or inspect aboveground containers for integrity on a regular schedule and whenever material repairs are made in accordance with 40 CFR § 112.8(c)(6).
- j. Respondent failed to discuss in plan the handling of visible discharges which result in a loss of oil from the container are promptly corrected and oil in diked areas promptly removed in accordance with 40 CFR § 112.8(c)(10).
- k. Respondent failed to discuss in plan the position of mobile or portable containers to prevent a discharge in accordance with 40 CFR § 112.8(c)(11).
- l. Respondent failed to discuss in plan the piping terminal connection at the transfer point are marked as to origin and capped or blank-flagged when not in service or in standby service in accordance with 40 CFR § 112.8(d)(2).
- m. Respondent failed to discuss in plan pipe supports are properly designed to minimize abrasion and corrosion and allow for expansion contraction in accordance with 40 CFR § 112.8(d)(3).
- n. Respondent failed to discuss in plan aboveground vales, piping and appurtenances are inspected regularly to assess their general condition in accordance with 40 CFR § 112.8(d)(4).

16. Respondent's failure to fully implement its SPCC plan for the facility violated 40 CFR § 112.3.

**Waiver of Rights**

17. Respondent admits the jurisdictional allegations set forth above and neither admits nor denies the other specific violations alleged above. Respondent waives the right to a hearing under Section 311(b)(6)(B)(i) of the Act, 33 U.S.C. § 1321(b)(6)(B)(i), and to appeal any Final Order in this matter under Section 311(b)(6)(G)(i) of the Act, 33 U.S.C. §1321(b)(6)(G)(i), and consents to the issuance of a Final Order without further adjudication.

**Penalty**

18. The Complainant proposes, and Respondent consents to, the assessment of a civil penalty of **\$11,701.00**.

**Payment Terms**

Based on the forgoing, the parties, in their own capacity or by their attorneys or authorized representatives, hereby agree that:

19. Within thirty (30) days of the effective date of the Final Order, the Respondent shall pay the amount of **\$11,701.00** by means of a cashier's or certified check, or by electronic funds transfer (EFT). The Respondent shall submit this Consent Agreement and Final Order, with original signature, along with documentation of the penalty payment to:

OPA Enforcement Coordinator  
U. S. Environmental Protection Agency  
Region 6 (6SF-PC)  
1445 Ross Avenue  
Dallas, Texas 75202-2733

- If you are paying by check, pay the check to "Environmental Protection Agency," noting on the check "**OSTLF-311**" and docket number **CWA-06-2016-4811**. If you use the

U.S. Postal Service, address the payment to:

U.S. Environmental Protection Agency, Fines & Penalties  
P.O. Box 979077, St. Louis, MO 63197-9000

- If you use a private delivery service, address the payment to:

U.S. Bank  
1005 Convention Plaza, Mail Station SL-MO-C2GL  
St. Louis, MO 63101

- The Respondent shall submit copies of the check (or, in the case of an EFT transfer, copies of the EFT confirmation) to the following person:

Lorena Vaughn  
Regional Hearing Clerk (6RC)  
U.S. Environmental Protection Agency  
Region 6  
1445 Ross Avenue  
Dallas, TX 75202-2733

20. Failure by the Respondent to pay the penalty assessed by the Final Order in full by its due date may subject Respondent to a civil action to collect the assessed penalty, plus interest, attorney's fees, costs and an additional quarterly nonpayment penalty pursuant to Section 311(b)(6)(H) of the Act, 33 USC §1321(b)(6)(H). In any such collection action, the validity, amount and appropriateness of the penalty agreed to herein shall not be subject to review.

#### **General Provisions**

21. The Final Order shall be binding upon Respondent and Respondent's officers, directors, agents, servants, employees, and successors or assigns.

22. The Final Order does not constitute a waiver, suspension or modification of the requirements of Section 311 of the Act, 33 USC §1321, or any regulations promulgated

thereunder, and does not affect the right of the Administrator or the United States to pursue any applicable injunctive or other equitable relief or criminal sanctions for any violation of law.

Payment of the penalty pursuant to this Consent Agreement resolves only Respondent's liability for federal civil penalties for the violations and facts stipulated to and alleged herein.


**South Coast Terminal Inc.**

Date: 8/15/2016

  
**Belinda Adame, HSE Manager**

**U.S. ENVIRONMENTAL PROTECTION AGENCY**

Date: 8/31/16


  
for **Ronnie D. Crossland**  
**Associate Director**  
**Emergency Management Branch**  
**Superfund Division**

**FINAL ORDER**

Pursuant to Section 311(b)(6) of the Act, 33 USC §1321(b)(6) and the delegated authority of the undersigned, and in accordance with the "Consolidated Rules of Practice Governing the Administrative Assessment of Civil Penalties, Issuance of Compliance or Corrective Action Orders, and the Revocation, Termination or Suspension of Permits," codified at 40 CFR Part 22, the forgoing Consent Agreement is hereby approved and incorporated by reference into this Final Order, and the Stipulations by the parties and Allegations by the Complainant are adopted as Findings in this Final Order.

The Respondent is ordered to comply with the terms of the Consent Agreement.

Date: 9/6/16

  
\_\_\_\_\_  
Carl E. Edlund, P.E.  
Director  
Superfund Division

**CERTIFICATE OF SERVICE**

I certify that the original and one copy of the foregoing "Consent Agreement and Final Order," issued pursuant to 40 C.F.R. 22.13(b), was filed on 9-7, 2016, with the Regional Hearing Clerk, U.S. EPA Region 6, 1445 Ross Avenue, Dallas, TX 75202-2733; and that on the same date a copy of the same was sent to the following, in the manner specified below:

Copy by certified mail,  
return receipt requested:  
7012 3460 0002 4090 9393

NAME: Ms. Belinda Adame  
ADDRESS: 7402 Wallisville Road  
Houston, TX 77020



Frankie Markham  
OPA Enforcement Administrative Assistant