



REGION 8

DENVER, CO 80202

October 29, 2025

FILED

Nov 12, 2025

11:05 AM

**U.S. EPA REGION 8
HEARING CLERK**

Ref: 8ECA-W-S

SENT VIA EMAIL
DIGITAL DELIVERY RECEIPT REQUESTED

LLN Limited LLC
Green River Bar Public Water System
c/o Nannette McKeough
nmckeoug@wyoming.com

Subj: Administrative Order Addendum regarding Green River Bar Public Water System,
PWS ID #WY5601726, Docket No. SDWA-08-2025-0036

Dear Ms. McKeough:

This is an Addendum to the Administrative Order (Order) issued to LLN Limited LLC (Respondent) on August 28, 2025. The purpose of this letter is to approve the Respondent's September 8, 2025, schedule (Schedule) for coming into consistent compliance with the sanitary defects. The Schedule is hereby incorporated into the Order pursuant to paragraph 13. Each milestone and deadline specified below is an enforceable provision of the Order.

<u>Milestone</u>	<u>Deadline</u>	<u>Projected Cost</u>
WL02 (New Well) - Perform pump test, install well cap, improve electrical junction box and conduit.	Reported as completed on 9/24/2025	\$4,200
WL01 (Old Well) - Properly abandon old well	Reported as completed on 9/24/2025	\$1,500
DEQ - Report and Permit Application Update and Submittal	Reported as completed on 10/10/2025	
EPA - Submittal of all Well Documentation from DEQ and SEO to Correct Deficiencies	12/31/2025	

The Order also requires Respondent to achieve and maintain compliance with the sanitary defect violation by the final date of December 31, 2025, specified in the approved Schedule.

Subj: Administrative Order Addendum, LLN Limited LLC regarding Green River Bar Public Water System, PWS ID #WY5601726, Docket # SDWA-08-2025-0036

The EPA is authorized to seek penalties if these deadlines are not met. If Respondent has a reasonable basis to believe it may be unable to meet any deadline in the Schedule, it must notify the EPA well in advance of the Scheduled deadline to request an extension. The EPA may, in its discretion, consider granting an extension.

If you have any questions or to request an informal conference with the EPA, please contact Steven Latino via email at latino.steven@epa.gov, or by phone at (800) 227-8917, extension 6440, or (303) 312-6440. Any questions from the Respondent's attorney should be directed to Mia Bearley, Senior Assistant Regional Counsel, via email at bearley.mia@epa.gov or by phone at (800) 227-8917, extension 6554, or (303) 312-6554.

Sincerely,

Suzanne J. Bohan, Director
Enforcement and Compliance Assurance Division

cc:

WY DEQ/DOH (via email)
Sublette County Commissioners
Anthony Ornelas, WY Office of Consumer Advocate
EPA Regional Hearing Clerk
Antolin Barraza, Operator
Dale Lee, WY DEQ District Engineer