



**EZY CHEK SYSTEMS
PRODUCT LINE TEST
FINAL REPORT**

MDE #1656

TEST DATE 03/23/18

Name	Easton Point 24 HR Gas and Diesel
Address	930 Port St.
City	Easton, MD. 21601
Phone	410-310-3553
Contact	Tim Miller

Name	Clean Fuels Associates
Address	7666A Baltimore-Annapolis Blvd.
City	Glen Burnie, MD. 21060
Phone	410-757-7576

Name	Matthew Eader
Cert #	236465
Applied Pressure	50 PSI

**PRODUCT LINE TEST
FINAL REPORT**

	Product Type	Result
#1	Reg. Gasoline Disp. 1/2	PASS
#2	Reg. Gasoline Disp. 3	PASS
#3	ULS Diesel Disp. 4/5	PASS
#4	Off Road Diesel Disp. 6	PASS
#5	Premium Gasoline Disp. 7	PASS
#6	0	0

Comments/Recommendations:

Every tank has one line to one dispenser. Each line was tested from dispenser back to the related tank. The tank number are confusing as products have changed over time. I labeled this 1-5 from left to right on the tank pad and matching the ascending dispenser numbers.

The important note is that all 5 lines and MLD's are tight and in working condition.