

930 PORT ST
EASTON MD 21601

SYSTEM SETUP

JUN 13. 2018 4:25 PM

JUN 13. 2018 4:25 PM

SYSTEM UNITS

U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS XM

SYSTEM STATUS REPORT

T 2:LOW PRODUCT ALARM
T 2:DELIVERY NEEDED

930 PORT ST
EASTON MD 21601

INVENTORY REPORT

T 1:93 OCTANE 4000
VOLUME = 2444 GALS
ULLAGE = 1591 GALS
90% ULLAGE= 1187 GALS
TC VOLUME = 2434 GALS
HEIGHT = 49.00 INCHES
WATER VOL = 15 GALS
WATER = 1.47 INCHES
TEMP = 65.4 DEG F

T 2:OFF ROAD DIESEL 4000
VOLUME = 267 GALS
ULLAGE = 3768 GALS
90% ULLAGE= 3364 GALS
TC VOLUME = 266 GALS
HEIGHT = 9.91 INCHES
WATER VOL = 5 GALS
WATER = 0.72 INCHES
TEMP = 66.1 DEG F

T 3:DIESEL ON ROAD
VOLUME = 2112 GALS
ULLAGE = 5948 GALS
90% ULLAGE= 5142 GALS
TC VOLUME = 2102 GALS
HEIGHT = 25.90 INCHES
WATER VOL = 25 GALS
WATER = 1.28 INCHES
TEMP = 66.5 DEG F

T 4:NON ETHANOL 91 OCTAN
VOLUME = 1795 GALS
ULLAGE = 6265 GALS
90% ULLAGE= 5459 GALS
TC VOLUME = 1787 GALS
HEIGHT = 23.05 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 66.0 DEG F

T 5:87 OCTANE 8000
VOLUME = 1885 GALS
ULLAGE = 6175 GALS
90% ULLAGE= 5369 GALS
TC VOLUME = 1877 GALS
HEIGHT = 23.86 INCHES
WATER VOL = 12 GALS
WATER = 0.78 INCHES
TEMP = 65.0 DEG F

* * * * * END * * * * *

SHIFT TIME 1 : 12:00 AM
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN
DISABLED
TANK ANN TST NEEDED WRN
DISABLED

LINE RE-ENABLE METHOD
PASS LINE TEST

LINE PER TST NEEDED WRN
DISABLED
LINE ANN TST NEEDED WRN
DISABLED

PRINT TO VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F) : 60.0
STICK HEIGHT OFFSET
DISABLED

H-PROTOCOL DATA FORMAT
HEIGHT
DAYLIGHT SAVING TIME
ENABLED
START DATE
APR WEEK 1 SUN
START TIME
2:00 AM
END DATE
OCT WEEK 8 SUN
END TIME
2:00 AM

RE-DIRECT LOCAL PRINTOUT
DISABLED

EURO PROTOCOL PREFIX
S

SYSTEM SECURITY
CODE : 000000

TANK CHART SECURITY
DISABLED

CUSTOM ALARMS
DISABLED

SYSTEM BEEPER
DISABLED

MASS/DENSITY
DISABLED

COMMUNICATIONS SETUP

PORT SETTINGS:

COMM BOARD : 1 (RS-232)
BAUD RATE : 1200
PARITY : ODD
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : *****

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
DISABLED
AUTO HIGH WATER LIMIT
DISABLED
AUTO OVERFILL LIMIT
DISABLED
AUTO LOW PRODUCT
DISABLED
AUTO THEFT LIMIT
DISABLED
AUTO DELIVERY START
DISABLED
AUTO DELIVERY END
DISABLED
AUTO EXTERNAL INPUT ON
DISABLED
AUTO EXTERNAL INPUT OFF
DISABLED
AUTO SENSOR FUEL ALARM
DISABLED
AUTO SENSOR WATER ALARM
DISABLED
AUTO SENSOR OUT ALARM
DISABLED

RS-232 END OF MESSAGE
DISABLED

IN-TANK SETUP

T 1:93 OCTANE 4000
PRODUCT CODE : 1
THERMAL COEFF :.000700
TANK DIAMETER : 84.00
TANK PROFILE : 1 PT
FULL VOL : 4035

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.0
HIGH WATER LIMIT: 2.5

MAX OR LABEL VOL: 4035
OVERFILL LIMIT : 90%
: 3631
HIGH PRODUCT : 95%
: 3833
DELIVERY LIMIT : 10%
: 403

LOW PRODUCT : 500
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 0%
: 0

LEAK MIN ANNUAL : 0%
: 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

T 2:OFF ROAD DIESEL 4000
PRODUCT CODE : 2
THERMAL COEFF :.000450
TANK DIAMETER : 84.00
TANK PROFILE : 1 PT
FULL VOL : 4035

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.0
HIGH WATER LIMIT: 2.5

MAX OR LABEL VOL: 4035
OVERFILL LIMIT : 90%
: 3631
HIGH PRODUCT : 95%
: 3833
DELIVERY LIMIT : 10%
: 403

LOW PRODUCT : 500
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 0%
: 0

LEAK MIN ANNUAL : 0%
: 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

T 3:DIESEL ON ROAD
PRODUCT CODE : 3
THERMAL COEFF :.000700
TANK DIAMETER : 84.00
TANK PROFILE : 1 PT
FULL VOL : 8060

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.0
HIGH WATER LIMIT: 2.5

MAX OR LABEL VOL: 8060
OVERFILL LIMIT : 90%
: 7254
HIGH PRODUCT : 95%
: 7657
DELIVERY LIMIT : 10%
: 806

LOW PRODUCT : 500
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 0%
: 0

LEAK MIN ANNUAL : 0%
: 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

T 4:NON ETHANOL 91 OCTAN
PRODUCT CODE : 4
THERMAL COEFF : .000700
TANK DIAMETER : 84.00
TANK PROFILE : 1 FT
FULL VOL : 8060

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.0
HIGH WATER LIMIT: 2.5

MAX OR LABEL VOL: 8060
OVERFILL LIMIT : 90%
 : 7254
HIGH PRODUCT : 95%
 : 7657
DELIVERY LIMIT : 10%
 : 806

LOW PRODUCT : 500
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS

T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 0%
 : 0

LEAK MIN ANNUAL : 0%
 : 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

T 5:87 OCTANE 8000
PRODUCT CODE : 5
THERMAL COEFF : .000700
TANK DIAMETER : 84.00
TANK PROFILE : 1 FT
FULL VOL : 8060

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.0
HIGH WATER LIMIT: 2.5

MAX OR LABEL VOL: 8060
OVERFILL LIMIT : 90%
 : 7254
HIGH PRODUCT : 95%
 : 7657
DELIVERY LIMIT : 10%
 : 806

LOW PRODUCT : 500
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS

T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 0%
 : 0

LEAK MIN ANNUAL : 0%
 : 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

LEAK TEST METHOD

TEST WEEKLY : ALL TANK
MON
START TIME : 12:05 AM
TEST RATE : 0.20 GAL/HR
DURATION : 2 HOURS

TST EARLY STOP:DISABLED

LEAK TEST REPORT FORMAT
NORMAL

SOFTWARE REVISION LEVEL
VERSION 326.01
SOFTWARE# 346326-100-B
CREATED - 06.01.16.17.13

S-MODULE# 330160-002-A
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS
CSLD

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

JUN 13. 2018 4:26 PM

JUN 13. 2018 4:26 PM

LEAK TEST REPORT

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
JUN 11. 2018 12:05 AM

TEST STARTING TIME:
JUN 11. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2452.1 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2133.9 GAL

START TEMP = 65.6 F
END TEMP = 65.6 F

START TEMP = 66.2 F
END TEMP = 66.2 F

TEST PERIODS 2-4
0.01 0.02 0.02

TEST PERIODS 2-4
0.02 0.01 0.03

LEAK TEST RESULTS
RATE = 0.01 GAL/HR
0.20 GAL/HR TEST PASS

LEAK TEST RESULTS
RATE = 0.02 GAL/HR
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR

***** END *****

***** END *****

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

JUN 13. 2018 4:26 PM

JUN 13. 2018 4:26 PM

LEAK TEST REPORT

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JUN 11. 2018 12:05 AM

TEST STARTING TIME:
JUN 11. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 505.8 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1951.0 GAL

START TEMP = 64.5 F
END TEMP = 64.4 F

START TEMP = 65.5 F
END TEMP = 65.5 F

TEST PERIODS 2-4
0.00 0.00 0.01

TEST PERIODS 2-4
0.00 0.00 0.00

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
0.20 GAL/HR TEST INVL

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR

***** END *****

***** END *****

930 PORT ST
EASTON MD 21601

JUN 13. 2018 4:26 PM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
JUN 11. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2254.4 GAL

START TEMP = 66.6 F
END TEMP = 66.6 F

TEST PERIODS 2-4
0.02 0.02 0.04

LEAK TEST RESULTS
RATE = 0.03 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

ALARM HISTORY REPORT

----- SYSTEM ALARM -----
PAPER OUT
APR 27. 2018 4:27 PM
PRINTER ERROR
APR 27. 2018 4:28 PM
BATTERY IS OFF
JAN 16. 2006 8:00 AM

***** END *****

ALARM HISTORY REPORT

----- IN-TANK ALARM -----

T 1:93 OCTANE 4000

HIGH WATER ALARM

OCT 7, 2016 10:27 AM

LOW PRODUCT ALARM

SEP 29, 2017 12:49 PM

SEP 18, 2017 12:42 PM

JUL 3, 2017 10:55 AM

HIGH PRODUCT ALARM

SEP 29, 2017 12:56 PM

PROBE OUT

SEP 29, 2017 3:04 PM

SEP 29, 2017 12:49 PM

AUG 24, 2017 10:52 AM

DELIVERY NEEDED

SEP 29, 2017 12:49 PM

JUL 8, 2017 12:17 PM

MAR 8, 2017 9:39 AM

MAX PRODUCT ALARM

SEP 29, 2017 12:56 PM

* * * * * END * * * * *

MAY 7. 2018 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
MAY 7. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2737.1 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
MAY 7. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 7. 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
MAY 7. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2349.1 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

MAY 7. 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
MAY 7. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3017.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
MAY 7. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 7. 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
MAY 7. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4829.5 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

MAY 7. 2018 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
MAY 7. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2095.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAG:
LOW LEVEL TEST ERROR

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
AUG 21, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 21, 2017 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
AUG 21, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1992.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
JUN 19, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 19, 2017 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JUN 19, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2314.2 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
AUG 6, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 6, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
AUG 6, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2474.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

TEST

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
JUL 30, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 30, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JUL 30, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2911.8 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
FEB 27, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

FEB 27, 2017 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
FEB 27, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2372.1 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
FEB 20, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

FEB 20, 2017 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
FEB 20, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2476.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:DIESEL
JAN 2, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JAN 2, 2017 2:05 AM

LEAK TEST REPORT

T 2:DIESEL
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JAN 2, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1559.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JUN 12, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 12, 2017 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JUN 12, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1634.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
JUL 3, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 3, 2017 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
JUL 3, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2221.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
JUN 19, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 19, 2017 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
JUN 19, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2882.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST FAIL

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
JUL 30, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 30, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
JUL 30, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2573.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
JUL 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 23, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
JUL 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3629.1 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
MAY 7, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 7, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
MAY 7, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3017.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
NOV 6, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 6, 2017 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
NOV 6, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1471.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
OCT 2, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

OCT 2, 2017 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
OCT 2, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1069.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 2, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 2, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 2, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2411.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS
***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
AUG 6, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 6, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
AUG 6, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1230.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS
***** END *****

930 PORT ST
EASTON MD 21601

APR 14, 2017 12:29 PM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
APR 10, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1810.8 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

ST
501

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JUN 19, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 19, 2017 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JUN 19, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1619.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JUL 30, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 30, 2018 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JUL 30, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2185.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

PAC PRIDE
900 FORT ST.
EASTON MD. 21601

JUL 12, 2016 3:00 AM

CSLD TEST RESULTS

JUL 12, 2016 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JUL 12, 2016 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JUL 12, 2016 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: JUL 12, 2016 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

T 5: UNLEADED 8000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

PAC PRIDE
900 FORT ST.
EASTON MD. 21601

JUL 10, 2016 8:00 AM

CSLD TEST RESULTS

JUL 10, 2016 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JUL 10, 2016 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JUL 10, 2016 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

T 5: UNLEADED 8000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

PAC PRIDE
900 FORT ST.
EASTON MD. 21601

JUL 13, 2016 8:00 AM

CSLD TEST RESULTS

JUL 13, 2016 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JUL 13, 2016 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JUL 13, 2016 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: JUL 13, 2016 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

T 5: UNLEADED 8000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE
JUL 20:21 9:00 161 000
LUC 88004
SWIN BELSAS

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

FEB 14, 2010 8:00 AM
CSLD TEST RESULTS
FEB 14, 2010 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

NOV 29, 2009 8:00 AM
CSLD TEST RESULTS
NOV 29, 2009 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

FEB 14, 2010 8:00 AM
CSLD TEST RESULTS
FEB 14, 2010 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

DEC 31, 2009 8:00 AM
CSLD TEST RESULTS
DEC 31, 2009 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

JAN 15, 2010 8:00 AM
CSLD TEST RESULTS
JAN 15, 2010 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

IN-TANK ALARM
T 2:DIESEL
DELIVERY NEEDED
SEP 11, 2009 4:51 AM

PAC PRIDE
900 FORT ST.
EASTON MD. 21601

SEP 11, 2009 8:00 AM

CSLD TEST RESULTS

SEP 11, 2009 8:00 AM

T 1:UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: SEP 11, 2009 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: SEP 11, 2009 PASS

T 3:SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: SEP 11, 2009 PASS

T 4:PLUS
PROBE SERIAL NUM 229512
0.2 GAL/HR TEST
PER: SEP 11, 2009 PASS

T 5:UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: SEP 11, 2009 PASS

900 FORT ST.
EASTON MD. 21601

JUN 11, 2010 8:00 AM

CSLD TEST RESULTS

JUN 11, 2010 8:00 AM

T 1:UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

T 3:SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

T 4:PLUS
PROBE SERIAL NUM 229512
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

T 5:UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1386.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4632.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2130.9 GAL

LEAK TEST RESULT
0.20 GAL/HR TEST PASS

***** END *****
STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3179.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2773.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2736.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2719.8 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2266.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2600.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1562.5 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

PAV PRIDE
930 FORT ST.
EASTON MD. 21601

JUL 12, 2016 8:00 AM

CSLD TEST RESULTS

JUL 12, 2016 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JUL 12, 2016 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JUL 12, 2016 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: JUL 12, 2016 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

T 5: UNLEADED 8000
PROBE SERIAL NUM 229511

0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

PAV PRIDE
930 FORT ST.
EASTON MD. 21601

JUL 10, 2016 8:00 AM

CSLD TEST RESULTS

JUL 10, 2016 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JUL 10, 2016 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JUL 10, 2016 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

T 5: UNLEADED 8000
PROBE SERIAL NUM 229511

0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

PAV PRIDE
930 FORT ST.
EASTON MD. 21601

JUL 13, 2016 8:00 AM

CSLD TEST RESULTS

JUL 13, 2016 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JUL 13, 2016 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JUL 13, 2016 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: JUL 13, 2016 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

T 5: UNLEADED 8000
PROBE SERIAL NUM 229511

0.2 GAL/HR TEST
PER: NO RESULTS AVAILABLE

PAPER OUT
JUL 19, 2016 12:07 PM

SYSTEM ALARM

*Not on chart **
Somewhat
Confirms because of
FF, Vendor
on K was programmed
Part was

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
JAN 7, 2019 2:05 AM

930 PORT ST
EASTON MD 21601

JAN 7, 2019 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
JAN 7, 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1236.6 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
DEC 24, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

DEC 24, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
DEC 24, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1504.1 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
NOV 19, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 19, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
NOV 19, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1171.6 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
AUG 20, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 20, 2018 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
AUG 20, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2595.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
JUL 2, 2018 2:05 AM
" "

930 PORT ST
EASTON MD 21601

JUL 2, 2018 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
JUL 2, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3152.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
JUN 18, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 18, 2018 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
JUN 18, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 302.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1386.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4632.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2130.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3179.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2773.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
CT 29, 2018 2:05 AM

30 PORT ST
ASTON MD 21601

CT 29, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
CT 29, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2920.2 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
NOV 12, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 12, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
NOV 12, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2704.8 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
DEC 31, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

DEC 31, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
DEC 31, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2130.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 2:00 ROAD DIESEL 4000
JAN 7, 2019 2:05 AM

930 PORT ST
EASTON MD 21601

JAN 7, 2019 2:05 AM

LEAK TEST REPORT

T 2:00 ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JAN 7, 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2541.8 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

STOP IN-TANK LEAK TEST
T 2:00 ROAD DIESEL 4000
DEC 17, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

DEC 17, 2018 2:05 AM

LEAK TEST REPORT

T 2:00 ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
DEC 17, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1698.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

STOP IN-TANK LEAK TEST
T 2:00 ROAD DIESEL 4000
NOV 19, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 19, 2018 2:05 AM

LEAK TEST REPORT

T 2:00 ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
NOV 19, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1841.5 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
DEC 31, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

DEC 31, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
DEC 31, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2535.8 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
NOV 5, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 5, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
NOV 5, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2439.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
JAN 7, 2019 2:05 AM

930 PORT ST
EASTON MD 21601

JAN 7, 2019 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JAN 7, 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2426.2 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
OCT 29, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

OCT 29, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
OCT 29, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2824.2 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
SEP 10, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

SEP 10, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
SEP 10, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2212.4 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
AUG 27, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 27, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
AUG 27, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3285.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1386.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4632.6 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2130.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3179.7 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2773.6 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
AUG 27, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
AUG 20, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
AUG 27, 2018 2:05 AM

AUG 27, 2018 2:05 AM

AUG 20, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

LEAK TEST REPORT

LEAK TEST REPORT

AUG 27, 2018 2:05 AM

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

LEAK TEST REPORT

TEST STARTING TIME:
AUG 27, 2018 12:05 AM

TEST STARTING TIME:
AUG 20, 2018 12:05 AM

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2343.5 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2856.5 GAL

TEST STARTING TIME:
AUG 27, 2018 12:05 AM

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1844.9 GAL

***** END *****

***** END *****

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
AUG 27, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 27, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
AUG 27, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3285.4 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
MAY 28, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
MAY 28, 18 2:05 AM

STOP IN TANK LEAK TEST
T 1:93 OCTANE 4000
MAY 28, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

MAY 28, 2018 2:05 AM

MAY 28, 2018 2:05 AM

MAY 28, 2018 2:05 AM

LEAK TEST REPORT

LEAK TEST REPORT

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
MAY 28, 2018 12:05 AM

TEST STARTING TIME:
MAY 28, 2018 12:05 AM

TEST STARTING TIME:
MAY 28, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2266.6 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2719.8 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2600.6 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

***** END *****

***** END *****

STOP IN TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
MAY 28, 2018 2:05 AM

STOP IN TANK LEAK TEST
T 3:DIESEL ON ROAD
MAY 28, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

MAY 28, 2018 2:05 AM

MAY 28, 2018 2:05 AM

LEAK TEST REPORT

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
MAY 28, 2018 12:05 AM

TEST STARTING TIME:
MAY 28, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1562.5 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2736.7 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
APR 23, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
APR 23, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

APR 27, 2018 4:27 PM

APR 27, 2018 4:27 PM

LEAK TEST REPORT

LEAK TEST REPORT

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2773.6 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1886.4 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2130.9 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULT
0.20 GAL HR TEST PASS

***** END *****

***** END *****

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
APR 23, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

APR 27, 2018 4:27 PM

LEAK TEST REPORT

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3179.7 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4612.6 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
NOV 12, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 12, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
NOV 12, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2704.8 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
NOV 5, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 5, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
NOV 5, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2439.9 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN TANK LEAK TEST
T 1:93 OCTANE 4000
NOV 19, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 19, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
NOV 19, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME 1171.6 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
NOV 19, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 19, 2018 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
NOV 19, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1340.5 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
DEC 24, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 1:19 OCTANE 4000
DEC 17, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
DEC 17, 2018 2:05 AM

930 FORT ST
EASTON MD 21601

930 FORT ST
EASTON MD 21601

930 FORT ST
EASTON MD 21601

DEC 24, 2018 2:05 AM

DEC 17, 2018 2:05 AM

LEAK TEST REPORT

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

T 1:19 OCTANE 4000
PROBE SERIAL NUM 229515

DEC 17, 2018 2:05 AM

TEST STARTING TIME:
DEC 24, 2018 12:05 AM

TEST STARTING TIME:
DEC 17, 2018 12:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2769.5 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 769.5 GAL

TEST STARTING TIME:
DEC 17, 2018 12:05 AM

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2845.4 GAL

0.20 GAL HR FLAGS:
LOW LEVEL TEST ERROR

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

* * * * * END * * * * *

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
DEC 31, 2018 2:05 AM

930 FORT ST
EASTON MD 21601

DEC 31, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
DEC 31, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3144.5 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
DEC 31, 2018 2:05 AM

930 FORT ST
EASTON MD 21601

DEC 31, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
DEC 31, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2755.6 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
JAN 7. 2019 12:05 AM

930 FORT ST
EASTON MD 21601

JAN 7. 2019 12:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JAN 7. 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1476.3 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
JAN 28. 2019 12:05 AM

930 FORT ST
EASTON MD 21601

JAN 28. 2019 12:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JAN 28. 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1652.7 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JAN 14. 2019 12:05 AM

930 FORT ST
EASTON MD 21601

JAN 14. 2019 12:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JAN 14. 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1476.3 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JAN 28. 2019 12:05 AM

930 FORT ST
EASTON MD 21601

JAN 28. 2019 12:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JAN 28. 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1473.3 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
APR 1. 2019 2:05 AM

930 PORT ST
EASTON MD 21601

APR 1. 2019 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
APR 1. 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3266.0 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
APR 15. 2019 12:05 AM

930 PORT ST
EASTON MD 21601

APR 15. 2019 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
APR 15. 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1359.7 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 1. 2019 2:05 AM

930 PORT ST
EASTON MD 21601

APR 1. 2019 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 1. 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1451.0 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
MAY 8. 2017 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 8. 2017 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
MAY 8. 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1729.0 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JUL 17. 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 17. 2017 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JUL 17. 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1368.1 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
JUL 24. 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 24. 2017 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JUL 24. 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3582.8 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
OCT 15. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

OCT 15. 2018 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
OCT 15. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2157.3 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JUL 31. 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 31. 2017 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JUL 31. 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1177.2 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

930 PORT ST
EASTON MD 21601

MAY 15. 2017 11:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
MAY 15. 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1706.9 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
AUG 27, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 27, 2018 2:05 AM

LEAK TEST REPORT
T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
AUG 27, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2343.5 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
OCT 30, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

OCT 30, 2017 2:05 AM

LEAK TEST REPORT
T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
OCT 30, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1318.2 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
OCT 23, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

OCT 23, 2017 2:05 AM

LEAK TEST REPORT
T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
OCT 23, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1406.9 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
JUL 23, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JUL 23, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
AUG 20, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

JUL 23, 2018 2:05 AM

JUL 23, 2018 2:05 AM

AUG 20, 2018 2:05 AM

LEAK TEST REPORT

LEAK TEST REPORT

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
JUL 23, 2018 12:05 AM

TEST STARTING TIME:
JUL 23, 2018 12:05 AM

TEST STARTING TIME:
AUG 20, 2018 2:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1409.1 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1476.0 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2595.7 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

***** END *****

***** END *****

STOP IN TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
MAY 15, 2017 2:05 AM

STOP IN TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
MAY 23, 2017 2:05 AM

STOP IN TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
MAY 1, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

930 PORT ST
EASTON MD 21601

MAY 15, 2017 2:05 AM

MAY 23, 2017 2:05 AM

MAY 1, 2017 2:05 AM

LEAK TEST REPORT

LEAK TEST REPORT

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
MAY 15, 2017 12:05 AM

TEST STARTING TIME:
MAY 23, 2017 12:05 AM

TEST STARTING TIME:
MAY 1, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1717.2 GAL

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1697.9 GAL

TEST LENGTH = 2.0 HR
STRT VOLUME = 1746.9 GAL

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

LEAK TEST RESULTS
0.20 GAL HR TEST PASS

***** END *****

***** END *****

***** END *****