

Toffel, Melissa

From: Tim Miller <tmiller@nationalpremiumbeer.com>
Sent: Thursday, August 23, 2018 1:09 PM
To: Toffel, Melissa
Subject: Re: Passing tests
Attachments: ATT00001.txt; ATT00002.txt; Passing Tests0001.pdf; Passing Tests 20001.pdf

Here you go.



Tim Miller
Owner, National Premium Beer
Phone: 410 310-3653
Email: tmiller@nationalpremiumbeer.com
Website: NATIONALPREMIUMBEER.COM

 Like us on Facebook  Follow on Instagram  Follow @twitter

Get your own  email signature

On Thu, Aug 23, 2018 at 1:01 PM Toffel, Melissa <Toffel.Melissa@epa.gov> wrote:

Sure, I'll definitely take a look at them!

Melissa Toffel

U.S. EPA Region III

Land & Chemicals Division

RCRA Underground Storage Tank Branch

1650 Arch Street (Mail Code 3LC31)

Philadelphia, PA 19103

P: 215-814-2060

F: 215-814-3163



From: Tim Miller [<mailto:tmiller@nationalpremiumbeer.com>]
Sent: Thursday, August 23, 2018 1:00 PM

To: Toffel, Melissa <Toffel.Melissa@epa.gov>

Subject: Passing tests

I found a few more from April 27 and May 28, do you want those?



Tim Miller

Owner, National Premium Beer

Phone: 410-310-3553

Email: tmiller@nationalpremiumbeer.com

Website: NATIONALPREMIUMBEER.COM



Like us on Facebook



Follow on Instagram



Follow @twitter

Get your own  email signature

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1386.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4632.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2130.9 GAL

LEAK TEST RESULT
0.20 GAL/HR TEST PASS

***** END *****
STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3179.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
APR 23. 2018 2:05 AM

930 FORT ST
EASTON MD 21601

APR 27. 2018 4:27 PM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
APR 23. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2773.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2736.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2719.8 GAL

LEAK TEST RESULTS
0.30 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2266.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2600.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
MAY 28. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 28. 2018 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
MAY 28. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1562.5 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****