



ESTABROOK'S EZY CHEK LEAK DETECTOR TEST RESULTS

DATE: <u>7/26/2016</u>	
TESTING <u>Clean Fuels Associates</u>	MDE SITE: <u>1656</u>
ADDRESS <u>7364 Edgewood Rd.</u>	ADDRESS: <u>930 Port St. Easton</u>
<u>Annapolis, MD 21403</u>	<u>MD. 21601</u>
PHONE: <u>(410) 757-7576</u>	

TECH NAME & CERT #: Matthew Eader #236465

TEST REPORT INDICATES

TYPE OF LEAK DETECTOR TESTED

PUMP #	MAKE	MODEL	SERIAL #
1	_____	_____	_____
2	_____	_____	_____
3	_____	_____	_____
4	VMI	99LD-2000	16061362 **NEW**
5	_____	_____	_____
6	_____	_____	_____
7	_____	_____	_____
8	_____	_____	_____

PUMP #	PRODUCT TYPE	METERING PRESSURE	FUNCTIONAL ELEMENT HOLDING PSI	RESILIENCY	TEST LEAK RATE ML/MIN	OPENING TIME	PASS FAIL
1					189 ml		
2					189 ml		
3					189 ml		
4	Unleaded Regular T4(Disp. 1/2)	26 psi	25 psi	450 ml	189 ml	4 sec.	P
5					189 ml		
6					189 ml		
7					189 ml		
8					189 ml		