



**EZY CHEK SYSTEMS
LEAK DETECTOR TESTER
DATA SHEET**

MDE #1656

TEST DATE 3/23/2018

Name	Easton Point 24 HR Gas and Diesel
Address	930 Port St.
City	Easton, MD. 21601
Phone	410-310-3553
Contact	Tim Miller

Name	Clean Fuels Associates
Address	7666A Baltimore-Annapolis Blvd.
City	Glen Burnie, MD. 21060
Phone	410-757-7576

Name	Matthew Eader
Cert #	301-525-6474

TYPE OF LEAK DETECTOR

PUMP #	MAKE	MODEL	SERIAL #
1	VMI	99LD-2000	16061362
2	Veeder-Root	FX1V	7808
3	Veeder-Root	FX1DV	6104
4	Veeder-Root	FX1DV	9461
5	VMI	99LD-2000	12011266
6			
7			
8			

PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Gasoline Disp. 1/2	28 PSI	26 PSI	200 ML	189ml	5 Sec.	PASS
2	Gasoline Disp. 3	28 PSI	15 PSI	150 ML	189ml	2 Sec.	PASS
3	ULS Diesel Disp. 4/5	30 PSI	16 PSI	50 ML	189ml	2 Sec.	PASS
4	Off-Road Disp. 6	28 PSI	14 PSI	75 ML	189ml	2 Sec.	PASS
5	Prem Gas Disp. 7	30 PSI	28 PSI	75 ML	189ml	5 Sec.	PASS
6					189ml		
7					189ml		
8					189ml		