

Toffel, Melissa

From: Tim Miller <tmiller@nationalpremiumbeer.com>
Sent: Wednesday, August 08, 2018 5:12 PM
To: Toffel, Melissa
Subject: Re: Easton Point follow-up questions to EPA's inspection on 6/13/18
Attachments: ATT00001.txt; EPA0001.pdf; Woof!.jpg



Tim Miller
Owner, National Premium Beer
Phone: 410-310-3553
Email: tmiller@nationalpremiumbeer.com
Website: NATIONALPREMIUMBEER.COM

Like us on Facebook Follow on Instagram Follow @twitter

Get your own email signature

On Wed, Aug 8, 2018 at 2:13 PM, Toffel, Melissa <Toffel.Melissa@epa.gov> wrote:

EPA considers "Passes" and "Fails" as valid release detection results. "Invalids" are not sufficient.

Melissa Toffel

U.S. EPA Region III

Land & Chemicals Division

RCRA Underground Storage Tank Branch

1650 Arch Street (Mail Code 3LC31)

Philadelphia, PA 19103

P: 215-814-2060

F: 215-814-3163




From: Tim Miller [<mailto:tmiller@nationalpremiumbeer.com>]
Sent: Wednesday, August 08, 2018 2:11 PM



To: Toffel, Melissa <Toffel.Melissa@epa.gov>

Subject: Re: Easton Point follow-up questions to EPA's inspection on 6/13/18

OK, I am just looking for passing tests.



Tim Miller
Owner, National Premium Beer
Phone: 410-310-3553
Email: tmiller@nationalpremiumbeer.com
Website: NATIONALPREMIUMBEER.COM



Get your own email signature

On Wed, Aug 8, 2018 at 1:23 PM, Toffel, Melissa <Toffel.Melissa@epa.gov> wrote:

Yes, going back as far as you have it... anything from January 2014 to the present.

Melissa Toffel

U.S. EPA Region III

Land & Chemicals Division

RCRA Underground Storage Tank Branch

1650 Arch Street (Mail Code 3LC31)

Philadelphia, PA 19103

P: 215-814-2060



F: 215-814-3163

From: Tim Miller [mailto:tmiller@nationalpremiumbeer.com]
Sent: Wednesday, August 08, 2018 1:16 PM
To: Toffel, Melissa <Toffel.Melissa@epa.gov>
Subject: Re: Easton Point follow-up questions to EPA's inspection on 6/13/18

So do you want the leak tests from the veeder root?



Tim Miller
Owner, National Premium Beer
Phone: 410-310-3553
Email: tmiller@nationalpremiumbeer.com
Website: NATIONALPREMIUMBEER.COM



Get your own  email signature

On Tue, Jul 24, 2018 at 9:54 AM, Toffel, Melissa <Toffel.Melissa@epa.gov> wrote:

Tim, I am able to offer up to a two-week extension to answer the questions, and since you have a vacation coming up it sounds like you will need it. If we make the new deadline August 17th, will you be able to provide me everything requested by then?

Melissa Toffel

U.S. EPA Region III

Land & Chemicals Division

RCRA Underground Storage Tank Branch

1650 Arch Street (Mail Code 3LC31)

Philadelphia, PA 19103

P: 215-814-2060

F: 215-814-3163

From: Tim Miller [mailto:tmiller@nationalpremiumbeer.com]
Sent: Tuesday, July 24, 2018 9:47 AM
To: Toffel, Melissa <Toffel.Melissa@epa.gov>
Subject: Re: Easton Point follow-up questions to EPA's inspection on 6/13/18

1. I will get you everything I have.

2. I will look but I think that is all I have.



3. I will look but I think that is all I have.

4. OK



5. I will look but I think that is all I have.

My best guess is that I took back over August 1, 2016 but I will look for an exact date.

I am going away for a week starting 7/28/2018, fyi.



Tim Miller
Owner, National Premium Beer
Phone: 410-310-3553
Email: tmiller@nationalpremiumbeer.com
Website: NATIONALPREMIUMBEER.COM



Get your own  email signature

On Thu, Jul 12, 2018 at 2:46 PM, Toffel, Melissa <Toffel.Melissa@epa.gov> wrote:

Hi Tim – now that I’ve had time to write up my report and look at what info was provided during the inspection, as I had mentioned I do have follow-up questions for you. You had said that you had taken over operating the facility about a year and a half ago. Can you please provide **an exact date** that you took back over? This will be important in that the information I am requesting below will need to be provided going back to when you resumed operating the facility.

1. Please provide monthly tank release detection records for all five tanks going back to when you resumed operating the facility up through April 2018.
2. Provide annual functionality testing documentation of the line leak detectors for each tank, going back to when you resumed operation at the facility. I already have testing dated 6/27/16 and 3/23/18, but if you have any others please provide them.
3. Provide line tightness testing documentation for each tank, going back to when you resumed operation at the facility. I already have testing dated 6/27/16 and 3/23/18, but if you have any others please provide them.
4. Overfill could not be verified in the field, but it was mentioned that you may be utilizing ballfloats for each tank. Please provide verification from a third party that overfill is installed and functioning. If in fact ballfloats are being utilized, please provide a picture of each ballfloat lying next to its adjacent fillport.
5. I reviewed cathodic protection testing dated 6/17/16, 2/1/18, and 3/8/18 – do you have any others to provide since you resumed operation at the site?

Please submit this information by August 3, 2018. If you will have trouble meeting this timeframe, please give me a call to discuss. Thank you,

Melissa Toffel

U.S. EPA Region III

Land & Chemicals Division

RCRA Underground Storage Tank Branch

1650 Arch Street (Mail Code 3LC31)

Philadelphia, PA 19103

P: 215-814-2060

F: 215-814-3163

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
AUG 21, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 21, 2017 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
AUG 21, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1992.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
JUN 19, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 19, 2017 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JUN 19, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2314.2 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
AUG 6, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 6, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
AUG 6, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2474.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS
***** END *****

TEST STARTING TIME:
JUL 30, 2018 12:05 AM

PROBE SERIAL NUM 229516

LEAK TEST REPORT

JUL 30, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
JUL 30, 2018 2:05 AM

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
FEB 27, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

FEB 27, 2017 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
FEB 27, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2372.1 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
FEB 20, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

FEB 20, 2017 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
FEB 20, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2476.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:DIESEL
JAN 2, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JAN 2, 2017 2:05 AM

LEAK TEST REPORT

T 2:DIESEL
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JAN 2, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1559.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JUN 12, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 12, 2017 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JUN 12, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1634.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
JUL 3, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 3, 2017 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
JUL 3, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2221.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
JUN 19, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 19, 2017 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
JUN 19, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2882.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
JUL 30, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 30, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
JUL 30, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2573.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
JUL 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 23, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
JUL 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3629.1 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
MAY 7, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

MAY 7, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
MAY 7, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3017.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
OCT 2, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

OCT 2, 2017 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
OCT 2, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1069.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
NOV 6, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 6, 2017 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
NOV 6, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1471.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 2, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 2, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 2, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2411.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS
***** END *****

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
AUG 6, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 6, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
AUG 6, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1230.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS
***** END *****

930 PORT ST
EASTON MD 21601

APR 14. 2017 12:29 PM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
APR 10. 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1810.8 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JUN 19. 2017 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 19. 2017 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JUN 19. 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1619.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JUL 30. 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 30. 2018 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JUL 30. 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2185.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

PT
601

PAC PRIDE
900 FORT ST.
EASTON MD. 21601

JUL 12, 2016 8:00 AM

CSLD TEST RESULTS

JUL 12, 2016 8:00 AM

T 1:UNLEADED 4000
PROBE SERIAL NUM 229515
0.2 GAL HR TEST
PER: JUL 12, 2016 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517
0.2 GAL HR TEST
PER: JUL 12, 2016 PASS

T 3:SUPER
PROBE SERIAL NUM 229514
0.2 GAL HR TEST
PER: JUL 12, 2016 PASS

T 4:PLUS
PROBE SERIAL NUM 229516
0.2 GAL HR TEST
PER:NO RESULTS AVAILABLE

T 5:UNLEADED 8000
PROBE SERIAL NUM 229511
0.2 GAL HR TEST
PER:NO RESULTS AVAILABLE

PAC PRIDE
900 FORT ST.
EASTON MD. 21601

JUL 10, 2016 8:00 AM

CSLD TEST RESULTS

JUL 10, 2016 8:00 AM

T 1:UNLEADED 4000
PROBE SERIAL NUM 229515
0.2 GAL HR TEST
PER: JUL 10, 2016 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517
0.2 GAL HR TEST
PER: JUL 10, 2016 PASS

T 3:SUPER
PROBE SERIAL NUM 229514
0.2 GAL HR TEST
PER:NO RESULTS AVAILABLE

T 4:PLUS
PROBE SERIAL NUM 229516
0.2 GAL HR TEST
PER:NO RESULTS AVAILABLE

T 5:UNLEADED 8000
PROBE SERIAL NUM 229511
0.2 GAL HR TEST
PER:NO RESULTS AVAILABLE

PAC PRIDE
900 FORT ST.
EASTON MD. 21601

JUL 13, 2016 8:00 AM

CSLD TEST RESULTS

JUL 13, 2016 8:00 AM

T 1:UNLEADED 4000
PROBE SERIAL NUM 229515
0.2 GAL HR TEST
PER: JUL 13, 2016 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517
0.2 GAL HR TEST
PER: JUL 13, 2016 PASS

T 3:SUPER
PROBE SERIAL NUM 229514
0.2 GAL HR TEST
PER: JUL 13, 2016 PASS

T 4:PLUS
PROBE SERIAL NUM 229516
0.2 GAL HR TEST
PER:NO RESULTS AVAILABLE

T 5:UNLEADED 8000
PROBE SERIAL NUM 229511
0.2 GAL HR TEST
PER:NO RESULTS AVAILABLE
MAY 20:21 9:00 '61 300
LNU
SYSTEM HARBOR

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

NOV 29, 2009 8:00 AM
CSLD TEST RESULTS
NOV 29, 2009 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JUN 11, 2010 PASS

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

NOV 29, 2009 8:00 AM
CSLD TEST RESULTS
NOV 29, 2009 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: NOV 29, 2009 PASS

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

FEB 14, 2010 8:00 AM
CSLD TEST RESULTS
FEB 14, 2010 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: FEB 14, 2010 PASS

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

DEC 31, 2009 8:00 AM
CSLD TEST RESULTS
DEC 31, 2009 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: DEC 31, 2009 PASS

PAC PRIDE
930 PORT ST.
EASTON MD. 21601

JAN 15, 2010 8:00 AM
CSLD TEST RESULTS
JAN 15, 2010 8:00 AM

T 1: UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

T 2: DIESEL
PROBE SERIAL NUM 229517
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

T 3: SUPER
PROBE SERIAL NUM 229514
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

T 4: PLUS
PROBE SERIAL NUM 229516
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

T 5: UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL/HR TEST
PER: JAN 15, 2010 PASS

IN-TANK ALARM
T 2:DIESEL
DELIVERY NEEDED
SEP 11, 2009 4:51 AM

PAC PRIDE
900 FORT ST.
EASTON MD. 21601

SEP 11, 2009 8:00 AM

CSLD TEST RESULTS

SEP 11, 2009 8:00 AM

T 1:UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL HR TEST
PER: SEP 11, 2009 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517
0.2 GAL HR TEST
PER: SEP 11, 2009 PASS

T 3:SUPER
PROBE SERIAL NUM 229514
0.2 GAL HR TEST
PER: SEP 11, 2009 PASS

T 4:PLUS
PROBE SERIAL NUM 229512
0.2 GAL HR TEST
PER: SEP 11, 2009 PASS

T 5:UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL HR TEST
PER: SEP 11, 2009 PASS

900 FORT ST.
EASTON MD. 21601

JUN 11, 2010 8:00 AM

CSLD TEST RESULTS

JUN 11, 2010 8:00 AM

T 1:UNLEADED 4000
PROBE SERIAL NUM 229511
0.2 GAL HR TEST
PER: JUN 11, 2010 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517
0.2 GAL HR TEST
PER: JUN 11, 2010 PASS

T 3:SUPER
PROBE SERIAL NUM 229514
0.2 GAL HR TEST
PER: JUN 11, 2010 PASS

T 4:PLUS
PROBE SERIAL NUM 229512
0.2 GAL HR TEST
PER: JUN 11, 2010 PASS

T 5:UNLEADED 8000
PROBE SERIAL NUM 229515
0.2 GAL HR TEST
PER: JUN 11, 2010 PASS