

Toffel, Melissa

From: Toffel, Melissa
Sent: Thursday, July 12, 2018 2:46 PM
To: 'tmiller@nationalpremiumbeer.com'
Subject: Easton Point follow-up questions to EPA's inspection on 6/13/18

Hi Tim – now that I've had time to write up my report and look at what info was provided during the inspection, as I had mentioned I do have follow-up questions for you. You had said that you had taken over operating the facility about a year and a half ago. Can you please provide **an exact date** that you took back over? This will be important in that the information I am requesting below will need to be provided going back to when you resumed operating the facility.

- 1) Please provide monthly tank release detection records for all five tanks going back to when you resumed operating the facility up through April 2018.
- 2) Provide annual functionality testing documentation of the line leak detectors for each tank, going back to when you resumed operation at the facility. I already have testing dated 6/27/16 and 3/23/18, but if you have any others please provide them.
- 3) Provide line tightness testing documentation for each tank, going back to when you resumed operation at the facility. I already have testing dated 6/27/16 and 3/23/18, but if you have any others please provide them.
- 4) Overfill could not be verified in the field, but it was mentioned that you may be utilizing ballfloats for each tank. Please provide verification from a third party that overfill is installed and functioning. If in fact ballfloats are being utilized, please provide a picture of each ballfloat lying next to its adjacent fillport.
- 5) I reviewed cathodic protection testing dated 6/17/16, 2/1/18, and 3/8/18 – do you have any others to provide since you resumed operation at the site?

Please submit this information by August 3, 2018. If you will have trouble meeting this timeframe, please give me a call to discuss. Thank you,

Melissa Toffel
U.S. EPA Region III
Land & Chemicals Division
RCRA Underground Storage Tank Branch
1650 Arch Street (Mail Code 3LC31)
Philadelphia, PA 19103
P: 215-814-2060
F: 215-814-3163

