



## Social Services

Scott M. Matheson, Governor, State of Utah  
Anthony W. Mitchell, Ph.D., Executive Director

533-6108  
July 12, 1979

Alfred J. Nowowiejski  
Deputy Civil Engineer  
Civil Engineering Division  
Department of the Air Force  
Headquarters 2849th Air Base Group (AFLC)  
Hill Air Force Base, Utah 84406

Re: Air Quality Approval Order  
for Remodeling Base Exchange  
BX Service Station

Dear Mr. Nowowiejski:

The thirty-day comment period ended on July 7, 1979 and no comments were received. Installation of the three new 10,000 gallon underground storage tanks which are to be equipped with submerged-fill equipment and a vapor return line is approved under the following conditions:

1. The proposed installation be as described in the May 15, 1979 Notice of Intent to Construct and as approved by the Executive Secretary.
2. The equipment be maintained and operated according to accepted operational and engineering practices.

Because we must both schedule and perform an initial compliance inspection, please give us an estimate of the date when the new equipment will be placed in service, followed by notice of the actual date.

Sincerely,

Alvin E. Rickers  
Executive Director  
Utah Air Conservation Committee

CAN:jo *tm*

cc: Weber-Morgan District Health Dept.

Division of Health  
Lyman J. Olsen, M.D., M.P.H.  
Director of Health

150  
P.O. Box 250

4.2.4-1035