



State of Utah
DEPARTMENT OF ENVIRONMENTAL QUALITY
DIVISION OF AIR QUALITY

Michael O. Leavitt 150 North 1950 West
Governor P.O. Box 144820
Dianne R. Nielson, Ph.D. Salt Lake City, Utah 84114-4820
Executive Director (801) 536-4000
Russell A. Roberts (801) 536-4099 Fax
Director (801) 538-4414 T.D.D.

September 20, 1995

DAQE-860-95

James R. Van Orman
Director, Environmental Management
Department of the Air Force
Headquarters Ogden Air Logistics Center (AFMC)
Hill Air Force Base, Utah 84056

Re: Your Letter of 6 September 1995, Phase II Vapor Recovery at Building 454

Dear Mr. Van Orman:

The attachments to the referenced letter includes a letter from James J. Morgester, Chief of Compliance Division of the State of California's Air Resources Board, to Wayne Tarpley of Schlumberger Technologies. Mr. Morgester's letter provides a certification of Schlumberger 4000 Series dispensers that use the Gilbraco VaporVac Assist System.

Section 4.9.9 of the Utah Air Conservation Rules [R307-1-4.9.9B(1)] requires all phase II vapor recovery systems to be designed and operated in accordance with CARB's requirement of 95% gasoline vapor recovery while dispensing, transferring, or pumping gasoline from storage tanks to vehicles.

In accordance with UACR-307-1-4.9.9, therefore, this letter may serve as a certification of your proposed phase II vapor recovery system to be installed and operated in Building 454 at HAFB. The installation, operation and maintenance of the proposed Schlumberger Model 4330 fuel dispensers shall be done in accordance with the manufacturer's specifications and requirements.

Sincerely,

Russell A. Roberts, Executive Secretary
Utah Air Quality Board

RAR:MMB:DN