

shall be valid for less than 380 days if necessary to remain within the allowable test period of October through April.

VI.D.4.d.(ii) Owners or operators of gasoline transport trucks with certificates that expire May 1, 1990 (1991) through July 31, 1990 (1991) shall renew their certificates in March or April, 1990 (1991).

VI.D.4.d.(iii) Owners or operators of gasoline transport trucks with certificates that expire August 1, 1990 (1991) through September 30, 1990 (1991) shall renew their certificates in October or November 1990 (1991). Certificates which expire August 1, 1990 (1991) through September 30, 1990 (1991) shall be valid until November 30, 1990 (1991).

VI.D.4.d.(iv) Owners or operators of previously uncertified trucks (new gasoline transport trucks) subject to this subsection may obtain initial certification May 1 through September 30, if necessary. Certification for such trucks certified May 1 through July 31 shall be valid for 270 days. Certification for such trucks certified August 1 through September 30 shall be valid for 430 days. All expiration dates for such certificates shall fall within the allowable testing period of October through April.

VI.D.4.d.(v) This certification shall be revoked if monitoring detects an exceedance which is not corrected within fifteen (15) days of initial detection, or if the exceedance is judged so severe as to warrant immediate revocation (i.e., no seal is maintained during transfer).

VI.D.4.e. The certification letter shall be kept with the tank or at the transport company office at all times and shall be shown to Division personnel upon their request. Copies of all records and reports required by the provisions of this Subsection D. shall be made available to the Division upon oral or written request. The tank shall at all times prominently display a valid sticker when containing gasoline in the ozone nonattainment area.

VII. Crude Oil

VII.A. General Exemptions

VII.A.1. Storage tanks of 151,412 liters (40,000 gallons) or less used to store crude oil are exempt from the provisions of this section.

VII.A.2. Storage tanks with capacities of less than 1,590 cubic meters (10,000 barrels) used to store crude oil and condensate prior to lease custody transfer are exempt from the provisions of this Regulation Number 7 other than Sections XII and XVII.

VII.B. Equipment

Pumps and compressors handling crude oil shall be subject to the provisions of Subsection VI.A.

VII.C. Storage

Except as provided in VII.A.2. above, crude oil stored in tanks greater than 151,412 liters (40,000 gallons) shall be subject to the provisions of Subparagraph B.1.b. and Paragraph B.2. of Section VI.